


TMAC USERS MANUAL

FM/AM - 1600S COMMUNICATIONS SERVICE MONITOR

FM/AM - 1600CSA DUAL MODE CELLULAR SYSTEM ANALYZER



10200 West York Street / Wichita, Kansas 67215 U.S.A. / (316) 522-4981 / FAX 316-524-2623

1002-8601-300 1600S Ver 3.02 CSA Ver 5.10 PUBLISHED BY IFR SYSTEMS INC. Wichita, Kansas

COPYRIGHT © 1996 by IFR SYSTEMS, INC.

All rights reserved. Printed in the United States of America. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording of otherwise without the prior permission of the publisher.

HP is a trademark of Hewlett-Packard.

Procomm Plus is a trademark of Datastorm Technologies, Inc.

LIST OF EFFECTIVE PAGES

The manual pages listed below that are affected by a current change or revision, are so identified by a revision number.

Date of Issue for original and changed pages are:

Original	 0	***************************************	October 1994
Revision	 1	*******	August 1995
Revision	 2	**************	January 1996

TOTAL NUMBER OF PAGES IN THIS MANUAL IS 685 CONSISTING OF THE FOLLOWING

Pg. No.	Rev. No.	Pg. No.	Rev. No.
Pg. No. Title	2	7-30H Blank. 7-31 through 7-33 through 7-36 through 7-38 through 7-42A through 7-51A through 7-51A through 7-52 7-53 through 7-60A 7-60 through 7-63 7-65 through 8-1 through 8-1 through 9-10 through 9-11 through 9-15A through 9-15A through 9-15A through 9-16 through 9-16 through 10-16 through	Rev. No. 2 7-32
7-24B Blank 7-25 through 7-30 7-30A through 7-3	2 0	Index-1 throu	gh Index-5 0

ı		
		·

PREFACE

SCOPE

This Manual contains instructions for remotely operating the FM/AM-1600S Communication Service Monitor and FM/AM-1600CSA Dual Mode Cellular System Analyzer. The instruction level is relatively basic and presupposes no previous experience on the part of the operator with remote operation of a communication service monitor or cellular system analyzer. A basic understanding of communication electronics and cellular system formats is helpful. It is strongly recommended that the operator be thoroughly familiar with this manual as well as the Operation Manuals of the Test Sets before attempting to operate the Test Sets remotely.

ORGANIZATION

The FM/AM-1600S, FM/AM-1600CSA TMAC Users Manual is composed of the following sections:

SECTION 1 - INTRODUCTION

Provides an introduction to the TMAC language.

SECTION 2 - REMOTE CONFIGURATION

Provides step-by-step procedures for configuring the FM/AM-1600S or FM/AM-1600CSA for various remote operations.

SECTION 3 - GENERAL TMAC (TEST MACRO LANGUAGE)

Describes and explains the various features of the General TMAC language.

SECTION 4 - 1600S SPECIFIC TMAC COMMANDS

Lists and details the Specific TMAC commands for the FM/AM-1600S. Commands are arranged by Operation Mode for convenience.

SECTION 5 - CSA QUICK REFERENCE LIST

Briefly lists the FM/AM-1600S TMAC commands in alphabetical order.

SECTION 6 - CREATING AND LOADING CSA SPECIFIC PROGRAMS

Provides step-by-step procedures and examples for creating and loading CSA specific programs.

SECTION 7 - CSA SPECIFIC TMAC COMMANDS

Lists and details the Specific TMAC commands for the FM/AM-1600CSA. Commands are arranged by Operation Mode for convenience.

SECTION 8 - 1600S QUICK REFERENCE LIST

Briefly lists the FM/AM-1600CSA TMAC commands in alphabetical order.

SECTION 9 - CSA PROGRAM EXAMPLES

Provides functional CSA program examples.

NOMENCLATURE

The following names are used interchangeably to indicate the FM/AM-1600S Communication Service Monitor:

- FM/AM-1600S
- 1600S
- FM/AM-1600S Test Set
- Test Set (Paragraphs applying only to the FM/AM-1600S are so indicated. Test Set is used in other paragraphs to indicate either configuration.)

The following names are used interchangeably to indicate the FM/AM-1600CSA Dual Mode Cellular System Analyzer (and when referring to connectors, the auxiliary unit in particular):

- FM/AM-1600CSA
- CSA
- FM/AM-1600CSA Test Set
- Test Set (Paragraphs applying only to the FM/AM-1600CSA are so indicated. Test Set is used in other paragraphs to indicate either configuration.)

TABLE OF CONTENTS

Paragraph	Title	Page
List of Eff	ective Pages	A
Preface		i
Table of C	Contents	iii
List of Illu	strations	xii
List of Tal	bles	xiii
	SECTION 1 - INTRODUCTION	
	SECTION 2 - INSTALLATION	
Paragraph	Title	Page
2-1	General	2-1
2-2	Configuring for RS-232 Operation	2-1
2-2-1	Remote Operation Using Host System	2-1
2-2-2	Remote Operation Using Modem	2-4
2-2-3	Operating Test Set as RS-232 Terminal (1600S Only)	2-6
2-3	Configuring for GPIB Operation	2-7
2-3-1	1600S - GPIB Setup and Operation	2-7
2-3-2	1600CSA - GPIB Setup and Operation (GPIB option installed)	2-8
	SECTION 3 - GENERAL TMAC (TEST MACRO LANGUAGE)
Paragraph	Title	Page
3-1	Syntax	3-1
3-2	Comments	3-2
3-3	Variables and Arrays	3-3
3-3-1	General	3-3
3-3-2	Saving Variables and Arrays (1600S Only)	3-4
3-4	Constants and Data Arrays	3-5

aragraph	Title	Page
3-5	Numeric Formats	3-6
3-5-1	Numerical Notation	3-6
3-5-2	Numeric Form	3-6
3-6	Mathematical Operators	3-7
3-6-1	Operators	3-7
3-6-2	Order Of Calculation	3-11
3-7	Mathematical Functions	3-12
3-8	String Variables and Functions	3-15
3-9	Macros	3-18
3-10	Conditional Expressions	3-20
3-11	Variables and Arrays in Macros	3-22
3-12	Multitasking Macros	3-23
3-13	Creating Windows and Graphics	3-25
3-13-1	Colors	3-25
3-13-2	CRT Display	3-26
3-13-3	Windows	3-26
3-13-4	Soft Function Key Displays	3-28
3-13-5	Graphics and Text	3-29
3-13-6	Audio Tones	3-31
3-14	System Commands	3-32
3-14-1	System Key Commands (1600S Only, except as noted)	3-32
3-14-2	System Error Command	3-33
3-14-3	System Defaults Command (1600S Only)	3-33
3-14-4	System Plot Commands (1600S Only)	3-33
3-14-5	System Time and Date Commands	3-33
3-14-6	System RS-232 Configure Commands	3-34

	Paragraph	Title	Page
	3-14-7	System Security Commands (1600S Only)	3-35
	3-15	GPIB Operation	3-36
	3-15-1	Operating Test Set Using GPIB Communication (CSA Only)	3-36
	3-15-2	Operating Test Set Using GPIB Communication (1600S Only)	3-36
	3-15-3	Test Set Operating as GPIB Controller (1600S Only)	3-37
	3-15-4	Test Set Operating as Talker Only (1600S Only)	3-39
	3-15-5	Test Set Operating as Listener Only (1600S Only)	3-39
	3-16	Status Subsystem (1600S Only)	3-40
	3-16-1	Status Registers	3-40
	3-16-2	Status Byte	3-42
	3-16-3	Standard Event Status Register	3-43
-	3-16-4	Operation Status Register	3-43
	3-16-5	Operation Instrument Register	3-44
	3-16-6	Questionable Status Register	3-44
	3-16-7	Instrument Status Register	3-44
	3-16-8	Instrument Summary Status Register	3-45
	3-17	IEEE 488.2 Compliance Commands	3-46
	3-18	FM/AM-1600S and FM/AM-1600CSA General TMAC Commands	3-47
		SECTION 4 - 1600S SPECIFIC TMAC COMMANDS	
	Paragraph	Title	Page
	4-1	General	4-1
	4-2	Setup Commands	4-1
	4-3	Screen Commands	4-2
	4-4	Auxiliary Test Set Commands	4-3
	4-5	RF Generator	4-4
	4-5-1	RF Generator Commands	A-A

a	ragraph	Title	Page
	4-5-2	Remote RF Generator Examples	4-10
	4-6	Receiver	4-14
	4-6-1	Receiver Commands	4-14
	4-6-2	Remote Receiver Examples	4-22
	4-7	Duplex Commands	4-29
	4-7-1	Duplex General Commands	4-29
	4-7-2	Duplex Transmitter Commands	4-29
	4-7-3	Duplex Receiver Commands	4-34
	4-7-4	Remote Duplex Examples	4-37
	4-8	AF Generator	4-38
	4-8-1	AF Generator Commands	4-38
	4-8-2	Remote AF Generator Examples	4-44
	4-9	Oscilloscope	4-45
	4-9-1	Oscilloscope Commands	4-45
	4-9-2	Remote Oscilloscope Examples	4-52
	4-10	Spectrum Analyzer	4-55
	4-10-1	Spectrum Analyzer Commands	4-55
	4-10-2	Remote Spectrum Analyzer Example	4-63
	4-11	Meter Commands	4-64
	4-11-1	AF Meter Commands	4-64
	4-11-2	Frequency Error Meter Commands	4-67
	4-11-3	Power Meter Commands	4-69
	4-11-4	Deviation Meter (Peak) Commands	4-71
	4-11-5	Modulation Meter Commands	4-74
	4-11-6	Distortion Meter Commands	4-76
	4-11-7	SINAD Meter Commands	4-78

Paragraph		Title	Page
4-11-8	Signal Strength Meter Com	mands	4-80
4-11-9	Bit Error Rate Meter Comm	ands	4-80
4-11-10	Digital Multimeter Comman	ds	4-82
4-11-11	Phase Meter Commands	•••••	4-84
4-11-12	Deviation Meter (RMS) Con	nmands	4-86
4-11-13	Phase Meter (RMS) Comma	ınds	4-88
4-11-14	AF Level Meter		4-89
4-12	Cellular AMPS		4-90
4-12-1	Cellular AMPS Commands		
4-12-1	Remote AMPS Cell Site Mo	nitor Example	4-98
4-13	Program Commands		4-99
4-14	Flash Memory File Director	/ Operation	4-100
4-15	Generic Measure Command	s	4-103
4-16	INITiate and FETCh Comma	ınds	4-104
	SECTION 5 - 1600S	QUICK REFERENCE L	.IST
SECT	TION 6 - CREATING AND	LOADING CSA SPECIF	IC PROGRAMS
Paragraph	,	Title	Page
6-1	Setup	•	6-1
6-1-1	Terminal Emulation Program	n Setup	6-1
6-1-2	Connection and FM/AM-160	0CSA Setup	6-2
6-2	Writing Programs		6-2
6-3	Loading	••••	6-4
6-3-1	Upload		6-4
6-3-2	Storing in Flash Memory		6-4
6-4	Front Panel Operation		6-5
6-6	Macro Examples		6-6

SECTION 7 - CSA SPECIFIC TMAC COMMANDS

Paragraph	Title	Page
7-1	General	. 7-1
7-2	Host Commands	. 7-1
7-3	Forward Control Channel (FOCC) Monitor Commands	. 7-2
7-3-1	Forward Control Channel Control	. 7-2
7-3-2	Forward Control Channel Decode Data	. 7-5
7-3-3	Forward Control Channel Raw Data	. 7-9
7-4	Forward Voice Channel (FVC) Monitor Commands	. 7-12
7-4-1	Forward Voice Channel Control	. 7-12
7-4-2	Forward Voice Channel Decode Data	. 7-12
7-4-3	Forward Voice Channel Raw Data	. 7-14
7-5	Forward Digital Traffic Channel (FDTC) Monitor Commands	. 7-15
7-5-1	Forward Digital Traffic Channel Control	. 7-15
7-5-2	Forward Digital Traffic Channel Decode Data	. 7-15
7-5-3	Forward Digital Traffic Channel Raw Data	. 7-20
7-5-4	IS-54 Raw Data	. 7-21
7-6	Reverse Control Channel (RECC) Monitor Commands	. 7-22
7-6-1	Reverse Control Channel Control	. 7-22
7-6-2	Reverse Control Channel Decode Data	. 7-22
7-7	Reverse Voice Channel (RVC) Monitor Commands	. 7-24
7-7-1	Reverse Voice Channel Control	. 7-24
7-7-2	Reverse Voice Channel Decode Data	. 7-24
7-8	Reverse Digital Traffic Channel (RDTC) Monitor Commands	. 7-25
7-8-1	Reverse Digital Traffic Channel Control	. 7-25
7-8-2	Reverse Digital Traffic Channel Decode Data	. 7-26
7-9	Cell Site Simulation Commands	. 7-31

Paragraph	Title	Page
7-9-1	General	. 7-31
7-9-2	FOCC Overhead Message Parameters	. 7-31
7-9-3	Calling Setup	. 7-34
7-9-4	Process and Handoff	. 7-36
7-9-5	Forward Voice Channel (FVC)	. 7-38
7-9-6	Forward Digital Traffic Channel (FDTC)	7-43
7-9-7	Talkback	7-52
7-9-8	Global Action Overhead Messages	7-53
7-9-9	Mobile Station Control Messages	7-57
7-9-10	Overhead Enable Commands	7-60A
7-10	BER Commands	7-61
7-11	Modulation Accuracy Commands	7-62
7-12	Generic Measure Commands	7-62
7-13	Flash Memory Commands	7-63
7-14	DCCH Mobile Station Simulation Commands	7-65
7-14-1	TDMA Transmission Overview	7-66
7-14-2	Setup Commands	7-70
7-14-3	RDCCH Raw Generator	7-72
7-14-4	Random Access Control Channel (RACH) Message Generator	7-75
7-14-5	RACH Layer 3 Message Builder	7-81
7-14-6	Base Station Performance	7-119
7-15	FDCCH Data Monitor	7-121
7-15-1	Setup Commands	7-121
7-15-2	Continuous Remote Raw Timeslot Data	7-122
7-15-3	Continuous Remote Raw Data	7-123
7-15-4	Buffered Raw Data	7-124

Paragraph	Title	Page
7-15-5	Layer 2 Data Monitor	7-125
7-15-6	L2 Filters	7-134
7-15-7	FDCCH Real Time Data Monitor	7-134
7-16	DCCH Cell Site Simulation	7-199
7-16-1	Setup Commands	7-199
7-16-2	Superframe Setup	7-200
7-16-3	F-BCCH Commands	7-205
7-16-4	E-BCCH Commands	7-229
7-16-5	SPACH Commands	7-263
7-16-6	RDCCH Real Time Data Monitor	7-313
7-17	RDCCH Data Monitor	7-303
7-17-1	Setup Commands	7-303
7-17-2	Continuous Remote Raw Timeslot Data	7-305
7-17-3	Continuous Remote Raw Data	7-306
7-17-4	Buffered Raw Data	7-307
7-17-5	Layer 2 Data Monitor	7-309
	SECTION 8 - CSA QUICK REFERENCE LIST	
	SECTION 9 - CSA PROGRAM EXAMPLES	
Paragraph	Title	Page
9-1	General	9-1
9-2	Forward Control Channel (FOCC)	9-1
9-2-1	Monitoring Decoded Data	9-1
9-2-2	Monitoring Raw Data	9-2
9-3	Forward Voice Channel (FVC)	9-3
9-3-1	Monitoring Decoded Data	9-3
9-3-2	Monitoring Raw Data	9-4

Paragraph	Title	Page
9-4	Forward Digital Traffic Channel (FDTC)	9-5
9-4-1	Monitoring Decoded Data	9-5
9-4-2	Monitoring Raw Data	9-6
9-4-3	Monitoring IS-54 Raw Data	9-7
9-5	Reverse Control Channel (RECC)) -8
9-6	Reverse Voice Channel (RVC)	8-8
9-7	Reverse Digital Traffic Channel (RDTC)	9-9
9-8	Cell Site Simulation (CSS)	-10
9-8-1	General Overhead Message9	-10
9-8-2	Global Action Overhead Message9	1-11
9-8-3	Mobile Station Control9)-11
9-8-4	Mobile Station Initiated Call9	-12
9-8-5	Base Station Initiated Call9	-13
9-8-6	Handoff9	-14
9-8-7	Page9	-15A
9-9	Bit Error Rate (BER)9	-16
9-10	Modulation Accuracy (MODACC)9	-16
9-11	GPIB9	-17
	APPENDICES	
Appendix	Title	age
Α	Predefined Macros and Constants	\-1
A-1	Predefined Macros	\-1
A-2	Predefined Constants	N-1
В	Front Panel Keys and Keycodes E	3-1
C	Abbreviations C	C-1
Index	1	ndex-

LIST OF ILLUSTRATIONS

Figure No.	Title	Page
2-1	Test Set - Host Cable Connections	. 2-1
2-2	FM/AM-1600S RS-232 Configure Menu	. 2-2
2-3	CSA External I/O Parameters Screen	. 2-3
2-4	Test Set - Modem Cable Connection	. 2-4
2-5	CSA External I/O Parameters Screen (Modem)	. 2-5
2-6	Test Set (as RS-232 Terminal) Connections	. 2-6
2-7	1600S Configure GPIB Submenu	. 2-7
2-8	CSA External I/O Parameters Screen (GPIB)	. 2-8
3-1	Window Example	. 3-27
3-2	Soft Function Key Example	. 3-28
3-3	Graphics Examples	
3-4	ICON Example	. 3-31
3-5	1600S Status Register Description	. 3-40
3-6	1600S Status Register Configuration	. 3-41
3-7	1600S RQS Bit and SRQ Generation	. 3-42
3-8	Box Example	. 3-51
3-9	KEYPAD:ERASE Example	. 3-73
3-10	KEYPAD:LABEL Example	. 3-74
3-11	KEYPAD:SOFT Example	. 3-75
6-1	JBox Flash Files Directory	. 6-5
7-1	Examples of Primary and Secondary Cycles	. 7-31B
7-2	JBox Flash Files Directory	. 7-63
7-3	Connector Input Power Ranges	. 7-65
7-4	Normal Length Message in the RDCCH	. 7-67
7-5	Abbreviated Length Message in the RDCCH	. 7-68

Figure No.	Title	Page
7-6	Contiguous and Sub Channel Transmissions	7-69
7-7	User Data Message Diagram	7-74
7-8	RDCCH Message Diagram	7-76
7-9	RACH Message Transmission (Contiguous)	7-77
7-10	RACH Message Transmission (Sub Channel)	7-78
7-11	Superframe Data Message	7-90
	LIST OF TABLES	
Table No.	Title	Page
2-1	Terminal Settings for RS-232 Host Operation	2-2
3-1	OR Operation Results	3-9
3-2	AND operation Results	3-10
3-3	XOR Operation Results	3-10
3-4	Colors and Color Selection Numbers	3-25
3-5	Character Rotation for n Values	3-82
4-1	DMM Upper and Lower Limit Ranges and Units	4-83
4-2	Flash Memory Remote Commands	4-101
4-3	Flash Memory Error Messages	4-102
7-1	Speech Parameter (27 bytes)	7-25
7-2	BER Bit Definition	7-26
7-3	CSA Flash Memory Remote Commands	7-64
7-4	Input/Output Connector Configurations	7-65
B-1	Front Panel Keys and Keycodes	B-1

		·	·	

SECTION 1 - INTRODUCTION

TMAC (Test Macro Language) was developed by IFR Systems Inc. to operate IFR test equipment in a remote configuration and allow internal versatile software to be created. TMAC is written so not just single measurements but entire batteries of tests may be performed. Combining this capability with the test functions available with the FM/AM-1600S and FM/AM-1600CSA gives the user a great deal of flexibility in testing communication devices in an ATE environment. Additionally this language also provides a format to store and perform user defined test sequences. TMAC is based on the IEEE-488.2 format and conforms to the SCPI Standard. Some commands and operators, created before and not conforming to the SCPI Standard, are so noted.

TMAC is written on several layers of complexity. The first layer consists of the Machine Specific TMAC Commands. These commands are what actually set up and control the Test Set and take the measurements. The Specific TMAC commands for the FM/AM-1600S and FM/AM-1600CSA encompass the complete operation of the Test Set. Every function of the FM/AM-1600S and FM/AM-1600CSA can be performed remotely with the exception of power up of the Test Set and CRT intensity control.

The second level of TMAC is the framework that is used to combine the machine specific commands into a coherent and fluid process. Decision making commands allow different procedures to be performed under differing circumstances. These decisions may be based on complex expressions as well as simple boolean answers being returned from the Test Set. Looping commands allow the continual monitoring of a parameter while performing tasks. Math and logic function commands together with bit manipulating commands allow the use and evaluation of complex functions. TMAC also provides a variety of data structures to assist in developing test procedures. Graphic commands allow the development of user defined screens and menus to aid the user in performing test sequences. The Status System provided allows the monitoring of the Status Registers called for in the IEEE-488.2 Standard.

The third layer and one of the main strengths of TMAC is the capability to define macros with procedures built of machine specific commands as organized by the framework commands. Macros allow step by step test procedures to be developed, stored and locally or remotely implemented. Using macros is easy. Entering the name of the macro along with any variable parameters, executes the macro. Macros can be executed within other macros, allowing complicated procedures to be divided into smaller tasks. Macros can be initiated remotely, from the Front Panel Keyboard or automatically upon power up of the Test Set.

The final layer of TMAC is the ability to Multitask Macros. The Multitasking feature of TMAC allows several macros to alternate command execution at once giving the appearance of being executed simultaneously. Multitasking in TMAC allows the user to activate a task, pass to the next task, put a task to sleep, wake a sleeping task and stop a task.



SECTION 2 - REMOTE CONFIGURATION


2-1 GENERAL

This section provide general configuration procedures for remote operation for the FM/AM-1600S and the FM/AM-1600CSA. Remote operation depends on having Test Set settings match user equipment and interface settings. Settings in configuration procedures may require variation depending on user equipment.

2-2 CONFIGURING FOR RS-232 OPERATION

2-2-1 REMOTE OPERATION USING HOST SYSTEM

The FM/AM-1600S and FM/AM-1600CSA Test Sets can be remotely operated from a Host System. The Host System can be a PC using Terminal Emulation Software or an RS-232 Terminal.




8602004

Figure 2-1 Test Set - Host Cable Connections

A. 1600S - HOST SYSTEM SETUP AND OPERATION

STEP PROCEDURE

- 1. Refer to Figure 2-1 and connect Host System Comm Connector to Test Set RS-232 Connector on FM/AM-1600S rear panel, using standard 9-pin to 9-pin RS-232 cable.
- 2. Press MTRS Mode Key to access Meter Menu.
- 3. Press "AUX" Soft Function Key F6 to access Auxiliary Functions Menu.
- 4. Press 5 DATA ENTRY Key to access Configure Submenu.
- 5. Press 1 DATA ENTRY Key to access Configure RS-232 Submenu.
- Press 1 DATA ENTRY Key to access RS-232 Operation Mode. Press 2 DATA ENTRY Key to select Host.
- 7. Press 2 DATA ENTRY Key to access Baud Rate Submenu. Use DATA ENTRY Keys to select desired Baud Rate.
- 8. Press 3 DATA ENTRY Key until Data Bits toggles to 8.



9110027

Figure 2-2 FM/AM-1600S RS-232 Configure Menu

- 9. Press 4 DATA ENTRY Key until Stop Bits toggles to 1.
- 10. Press 5 and 1 DATA ENTRY Keys to select None for Parity.
- 11. Press 6 and 3 DATA ENTRY Keys to select Xon/Xoff Handshaking.
- 12. Press 7 DATA ENTRY Key until Echo is toggled *Off* (faster action and displaying transmission is not desired) or *On* (displaying transmission is desired).
- 13. Press "ESC" Soft Function Key F6 twice to return to Auxiliary Functions Menu.
- 14. Set Terminal Emulator Software or RS-232 Terminal parameters to match Table 2-1. Set Duplex or Echo mode as desired according to Terminal Emulator software program used.

PARAMETER	SETTING		
Baud Rate	Same as Test Set		
Data Bits	8		
Stop Bits	1		
Parity	None		
Handshaking	Xon/Xoff		


Table 2-1 Terminal Settings for RS-232 Host Operation

15. Send desired 1600S commands from Host terminal to FM/AM-1600S Test Set. Write and save macros, as desired, using Host System text editor. Transfer macros and programs, as desired, to Test Set using Host System.

B. CSA - HOST SYSTEM SETUP AND OPERATION

STEP PROCEDURE

- Refer to Figure 2-1 and connect Host System Comm Connector to Test Set RS-232 Connector on FM/AM-1600CSA rear panel, using standard 9-pin to 9-pin RS-232 cable.
- 2. Press DPLX Mode Key to access Duplex Operation Screen.
- 3. Press "Sp Tst" Soft Function Key F5 to access Dual Mode Cellular main menu.
- 4. Press "AUX2" Soft Function Key F5 to access Auxiliary Functions Menu (#2).
- 5. Press 5 DATA ENTRY Key to access External I/O Parameters Screen.




9117127

Figure 2-3 CSA External I/O Parameters Screen

- Use FIELD SELECT Keys to select parameter. Use DATA SCROLL Spinner or DATA SCROLL ↑ and ↓ Keys to edit parameter. Set parameters as desired (see Figure 2-3).
- 7. Press DPLX Mode Key to access Duplex Operation Screen.
- 8. Set Terminal Emulator Software or RS-232 Terminal parameters to match CSA settings.
- Send desired CSA commands from Host terminal to FM/AM-1600CSA Test Set. Write and save macros, as desired, using Host System text editor. Transfer macros and programs, as desired, to Test Set using Host System.

2-2-2 REMOTE OPERATION USING MODEM

The FM/AM-1600S and FM/AM-1600CSA Test Sets can be connected to a Modem and then operated remotely over the telephone line.



8602002

Figure 2-4 Test Set - Modem Cable Connection

PROCEDURE

A. 1600S - MODEM SETUP AND OPERATION

STEP


- Refer to Figure 2-4 and connect Modem to Test Set RS-232 Connector on FM/AM-1600S rear panel.
- 2. Press MTRS Mode Key to access Meter Menu.
- 3. Press "AUX" Soft Function Key F6 to access Auxiliary Functions Menu.
- 4. Press 5 DATA ENTRY Key to access Configure Submenu.
- 5. Press 1 DATA ENTRY Key to access Configure RS-232 Submenu.
- 6. Press 1 DATA ENTRY Key to access RS-232 Operation Mode. Press 2 DATA ENTRY Key to select *Host*.
- 7. Press 2 DATA ENTRY Key to access Baud Rate Submenu. Set Baud Rate as desired, according to Modem requirements.
- 8. Press 3 DATA ENTRY Key until Data Bits toggles to 8.
- 9. Press 4 DATA ENTRY Key until Stop Bits toggles to 1.
- 10. Press 5 and 1 DATA ENTRY Keys to select None for Parity.
- 11. Press 6 and 1 DATA ENTRY Keys to select None for Handshaking.
- 12. Press 7 DATA ENTRY Key until Echo is toggled Off.
- 13. Press "ESC" Soft Function Key F6 twice to return to the Auxiliary Functions Menu.

- 14. Press "TERM" Soft Function Key F5 to access RS-232 Monitor Screen.
- 15. Use DATA ENTRY Keys to enter attention prefix and dialing command of Modem.
- 16. Operate FM/AM-1600S Test Set from destination telephone number.
- B. 1600CSA MODEM SETUP AND OPERATION

STEP

PROCEDURE

- Refer to Figure 2-4 and connect Modem to Test Set RS-232 Connector on FM/AM-1600CSA rear panel.
- 2. Press DPLX Mode Key to access Duplex Operation Screen.
- 3. Press "Sp Tst" Soft Function Key F5 to access Dual Mode Cellular main menu.
- 4. Press "AUX2" Soft Function Key F5 to access Auxiliary Functions Menu (#2).
- 5. Press 5 DATA ENTRY Key to access External I/O Parameters Screen.




9117128

Figure 2-5 CSA External I/O Parameters Screen (Modem)

- 6. Use FIELD SELECT Keys to select parameter. Use DATA SCROLL Spinner or DATA SCROLL ↑ and ↓ Keys to edit parameter. Set parameters according to Figure 2-5.
- 7. Press DPLX Mode Key to access Duplex Operation Screen.
- Call Modem and operate FM/AM-1600CSA Test Set from destination telephone number.

2-2-3 OPERATING TEST SET AS RS-232 TERMINAL (1600S Only)

The FM/AM-1600S Test Set can be used as an RS-232 Terminal.



8602003

Figure 2-6 Test Set (as RS-232 Terminal) Connections

STEP

PROCEDURE

- Refer to Figure 2-6 and connect Test Equipment to Test Set RS-232 Connector on FM/AM-1600S rear panel.
- 2. Press MTRS Mode Key to access Meter Menu.
- 3. Press "AUX" Soft Function Key F6 to access Auxiliary Functions Menu.
- 4. Press 5 DATA ENTRY Key to access Configure Submenu.
- Press 1 DATA ENTRY Key to access Configure RS-232 Submenu.
- Press 1 DATA ENTRY Key to access RS-232 Operation Mode. Press 2 DATA ENTRY Key to select Host.
- 7. Press 2 DATA ENTRY Key to access Baud Rate Submenu. Set Baud Rate as desired, according to Test Equipment requirements.
- 8. Press 3 DATA ENTRY Key until Data Bits toggles to 8.
- 9. Press 4 DATA ENTRY Key until Stop Bits toggles to 1.
- 10. Press 5 and 1 DATA ENTRY Keys to select None for Parity.
- 11. Press 6 and 3 DATA ENTRY Keys to select Xon/Xoff for Handshaking.
- 12. Press 7 DATA ENTRY Key until Echo is toggled On.
- 13. Press "ESC" Soft Function Key F6 twice to return to Auxiliary Functions Menu.
- 14. Set Test Equipment parameters to match Table 2-1.

- 15. Press "TERM" Soft Function Key F5 to access RS-232 Monitor Screen.
- 16. Use DATA ENTRY Keys to enter commands. Use Soft Function Keys to enter characters not included in DATA ENTRY Keys. Use SHIFT Key to toggle between numeric and alphabetic keys.
- 17. Press any MODE Key to exit RS-232 Monitor Screen.

2-3 CONFIGURING FOR GPIB OPERATION


The FM/AM-1600S and FM/AM-1600CSA (with GPIB installed) Test Sets can be remotely operated, individually or at the same time (with separate addresses), using GPIB protocol.

2-3-1 1600S - GPIB SETUP AND OPERATION

STEP

PROCEDURE

- 1. Press MTRS Mode Key to access Meter Menu.
- 2. Press "AUX" Soft Function Key F6 to access Auxiliary Functions Menu.
- 3. Press 5 DATA ENTRY Key to access Configure Submenu.
- 4. Press 2 DATA ENTRY Key to access Configure GPIB Submenu.



8610025

Figure 2-7 1600S Configure GPIB Submenu


- Press 1 DATA ENTRY Key to access GPIB Operation Mode. Use DATA ENTRY Keypad to select operation Mode. Select *Talk/Listen* to operate FM/AM-1600S from GPIB Controller (see 3-15-2). Select *Controller* to operate other test equipment from FM/AM-1600S (see 3-15-3).
- Press 2 DATA ENTRY Key to access GPIB address. Use DATA ENTRY Keypad to select GPIB address to not conflict with address of any other device connected to GPIB.
- 7. Connect GPIB cable to GPIB Connector on FM/AM-1600S Rear Panel.
- 8. Initiate parallel remote operation.

2-3-2 1600CSA - GPIB SETUP AND OPERATION (GPIB option installed)

STEP

PROCEDURE

- 1. Press DPLX Mode Key to access Duplex Operation Screen.
- 2. Press "Sp Tst" Soft Function Key F5 to access Dual Mode Cellular main menu.
- 3 Press "AUX2" Soft Function Key F5 to access Auxiliary Functions Menu (#2).
- 4 Press 5 DATA ENTRY Key to access External I/O Parameters Screen.



9117127

Figure 2-8 CSA External I/O Parameters Screen (GPIB)

- Use FIELD SELECT Keys to select GPIB ADDRESS parameter.
- 6. Use DATA SCROLL Spinner or DATA SCROLL \uparrow and \downarrow Keys to select GPIB ADDRESS, not conflicting with address of any other device connected to GPIB.
- 7. Press DPLX Mode Key to access Duplex Operation Screen.
- 8. Connect GPIB cable to GPIB Connector on FM/AM-1600CSA Rear Panel.
- 9. Initiate parallel remote operation from GPIB Controller (see 3-15-1).

SECTION 3 - GENERAL TMAC (TEST MACRO LANGUAGE)

3-1 SYNTAX

When working with TMAC, punctuation marks are used to establish a format of how commands and parameters are entered. The syntax needed to use TMAC is detailed below.

• Colon (:)

TMAC commands are arranged in hierarchical levels using the colon to separate the different levels. A colon before the beginning of a command (:FGEN) signifies the command starts at the first hierarchical level.

Example: FGEN:GEN1:SHAPE:SIN

FGEN precedes all Function Generator commands. The FGEN:GEN1 precedes all Function Generator commands dealing with Generator 1. FGEN:GEN1:SHAPE precedes all Function Generator commands selecting the waveform of Generator 1. FGEN:GEN1:SHAPE:SIN selects a sine wave for the waveform of Generator 1 of the Function Generator.

A new line character marks the end of a command and places the next command at the first command level.

Semicolon (;)

A semicolon signifies the end of a command and starts the next command at the last level of the previous command.

Example: FGEN:GEN1:FREQ 2000; SHAPE:SIN; :SCREEN:FUNC

The first command, FGEN:GEN1:FREQ 2000, leaves the TMAC Compiler at the FGEN:GEN1 level. Preceded by a semicolon, the next command, SHAPE:SIN, starts from this level. The next semicolon leaves the TMAC Compiler at the FGEN:GEN1:SHAPE level. The following colon resets the Compiler to the first hierarchical level to start the next command, SCREEN:FUNC.

Example: DUP:INP:FREQ?;MOD:USER:MOD:DATA;FILTER 30;:SCREEN:DUP

This command line performs the following commands:

DUP: INP: FREQ?

DUP:INP:MOD:USER:MOD:DATA
DUP:INP:MOD:USER:FILTER 30

SCREEN: DUP

Whitespace

At least one space is needed between commands and parameters. Other spaces or lack of them between items do not affect command execution. Spaces inside command words or between command word and ending punctuation (ME AS:FREQ? or MEAS:FREQ?) are not allowed.

Comma (,)

Commas are used between parameters when more than one is listed.

Example: MACRO 1,2,3,4

Back slash (\)

A back slash allows a command to be continued on the next line. The back slash cannot break a command word.

Example: FGEN:GEN1:\

FREQ 2000

This is the same command as FGEN:GEN1:FREQ 2000.

Example: FGEN:GE\

N1:FREQ 2000

This command fails to execute and produces an error message because command word **GEN1** is broken.

Many commands can be entered using a short form or a long form. In this manual, the short form is shown in upper case, while the remainder of the long form is shown in lower case. Upper and lower case letters are used only in this manual to differentiate between the long and short form of commands. TMAC does not differentiate between upper and lower case letters; therefore entries can be either.

Example: STATus: QUEStionable: CONDition?

STAT:QUES:COND? is the same as STATUS:QUESTIONABLE:CONDITION?

3-2 COMMENTS

Comments provide clarity in macros and are ignored by the TMAC compiler/interpreter. There are two types of comments.

Characters // cause the rest of line to be a comment.

Example: PRINT COS(freqstSQR(2)) // PRINTS COS OF FREQ imes SQUARE ROOT OF 2

The message PRINTS COS OF FREQ \times SQUARE ROOT OF 2 is not executed by the TMAC compiler/interpreter.

Characters /* and */ start and end the second type of comment. It can contain several lines.

Example: PRINT COS(freq*SQR(2)) /* prints cosine of the quantity RF Generator frequency multiplied by the square root of 2 */

The TMAC compiler/interpreter ignores everything between the comment characters.

3-3 VARIABLES AND ARRAYS

3-3-1 GENERAL

Variables and arrays are used to hold numeric values and can be local or global. If a variable or array is declared inside a macro, it is local and is used inside that macro only. If it is declared outside a macro, it is global and is used outside or inside any macro (unless a local variable has the same name as the global variable). Locality takes precedence.

The number of variables and arrays allowed is limited by the amount of memory available. There is a maximum of 998 memory locations for global variables. A global variable takes one location, global arrays take a location for each array element and global string variables take 9 locations each. Local variables are also limited by memory space which varies depending on many factors including call nesting (see Macros in 3-9). One to two hundred local variables are usually available with arrays taking the space of a variable for each array element and string variables taking nine times the space needed for a variable.

The first character of a variable or array name is a letter while the remaining characters can be letters, digits 0 through 9 and the underscore. The maximum length is 31 characters. There are 26 free variables that do not need to be declared. These have the single letter names A through Z. To declare a variable, use the **VAR** command:

VAR name, name,..... ,name

Example: VAR Freq, Rad, Mod

Freq, Rad and Mod are now declared variables.

Variables can be initialized when they are declared by including an equal sign and the value. Variables are equal to 0 when declared if not changed by the user.

Example: VAR Rad = 4.32876, Mod

Rad is declared and assigned a value of 4.32876. Mod is declared and contains a value of 0.

Arrays are also declared using the VAR command. The highest index is included in brackets as shown:

VAR name[index]

The index count starts with 0, making index one less than the total number of variables in the array.

Example: VAR BB[9]

This command declares array BB with 10 variables: BB[0] through BB[9].

Braces are used to initialize arrays. More than one can be initialized at a time.

Examples: VAR BUNCH[10] = $\{1,2,3,4,5,6,7,8,9,10,11\}$ VAR AA[2]= $\{1,2,3\}$, BB[1]= $\{7,4\}$, CC[3]= $\{24,345.754,2,100\}$

A variable and an array cannot have the same name at the same time. Accessing an array without specifying an index yields erroneous results.

3-3-2 SAVING VARIABLES AND ARRAYS (1600S ONLY)

NOTE: Refer to section 7-2 to run 1600S only commands when operating as the FM/AM-1600CSA.

Global variable and array values are not saved in memory when the Test Set power is turned off. To save variable or array values in non-volatile memory, use the NVSAV command. To recall a variable, use the NVRCL command:

NVSAV name, location

NVRCL name.location

name is the name of the variable or array and *location* is the memory location. Each variable uses one memory location and arrays use a memory location for each value. Free variables, local variables and local arrays cannot be saved in non-volatile memory.

Example: VAR DD

NVSAV DD, 10

DD is now saved in non-volatile memory location 10. To recall DD, use the NVRCL command.

Example: NVRCL DD, 10

The content of memory location 10 is loaded into variable DD.

When an array is saved using the NVSAV command, the whole array is saved in consecutive memory locations.

Example: VAR list[5]

NVSAV list,1

The values of list are saved in memory locations 1 through 6 (6 values starting at 1). Arrays are recalled the same as variables.

Example: NVRCL list,1

The contents of memory locations 1 through 6 are loaded into list[0] through list[5].

NOTE: Overwriting previously used memory locations deletes previous entries.

```
Example: VAR List[4]={2,4,6,8,10} // Declares an array named List.

VAR Group[2]={23,46,69} // Declares an array named Group.

NVSAV List, 10 // Saves List in memory locations

// 10 through 14.

NVSAV Group,12 // Saves Group in memory locations

// 12 through 14.

NVRCL List,10 // Recalls memory locations 10 through

// 14 and assigns the values to List.
```

Three of the saved values of List were lost when the same memory locations were used to save the array Group.

3-4 CONSTANTS AND DATA ARRAYS

Constants are declared using the CONST command. Constants are global only and cannot be declared inside a macro.

CONST name, expression, name, expression,..., name, expression

A constant *name* starts with a letter while the remaining characters can be letters, numbers and the underscore. A constant *name* can be 2 to 31 characters in length.

Example: CONST PI, 3.1415, FREQ, 3000

String data cannot be assigned to a constant. Expressions do not have to be in simplest form.

Example: CONST AA, (4+6)/2

AA is set equal to 5.

Once a constant is declared with the CONST command, it is changed only with another CONST command.

Example: CONST AA, 36

AA=20

The second command results in an error message and is not performed, leaving AA equal to 36.

Constant data arrays are declared using the DATA command:

DATA name = {expression, expression,..., expression}

A data array name starts with a letter while the remaining characters can be letters, numbers and the underscore. A data array name can be 2 to 31 characters in length.

Example: DATA offsets $1 = \{2, 3, 4, 5, 6, 7, 8, 9\}$

Like a constant, data arrays cannot be assigned string data nor do expressions have to be in their simplest form. Once a data array is declared, it is changed only by another **DATA** command. Contents of data arrays are accessed using the index enclosed in brackets.

Example: DATA Points = {11.6, 17.3, 22.4, 27.1}

Y = Points[2]

Variable Y is set equal to 22.4.

3-5 NUMERIC FORMATS

3-5-1 NUMERICAL NOTATION

Numerals are expressed as fixed point decimal, scientific notation or as an integer. Numerals are specified as negative with a - character as shown:

Example: -51

This denotes a negative 51.

The maximum fixed point decimal numeral that can be entered is ± 2147483647 . Scientific notation uses the letter e to denote an exponent of 10.

Example: 54e7

This number signifies 54 multiplied by 10 to the 7th power or 540,000,000.

100 is the maximum power of 10 that can be entered, although the maximum number in scientific form allowed is + 1.797693e308. Numbers with a larger power of 10 than 100 are assigned to a variable by multiplying powers of 10.

Example: Large = 54e7*1e100*1e100

This example assigns 54e207 or 54 multiplied by 10 to the 207th power to variable Large.

NOTE: For execution reasons, the CSA uses single precision floating point numbers e.g. 1e±38.

3-5-2 NUMERIC FORM

To enter data in a different format (base 2, 8 or 16), precede data with one of the following characters:

#B Binary

#Q Octal

#H Hexadecimal

Data format for the returned data for queries is changed to base 2, 8, 10 or 16 using the **FORMat** command. The default format is base 10.

FORMat BINary Data is returned in base 2 format.

FORMat OCTal Data is returned in base 8 format.

FORMat HEXadecimal Data is returned in base 16 format.

FORMat ASCII (1600S) Data is returned in base 10 format.

FORMat DECimal (CSA) Data is returned in base 10 format.

Binary, octal or hexadecimal data received from the Test Set (1600S only) is preceded by #B, #Q or #H notation. Data in scientific notation is not affected by these commands.

3-6 MATHEMATICAL OPERATORS

TMAC provides a variety of mathematical operators and bit manipulating functions to perform mathematical operations. A 32 bit word is used for binary and bitwise operations.

3-6-1 OPERATORS

= Assignment operator

Assigns a value to a variable. Variable on the left of the = operator is the given value computed for the expression on the right.

Examples: x=2; Mod = w * 2 + z

The assignment operator does not denote an equation.

Example: x = x + 2

Assigns a new value to x, 2 greater than the previous value.

** Exponential operator (does not conform to SCPI Standard)

Consists of two consecutive asterisks.

Examples: y=4**-2; MM = NN**4; Freq = C**D

The first example assigns y to 4 raised to the -2 power. The second example assigns MM to NN raised to the 4th power. The third example assigns Freq to C raised to the D power.

* Multiplication operator

Examples: x=4*6; T = 25*S; JJ = K*LL

The first example assigns x to 4 multiplied by 6. The second example assigns T to 25 multiplied by the value of S. The third example assigns JJ to the value of K multiplied by the value of LL.

/ Division operator

Examples: Y=8/3.867; Z = x/7; P = O/R

The first example assigns y to 8 divided by 3.867. The second example assigns Z to the value of x divided by 7. The third example assigns P to the value of Q divided by the value of R.

NOTE: A command to divide by zero results in an error message.

+ Addition operator and positive unary operator

Examples: G=4+F; AA = B1 + B2, +x

The first example assigns G to 4 added to the value of F. The second example assigns AA to the value of B1 added to B2. The last example is the value of X.

Subtraction operator and negative unary operator

Examples: H = I - 5; V = U - T, -B

The first example sets assigns H to 5 subtracted from the value of I. The second example assigns V to the value of T subtracted from the value of U. The last is the negative or opposite value of B.

% Modulo operator (does not conform to SCPI Standard)

Returns the integer truncated remainder of a division operation. If operands are not integers, they are truncated first.

Examples: x=7%3; RR=16%4; N = 20.5%3.3; M = 27%L;

The first example assigns x to 7 modulo 3 (1). The second example assigns variable RR to 16 modulo 4 (0). The third example assigns N equal to 20 modulo 3 (2). The fourth example assigns M to 27 modulo the value of L.

-- Decrement and

++ Increment operators

The decrement operator subtracts 1 from the value of a variable either before or after execution of the command it is included in. The increment operator acts in the same manner, except it adds instead of subtracts.

--variable Decrements variable before execution of the command.

variable-- Decrements variable after execution of the command.

++variable Increments variable before execution of the command.

variable++ Increments variable after execution of the command.

Examples: y = 7

The x = --y command subtracts 1 from y and then assigns this value to x. After the second command is executed, x and y equal 6.

Examples: y = 7x = y++

The x = y++ command assigns x to the y value (7) and then adds 1 to y. After the command is executed, x equals 7 and y equals 8.

Bitwise complement

Inverts the binary representation of the operand using the one's complement form of negative numbers.

Example: $X = \sim 6$

0110 (6) is inverted to 1001 (one's complement of -7) and -7 is assigned to X.

Logical negation (NOT) unary operator

Reverses the truth value.

Example: !D

The example is true when D equals 0.

Bitwise OR

Performs OR operation on each bit of the binary representation of the two operands and returns the result in the original form of the operands. Table 3-1 lists the bit combinations and their OR operation results.

operand 1	operand 2	OR result	
0	0	0	
0	1	1	
1	0	1	
1	1	1	

Table 3-1 OR Operation Results

Example:
$$y = 4 | 2$$

OR
$$\frac{4}{2}$$
 $\frac{100}{010}$

The left bit of 4 (100) and 2 (010) are 1 and 0, providing an OR result of 1. The middle bits are 0 and 1, providing an OR result of 1. The right bits are both 0, providing an OR result of 0 and setting y equal to 6 (110).

Example:
$$Z = 12 \mid 10$$

& Bitwise AND

Performs AND operation on each bit of the binary representation of two operands and returns the result in the original form of the operands. Table 3-2 lists the bit combinations and the AND operation results.

operand 1	operand 2	AND result	
0	0	0	
0	1	0	
1	0	0	
1	1	1	

Table 3-2 AND Operation Results

Example: JJ = 4 & 6

AND 6 1 1 0 0 4 1 0 0

The left bit of 4 (100) and 6 (110) are 1, providing an AND result of 1. The middle bits are 0 and 1, providing an AND result of 0. The right bits are both 0, providing an AND result of 0 and setting JJ equal to 4 (100).

Example: w = 12 & 10

12 1 1 0 0 AND 10 1 0 1 0 8 1 0 0 0

A Bitwise XOR (conflicts with SCPI Standard for Exponential operator)

Performs XOR operation on each bit of the binary representation of two operands and returns the result in the operands original form of the operands. Table 3-3 lists the bit combinations and the XOR operation results.

operand 1	operand 2	XOR result
0	0	0
0	1	1
1	0	1
1	1	0

Table 3-3 XOR Operation Results

Example: $y = 4 ^ 6$

XOR 6 1100 2 010

The left bit of 4 (100) and 6 (110) are 1 providing a XOR result of 0. The middle bits are 0 and 1, providing a XOR result of 1. The right bits are both 0, providing a XOR result of 0 and setting y equal to 2 (010).

Example: $v = 12 ^10$

>> Shift right and

<< left operators

Shift right (>>) and shift left (<<) operators shift the operands binary representation a specified number of bits and returns the result in the operands original format. During shifts, emptied bit positions are filled with zeros. Shift operators use the twos complement representation for negative numbers.

Example: Q = 14>>1

14 (1110) shifts right 1 bit to become 7 (0111) and is loaded into variable Q.

Example: VAR DIV4

m = 2DIV4 = 75<<m

DIV4 = /5<<m

75 (1001011) shifts left 2 bits to become 300 (100101100) and is loaded into variable DIV4.

Example: x = -19 << 3

-19 (11101101) shifts left 3 bits to become -152 (111101101000).

3-6-2 ORDER OF CALCULATION

When more than one operator is contained in an expression, the operators are calculated in the following order:

- Contents of parenthesis, calculating from inner sets to outer sets of parenthesis.
- Positive (+), negative (-), bitwise complement (~) and logical negation (!).
- Exponentiation (**).
- Multiplication (*), division (/) and modulus (%).
- Addition and subtraction.
- Shift left (<<) and right (>>) operations.
- Bitwise AND (&).
- Bitwise XOR (^).
- Bitwise OR (¦).
- Logical AND.
- Logical OR.
- Condition? true:false (Refer to IF ELSE [Shorthand] command in section 3-18.)

3-7 MATHEMATICAL FUNCTIONS

TMAC provides mathematical functions to assist in mathematical calculations:

TRUE, ON

Produces 1.

Example: X=TRUE

X is set to 1.

FALSE, OFF

Produces 0.

Example: Y=OFF

Y is set to 0.

RND(n)

Produces a random integer between 0 and n. If n is not an integer, it is truncated.

Example:

WW=RND (100)

WW now contains a randomly generated number between 0 and 100.

RAND x

Sets the seed (starting point) for the random generator which allows the random generator to produce the same series of random numbers each time the starting point is set to the same value.

Example:

RAND 12

FOR X=1 TO 10 STEP 1

Z=RND (100) PRINT Z NEXT X

The RAND 12 command sets a starting point for the RND command. When the RND(100) command is executed 10 times the following numbers are generated:

47, 77, 31, 27, 39, 100, 57, 46, 41 and 30

Each time RAND is set to 12, the RND(100) command produces the same series of random numbers.

Produces the base 10 logarithm of n.

Example: VAR Log_C

C = 5

 $Log_C = LOG(C)$

Log_C now holds base 10 logarithm of 5 (0.698970004).

NOTE: If $n \le 0$, LOG(n) command execution results in an error message as this function is not defined for these values.

LN(n)

Produces the natural logarithm (base e) of n.

Example: VAR Nat_log

 $Nat_log = LN(D)$

Nat_log now holds natural logarithm of 5 (1.609438).

NOTE: If $n \le 0$, LN(n) command execution results in an error message

as this function is not defined for these values.

ABS(n)

Produces the absolute value of n.

Example: Y=ABS (-4)

Y now equals +4.

Example: z=-7

POS=ABS(Z)

POS now holds +7.

FLOOR(n)

Produces the truncated value of n.

Example: VAR Round off

Round off = FLOOR(5.99)

Round_off now holds 5 the truncated value of 5.99.

Produces the positive square root of n.

Example: VAR Square Root

Square Root = SQR(30)

Square_Root now holds the positive square root of 30 (5.477226).

NOTE: The square root function returns 0 for the square root of negative numbers.

EXP(n)

Produces e to the power of n.

Example: VAR Expo

x=1.57Expo=EXP(x)

Expo now holds e to 1.57th power (4.810255).

SIN(n)

Produces the sine of n measured in radians.

Example: VAR Sine_of_radians

Sine_of_radians=SIN(3.1415/3)

Sine_of_radians now holds the sine of $\pi/3$ (0.86601).

COS(n)

Produces the cosine of n measured in radians.

Example: VAR Cosine of radians

Cosine of radians=COS(5*3.1415/6)

Cosine_of_radians now holds the cosine of $5\pi/6$ (-0.8659868).

SIGN(n)

Produces -1 if n<0, 0 if n=0 or 1 if n>0.

Example: S=SIGN(-6)

Value of S is set to -1.

3-8 STRING VARIABLES AND FUNCTIONS

A string is a segment of text consisting of ASCII characters. String variables are declared using the **STRING** command. There is a free string variable, represented by the \$ character that does not need to be declared. String variables are either local (declared inside a macro) and are used only inside that macro or are global (declared outside a macro) and are used outside or inside any macro, depending on scope.

A literal string (actual ASCII text segment) is enclosed in quotation marks or apostrophes. To signify a quotation mark inside a literal string enclosed with quotation marks, a pair of quotation marks are used. When quotation marks are used to signify a literal string, apostrophes are treated as normal characters. To signify an apostrophe inside a literal string enclosed in apostrophes, a pair of apostrophes are used. When apostrophes are used to signify a literal string, quotation marks are treated as normal characters.

String variable names start with a letter while the remaining characters can be letters, numbers and the underscore. String variable names can be 2 to 31 characters in length. The **STRING** command has the following form:

```
STRING name, name,..., name
```

String variables cannot be initialized when declared. Only literal strings and/or other declared string variables can be assigned to the initialized string variable.

```
Example: STRING WARNING, Note1, Message_no_2
Note1 = "This is a string variable"
```

Strings and string variables are combined by using + character as follows:

```
Example: STRING Note_1, Note_2, Note_3
    Note_1 = "A STRING"
    Note_2 = "COMBINING"
    Note_3 = Note_1 + " " + Note_2 + " EXAMPLE"
```

Note 3 now equals A STRING COMBINING EXAMPLE.

Segments are removed from strings using brackets in the following manner:

```
name1 = name2[start][end]
```

name1 is set equal to the segment in name2 that begins with the start number and ends with the end number. Count of string name2 begins with 0. String name2 is not affected unless name1 and name2 are the same name.

```
Example: STRING Test

$ = "Test1"

Test = $[4][4]
```

Test equals 1, the fourth (count begins with 0) character of string \$.

Example: STRING MEMO1

MEMO1 = "Message example"

MEMO1 = MEMO1[10][15] + MEMO1[0][3]

MEMO1 now contains the string "ample mess".

String Arrays are also declared using the STRING command by including the highest index in brackets as shown:

STRING name[index]

The index count starts with 0, making *index* one less than the actual number of variables in the array. String arrays cannot be initialized when declared. Only one string array element is assigned a value at a time.

Example: STRING MESSAGE[5]

This command declares a string array named message containing six elements.

Example: message[0] = "see"

MESSAGE[1] = "spot"
MESSAGE[2] = "run"

This example assigns values to the first three elements of string array MESSAGE.

Substringing on string arrays allows segment selection from one or more elements in a string array. Adding a *start* and *end* number selects the segment in the *element* of the declared and initialized string array (*arrayname*). Segments are selected using the following format:

arrayname[element][start][end]

Example: \$ = MESSAGE[0][1][2]

This example assigns the string "ee" to \$. ee is the segment in the first element [0], starting at character [1] and going through character [2].

There are several string functions that allow manipulations of strings:

CHR(n)

Returns the character equivalent of ASCII number n.

Example: \$=CHR(82)

\$ is set equal to R (ASCII number of R is 82).

TAB(n)

Returns a blank string of length n spaces.

Example: PRINT TAB (7), "FREQ = "

FREQ = is printed starting seven spaces from left edge of the CRT.

Returns ASCII value of the first character of a string.

Example: VAR Ascii_value

STRING Char Char="Example"

Ascii value = ASC(Char)

Ascii_value, a numeric variable, contains 67 (ASCII number of E).

LEN(\$)

Returns the length of string \$ in the number of characters.

Example: Fred = "string"
B = LEN(Fred)

B, a numeric variable, contains 6 (the number of characters in "string").

STR(n)

Returns the string equivalent (character representation) of number n.

Example: \$ = STR(236)

\$, a string variable, contains characters 236.

VAL(\$)

Returns the numeric value represented by string \$.

Example: STRING Commd
Commd = "567"

C = VAL(Commd)

C, a numeric variable, contains the number 567.

PIXLEN(\$)

Returns the length of a string in pixels (useful in centering text for the 1600S).

Example: STRING Mode // Declare Mode string.

Mode = "Test Mode 4" // Initialize Mode string.

P = PIXLEN(Mode) // Assign pixel length of Mode to P.

XY ((640-P)/2)-1,40 // Set point for horizontal center.

XY ((640-P)/2)-1,40 // Set point for hori Print Mode // Print Mode string.

P, a numeric variable, contains the number 160, the length of "Test Mode 4" in pixels. (See PRINT and XY commands in section 3-18.)

Returns the position of string \$2 inside string \$1. If string \$2 is not found, -1 is returned. The count in string \$1 begins with 0.

Example: STRING One, Two
One = "preset"
Two = "set"
X = STRPOS(One, Two)

X is set to 3, "set" starts with the fourth character in "preset."

3-9 MACROS

Macros are programs, groups of commands arranged to accomplish one or more tasks. Macros are written and transferred to the Test Set by a Host System (PC with terminal emulating software). Once the macro is transferred to the Test Set, it is stored in memory (non-volatile for 1600S) until deleted by a *PMC or FORGET command or for CSA, power is removed. Once in memory, macros can be transferred to Flash Memory (see 4-14 for 1600S or 7-13 for CSA).

Macros are defined using the *DMC command (complying with IEEE-488.2) and have the form:

*DMC "name", command,... , command

The name must start with a letter, the rest of the characters can be letters, numbers and the underscore. The maximum length is 31 characters (IEEE-488.2 allows only 12 characters).

Example: *DMC "Square", Y=X**2; PRINT "Y holds X squared"

Once the macro is loaded into memory, it is executed by entering the macro name. If the above macro is loaded, entering Square executes the macro Square. Macros can be called out and executed from other macros. However, a macro cannot be transferred into memory if it contains the name of an undefined macro, unless the name is in an INTERP command.

Example: *DMC "Test_1", BEGIN

Average END

Example: *DMC "Test_2", BEGIN

INTERP "Total"

END

If the macro Average is not already defined, the macro Test_1 cannot be transferred into memory. Macro Test_2 can be loaded into memory because the string Total is not evaluated until execution of the INTERP command. The macro Total has to be defined prior to Test_2 execution, otherwise an execution error will occur.

Call nesting is the extended process of calling out other macros that call out other macros that call out other macros, etc. Call nesting uses a limited stack to contain all the internal variables and arrays for each macro called out. Reaching the stack limit initiates a memory error.

With TMAC as opposed to IEEE-488.2, macros are not limited to one line. Using the **BEGIN** and **END** commands lets the macro contain multiple lines, allowing large involved macros, while also providing clarity that one line macros cannot afford.

Example: *DMC "Square_x", BEGIN Y=X**2

END

A macro is deleted from memory using the FORGET command. All macros and variables declared after the deleted macro was declared, are also deleted (because they may contain references to the deleted macro). The *PMC command deletes all macros and declared variables in memory regardless of location. Predefined macros, listed in Appendix A, are permanently in memory and are not affected by the *PMC or FORGET commands. The *LMC? query (1600S only) returns a list of the macros and defined variables contained in memory.

The address of a macro (location of macro in memory) is assigned to a variable by using an ampersand in the following manner:

X=&name

The EXEC command executes the macro at the address following the command. It has the form:

EXEC address

Example: ADD = &Square x

EXEC ADD

The first command loads the address of Square_x into ADD. The **EXEC** command then executes Square_x.

The **EXEC** command can be used to call out undefined macros by simply declaring a variable and using the variable as the address.

(1600S only) The ***WAI** command pauses command execution until all previous operations are complete. ***WAI** is used following **SCREEN** commands and commands involving routing changes or long execution times. It has the form:

*WAI

The size of the Test Set memory is the only limit to the number of macros that can be loaded. The **ROOM** command provides the available amount of memory space, in bytes.

Example: PRINT ROOM

Prints the number of available bytes left in memory on the CRT.

Refer to 4-13 and 4-14 for 1600S specific **PROGram** and **MMEM** commands used in executing 1600S specific macros from the Front Panel.

Refer to Section 6 for loading CSA macros into Test Set memory for Front Panel execution.

3-10 CONDITIONAL EXPRESSIONS

TMAC allows decision points to be placed inside a macro to allow different courses of action. For instance, If a condition is true, then one course of action is taken. If the condition is false, then another course of action is taken. See CASE, IF, IF ELSE and IF ELIF. All conditions have relational operators:

- = Equal
- != Not equal
- < Less than
- > Greater than
- <= Less than or equal</p>
- >= Greater than or equal

Example:

IF x=6
PRINT Y
ENDIF

Condition x equals 6 must be true for the next command (PRINT y) to execute; otherwise it is ignored and command execution passes to the command following the **ENDIF** command.

Example:

IF x!=z PRINT y ENDIF

Condition x = z (x not equal to z) must be true for the next command to execute. If it is not true, the command following the **ENDIF** is executed next.

Conditions may also contain logical operators AND and OR. These operators connect two conditions. An expression with an OR is true if one or both conditions it connects are true. An expression with an AND is true if both conditions it connects are true. There can be many logical operators in a condition.

Example:

IF x=6 OR x!=z PRINT y ENDIF

This condition is true if either x is equal to 6, if x is not equal to z or if both are true.

Example:

IF x=6 AND x!=z PRINT y ENDIF

This condition is true if both x is equal to 6 and x is not equal to z.

Example: II

IF W=3 OR U< 8 AND V=4

PRINT y

ENDIF

This condition is true if either W is equal to 3 or both U is less than 8 and V is equal to 4.

Mathematical operators can be used in conditions.

Example:

IF W> 2*X**3

The quantity 2*X**3 is calculated before compared to W.

Example:

IF T = U&++V

In this example, V is incremented and bitwise AND is performed before comparison with T is done.

Mathematical functions can also be used in conditions.

Example:

IF Y = SQR(COS(2*Freq))

In this example, the square root of the cosine of the quantity of 2 multiplied by Freq is calculated before the quantity is compared to Y.

Conditional expressions can be used without IF or other decision commands. Conditional expressions alone return a 1 if they are true and a 0 if they are false.

Example:

X=W<2*y**2

If W is less than $2 \times y^2$, X is set to 1. If W is greater than $2 \times y^2$, X is set to 0.

Example:

X=W=ABS(W)

If W is positive, W equals ABS(W) and X is set to 1. If W is negative, W does not equal ABS(W) and X is set to 0.

3-11 VARIABLES AND ARRAYS IN MACROS

Variables and arrays are passed to a macro when entering the macro by entering variables and arrays (parameters) after the name of the macro. Inside the macro, characters \$1, \$2, \$3,...., \$9 are placeholders for the passed parameters. Parameters may be passed to macros during execution.

Example: *DMC "Compute", Y=\$1**\$2; PRINT \$1, "TO THE POWER OF ",\$2," IS ",Y

Entering Compute 4,3 executes the macro Compute and sets \$1 equal to 4 and \$2 equal to 3. The CRT displays the result: 4 TO THE POWER OF 3 IS 64.

Example: $VAR LIST[2] = \{1,3,5\}$

*DMC "Average", BEGIN

VAR SUM=0

FOR N=0 TO \$1-1

SUM=SUM + \$2[N]

NEXT N

PRINT "THE AVERAGE IS ",SUM/\$1

END

Average 3,LIST

The macro Average reads an array and finds the average of the elements of the array. The length and name of the array is passed upon macro execution. When Average 3, LIST is entered, array LIST is passed using a **FOR** loop. The macro then prints the average of the 3 array values.

Example: Add=&Compute EXEC Add, 4,3

A comma is placed before the variables when a macro is executed using the EXEC command. This example executes the macro Compute and has the same result as the first example.

The **INPUT** command allows data entry during macro execution. Data is entered using the Test Set DATA ENTRY Keypad (1600S) or the RS-232 terminal keyboard (CSA). After pressing the applicable ENTER key, variable x is given the value entered. For the 1600S, the **INPUT** command causes the CRT to display a blinking cursor. The **EDIT:WIDTH** command limits the width of the blinking cursor to n number of pixels. These commands have the form:

INPUT x EDIT: WIDTH n

If Compute 5 is entered to execute the macro and 3 is entered using the DATA ENTRY Keypad (1600S), 5 TO THE POWER OF 3 IS 125 is printed.

3-12 MULTITASKING MACROS

Multitasking allows command execution to alternate between different macros prior to their completion. This allows complex macros to be separated into more manageable macros. Before a macro can share execution time with other macros, it must be declared a task using the **TASK** command and be put into the schedule queue using the **ACTIVATE** command. Multitasking requires the first macro in the schedule queue to also be the last macro to finish execution.

TASK "name"

Declares the named macro a task. Macro named must be in memory. A macro must be declared a task before it can be placed on the schedule queue.

ACTIVATE "name"

This command places the specified task on the schedule queue.

TPAUSE

This command passes command execution to the next macro or any Test Set activity in the schedule queue.

TSTOP

This command removes the currently executing task from the schedule queue and performs a **TPAUSE**.

SLEEP "name"

Takes the specified task out of the schedule queue.

WAKE "name"

Puts the specified task into the schedule queue and starts execution from point of last executed command.

```
Example: *DMC "Main", BEGIN
ACTIVATE "First"
ACTIVATE "Second"
A=0
B=0
WHILE A=0 OR B=0
TPAUSE
WEND
END

*DMC "First", BEGIN
FOR x = 1 to 10
PRINT "FIRST"
```

```
FOR x = 1 to 10

PRINT "FIRST"

IF x=3

A = 1

TSTOP

ENDIF

TPAUSE

NEXT x

A = 1

END
```

```
*DMC "Second", BEGIN
n=1
FOR m=1 to 10
PRINT "SECOND"
IF n=2
TPAUSE
n=0
ENDIF
n=n+1
NEXT m
B = 1
END
```

Executing the macro Main places Main in the schedule queue and then loads tasks First and Second into the schedule queue with Main. The macro Main fulfills the requirement of a macro to continue executing with its WHILE loop. This loop assures Main executes until First and Second have finished execution. The following sequence occurs:

- First begins execution, x is set to 1 and FIRST is printed. The IF command is skipped $(x \neq 3)$, the TPAUSE command executes and command execution passes to Second.
- Second begins execution, n and m are set to 1 and SECOND is printed. The IF command is skipped (n ≠ 2) and n is incremented to 2. Command execution loops to top of the FOR loop and m is incremented to 2. SECOND is printed and the TPAUSE command inside the IF command executes passing command execution to Main.
- Command execution begins again inside the WHILE loop. A and B are compared and the TPAUSE command is executed passing command execution to First.
- In First, command execution loops to the top of the FOR loop and x is set to 2. FIRST is printed, the IF command is skipped ($x \neq 3$) and the TPAUSE command passes command execution to Second.
- In Second, n is set to 0 and then incremented to 1. Command execution loops to the top of the FOR loop and m is set to 3. SECOND is printed, the IF command is skipped (n ≠ 2) and n is incremented to 2. Command execution loops to the top of the FOR loop and m is incremented to 4. SECOND is printed and the TPAUSE command inside the FOR loop executes passing command execution to Main.
- Command execution begins again inside the WHILE loop. A and B are compared and the TPAUSE command is executed passing command execution to First.
- In First, command execution loops to the top of the FOR loop and x is set to 3. FIRST is printed, A is set to 1 and the TSTOP command inside the FOR loop executes taking First out of the schedule queue. Command execution passes to Second.
- In Second, n is set to 0 and then incremented to 1. Command execution loops to the top of the FOR loop and m is set to 4. SECOND is printed, the IF command is skipped (n ≠ 2) and n is incremented to 2. Command execution loops to the top of the FOR loop and m is incremented to 5. SECOND is printed and the TPAUSE command inside the FOR loop executes with no result. Second continues to run in this manner until the loop is finished printing SECOND six more times. B is set to 1 and Second finishes execution returning command execution to Main.
- The WHILE loops conditional expression is satisfied ending the loop and the macro Main finishes execution.

3-13 CREATING WINDOWS AND GRAPHICS

TMAC allows creation of new screen displays and changes to CRT screen configurations. Colors can be changed. Windows can be created and moved. Pixels, boxes, lines and figures may be drawn and placed anywhere on the CRT screen. Audio cues can be implemented.

Some commands work in either the FM/AM-1600S or FM/AM-1600CSA. Other commands work only with one or the other as indicated.

3-13-1 COLORS

Table 3-4 lists the 16 colors, according to selection number, available for the CRT display.

COLOR	NUMBER	COLOR	NUMBER
Black	0	Dark Grey	8
Dark Blue	1	Blue	9
Dark Green	2	Green	10
Dark Cyan	3	Cyan	11
Dark Red	4	Red	12
Dark Magenta	5	Magenta	13
Brown	6	Yellow	14
Light Gray	7	White	15

Table 3-4 Colors and Color Selection Numbers

COLOR commands change the color selection for the CRT screen except for Soft Function Keys and menus which are changed by **EDIT:COLOR** commands (1600S only).

NOTE: Colors are entered using selection number or constant name (see Appendix A).

COLOR f,b

Changes the foreground color to the color selected for f and the character contrast color to the color selected for b.

COLOR?

Returns the current foreground color.

BCOLOR b

Changes the background color to the color selected for b.

NOTE: EDIT commands only apply to the FM/AM-1600S.

EDIT:COLOR:MENU C

Changes the menu color to the color selected for c.

EDIT:COLOR:MENU?

Returns the current menu color.

EDIT:COLOR:LETTER c

Changes the menu letter color to the color selected for c.

EDIT:COLOR:LETTER?

Returns the current menu letter color.

EDIT:COLOR:SOFT:BOX c

Changes the Soft Function Key background color to the color selected for c.

EDIT:COLOR:SOFT:BOX?

Returns the current Soft Function Key background color.

EDIT:COLOR:SOFT:LETTER c

Changes the Soft Function Key letter color to the color selected for c.

EDIT:COLOR:SOFT:LETTER?

Returns current Soft Function Key letter color.

EDIT:COLOR:SOFT:SELECT c

Changes the Soft Function Key selected color to the color selected for c.

EDIT:COLOR:SOFT:SELECT?

Returns the current selected Soft Function Key background color.

EDIT:WIDTH n

Sets the width of the blinking cursor that appears with the **INPUT** command to n pixels.

3-13-2 CRT DISPLAY

The display subsystem divides the CRT screen into pixels: 640 in the horizontal direction and 350 in the vertical direction. Window and graphic commands use these pixels to determine screen location. Screen locations are specified using a coordinate system with point 0,0 located in the top left corner of the CRT screen. The positive horizontal component is to the right and the positive vertical component is in the downward direction.

3-13-3 WINDOWS

Windows, used primarily for menus, can be created and moved. There can be up to 15 windows on a screen at one time. Windows are numbered in the order they are opened and must be closed in reverse order if overlapped. The last window opened is the selected window unless selection is changed by a **WSEL** command. Windows can be any size or color and can be moved to any location on the screen. Following are the window commands:

CLS

Clears everything from entire display screen (window 0) or currently selected window except for active readings.

SCREEN: USER (1600S) or USER (CSA)

Clears everything from active window. Displays blank user screen when active window is the default value of 0 (background screen). Decreases run time because of no readings to update.

WOPEN c, x1, y1, x2, y2

Opens a c colored window. The top left corner is located at point x1, y1 and the bottom right corner is located at point x2, y2.

WMOVE x, y

Moves the window so the top left corner is located at point x, y.

NOTE: When a window is moved, parts of windows and graphics overlapping the moved window are moved also.

WCLOSE n

Closes n window. Range of n is 1 to 16 with n=16 closing all open windows.

WSEL n,h

Makes window n the currently selected window. If h is set to 1, the window specified is hidden. To show the hidden window again, it must be closed and reopened. Selecting window 0 selects the background window.


WINDOW?

Returns the number of the last opened window (useful when closing or selecting windows).

Print commands executed while a window is open prints inside the currently selected window. To print outside the windows, select window 0 (background screen).

Example: VAR Win1, Win2
CLS
WOPEN 10, 100,50, 250,300
Win1=WINDOW?
WOPEN 12, 300,100, 550,250
PRINT "WIN 2"
Win2=WINDOW?
WSEL Win1
PRINT "WIN 1"
WSEL 0
PRINT "THIS IS THE BACKGROUND"

These commands produce the following display:



8618010

Figure 3-1 Window Example

NOTE: The EGA control software forces the window locations and sites to the nearest multiple of eight (byte size). Therefore, it is a good idea to determine the location values prior to opening or moving a window.

3-13-4 SOFT FUNCTION KEY DISPLAYS

Soft Function Key definitions and the Soft Function Key frame at the bottom of the CRT screen are added using the following commands.

KEYPAD:SOFT

(1600S only) Creates a Soft Function Key frame at the bottom of the current screen displayed on the CRT.

KEYPAD:LABel n,"label"

Changes the *label* of Soft Function Key n (1 to 6) on the current screen to the specified string.

NOTE: KEYPAD:LABel n, "" is equivalent to KEYPAD:ERASE n.

KEYPAD:ERASE n


(1600S only) Erases the label of Soft Function Key n (1 to 6) on the current screen.

Example: CLS

KEYPAD:SOFT

KEYPAD: LAB 3, " Test"

The following is shown on the Test Set CRT:



8618012

Figure 3-2 Soft Function Key Example

3-13-5 GRAPHICS AND TEXT

Graphics and text commands create text, pixels, lines, boxes and user defined shapes for display on the CRT:

XY n.m

Places a point location into memory with *n* being the x position (0 to 639) and *m* being the y position (0 to 349). 0,0 is the upper left hand corner of the CRT. **PIXEL**, **PRINT**, **HPRINT** and **ICON** commands start at the current xy position.

PIXEL

Displays a point on the CRT at the current xy location. A point is displayed in the current foreground color and does not change color if the foreground color changes. The point does not move if an XY command changes the point location in memory.

DRAW x1, y1, x2, y2, c

Draws a line from point x1, y1 to point x2, y2 in the color selected for c.

BOX f, x1, y1, x2, y2, c


Draws a box with the top left corner at point x1, y1 and the bottom right corner at point x2, y2. Box is drawn in color selected for c. If f is set to 0, the box is empty. If f is set to 1, the box is created solid.

Example:

XY 400,100 COLOR 9,0 PIXEL DRAW 200,100 250,300, 12 BOX 0, 250,20 350,120, 10 BOX 1, 280,200, 550,280, 13

This set of commands creates the following graphics displayed in Figure 3-3.

- Blue pixel at point 400, 100 and red line from point 200, 100 to point 250, 300.
- Hollow green box with top left corner at point 250, 20 and lower right corner at point 350, 120.
- Solid magenta box with top left corner at point 280, 200 and lower right corner at point 550, 280.



8618011

Figure 3-3 Graphics Examples

HEIGHT n

Changes the text height displayed on the CRT to n times the standard height (0.175 inches). n is 1,2,3 or 4 to provide text heights of 0.175, 0.35, 0.525 or 0.7 inches, respectively.

The following commands apply only to the FM/AM-1600S except as noted:

PRINT %0nl, expression, expression,, expression,

Displays information on the CRT, starting at the current xy position. An *expression* may be a variable (displayed as a value), string or characters and spaces designated within quotation marks. The % *Onl* sets the format for numeric values (see **PRINT** command in 3-18).

NOTE: For CSA operation, the PRINT command prints out the CSA RS-232 Connector. For CSA operation the HPRINT (host print) command prints on the CRT.

ELLIPSE b,x,y,r,a,c

Draws an ellipse centered at x,y with radius r and aspect ratio a. Ellipse is drawn in color selected for c. If b is 1, the ellipse is solid. If b is 0, the ellipse is hollow. An aspect ratio of 0.75 creates a circle. Parameters x, y, r and a are measured in pixels. The height and width of other ellipses are found using the following equations:

```
a < 0.75 Width = 0.2 \times r Height = 24 \times a

0.75 < a < 1 Width = 2 \times r Height = 13.7 a^2 + 16.3

a \ge 1 Width = r \div (5 \times a) Height = 1.25 \times r
```

ICON b,r,name

Creates a user defined graphic displayed on the CRT. The CRT displays a predefined bit pattern with each bit represented by a pixel. Parameter b sets how many bits per row, r sets how many rows and name is a data array name which contains the preset bit pattern. The data array consists of 32 bit words. The graphics top left corner is the current xy position.

The example creates the following image:




Figure 3-4 ICON Example

The following commands apply only to the FM/AM-1600CSA:

CENTER element, x, y, pw

Displays given text *element* (string or characters and spaces designated within quotation marks) in the center of the CRT display area defined by x,y position and pixel width, pw.

ERASE:TEXT x,y,pw

Erases the CRT display area defined by the x,y position and pixel width, pw.

HPRINT %Onl, expression, expression,, expression,

Displays information on the CRT, starting at current xy position. An expression may be a variable (displays value), string or characters and spaces designated within quotation marks. The %0nl sets the format for numeric values (see HPRINT command in 3-18).

LJPRINT value, x, y, pw

Erases the CRT display area defined by the x,y position and pixel width, pw. Displays the entered value, left justified, in the defined area on the CRT.

PIXLEN? value

Returns number of pixels required to display given value.

RJPRINT value, x, y, pw

Erases the CRT display area defined by the x,y position and pixel width, pw. Displays the entered value, right justified, in the defined area on the CRT.

XYPRINT x, y, % Onl, expression, expression,, expression,

Combines the XY and HYPRINT commands. Displays information on the CRT, starting at the selected x,y position. (see XYPRINT command in 3-18).

3-13-6 AUDIO TONES

Audio tones are generated using the SOUND command:

SOUND f,t

This command generates a tone of frequency f Hz for t ms. The tone is routed to the Test Set Speaker. There are two predefined macros, Chirp_1 and Chirp_2, that produce a short series of tones. Chirp_1 and Chirp_2 are detailed in Appendix A.

8618006

3-14 SYSTEM COMMANDS

3-14-1 SYSTEM KEY COMMANDS (1600S Only, except as noted)

SYSTEM:KEY commands assign Front Panel Keys to command strings that can execute macros. Command strings are limited to 80 characters. Only 16 keys can be assigned at one time. Appendix B lists Front Panel Keys with keycodes. Appendix A lists Front Panel Keys having predefined constants.

SYSTem:KEY:DEFine n, sequence

Assigns the specified command sequence to the key with keycode n. If the key is pressed, the command sequence is executed.

SYSTem:KEY:DELete n

Cancels the assignment of a key with keycode n.

SYSTem:KEY n

Simulates pressing a Front Panel Key with keycode n.

```
Example: SYST:KEY:DEF 8200, Test_1 // Assigns macro Test_1 to the *
// DATA ENTRY Key.

SYST:KEY:DEL 8200 // Deletes the *-Test_1 assignment.

SYST:KEY 2112 // Simulates pressing RCVR MODE Key.
```

SYSTem:KEY?

Returns the keycode of the last key pressed or simulated pressed. If a key has not been pressed, -1 is returned.

KEY

Initiates a function to wait and provide the keycode of the next pressed key. Used with a **PRINT**, **PPRINT** or **XYPRINT** command.

NOTE: For CSA, the KEY command waits and provides the ANSI terminal keycode (usually ASCII) of the next key pressed on the terminal keyboard.

Example: PRINT KEY

For 1600S: After a Front Panel Key is pressed, the keycode is printed on the CRT. For CSA: After a terminal key is pressed, the keycode is printed on the terminal monitor.

KEY?

Returns a 1 if a Front Panel Key is pressed, otherwise returns a 0.

NOTE: For CSA, the KEY? query returns 1 if a terminal key is pressed or 0, otherwise.

When a macro is running, the Test Set provides keys for both macro and front panel functions. To specify the Front Panel Keyboard input for TMAC use only, use the following commands:

KEYPAD:CLAIM

Directs all input from the Front Panel Keyboard to the TMAC Interpreter. Keyboard input not used for INPUT and SYSTEM:KEY commands is used once the keypad is unclaimed.

KEYPAD:UNCLAIM

Releases the Front Panel Keyboard for normal use.

3-14-2 SYSTEM ERROR COMMAND

The SYSTem: ERRor command reports system errors.

SYSTem: ERRor?

Returns the error number and description of the earliest error not yet read. Once read, the data for the error read is removed from memory. The earliest 16 errors that have not been read are held in memory with the rest being ignored. The 16 stored errors can be cleared from memory using the *CLS command.

3-14-3 SYSTEM DEFAULTS COMMAND (1600S Only)

SYSTEM: DEFaults

Restores the Test Set to the original factory default state.

3-14-4 SYSTEM PLOT COMMANDS (1600S Only)

SYSTem:PLOT:GPIB

Selects the GPIB Connector for plotter output.

SYSTem:PLOT:SERIal

Selects the RS-232 Connector for plotter output.

3-14-5 SYSTEM TIME AND DATE COMMANDS

System commands allow setting and recording the date and time.

SYSTem:DATE?

Returns date in the form: year, month, day.

SYSTem:DATE year, month, day

Sets calendar to the entered date.

SYSTem:TIME?

Returns 24 hour time in the form: hour, minutes, seconds and milliseconds.

NOTE: Although 0.1 milliseconds are displayed, accuracy is assured to 16.5 milliseconds.

Example: SYST:TIME?

13,17,32.760 (1:17:32.760 PM) returns to the Host.

SYSTem:TIME hour, minutes, seconds Sets the clock to the entered time.

3-14-6 SYSTEM RS-232 CONFIGURE COMMANDS

The following commands, applying only to the 1600S, allow the Test Set to control another device using serial RS-232 communication. Commands unique to the device controlled are sent as strings. Responses are received as strings.

SYSTem:PTHRough:SERial "string"

Passes the string through the RS-232 Connector.

SYSTem:PTHRough:SERial?

Waits for and returns a string from the RS-232 Connector.

SYSTem:PTHRough:SERial:QUEue?

Returns a non-zero value if data is in the RS-232 queue, 0 if the RS-232 queue is empty.

SYSTem:PTHRough:SERial:KEY?

Waits for and returns one character from the RS-232 Connector.

The following commands, applying to the 1600S and CSA, edit the RS-232 parameters remotely:

SYSTem:COMMunicate:SERial:BAUD n

Sets the RS-232 Connector baud rate to n. Select 300, 600, 1200, 2400, 4800, 9600 or 19200 or 38400 (CSA).

SYSTem:COMMunicate:SERial:PARity type

Sets the RS-232 Parity to type. Select NONE, EVEN, ODD, MARK or SPACE.

SYSTem:COMMunicate:SERial:BITS n

Sets the number of RS-232 Data Bits to n. Select 7 or 8.

SYSTem:COMMunicate:SERial:SBITs n

Sets the number of RS-232 Stop Bits to n. Select 1 or 2.

SYSTem:COMMunicate:SERial:PACE type

Sets the RS-232 Handshaking to type. Select XON (Xon/Xoff), HW (Hardware) or NONE.

SYSTem:COMMunicate:SERial:ECHO b

Sets the RS-232 Echo on if b is 1, off if b is 0.

```
Example: *DMC "Control", BEGIN
                                     // Defines macro to send query to
                                     // controlled device & receive result.
         STRING Result
                                     // Defines string to hold query result.
         SYST:COMM:SER:BAUD 19200
                                     // Sets RS-232 baud rate to 19200.
         SYST: COMM: SER: PAR NONE
                                     // Sets RS-232 parity to none.
         SYST: COMM: SER: BITS 8
                                     // Sets RS-232 data bits to 8.
         SYST: COMM: SER: SBITS 1
                                     // Sets RS-232 stop bits to 1.
         SYST: COMM: SER: PACE XON
                                     // Sets RS-232 handshaking to XON-XOFF.
         SYST: COMM: SER: ECHO 1
                                    // Sets RS-232 echo on.
         SYST:PTHR:SER "query?"
                                    // Sends string "query?" to device.
         WHILE ! (SYST:PTHR:SER:QUE?) // Loops while RS-232 queue is empty.
           TPAUSE
                                     // Allows Test Set operation while
                                     // looping.
         WEND
                                    // End of WHILE loop.
         Result = SYST:PTHR:SER?
                                    // Stores received string in Result.
                                    // End of macro Control.
```

3-14-7 SYSTEM SECURITY COMMANDS (1600S Only)

SYSTem:SECurity:STATe: n

Enables the Security System if n is 1 to 255, disables if n is 0.

SYSTem:SECurity:STATe?

Returns the Security setting. If not zero, Security is activated.

SYSTem:FREQuency:LOCK b

Enables the Receiver, Generator and Spectrum Analyzer RF lock feature if b is 1 or disables frequency lock feature if b is 0.

SYSTem:FREQuency:LOCK?

Returns the Security setting. If not zero, Security is activated.

SYSTem:KLOCk b

Locks the Test Set keyboard if b is 1. Unlocks the keyboard if b is 0 and System Security is deactivated. Security System must be enabled for keyboard to be locked. Pressing keys on the locked keyboard has no affect on the Test Set.

3-15 GPIB OPERATION

The FM/AM-1600CSA operates as a GPIB Talker/Listener device. The FM/AM-1600S operates as a GPIB Talker/Listener, Controller, Talk Only or Listen Only device. The GPIB Mode of Operation is selected using commands received through the RS-232 Connector, commands from a macro executed within the Test Set or from the Front Panel Auxiliary Functions Menu.

Commands are received and transmitted as strings on GPIB. Convert all commands to strings before transmitting. Precede non-printable characters with the \ character to transmit.

NOTE: Both the CSA and 1600S can operate on the same GPIB at the same time, using different addresses. Refer to Section 2.

3-15-1 OPERATING TEST SET USING GPIB COMMUNICATION (CSA Only)

The CSA is a GPIB Talker/Listener. The CSA Test Set address setting should not conflict with another device. The CSA provides a user defined Status Byte to generate Service Requests. The following commands are used when operating the CSA on the GPIB:

GPIB:ADDRess a

Sets CSA Test Set address to a (0 to 31).

GPIB:MASK n

Sets SRQ interrupt mask (eight bit value). The corresponding user defined Status Byte bit is masked unless the mask bit is active (set to 1). Range of n is 0 to 255.

GPIB:SRQ n

Sets a user defined Status Byte bit to trigger a Service Request (eight bit value). The corresponding mask bit must be active to generate an SRQ. Range of n is 0 to 255. The **GPIB:SRQ** command is used in decision loops (**IF**, **WHEN**, **FOR**, etc.) to trigger a Service Request when a user defined event, such as a cellular phone message capture, occurs.

```
Example: GPIB:ADDR 30; MASK 32 // Set address and unmask bit 5.

FOCC:SET; CHAN 333; STAR // Setup and monitor FOCC 333.

FOCC:CAPT:MIN "316/522-4981" // Set to capture specified MIN.

IF FOCC:CAPT?=1 GPIB:SRQ 32; ENDIF // If capture occurs, send SRO.
```

3-15-2 OPERATING TEST SET USING GPIB COMMUNICATION (1600S Only)

For the Test Set to become a GPIB Talker/Listener, Talk/Listen is selected as the GPIB Mode and the Test Set address is set to an address that does not conflict with another device. Both of these functions are performed remotely by executing the following command:

SYSTem:COMMunicate:GPIB:ADDRess a

Sets 1600S Test Set address to a (0 to 31) and selects Talk/Listen for GPIB Mode.

The following suggested procedures operate the 1600S Test Set using GPIB communication.

- A. Initialization of the Test Set
 - Prepare Controller for adding the 1600S Test Set to the GPIB.
 - Clear the 1600S Test Set.
 - Send "*ESE 1" command to Test Set. This command sets the event register of the Standard Event Status Register to 1 to allow reading of the operation complete bit.

- B. Sending Commands to Test Set.
 - Send **SRE 36* command to the Test Set. This command sets the Service Request enable register to generate an RQS upon the occurrence of an OPC or Error.
 - Send desired command with "*OPC" command following.
 - Wait for RQS bit to be set (bit 6 of Status Byte) or for a time out.
 - Retrieve Status Byte of Test Set and store response to value variable.
 - If (value AND 4) is true, send error has occurred.
 - If (value AND 4) is false and (value AND 32) is true, command executed.
- C. Sending Queries to Test Set.
 - Send "*SRE 20" command to Test Set. This command sets the Service Request enable register to report the Message Available (MAV) bit and error bit.
 - Send query command to Test Set.
 - Wait for RQS bit to be set (bit 6 of Status Byte) or for a time out.
 - Retrieve Status Byte of Test Set and store response to value variable.
 - If (value AND 4) is true, send error has occurred.
 - If (value AND 4) is false and (value AND 16) is true, send read command to return results of query.
- D. Sending Macros to Test Set.

Perform the following procedure until all command lines of macro are sent to Test Set.

- Send command line to Test Set.
- Wait for CMPL (completed I/O) or for a time out.
- If time out, stop sending of macro. Restart sending of macro (see *PMC in 3-17).

3-15-3 TEST SET OPERATING AS GPIB CONTROLLER (1600S Only)

For the Test Set to become a GPIB controller, the address of the Test Set must be set to an address that does not conflict with a slave device address (30 is advised) and the GPIB Operation Mode must be set to Controller. The commands used to set these parameters are:

SYSTem:COMMunicate:GPIB:ADDRess a

Sets 1600S Test Set address to a (0 to 31) and selects Talk/Listen for GPIB Mode.

SYSTem:COMMunicate:GPIB:CONTroller

Selects Controller for the GPIB Operation Mode making the Test Set a GPIB controller.

Once the Test Set is made a GPIB Controller, the talker/listener status is returned by repeating the SYST:COMM:GPIB:ADDR command. The following commands are used when operating the Test Set as a GPIB Controller:

SYSTem:COMMunicate:GPIB:SLAVe a

Sets the destination of SYST:PTHR:GPIB commands to the peripheral device with address a (0 to 31).

SYSTem:PTHRough:GPIB address, "string"

Sends out a *string* through the GPIB Connector. Optional peripheral *address* (0 to 31) defaults to the address set by the last **SYSTem:COMMunicate:GPIB:SLAVe** command.

SYSTem:PTHRough:GPIB? address

Waits for and receives a command at the GPIB Connector. Optional peripheral address (0 to 31) defaults to address set by last SYSTem:COMMunicate:GPIB:SLAVe command.

SYSTem:COMMunicate:GPIB:DCL

Issues a Device Clear message.

SYSTem:COMMunicate:GPIB:GET

Issues a Group Execute Trigger.

SYSTem:COMMunicate:GPIB:CMD "string"

Issues a command sequence through the GPIB Connector.

SYSTem:COMMunicate:GPIB:SRQ?

Checks peripheral devices for a Service Request. Returns a 1 if there was a Service Request since last check. Once read, the value is reset to 0 until next Service Request.

SYSTem:COMMunicate:GPIB:SPOLL? a

Performs a Serial Poll on the device with address a and returns the result. The 8 bit result is device dependent, except bit 6, which is the Service Request bit.

```
Examples: *DMC "Control", BEGIN // Defines a macro that sets the SYST:COMM:GPIB:ADDR 30 // Test Sets address to 30 and SYST:COMM:GPIB:CONT // makes the Test Set a GPIB END // Controller.
```

The macro Control establishes the Test Set as a GPIB Controller.

```
*DMC "Slave", SYST:COMM:GPIB:SLAV $1
```

The macro Slave sets the slave address for a peripheral device to \$1.

```
*DMC "M1200", SYST:PTHR:GPIB 5, STR($1)+"\n"
```

The macro M1200 passes \$1, as a string, through the GPIB Connector to the peripheral device with an address of 5. The " \n " provides a line feed and marks the end of the command passed.

```
*DMC "Read 1200", BEGIN
Control
                              // Activates Control macro.
M1200 "DVMAC"
                              // Sets 1200 to operate voltmeter.
WHILE SYT:PTHR:SER:QUE? =0
                              // While no Input from RS-232 Host
   IF SYST:COMM:GPIB:SRQ? =1 // If there is a Service Request,
    P=SYST:COMM:GPIB:SPOLL? 5 // Poll to see if it is from 1200.
       IF P&64 != 0
                              // If bit 6 is 1, SRQ is from 1200.
                              // If SRQ is from 1200, take a
         M1200 "DVMRM"
                              // reading.
        ENDIF
   ENDIF
WEND
END
```

The macro Read_1200 assumes a FM/AM-1200S/A (1200) is connected to the GPIB Connector of the Test Set and has its address set to 5. The following sequence occurs:

- Makes the Test Set a controller.
- Passes the DVMAC command to the 1200. Sets the 1200 for autoranging voltmeter readings.
- While there is no Input from the RS-232 Host of the Test Set, continually checks for Service Requests from the 1200.
- Upon each 1200 Service Request, the Test Set passes the DVMRM command to the 1200. This command returns a voltmeter reading to the Host of the Test Set.

3-15-4 TEST SET OPERATING AS TALKER ONLY (1600S Only)

When the Test Set becomes a GPIB Talk Only device, there are no address considerations. The Test Set must be the only talking device on the GPIB bus and the remaining devices must be compatible listeners. The following command selects Talk Only as the GPIB Mode of Operation.

SYSTem:COMMunicate:GPIB:TONly

Selects Talk Only as the GPIB Operation Mode.

To select the Talk/Listen GPIB Mode of Operation again, reset the Test Set address using the SYST:COMM:GPIB:ADDR command.

3-15-5 TEST SET OPERATING AS LISTENER ONLY (1600S Only)

When the Test Set becomes a GPIB Listen Only device, the address is set first using the SYST:COMM:GPIB:ADDR command. After setting the address, the following command selects Listen Only as the GPIB Mode of Operation.

SYSTem:COMMunicate:GPIB:LONly

Selects Listen Only as the GPIB Operation Mode.

To select the Talk/Listen GPIB Mode of Operation again, reset the Test Set address using the SYST:COMM:GPIB:ADDR command.

3-16 STATUS SUBSYSTEM (1600S Only)

TMAC provides an implementation of the Event Status register structure as designated by IEEE-488.2 and SCPI Standards. Standard Event, Operation, Operation Instrument, Questionable, Instrument and Instrument Summary Status Registers and their relationship to one another are shown in Figure 3-6.

3-16-1 STATUS REGISTERS

Each Status Register shown in Figure 3-6 consists of a condition, event and enable register shown in Figure 3-5. The condition register continually receives data coming into the Status Register. When a bit is changed from 0 to 1 for the first time since being cleared, the same bit in the event register is set to 1. The event register is only changed by the first 0 to 1 transitions that occur in the condition register. The condition or event registers are cleared when read.

The 16 bits of the event register and the 16 bits of the enable register undergo a bitwise AND operation. In order for an event register bit to be reported, its corresponding bit in the enable register must be set to 1. The 16 bits resulting from this bitwise AND operation undergo an OR operation with each other. The result is 1 if one or more bits were 1.

CONDITION REGISTER 16 BITS EVENT REGISTER 16 BITS AND OR 1 BIT STATUS REGISTER OUTPUT

Figure 3-5 1600S Status Register Description

8618008




Figure 3-6 1600S Status Register Configuration

3-16-2 STATUS BYTE

The Status Byte reports an occurrence in any of the Status Registers, and is used to activate a SRQ message and the RQS bit (bit 6 of the Status Byte) (see Figure 3-6). A Status Byte bit determines an SRQ and RQS if the corresponding Service Request enable register bit is set to 1. Bits 0 to 5 and bit 7 of the Status Byte and the same bits of the Service Request enable register undergo a bitwise AND operation. The resulting bits of the AND operation undergo an OR operation. If any of the enabled Status Byte bits are 1, an SRQ is generated and the RQS Status Byte bit (bit 6) is set to 1.




Figure 3-7 1600S RQS Bit and SRQ Generation

The following commands pertain to the Status Byte and Service Request enable register:

*SRE n

Sets the Service Request enable register contents to n (eight bit value).

*SRE?

Returns the value of the Service Request enable register contents.

*STB?

Returns the value of the Status Byte. The Status Byte is not cleared when read but maintains the current value until the *CLS command is used (*CLS command also clears the condition and event registers of each Status Register).

3-16-3 STANDARD EVENT STATUS REGISTER

The Standard Event Status Register contains an operation complete bit, several error bits and a power on bit. Figure 3-6 shows the Standard Event Status Register bits. The power on bit is set to 1 following power up of the Test Set. The following commands control this register:

*ESE r

Sets the enable register of the Standard Event Status Register to n (eight bit value).

*ESE?

Returns the enable register contents of the Standard Event Status Register.

*ESR?

Returns the event register contents of the Standard Event Status Register.

*OPC

Sets the Operation Complete bit of the event register to 1 when all pending selected device operations have finished.

*OPC?

Generates an ASCII 1 in the output queue when operation is complete, activating the Message Available bit in the Status Byte.

```
Example:
         *DMC "ERROR CHECK", BEGIN // Define macro named ERROR CHECK.
         *ESE 61
                                   // Enable Std Event Status Register.
         IF (*ESR & 1) = 0
                                   // Check Operation Complete bit.
           IF (*ESR? & 4)=1
                                   // If Standard Event Status Register
            PRINT "QUERY ERROR"
                                   // reports Query Error, print message.
           ELIF (*ESR? & 8)=1
                                   // If Standard Event Status Register
                                   // reports Device Specific Error,
            PRINT "DEVICE SPECIFIC ERROR" // print message.
                                   // If Std Event Status Rgtr reports
           ELIF (*ESR? & 16)=1
            PRINT "EXECUTION ERROR" // Execution Error, print message.
           ELIF (*ESR? & 32)=1
                                   // If Standard Event Status Register
            PRINT "COMMAND ERROR"
                                   // shows Command Error, print message.
                                   // If Std Event Status Rgtr does not
            PRINT "NO ERROR DETECTED" // report an error type, print msg.
```

3-16-4 OPERATION STATUS REGISTER

The Operation Status Register contains the Waiting For Arm, Waiting For Trigger and Instrument Summary bits. The Operation Instrument Register sets the Instrument Summary bit (see 3-16-5). The following commands control the Operation Status Register:

STATus: OPERation: CONDition?

Returns the condition registers contents of the Operation Status Register.

STATus: OPERation: ENABle n

Sets the enable register contents of the Operation Status Register to n (16 bit value).

STATus: OPERation: ENABle?

Returns the enable registers contents of the Operation Status Register.

STATus:OPERation:EVENt?

Returns the event registers contents of the Operation Status Register.

3-16-5 OPERATION INSTRUMENT REGISTER

The Operation Instrument Register is used with the INITiate and FETCh commands. Once an INITiate command is completed and the meter is ready to be read, the appropriate meter ready bit is set to 1. This indicates the meter is ready for the FETCh command. The following STATUS commands control the Operation Instrument Register:

STATus: OPERation: INSTRument: CONDition?

Returns the condition register contents of the Operation Instrument Status Register.

STATus:OPERation:INSTRument:ENABle n

Sets enable register contents of Operation Instrument Status Register to n (16 bit value).

STATus:OPERation:INSTRument:ENABle?

Returns the enable register contents of the Operation Instrument Status Register.

STATus: OPERation: INSTRument: EVENt?

Returns the event register contents of the Operation Instrument Status Register.

3-16-6 QUESTIONABLE STATUS REGISTER

The Questionable Status Register reports events that could bring Test Set results into question. The Instrument Status Register provides the input. Figure 3-6 shows events reported by both registers. The following **STATUS** commands control the Questionable Status Register:

STATus: QUEStionable: CONDition?

Returns the condition register contents of the Questionable Status Register.

STATus:QUEStionable:ENABLe n

Sets the enable register contents of the Questionable Status Register to n (16 bit value).

STATus: QUEStionable: ENABLe?

Returns the enable register contents of the Questionable Status Register.

STATus:QUEStionable:EVENt?

Returns the event register contents of the Questionable Status Register.

3-16-7 INSTRUMENT STATUS REGISTER

The Instrument Status Register reports meter readings exceeding the upper and lower limit of the AF, RF Power, FM Deviation, AM Modulation and Distortion Meters. The results of the Instrument Summary Status Register (an extension of the Instrument Status Register) are also reported. The following **STATUS** commands control the Instrument Status Register.

STATus:QUEStionable:INSTRument:CONDition?

Returns the condition register contents of the Instrument Status Register.

STATus:QUEStionable:INSTRument:ENABLe n

Sets the enable register contents of the Instrument Status Register to n (16 bit value).

STATus:QUEStionable:INSTRument:ENABLe?

Returns the enable register contents of the Instrument Status Register.

STATus:QUEStionable:INSTRument:EVENt?

Returns the event register contents of the Instrument Status Register.

3-16-8 INSTRUMENT SUMMARY STATUS REGISTER

The Instrument Summary Status Register acts as an extension of the Instrument Status Register. The Instrument Summary Status Register reports the exceeding of the upper and lower limit of the SINAD and Phase Meter and Digital Multimeter. Following are STATUS commands controlling the Instrument Summary Status Register.

STATus:QUEStionable:INSTRument:ISUMmary:CONDition?

Returns the condition registers contents of the Instrument Summary Status Register.

STATus:QUEStionable:INSTRument:ISUMmary:ENABLe n

Sets the enable register contents of the Instrument Summary Status Register to n (16 bit value).

STATus:QUEStionable:INSTRument:ISUMmary:ENABLe?

Returns the enable registers contents of the Instrument Summary Status Register.

STATus:QUEStionable:INSTRument:ISUMmary:EVENt?

Returns the event registers contents of the Instrument Summary Status Register.

The following example performs a DMM reading and checks the Status Byte for the reporting of the DMM Upper or Lower Limit being exceeded. The enable registers of the Instrument Summary, Instrument and Questionable Status Registers are set to pass the information to the Status Byte.

```
// Define macro named DMM READ:
         *DMC "DMM READ", BEGIN
Example:
                                           // Set enable register to read DMM
         STAT: OUES: INSTR: ISUM: ENABLE 12
                                           // Upper and Lower Limit exceeded.
                                           // Set enable register to pass the
         STAT: QUES: INSTR: ENABLE 2
                                           // Instrument Summary Status
                                           // Register result.
                                           // Set enable register to pass the
         STAT: QUES: ENABLE 8192
                                           // Instrument Status Register result.
                                           // Clear all condition and event
         *CLS
                                           // registers.
                                           // Display DMM Operation Screen.
         SCREEN: DMM
                                           // Print DMM reading to Host.
         PPRINT M DMM?
                                           // If Status Byte reports
         IF (*STB? & 8) != 0
                                           // Questionable Status bit as 1,
                                            // print limit exceeded to Host.
             PPRINT "limit exceeded"
                                           // If Status Byte reports
                                           // Questionable Status bit as 0,
                                           // print limit not exceeded to Host.
             PPRINT "limit not exceeded"
                                            // End IF statement.
         ENDIF
                                            // End macro DMM READ.
         END
```

3-17 IEEE 488.2 COMPLIANCE COMMANDS

TMAC contains the following IEEE 488.2 mandated commands (1600S only except as noted):

*CLS

(CSA also) Clear Status command. Sets all Status Registers including the Status Byte to zero.

*DDT

Define Device Trigger command. Defines what commands are executed by the GET (Group Execute Trigger) command received at the GPIB Connector or the *TRG command.

Example: *DDT SCOPE:TRIGGER:ONE; SCOPE:ARM

These commands are executed when a GET (Group Execute Trigger) command is received at the GPIB Connector or a *TRG command is executed.

*DMC

(CSA also) Define Macro command. Assigns commands to a macro label (see 3-9).

*EMC b

Enable Macro command. Disables macros when b is set to 0, enables macros when b is set to 1. Used to execute commands which have the same name as a macro.

*EMC?

Enable Macro Query. Returns the Enable Macro command status. 0 is returned if macros are disabled, 1 is returned if macros are enabled.

*ESE n

Standard Event Status Enable command. Sets Standard Event Status Enable Register to value specified by n (see 3-16-3).

*ESE?

Standard Event Status Enable Query. Returns the contents of the Standard Event Status Enable Register (see 3-16-3).

*ESR?

Standard Event Status Register Query. Returns the contents of the Standard Event Status Register (see 3-16-3).

*IDN?

(CSA also) Identification Query. Returns device Identification. Manufacturer, model, serial number and version of device is returned.

*LMC?

List Macro Query. Returns the currently defined macros (see 3-9).

*OPC

Operation Complete command. Causes the device to activate the operation complete bit in the Standard Event Status Register when operation is finished (see 3-16-3).

*OPC?

Operation Complete Query. Puts an ASCII 1 into the device output queue when operation is finished (see 3-16-3).

*PMC

(CSA also) Purge Macro command. Deletes all macros and declared variables from memory (see 3-9).

*RCL n

Recall command. Restores device to the environment (routings and settings) stored in local memory location n. Range of n is 0 to 9.

*RST

Reset command. Resets device to preset condition.

*SAV n

Save command. Saves current environment (routings and settings) in local memory location n. Range of n is 1 to 9.

*SRE n

Service Request Enable command. Sets Service Request enable register to value specified by n (see 3-16-2).

*SRE?

Service Request Enable Query. Returns contents of Service Request enable register (see 3-16-2).

★STB?

Read Status Byte Query. Returns Status Byte contents (see 3-16-2).

*TRG

Trigger command. Executes trigger command as defined by the *DDT command See SCOPe:TRIGger:SOURce (4-9) command.

*TST?

Self-Test Query. Performs Self Test and returns 0 if passed, 1 if failed.

*WAI

Wait To Continue command. Stops device command execution until *OPC? is true. Used following Screen commands to allow the Screen to mature before readings are taken.

3-18 FM/AM-1600S and FM/AM-1600CSA GENERAL TMAC COMMANDS

The following pages contain General TMAC commands; listing syntax, use and action. Examples are also provided to aid in the understanding of the commands. Cross references to relating commands are also included. Commands are in alphabetical order.

*DMC

USE

To define macros and functions.

SYNTAX

*DMC "name", command;; command

ACTION

Defines a macro or function with the *name* specified and containing the *commands* listed. After a macro or function is defined, entering the macros or functions *name* executes it (and all the *commands* contained within it).

Macros utilize several lines using the **BEGIN** and **END** commands. A function is a macro with a **RETURN** command used to return values. The **RETURN** command returns results directly through the active interface connector.

VARIABLE DESCRIPTION

name

Name of the macro or function defined. The first character of the *name* is a letter while the remaining characters can be letters, digits and the underscore. The length of the *name* can be from 2 to 31 characters.

command

Commands performed when macro or function is executed.

SEE ALSO

Macros (3-9), BEGIN, END, RETURN, *LMC, FORGET, *PMC

EXAMPLES

```
*DMC "Sq", SCREEN: USER; : INPUT X; Y=X**2; PPRINT X, " squared is ", Y
```

The above *DMC command defines these commands as a macro named Sq. Upon entering Sq, the INPUT command is executed, Y is set to X^2 , and the PPRINT command is executed.

```
*DMC "Square", BEGIN
SCREEN: USER
INPUT X
Y=X**2
PPRINT X," squared is ", Y
END
```

The macro Square accomplishes the same as the Sq macro. The **BEGIN** and **END** command allows the macro to be written over several lines.

```
*DMC "SQ", RETURN($1**2) // Defines a function named SQ.

PRINT SQ 11 // Prints the result of the function // named SQ (121).

*DMC "Av", RETURN(($1+$2+$3)/4) // Defines a function named Av.

X=Ave 13,14,17 // Executes the function Av. // Returns 11.

*DMC "Sph_Sec_Surface", RETURN(3.1415*$1/2*(4*$2+$3))

PRINT Sph_Sec_Surface 4.4, 2.12, 6.7
```

The ***DMC** command defined the function (3.1415*\$1/2*(4*\$2+\$3)) with the name Sph_Sec_Surface. 104.9135 is printed on the CRT.

*IDN?

USE

To return Test Set Identification.

SYNTAX

*IDN?

ACTION

Returns the identification parameters of the Test Set. Includes the manufacturer, model, serial number and various firmware versions.

EXAMPLE

*IDN?

An example return from a query to an FM/AM-1600S is as follows:

IFR SYSTEMS, FM/AM-1600S, 1583, 3.02/C-03.01S/F-03.02S/M-02.00S

The serial number is 1583. The system firmware version is 3.02. The Counter firmware version is 3.01S. The Function Generator firmware version is 3.02S. The Monitor firmware version is 2.00S.

is 3.028. The Monitor tirmware version is 2.008.

*PMC

USE

To delete all macros and declared variables.

SYNTAX

*PMC

ACTION

Deletes all macros and declared variables except the predefined macros

listed in Appendix A.

SEE ALSO

Macros (3-9), FORGET

*WAI (1600S Only)

USE

To pause command execution until previous operations are complete.

SYNTAX

*WAI

ACTION

Stops command execution until all operations are complete. ***WAI** is used after **SCREEN** and **SETUP** commands and other commands involving routing changes or lengthy measurement times.

SEE ALSO

DELAY

EXAMPLE

SCREEN: REC // Displays the Receiver Screen. *WAI // Stops command execution until

// the screen matures.

RECEIVE: INPUT: TR

// Stops command execution until

*WAI

// the routing change is completed.

// Selects T/R Connector for Receiver Input.

ACTIVATE

USE

To place a task on the schedule queue so the task can be multitasked.

SYNTAX

ACTIVATE "name"

ACTION

A macro must be declared a task using the TASK command before it can be put in the schedule queue using the ACTIVATE command. This must be done to each macro before it can be multitasked. Once execution of the macro begins, execution starts from the beginning of the macro.

VARIABLE

DESCRIPTION

name

Name of the task to be loaded into the schedule queue.

SEE ALSO

Multitasking Macros (3-12), TASK, TPAUSE, TSTOP

EXAMPLES

See Multitasking examples (3-12).

BEGIN

USE

To allow macros to contain multiple lines.

SYNTAX

*DMC "name", BEGIN

sequence

END

ACTION

Combines with the END command to define the command lines in multiple line macros. The BEGIN command is not used with single line macros.

VARIABLE

DESCRIPTION

name

Name of the macro being defined.

sequence

Command sequence performed inside the macro.

SEE ALSO

Macros (3-9), *DMC, END

EXAMPLES

*DMC "MPt", VAR Mid; Mid=(Freq1+Freq2)/2; NVSAV Mid, 60; PRINT Mid

The above macro can be entered as:

VAR Mid

*DMC "MPt", BEGIN Mid=(Freq1+Freq2)/2

NVSAV Mid,60 PRINT Mid

END

BOX

USE

To create a user defined box on the CRT.

SYNTAX

BOX f, x1, y1, x2, y2, c

ACTION

Creates a box using the points specified as the top left and bottom right corners. The box can be created hollow or solid. Text can not be printed in boxes as it can in windows.

VARIABLE	DESCRIPTION	
f	Creates the box solid or hollow. f is 1 for a solid box. f is 0 for the box to appear hollow.	
x1, y1	Point signifying the top left corner of the box.	
x2, y2	Point signifying the bottom right corner of the box.	
С	Number specifying the color of the box. See Table 3-4 for the available colors and their numbers.	


SEE ALSO

Graphics (3-13-5)

EXAMPLES

BOX 1,150,50,200,250,7

The above command displays a light gray box on the CRT as follows:



8618021

Figure 3-8 Box Example

CALCULATE

USE

To calculate a function and return the result to the Host.

SYNTAX

CALCulate? expression

ACTION

The expression is calculated and returned through the active interface

connector. This command cannot be used inside a macro.

VARIABLE

DESCRIPTION

expression

Mathematical expression or formula calculated.

SEE ALSO

Mathematical Functions (3-7)

EXAMPLES

X=4, Y=3

CALC? X*Y**3

// Initializes variables.

// Calculates the mathematical

// expression and returns the result
// to the Host. 108 is returned.

CASE OF OTHERWISE ENDCASE

USE

To provide a predetermined decision point inside a macro.

SYNTAX

CASE variable

OF value1: command OF value2: command

OTHERWISE: command

ENDCASE

ACTION

There is no limit to the number of OF statements and the OTHERWISE statement is optional. The OF values are compared to the CASE variable. The command sequence following the OF value that equals the CASE variable is executed. If no OF value equals the CASE variable, the OTHERWISE command is executed if present, and macro execution passes

to the command following the ENDCASE command.

VARIABLE	DESCRIPTION		
variable	Expression compared with the values to decide which OF command to perform.		
value	Expression compared with variable. If equal to variable, the command following value is performed.		
command	Command performed if value is equal to variable.		
Conditional E	varossions (2 tA) IE IE ELGE IE ELLE		

SEE ALSO

Conditional Expressions (3-10), IF, IF ELSE, IF ELIF

EXAMPLES

```
*DMC "Val"

SCREEN:USER

CASE X

OF 1: PRINT "X=1"

OF 2: PRINT "X=2"

OF 5: PRINT "X=5"

OTHERWISE:PRINT "X unknown"

ENDCASE
```

X is compared to the OF values 1, 2 and 5. If X is equal to one of the OF values, the commands following that OF value are executed. For example: if X=2, the PRINT "X=2" command is executed, if X=6, the PRINT "X unknown" command is executed.

```
* "Menu", BEGIN
SCREEN: USER
VAR Choice
PRINT "Press a DATA ENTRY Key to select a Test"
PRINT " and press the ENTER Key."
PRINT "1. Test 1"
PRINT "2. Test 2"
PRINT "3. Test 3"
PRINT "Any other selection other than the ones listed"
PRINT "
         displays the Receiver Operation Screen."
XY 100,250
INPUT Choice
CASE Choice
 OF 1: PRINT "Test_1 is running"
        DELAY 3000
        CLS
        Test 1
 OF 2: PRINT" Test 2 is running"
        DELAY 3000
        CLS
        Test 2
  OF 3: PRINT" Test 3 is running"
        DELAY 3000
        CLS
        Test 3
  OTHERWISE: PRINT "No Test Performed"
ENDCASE
SCREEN: REC
*WAI
END
```

The macro Menu displays a user created menu allowing the selection of one of three tests. These tests are actually macros Test_1, Test_2 and Test_3. which are executed if 1, 2 or 3 is entered in response to the INPUT command. If the entered data is not 1, 2 or 3, the Otherwise command is performed and No Test Performed is printed. After a Test is executed or the PRINT command is performed, command execution resumes beneath the ENDCASE command.

CLS

USE

To erase the contents of a window or the CRT.

SYNTAX

CLS

ACTION

Clears the currently selected window. To clear the entire CRT, select window 0 (the background) using the **WSEL** command.

SEE ALSO

WSEL

CONST

USE

To define constants.

SYNTAX

CONST name, expression, name, expression,...., name, expression

ACTION

Declares constants and their values. Constants are global and can not be declared inside a macro. String data cannot be assigned to a constant. Constant values can only be changed using another **CONST** command.

	Constant values can only be changed using another CONST command.		
	VARIABLE	DESCRIPTION	
	name	name is a letter letters, digits a	nstant defined. The first character of the remaining characters can be nd the underscore. The length of <i>name</i> o 31 characters.
	expression		tant is defined as. The <i>expression</i> does in its simplest form.
SEE ALSO	Constants and D	ata Arrays (3-4)	, DATA
EXAMPLES	CONST PI,3.141	.5,Wid,X/4.3	<pre>// Defines PI as a constant and // gives it a value of 3.1415. // Defines Wid as a constant, // evaluates X/4.3 and assigns this // value to Wid.</pre>

DATA

USE

To define constant data arrays.

SYNTAX

DATA name={expression, expression, ..., expression}

ACTION

Declares data arrays and their values. A data array is an array of constants. Data arrays are global and can not be declared inside a macro. String data cannot be assigned to a data array. Data arrays values can only be changed using another **DATA** command. Data array values are specified by including the order of occurrence in brackets following the name. This order begins with 0 so that Stat[3] returns the fourth constant in the data array Stat.

VARIABLE	DESCRIPTION	
name	Name of the constant defined. The first character of the name is a letter while the remaining characters can be letters, digits and the underscore. The length of the name can be from 2 to 31 characters.	
expression	Value the constant is defined as. The expression does not have to be in its simplest form. The first expression is assigned to the first index (name[0]) and so on.	

SEE ALSO

Constants and Data Arrays (3-4), CONST, ICON

EXAMPLES

DATA STAT={2,34.7,2.874836593,336/4}

X=STAT[1]

Y=STAT[4]

Z=STAT[0]

The value of X is set to 24.7. The Y=STAT[4] command does not execute and an error is produced because STAT[4] is not defined. The value of Z is set to 2.

DELAY

USE

To delay command execution.

SYNTAX

DELAY t

ACTION

Delays provide a time delay before the next command is executed. Delays are used to allow physical changes enough time to occur before command execution continues. Such changes could be: code generation, routing changes and displaying Operation Screens.

VARIABLE

DESCRIPTION

ŧ

The length of time delayed in ms.

SEE ALSO

Macros (3-9), *WAI

EXAMPLES

SCREEN: GEN

*WAI

GEN:DCS:INV 311 DELAY 2000 GEN:DCS:STOP

The **DELAY** command delays for 2 seconds to allow time for the DCS Code generation.

DO UNTIL

USE

To perform a set of commands repeatedly until a specified condition occurs (becomes true).

SYNTAX

DO

sequence UNTIL condition

ACTION

The **DO** loop repeatedly executes a command sequence until a condition is true. If *condition* is true when first evaluated, the command sequence is executed once. If the *condition* does not eventually become true, the **DO** loop continues to loop until power is cycled.

VARIABLE	DESCRIPTION
condition	Conditional expression evaluated. If true, command execution loops to the top of the DO loop.
sequence	Command sequence performed at least once, then performed repeatedly until <i>condition</i> is true.

SEE ALSO

FOR, WHILE

EXAMPLES

```
*DMC "Count", BEGIN // Defines a macro named Count.

N=0 // Sets N to 0.

DO // Starts the DO loop.

N = N + 1 // Increments N by 1.

PRINT N // Prints current value of N.

UNTIL N=2 // Loops N to the DO command

// until N equals 2.

END // Ends macro Count.
```

N is set to 0 and the **DO** command is executed, initiating the following sequence:

- 1 is added to N and N is printed (1).
- N is compared to its ending value (1 compared to 2).
- 1 is added to N and N is printed (2).
- N is compared to its ending value (2 compared to 2).
- The command following the UNTIL command is executed as command execution continues on.

```
*DMC "Compute", RETURN (FLOOR (50-$1) / 4+50)
                         // Defines a function named Compute.
*DMC "Compute x", BEGIN
                         // Defines a macro named Compute x.
X = 6
                         // Sets X to 6.
                         // Starts the DO loop.
DO
                         // Sets X to the result of the
 X = Compute X
                         // function Compute with the old
                         // value of X as the input.
                         // Prints X.
PRINT X
UNTIL X=50
                         // Loops X to the DO command
                         // until X equals 50.
END
                          // Ends the macro Compute x.
```

After setting X to 6 and executing the **DO** command, the following sequence occurs:

- The Compute function is calculated and sets X equal to 61. X is printed.
- The conditional expression (X = 50) is evaluated and, if not true, command execution loops up to the DO loop.
- The Compute function is calculated and sets X equal to 48. X is printed.
- The conditional expression (X = 50) is evaluated and, if not true, command execution loops up to the DO loop.
- The Compute function is calculated and sets X equal to 50. X is printed.
- The conditional expression (X = 50) is evaluated and, if true, command execution continues below the UNTIL command.

The conditional expression does not have to involve a variable manipulated inside the loop.

DO

commands

UNTIL SYSTEM: KEY? > 0

This **DO** loop continues looping until a Front Panel Key is pressed (for **SYSTEM** Commands, see 3-14).

D	Н	Α	W

USE

To create a user defined line on the CRT.

SYNTAX

DRAW x1, y1, x2, y2, c

ACTION

Creates a line from one point to the another point in a specified color.

VARIABLE	DESCRIPTION		
x1, y1	Point signifying the first end of the line.		
x2, y2	Point signifying the second end of the line.		
c	Number specifying color of the line. See Table 3-4 for colors and their numbers.		
Graphics (3-1	3-5)		

SEE ALSO

EXAMPLES

See Graphic examples (3-13-5).

END

USE

To allow macros to contain multiple lines.

SYNTAX

*DMC "name", BEGIN

sequence

END

ACTION

The END command defines the end of a multiple line macro.

VARIABLE

DESCRIPTION

name

Name of macro being defined.

sequence

Command sequence performed inside the macro.

SEE ALSO

Macros (3-9), *DMC, BEGIN

EXAMPLES

EXEC

USE

To execute a macro at a specified address.

SYNTAX

EXEC address or EXEC & name

ACTION

Executes the macro located at the *address* specified. An & with the *name* of the macro as shown is equivalent to the address of the macro. Macros requiring variables to be passed when the macros *name* is entered cannot be executed using the **EXEC** command. Unpredictable results occur when using an invalid *address*.

VARIABLE	DESCRIPTION

address

Address of macro to be executed.

name

Name of the macro to be executed.

SEE ALSO

Macros (3-9)

EXAMPLES

```
ADD=&First // The address of the macro First // is loaded into the variable ADD. EXEC ADD // The macro located at the address
```

// loaded in the variable ADD is executed.

EXEC &First

// Macro First is executed.

FLUSH

USE

To return pending responses.

SYNTAX

FLUSH

ACTION

Returning data from the queries in a macro is collected in the output queue of the Test Set. The contents of the output queue is returned at the end of any loops present, at the end of the macro or when the queue becomes full (the output queue is 2 kilobytes in size). The **FLUSH** command returns all pending return data upon execution.

SEE ALSO

Macros (3-9)

EXAMPLES

```
*DMC "Without FLUSH", BEGIN // Defines a macro named
                            // Without FLUSH.
SCREEN: REC
                            // Displays the Receiver Operation
                            // Screen.
                            // Waits for the Receiver Operation
*WAI
                            // Screen to be completely displayed.
REC: FREQ?
                            // Queries the Receiver Frequency.
M RF?
                            // Queries the Frequency Error Meter
                            // reading.
                            // Queries the Power Meter reading.
M PWR?
END
                            // Ends macro Without FLUSH.
```

The returned data in this macro without using the **FLUSH** command appears as follows:

100320,100318,62

```
*DMC "With FLUSH", BEGIN // Defines a macro named With FLUSH.
SCREEN: REC
                          // Displays the Receiver Operation
                          // Screen.
*WAI
                          // Waits for the Receiver Operation
                          // Screen to be completely displayed.
                          // Queries the Receiver Frequency.
REC: FREQ?
FLUSH
                          // Returns impending responses.
M RF?
                          // Queries the Frequency Error Meter
                          // reading.
                          // Returns impending responses.
FLUSH
                          // Queries the Power Meter reading.
M PWR?
END
                          // Ends macro With FLUSH.
```

The returned data in this macro with the **FLUSH** commands appears as follows:

100320 100318 62

FOR NEXT

USE

To perform a set of commands in a loop a given number of times within a macro.

SYNTAX

FOR variable= initial TO ending STEP step sequence

NEXT variable

ACTION

The FOR command sets variable equal to initial, executes commands until the NEXT command, increments variable by the step value and starts command execution again just below the FOR command. The sequence between the FOR and NEXT command is executed repeatedly until variable is equal to ending. When variable equals ending, the sequence is executed once again before command execution proceeds below the NEXT command.

The values, initial, ending and step, can be negative. If optional STEP and step are left off, the default step is +1 even when initial and/or ending are negative. If step is set so variable will not equal ending exactly, the looping stops when variable comes the closest while not crossing the ending value. If step is given the opposite sign needed to increment variable towards the ending value or if step is larger than ending minus initial, the command sequence is executed once and no looping takes place.

Do not set *step* equal to 0 as this loops indefinitely and requires cycling power of the Test Set to stop execution of the loop.

VARIABLE	DESCRIPTION
variable	variable used to step through the looping process.
initial	Starting value of <i>variable</i> .
ending	Ending value of <i>variable</i> . When <i>variable</i> reaches this value, looping is stopped and the <i>command sequence</i> is executed once more.
step	Amount <i>variable</i> is incremented for each pass through the loop.
sequence	Command sequence is executed once and then repeatedly until variable equals ending.

SEE ALSO

DO, WHILE

EXAMPLES

FOR N=1 TO 3 STEP 1
 command1
NEXT N
command2

The following sequence occurs:

- N is set equal to 1.
- Command1 is executed.
- N is incremented by 1 (N=2) and compared to ending (3).
- Command1 is executed.
- N is incremented by 1 (N=3) and compared to ending (3).
- Command1 is executed.
- Command2 is executed and macro execution proceeds after command2.

```
FOR A=10 TO 4 STEP -3
PRINT A
NEXT A
PRINT 2*A
```

The following sequence occurs:

- A is set equal to 10.
- A is printed (10).
- -3 is added to A (A = 7) and A is compared to ending (4).
- A is printed (7).
- -3 is added to A (A = 4) and A is compared to ending (4).
- A is printed (4).
- 2*A is printed (8) as command execution proceeds below the NEXT command.

```
FOR MM = -1 TO -6 STEP -2
PRINT MM
NEXT MM
```

-1, -3 and -5 is printed. Since MM=-7 is beyond the ending value, the last loop occurs when MM is equal to -5.

FOR N=1 TO 4 STEP -1 PRINT N NEXT N

N is set equal to 1 and printed once and command execution proceeds below the **NEXT** command. No looping takes place because *step* does not have the sign needed to proceed the *variable* value toward the *ending* value.

FORGET

USE

To delete a macro from memory.

SYNTAX

FORGET "name"

ACTION

Deletes the macro specified. All macros and variables declared after the specified macro was declared are also deleted.

VARIABLE

DESCRIPTION

name

Name of macro to be deleted.

SEE ALSO

*PMC

EXAMPLES

*DMC "FIRST", BEGIN
PRINT "first macro"
END
*DMC "SECOND", BEGIN
PRINT "second macro"
END
VAR TO_BE_ERASED

FORGET "SECOND"

Upon execution of the **FORGET** command, the macro SECOND and the variable TO_BE_ERASED are deleted from memory. The macro FIRST is still contained in memory.

FORMat

USE

To specify the form of the returned data for queries.

SYNTAX

FORMat BINary FORMat OCTAI

FORMat HEXadecimal FORMat ASCII (1600S Only)

FORMAT DECIMAL (CSA Only)

ACTION

Specifies form of the returned data for queries. The four forms are Binary (base 2), Octal (base 8), Hexadecimal (base 16) and ASCII (1600S) or Decimal (CSA) (base 10). Default is base 10. For the 1600S, all returned data not in ASCII format is preceded with a prefix signifying the format: #B for Binary, #Q for Octal and #H for Hexadecimal. Data in scientific notation is not affected by these commands.

SEE ALSO

Numeric Form (3-5-2)

EXAMPLES

```
REC:FREQ 103.7 MHZ // Sets Receiver Frequency to 103.7 MHz.

FORM BIN // Selects binary format for the
// returned data.

REC:FREQ? // Queries the Receiver Frequency.
// #B11001010100010100 is returned.

FORM HEX // Selects Hexadecimal format for
// the returned data.

REC:FREQ? // Queries the Receiver Frequency.
// #H19514 is returned.
```

HEIGHT

USE

To change height of text printed on CRT.

SYNTAX

HEIGHT n

ACTION

The height of text printed on the CRT after this command is changed to n times the standard height (0.175 inches). Text can be printed in four heights: 0.175, 0.35, 0.525 or 0.7 inches.

VARIABLE

DESCRIPTION

n

Height parameter setting height $n \times$ the standard height. n is an integer from 1 to 4.

SEE ALSO

Graphics (3-13-5), PRINT, ROTATE

EXAMPLES

```
// Sets the text height to 0.175''.
HEIGHT 1
                         // PRINT command.
PRINT "standard"
                         // Each PRINT command moves the xy
PRINT
                         // position down a line the current
PRINT
                          // height set by the HEIGHT command
PRINT
                         // (currently 0.175'').
                         // Sets the text height to 0.7''.
HEIGHT 4
                         // PRINT command.
PRINT "large"
                          // Sets the text height to 0.35''.
HEIGHT 2
PRINT "double standard"
                         // PRINT command.
                          // Returns the HEIGHT setting to 1.
HEIGHT 1
```

The following is printed on the CRT: standard in 0.175 inch high text, large in 0.7 inch high text and double standard in 0.35 inch high text.

Each **PRINT** command without an ending comma moves the xy position to the beginning of the next line using the height setting for the height of the line. The first four **PRINT** commands move the xy position down 0.7" (0.175" for each PRINT command). The **PRINT** "large" command moves the xy position down 0.7". The **PRINT** "double standard" command moves the xy position down 0.35".

NOTE: The HEIGHT setting should be returned to 1 because all printing on the CRT uses this setting.

HFLUSH (CSA Only)

USE

To quickly send HOST commands through the SCSI Bus.

SYNTAX

HFLUSH

ACTION

Gives previous HOST commands priority by flushing all commands currently in the task queue out the SCSI at that time. (Normally, to avoid time consuming SCSI traffic, HOST commands are held in the task queue. When the task queue becomes full, commands are sent across the SCSI Bus to the 1600S.)

EXAMPLES

host "fgen:gen1:mod1 5; shape:sin"
host "fgen:gen1:freq 1000; mod:fm

hflush

HPRINT (CSA Only)

USE

To print on the CRT screen.

SYNTAX

HPRINT %0nl, expression, ,expression, or **HPRINT** expression, ,%0nl, expression,

ACTION

The HPRINT command (HOST PRINT command) prints numerical and string values at the current xy location on the CRT. Several values are printed on the same line by separating them with commas. If the optional ending comma is used, the next HPRINT command continues on the same line, otherwise a new line is started. If an expression is a variable, the value of the variable is printed. Mathematical expressions are calculated before printing.

The %0nl is the format settings for numeric expressions and can be placed anywhere in the HPRINT command. There can be several format settings in each HPRINT command, each one changing the leading zero format, the numeric base and the field width for the expressions that follow. Format settings do not affect the printing of strings.

VARIABLE	DESCRIPTION
0	Zero signifies leading zeros are added to fill the field width. The 0 is omitted for no leading zeros. Applies only to numeric expressions.
n	Specifies field width. n is the minimum number of digit spaces (decimal point counts as one). Applies only to numeric expressions. If l is D , n can be in the form of $b.a$, where b designates minimum number of total digit spaces (decimal point counts as one) and a designates the maximum number of digits after the decimal point.
1	Specifies the numeric base the data is printed in. Applies only to numeric expressions. Omit for a default of Signed Decimal or enter one of the following:
	B Binary Q Octal H Hexadecimal U Unsigned decimal D Signed decimal
expression	Expression to be printed. Can be a mathematical expression, a literal string or the contents of variables. Mathematical expressions are calculated and string functions are performed before the results are printed.

SEE ALSO

PRINT, XYPRINT, PPRINT, PSCREEN, XY

EXAMPLES

HPRINT "CELLULAR PHONE TEST"

This **HPRINT** command prints the string text, between the quotation marks, on the CRT, starting at the current xy location.

HPRINT "The Receiver Frequency is ",%3.0, HOST "REC: FREQ?"

No leading zeros and a field width of 3 is specified after the string text is printed. The Receiver frequency setting is printed with the field width of 3, rounded to the nearest kHz because no digits are printed after the decimal point.

ICON (1600S Only)

USE

To create a user defined graphic on the CRT.

SYNTAX

ICON b, r, name

ACTION

A graphic is created by defining an area of pixels and a data array specifying which pixels to appear and which not to appear (1's to appear, 0's not to appear). The top left corner of the defined area is placed at the current XY setting. The data array must contain 32 bit words.

	VARIABLE	DESCRIPTION
	b	Number of bits per row in the icon to be generated.
	r	Number of rows in the icon to be generated.
	name	Name of data array containing the bit pattern used for the icon.
SEE ALSO	Graphics (3-13-5), XY, DATA	
EXAMPLES	See Graphic examples (3-13-5).	

IF ENDIF

USE

To provide a decision point inside a macro.

SYNTAX

IF condition sequence; ENDIF

or IF condition sequence

ENDIF

ACTION

The condition must be true for sequence to execute. If the condition is not true the sequence is not executed and execution flow passes to the next command after the ENDIF command. Every IF command must have an ENDIF. IF commands can be put inside other IF commands if the ENDIF to the inner IF command is also inside the outer IF command.

VARIABLE	DESCRIPTION
condition	Conditional expression evaluated to determine which command sequence is executed.
sequence	Command sequence performed if the condition is true.

SEE ALSO

IF ELSE, IF ELIF, CASE

EXAMPLES

IF Mod>20 Flag=1; ENDIF

This set of commands sets Flag equal to 0 if Mod is greater than 20. If Mod is not greater than 20, this set of commands has no effect, as the Flag=0 command is not performed.

```
IF Dev > 3
   IF Freq_Err < 1000
    Freq=200000
   ENDIF
ENDIF</pre>
```

The Inner IF-ENDIF commands are executed if Dev is greater than 3. The Freq=200000 command is executed if Freq_Err is less than 1000 and Dev is greater than 3.

IF ELIF ELSE ENDIF

USE

To provide a decision point inside a macro.

SYNTAX

IF condition sequence ELIF condition sequence ELIF condition sequence

ELSE

sequence

ENDIF

ACTION

IF ELIF command allows several conditions to be checked instead of one or two. Each ELIF (Else If) part allows the checking of a condition. If the condition is true, the following sequence is executed. The optional ELSE sequence is executed if no ELIF condition is true. An ENDIF command must be included at the end of a IF ELIF group of commands. If two ELSE IF commands are true, only the sequence following the first one is executed.

VARIABLE	DESCRIPTION
condition	Conditional expression
sequence	Command sequence (set of commands) performed if previous conditional expression is true.

SEE ALSO

IF, IF ELSE, IF ELIF, CASE

EXAMPLES

IF X=3
PRINT "X=3"
ELIF X=4
PRINT "X=4"
ELIF X=5
PRINT "X=5"
ENDIF

Executes the **PRINT** command that follows a true *condition* if there is one and ignores all other **PRINT** commands.

IF ELSE ENDIF

USE

To provide a decision point inside a macro.

SYNTAX

IF condition sequence1 ELSE sequence2

ENDIF

or

IF condition sequence1

ELSE

sequence2

ENDIF

ACTION

IF ELSE command allows one of two command sequences to be executed depending on the validity of the *condition*. If the *condition* is true, *sequence1* is executed. If the *condition* is false, *sequence2* is executed. Every IF ELSE command must have an ENDIF.

VARIABLE	DESCRIPTION
condition	Conditional expression that determines which command sequence is executed.
sequence1	First command sequence. sequence1 is executed if condition is true.
sequence2	Second command sequence. sequence2 is executed if condition is not true.

SEE ALSO

IF, IF ELIF, CASE

EXAMPLES

IF D>4 PRINT "D HIGH"
ELSE PRINT "D LOW"
ENDIF

Example prints D HIGH if D is greater than 4; otherwise D LOW is printed.

IF T=3 T=T+1 ELSE T=T-1 ENDIF

1 is added to T if T is equal to 3. If T is not equal to 3, 1 is subtracted.

IF ELSE (Shorthand)

USE As an abbreviated version of the IF ELSE command.

SYNTAX command (condition? true:false)

ACTION

The shorthand version of the IF ELSE command allows one of two arguments to be performed with the same command. If the condition is true, the first argument (true) is performed. If the condition is false, the second argument

(false) is performed. No ENDIF is used with this command.

VARIABLE	DESCRIPTION
command	Incomplete command which is performed with one of the arguments.
condition	Conditional expression that determines which argument is performed with the command.
true	Argument command performs if condition is true.
false	Argument command performs if condition is false.

SEE ALSO IF, IF ELSE, IF ELIF, CASE

EXAMPLES PRINT (D>4? "D HIGH": "D LOW")

The conditional expression (D>4?) is evaluated, and if true, the command PRINT "D HIGH" is executed. If the conditional expression is false, the command PRINT "D LOW" is executed.

T = (T=3? T+1:T-1)

The conditional expression (T=3?) is evaluated, and if true, the command T=T+1 is executed. If the conditional expression is false, the command T=T-1 is executed.

INPUT

USE

To enter data during macro execution.

SYNTAX

INPUT variable

ACTION

Stops execution of the macro until data is input. The value of the data entered is assigned to the *variable* specified in the command and command execution continues. For the 1600S, the CRT displays a blinking cursor with a width set using the **EDIT:WIDTH** command. Data is entered using the DATA ENTRY Keys and pressing the ENTER Key. For the CSA, there is no blinking cursor and the data is entered using the remote controller keyboard.

VARIABLE

DESCRIPTION

variable

Variable given the value entered.

SEE ALSO

Variables and Arrays in Macros (3-11), Colors (3-13-1)

EXAMPLES

*DMC "GET_X" EDIT:WIDTH 30 INPUT X

PRINT X
END

Upon execution of the macro GET_X, a blinking cursor appears on the CRT (1600S only). The cursor is set to a width of 30 pixels by the **EDIT:WIDTH** command. If 6, 5, • and 3 DATA ENTRY Keys are pressed, variable X is assigned the value of 65.3 and 65.3 is printed on the CRT.

INTERP

USE

To execute commands that may not be known when the macro containing the commands is defined.

SYNTAX

INTERP "string; string; string"

ACTION

The INTERP command executes each *string* as a command and is limited to one line. The INTERP command is not required to be inside a macro.

VARIABLE

DESCRIPTION

string

String variables, literal strings and string functions.

EXAMPLES

*DMC "Run_tests", BEGIN

INPUT \$

INTERP "PRINT \$; TEST"+STR(\$1)

END

Entering Run_tests 4 executes this macro. If Test Working is entered at the INPUT prompt, Test Working is printed and the macro Test4 is executed. If the INTERP command is not used, the Run_tests macro can not be defined because the \$ in the PRINT command and TEST4 are not yet defined.

is executed

KEYPAD:ERASE (1600S Only) USE To erase Soft Function Key definitions. KEYPAD: ERASE n SYNTAX **ACTION** Erases definition for *n* Soft Function Key. VARIABLE DESCRIPTION Number of the Soft Function Key affected. The range of n n is from 1 to 6. SEE ALSO Soft Function Key Displays (3-13-4), KEYPAD:LABEL, KEYPAD:SOFT **EXAMPLES** KEYPAD: ERASE 4 // Erases definition for Soft // Function Key F4. TEST 1 TEST 2 TEST 3 TEST 4 Setup Ret TEST 1 TEST 2 TEST 3 Setup Ret 8618022 Before KEYPAD: ERASE command After KEYPAD: ERASE command

Figure 3-9 KEYPAD: ERASE Example

is executed

KEYPAD:LABEL

USE To create Soft Function Key definitions.


SYNTAX KEYPAD:LABEL n, "label"

ACTION Creates a definition for the specified Soft Function Key.

VARIABLE	DESCRIPTION
n	Number of the Soft Function Key. Range of <i>n</i> is from 1 to 6.
label	Definition for the specified Soft Function Key. Executing without a label between the quotation marks ("") is the same as initiating the KEYPAD:ERASE command.

SEE ALSO Soft Function Key Displays (3-13-4), KEYPAD:ERASE, KEYPAD:SOFT

EXAMPLES KEYPAD: LABEL 4, "Menu"



8618023

Before **KEYPAD:LABEL** command is executed

After KEYPAD:LABEL command is executed

TEST 1 TEST 2 TEST 3 Menu Setup Ret

Figure 3-10 KEYPAD:LABEL Example

KEYPAD:SOFT (1600S Only)

USE To create the Soft Function Key frame located at the bottom of the current


screen.

SYNTAX KEYPAD:SOFT


ACTION Creates the Soft Function Key frame at the bottom of the current screen.

SEE ALSO Soft Function Key Displays (3-13-4), KEYPAD:ERASE, KEYPAD:LABEL

EXAMPLES KEYPAD: SOFT



8618024



Before **KEYPAD:SOFT** command is executed

After **KEYPAD:SOFT** command is executed

Figure 3-11 KEYPAD:SOFT Example

NVRCL (1600S Only)

USE To recall a variable or array stored in non-volatile memory.

SYNTAX NVRCL name, location

ACTION Recalls global variables and arrays saved in nonvolatile memory

VARIABLE DESCRIPTION

name Name given to recalled variable or array.

location Location of the variable or first element of the array.

SEE ALSO Saving Variables and Arrays (3-3-2), NVSAV

EXAMPLE See NVRCL examples (3-3-2).

NVSAV (1600S Only)

USE To save variables and arrays in non-volatile memory.

SYNTAX NVSAV name, location

ACTION Saves global variables or arrays in non-volatile memory. Global variables and

arrays are not saved when Test Set is turned off and need to be saved in

non-volatile memory.

VARIABLE DESCRIPTION

name Name of variable or array to be saved.

Iocation Memory location to store variable or first element of array. There are 111 memory locations available. Arrays

take a memory location for each element.

SEE ALSO Saving Variables and Arrays (3-3-2), NVRCL

EXAMPLE See **NVSAV** examples (3-3-2).

PIXEL

USE To create a user defined dot on the CRT.

SYNTAX PIXEL

ACTION Creates a dot in the current foreground color at the current xy location set

by the XY command. If the foreground color or xy location is changed, the

dot does not change.

SEE ALSO Graphics (3-13-5), XY

EXAMPLES XY 300,150

COLOR 6 PIXEL

A brown dot appears at the xy location of 300, 150.

PPRINT (1600S Only)

USE

To print responses out the RS-232 Connector.

SYNTAX

PPRINT %Onl, expression, ... ,expression, "\ccc"

ACTION

Sends all responses that would normally be printed on the CRT to the device connected to the RS-232 Connector. (xy location has no affect on the **PPRINT** command.)

VARIABLES	DESCRIPTION	
0	Zero signifies leading zeros are added to fill the field width. The 0 is omitted for no leading zeros. Applies only to numeric expressions.	
n	Specifies the field width. n is the number of digit spaces (decimal point counts as one). Applies only to numeric expressions.	
1	Specifies the numeric base the data is printed in. Applies only to numeric expressions. Omit for a default of Signed Decimal or enter one of the following:	
	B Binary Q Octal H Hexadecimal U Unsigned decimal D Signed decimal	
expression	Expression to be printed. Can be a mathematical expression, a literal string or the contents of variables. Mathematical expressions are calculated and string functions are performed before the results are printed.	
ccc	Non-printable characters in octal form used to specify the output. Select characters specified by the devise being printed to or as follows:	
	n or I Specifies a line feed character. r Specifies a carriage return.	
PRINT, PSCREEN		

SEE ALSO

EXAMPLES

PPRINT "Ring\007\n"

Prints Ring on the RS-232 device. The $\007$ causes the devices bell to sound (if device has a bell). The \n provides a line feed to the device.

PRINT

USE

To print on the CRT screen (1600S) or to print responses out the RS-232 Connector (CSA).

SYNTAX

PRINT %0nl, expression,, expression, or **PRINT** expression,, %0nl, expression,

ACTION

Prints numerical and string values at the current xy location on the CRT. Several values are printed on the same line by separating them with commas. If the optional ending comma is used, the next **PRINT** command continues on the same line, otherwise a new line is started. If an expression is a variable, the value of the variable is printed. Mathematical expressions are calculated before printing.

The %0nl is the format settings for numeric expressions and can be placed anywhere in the PRINT command. There can be several format settings in each PRINT command, each one changing the leading zero format, the numeric base and the field width for the expressions that follow. Format settings do not affect the printing of strings.

VARIABLE	DESCRIPTION
0	Zero signifies leading zeros are added to fill the field width. The 0 is omitted for no leading zeros. Applies only to numeric expressions.
n	Specifies field width. n is the minimum number of digit spaces (decimal point counts as one). Applies only to numeric expressions. For CSA, if l is D , n can be in the form of $b.a$, where b designates minimum number of digits before the decimal point and a designates the maximum number of digits after the decimal point.
I	Specifies the numeric base the data is printed in. Applies only to numeric expressions. Omit for a default of Signed Decimal or enter one of the following:
	B Binary Q Octal
	H Hexadecimal U Unsigned decimal
	D Signed decimal
expression	Expression to be printed. Can be a mathematical expression, a literal string or the contents of variables. Mathematical expressions are calculated and string functions are performed before the results are printed.

SEE ALSO

HPRINT, XYPRINT, PPRINT, PSCREEN, XY

EXAMPLES

X=44
Y=37.83
\$="String"

PRINT %04, X, " ", \$

This **PRINT** command contains a format setting specifying leading zeros and a width of 4 characters. Signed decimal is the numeric base by default. 0044 String is printed.

PRINT X, %3, " ", Y

No leading zeros and a field width of 3 is specified after X is printed. 44 37.83 is printed with the field width of 3 being expanded to fit Y.

PRINT %4B,X

No leading zeros, a field width of 4 and the Binary numeric base is specified. 101100 is printed. The field width is enlarged to accommodate X.

PRINT %7, \$, Y

No leading zeros and a field width of 7 is specified. String 37.83 is printed with the 3 blank character spaces provided by the field width of 7.

PRINT %03Q, X, \$, %6, Y

Leading zeros, a field width of 3 and the Octal number base is specified by the first format setting printing 054string. No leading zeros, a field width of 6 and the Signed Decimal number base (by default) is specified by the second format setting printing 37.83. Each % changes the format for the expressions that follow. The complete printed statement is 054string 37.83.

PSCREEN (1600S Only)

USE

To print the CRT Screen.

SYNTAX

PSCREEN

ACTION

Prints the CRT display using the device connected to the RS-232 Connector. RS-232 parameters must be configured for printing (see 6-2 of FM/AM-1600S or FM/AM-1600CSA Operation Manual). Command is entered through GPIB Connector or placed in a macro since printer is connected to RS-232 Connector.

SEE ALSO

PRINT, PPRINT

RETURN

USE

To return a value from a function or to return macro execution to the previous macro.

SYNTAX

RETURN

ACTION

Stops command execution of the macro it is contained in. If the macro was called from another macro, command execution resumes in the previous macro. If a variable is specified with the **RETURN** command, the variables value is returned.

EXAMPLE

*DMC "Even", BEGIN

IF \$1 % 2 = 0
PRINT \$1," IS EVEN"

ELSE
RETURN

ENDIF

END

*DMC "Test", BEGIN
Y= \$1**\$2
PRINT \$1,"TO THE POWER OF ",\$2," IS ",Y

Even Y
PRINT "TEST IS DONE"

If passed variable is odd, \$1 % 2 equals 1 and the **RETURN** command returns command execution back to the macro Test at the PRINT "TEST IS DONE" command.

*DMC "Maximum", BEGIN
VAR Max=0
EDIT:WIDTH 45
FOR X=1 TO 10
INPUT Y
IF Y>Max
Max=Y
ENDIF
NEXT X
RETURN Max
END

The **RETURN** command returns the value of Max. The function Maximum cannot be executed by simply entering it's name. Functions are executed by assigning them to a variable or using them in a **PRINT** command.

Z=Maximum

Function Maximum is executed and the result is assigned to Z.

PPRINT Maximum

Function Maximum is executed and the result is printed on the Host Terminal.

ROOM

USE

Finds the amount of memory size available.

SYNTAX

ROOM

ACTION

Returns the available memory size, in bytes, when printed.

SEE ALSO

Macros (3-9)

EXAMPLES

PRINT ROOM

130944 is printed on the CRT (1600S) or RS-232 Host device (CSA).

ROTATE (1600S Only)

USE

Rotates text character by character.

SYNTAX

ROTATE n

ACTION

Rotates the font of text printed on the CRT. Font rotates clockwise character by character in 90° intervals.

VARIABLE

DESCRIPTION

n

Degrees the character is rotated. Table 3-5 shows the amount of clockwise rotation for values of n.

n	ROTATION
0 to 89	0
90 to 179	90°
180 to 269	180°
270 to 359	270°

Table 3-5 Character Rotation for n Values

SLEEP

USE

To temporarily stop multitasking a macro.

SYNTAX

SLEEP "name"

ACTION

Removes the specified task from the schedule queue. The task can be put back on the schedule queue using the WAKE command.

VARIABLE

DESCRIPTION

name

Name of the macro to take off the schedule queue.

SEE ALSO

Multitasking Macros (3-12), WAKE

EXAMPLES

See Multitasking examples (3-12).

SOUND

USE

To create audio tones.

SYNTAX

SOUND f, t

ACTION

Generates a tone of frequency f for a length of time t and routes the tone to

the Test Set Speaker.

VARIABLE

DESCRIPTION

f

Frequency of tone (in Hz) generated.

t

Length of time (in ms) tone is generated.

EXAMPLES

SOUND 600,1000

// Creates a 600 Hz tone for 1 sec.

STOP

USE

For Multitasking.

SYNTAX

STOP

ACTION

Stops command execution of all macros regardless of where the **STOP** command is located.

EXAMPLES

*DMC "Test", BEGIN Y= \$1**\$2 IF \$2 < 0

STOP ENDIF

PRINT \$1, "TO THE POWER OF ", \$2, " IS ", Y

PRINT "TEST IS DONE"

END

If the passed variable is negative, the STOP command is executed and all macro command execution stops.

SEE ALSO

Multitasking Macros (3-12)

STRING

USE

To declare string variables and arrays.

SYNTAX

STRING name, , name

STRING name[index], ..., name[index]

ACTION

String variables and arrays are either local or global. Local string variables are declared inside a macro and have no meaning outside that macro. Global string variables are declared outside macros and are used inside or outside any macro. String variables and arrays cannot be initialized when declared.

VARIABLE

DESCRIPTION

name

Name of the string declared. The first character of the *name* is a letter while the remaining characters can be letters, digits and the underscore. The length of the *name* can be from 2 to 31 characters.

[index]

Number of array elements minus one.

SEE ALSO

String Variables and Functions (3-8)

EXAMPLES

```
STRING Mess_1, Mess_2 // Declares string variables named // Mess_1 and Mess_2.

Mess_1="Test" // Assigns "Test" to variable Mess_1.

Mess_2=Mess_1+"complete" // Assigns "Test complete" to the // string variable Mess_2.
```

TASK

USE

For Multitasking.

SYNTAX

TASK "name"

ACTION

Declares the specified macro as a task. A macro must be declared a task before it can be placed on the schedule queue for multitasking. The macro

must already be loaded in memory.

VARIABLE

DESCRIPTION

name

Name of the macro to be declared a task.

SEE ALSO

Multitasking Macros (3-12), ACTIVATE

EXAMPLES

See Multitasking example (3-12).

TPAUSE

USE

For Multitasking and sharing execution time with other Test Set activities.

SYNTAX

TPAUSE

ACTION

While multitasking, stops command execution and passes command

execution to the next task in the schedule queue.

SEE ALSO

Multitasking Macros (3-12), TSTOP

EXAMPLES

See Multitasking example (3-12)

TSTOP

USE

For Multitasking.

SYNTAX

TSTOP

ACTION

While multitasking, stops command execution and removes the currently running task from the schedule queue and performs a TPAUSE. Command

execution passes to the next task in the schedule queue.

SEE ALSO

Multitasking Macros (3-12), TPAUSE

EXAMPLES

See Multitasking example (3-12).

VAR

USE

To declare variables and arrays.

SYNTAX

VAR name, , name

VAR name[index], ..., name[index]

ACTION

Variables are declared with a *name*. Arrays are declared with a *name* and an *index*. Variables and arrays are either local or global. Local variables and arrays are declared inside a macro and have no meaning outside that macro. Global variables and arrays are declared outside macros and are used inside or outside any macro. Variables and arrays can be initialized when declared using an = character. Using a variable name already used to declare another variable, voids the previous variable.

VARIABLE	DESCRIPTION
name	Name of variable or array declared. The first character of the <i>name</i> is a letter while the remaining characters can be letters, digits or the underscore. The length of the <i>name</i> can be from 2 to 31 characters.
[index]	Index of an array. Identifies the elements of the array by specifying the order of occurrence. The count of elements starts with 0.

SEE ALSO

Variables and Arrays (3-3)

EXAMPLES

```
VAR Flag=0,Set_Squ=.9 // Variables Flag and Set_Squ are // declared and initialized to 0 // and 0.9.

VAR Dat[2]={3.2,3.4,3.6} // Array Data is declared with // 3 elements and each element iss // initialized to a value.
```

WAKE

USE

For Multitasking.

SYNTAX

WAKE "name"

ACTION

Reenters a task (taken off the schedule queue by a SLEEP command) into the schedule queue.

VARIABLE DESCRIPTION

name

Name of the task put back on the schedule queue.

SEE ALSO

Multitasking macros (3-12), SLEEP

EXAMPLES

See Multitasking examples (3-12).

WCLOSE

USE

To erase a generated window on the CRT.

SYNTAX

WCLOSE n

ACTION

Closes (deletes) the window specified by n.

VARIABLE

DESCRIPTION

n

Number of the window to close. Windows are numbered in the order they are created. Overlapping windows must be closed in the reverse order they are opened.

SEE ALSO

Windows (3-13-3), WOPEN, WINDOW?

EXAMPLES

See Window examples (3-13-3).

WHILE WEND

USE

To perform a set of commands repetitiously while a conditional expression is true.

SYNTAX

WHILE condition sequence

WEND

ACTION

The WHILE loop repeatedly executes a command sequence until a condition is false. If condition is false when first evaluated, the command sequence is not executed once like the DO loop since the condition is tested before the command sequence.

VA	R	IA	В	L	E
***************************************	*****	*******			

DESCRIPTION

condition

Conditional expression evaluated. If true the command sequence is performed and command execution is looped up to the WHILE command until condition is false.

sequence

Command sequence performed as long as condition is true.

EXAMPLES

N=0

WHILE N!=2 N=N+1

WEND

N is equated to 0 and the WHILE command is executed initiating the following sequence:

- N is compared to 2 (N=0).
- 1 is added to N.

- N is compared to 2 (N now equals 1).
- 1 is added to N.
- N is compared to 2 (N now equals 2).
- N skips over commands inside loop and these commands are not executed. Macro execution continues after WEND command.

```
VAR FF
WHILE FF<=LN(2*S)
FF=FF<<2
PRINT FF
WEND
```

The value of FF is shifted left 2 bits and printed until it is greater than LN(2*S).

```
WHILE SYSTEM: KEY? != 32896
  command
  .
  .
WEND
```

This WHILE loop continues looping until the Front Panel Key with a keycode of 32896 is pressed.

WINDOW?

USE

To return the window currently selected.

SYNTAX

WINDOW?

ACTION

Returns the number of the currently selected window. The selected window is the window affected by the WMOVE and WCLOSE commands. The last opened window is the selected window unless a WSEL command has selected another window.

SEE ALSO

Windows (3-13-3), WSEL, WMOVE, WCLOSE

EXAMPLES

See Window examples (3-13-3).

WMOVE

USE To move windows.

SYNTAX WMOVE x, y

ACTION Moves the currently selected window so that the top left corner of the window

is located at the specified point. Moving a window that overlaps another

window disrupts the window overlapped.

VARIABLE DESCRIPTION
 x, y New coordinates on the CRT of the top left corner of the window to be moved. Window size and shape are not affected.

SEE ALSO Windows (3-13-3), WSEL, WINDOW?

EXAMPLES See Window examples (3-13-3).

WOPEN

USE To create windows.

SYNTAX WOPEN *c*, *x*1, *y*1, *x*2, *y*2

ACTION Creates a window on the CRT of color c with a top left point of x1, y1 and a

bottom right corner of x2, y2. Height and width of window are forced to

16 pixel increments.

NOTE: A lack of available memory can cause a window not to open.

C Number of the color selected for the window.

X1, Y1 CRT coordinates of the top left corner of the window being opened.

X2, Y2 CRT coordinates of the bottom right corner of the window being opened.

SEE ALSO Windows (3-13-3), WCLOSE

EXAMPLES See Windows examples (3-13-3).

WSEL

USE

To change which window is currently selected.

SYNTAX

WSEL n, h

ACTION

Makes the specified window the currently selected window and hides the window if h is set to 1. The selected window is the window affected by the WMOVE and WCLOSE command.

VARIABLE	DESCRIPTION
n	Number of the window to become the currently selected window. Windows are numbered in the order they are opened.
h	Specifies if window should be hidden (h is 1 for window to be hidden, 0 for window to show). A hidden window does not appear on the CRT and must be closed and opened again to reappear.
Windows (3-1	3-3), WINDOW?, WMOVE, WCLOSE
Soo Window o	ovembles (2-12-2)

SEE ALSO

EXAMPLES

See Window examples (3-13-3).

XY

USE

To specify a point on the CRT for other display commands to use.

SYNTAX

XY n, m

ACTION

Specifies a point (one pixel) on the CRT to be used by the **PRINT**, **PIXEL**, **HPRINT** and **ICON** commands. The point 0,0 is the top left corner of the CRT, with positive m in the downward direction and positive n in the right direction. The **PRINT** command moves the xy position to a new line using the current **HEIGHT** setting for the height of the new line.

VARIABLE	DESCRIPTION
n	The x coordinate (horizontal position) of the xy location. Range is the number of pixels across the CRT (left to right side) (0 to 639).
m	The y coordinate (vertical position) of the xy location. Range is the number of pixels across the CRT (top to bottom) (0 to 349).
CRT Display ((3-13-2), Graphics (3-13-5)

SEE ALSO

EXAMPLES

See Graphics example (3-13-5).

XYPRINT (CSA Only)

USE

To print on the CRT screen.

SYNTAX

XYPRINT x,y, %0nl, expression,, expression, or **XYPRINT** x,y, expression,, %0nl, expression,

ACTION

Combines the XY and HPRINT commands. Prints numerical and string values at the selected x,y location on the CRT. Several values are printed on the same line by separating them with commas. If an expression is a variable, the value of the variable is printed. Mathematical expressions are calculated before printing.

The %0nl is the format settings for numeric expressions and can be placed anywhere in the XYPRINT command. There can be several format settings in each XYPRINT command, each one changing the leading zero format, the numeric base and the field width for the expressions that follow. Format settings do not affect the printing of strings.

VARIABLE	DESCRIPTION		
x	The x coordinate (horizontal position) of the xy location. Range is the number of pixels across the CRT (left to right side) (0 to 639).		
У	The y coordinate (vertical position) of the xy location. Range is the number of pixels across the CRT (top to bottom) (0 to 349).		
0	Zero signifies leading zeros are added to fill the field width. The θ is omitted for no leading zeros. Applies only to numeric expressions.		
n	Specifies field width. n is the minimum number of digit spaces (decimal point counts as one). Applies only to numeric expressions. If l is D , n can be in the form of $b.a$, where b designates minimum number of digits before the decimal point and a designates the maximum number of digits after the decimal point.		
I	Specifies the numeric base the data is printed in. Applies only to numeric expressions. Omit for a default of Signed Decimal or enter one of the following:		
	B Binary Q Octal H Hexadecimal U Unsigned decimal D Signed decimal		
expression	Expression to be printed. Can be a mathematical expression, a literal string or the contents of variables. Mathematical expressions are calculated and string functions are performed before the results are printed.		

SEE ALSO PRINT, PPRINT, PSCREEN

EXAMPLES

U=44
T=37.83
STRING NOT
NOT="MOBILE PHONE DOES NOT RESPOND"

XYPRINT 5,5,%04,U," ",NOT

This XYPRINT command contains a format setting specifying leading zeros and a width of four characters. Signed decimal is the numeric base by default. The command prints 0044 MOBILE PHONE DOES NOT RESPOND starting at point 5, 5 location on the CRT.

XYPRINT 319,174,U,%3," ",T

No leading zeros and a field width of 3 is specified after U is printed. The CRT displays 44 37.83 starting in the middle of the screen. The field width of 3 was expanded to fit T.

XYPRINT 0,0,%4B,X

No leading zeros, a field width of 4 and the Binary numeric base is specified. 101100 is printed in the upper left corner of the screen. The field width is enlarged to accommodate U.

XYPRINT 30,55,%7,\$,Y

No leading zeros and a field width of 7 is specified. Starting at xy location (30, 50), MOBILE PHONE DOES NOT RESPOND 37.83 is printed. The three blank character spaces are provided by the field width of 7.

XYPRINT 319,174,%3.1,T

No leading zeros and a minimum field width of 3 with a maximum of 1 digit after the decimal point is specified. The CRT displays 37.8 starting in the middle of the screen. The field width of 3 was expanded to fit T, counting the decimal point.

SECTION 4 - 1600S SPECIFIC TMAC COMMANDS

4-1 GENERAL

This Section lists FM/AM-1600S specific commands by Operation Mode. Many commands do not operate unless Test Set routing is configured for the operation mode of that command. **SETUP** commands establish routings for selected operation modes (see 4-2). **SCREEN** commands establish routings and display the operation screen for the selected operation mode (see 4-3).

Commands affect the Test Set when executed; however changes do not appear on the Operation Screens until the Screen is renewed using a **SCREEN** command.

The short form of the command is shown in uppercase letters and the long form is finished in lower case. When entering commands, it is not necessary to use a particular letter case. The TMAC compiler/interpreter is not case sensitive. Brackets ([]) indicate optional command items.

4-2 SETUP COMMANDS

SETUP commands establish the routings for various Operation Modes without displaying the Operation Screens on the CRT.

SETUP:

AF

Configures Test Set routing for AF Meter Operation.

ANLZ

Configures Test Set routing for Spectrum Analyzer Operation.

DISTortion

Configures Test Set routing for Distortion Meter Operation.

DUPlex

Configures Test Set routing for Duplex Operation.

DUPRX

Configures Test Set routing for Duplex Receiver Operation.

DUPTX

Configures Test Set routing for Duplex Transmitter Operation.

FUNC

Configures Test Set routing for AF Generator Operation.

GENerator

Configures Test Set routing for RF Generator Operation.

MONItor

Configures Test Set routing for Generator/Monitor Operation.

RECeiver

Configures Test Set routing for Receiver Operation.

SCOPe

Configures Test Set routing for Oscilloscope Operation.

SINAD

Configures Test Set routing for SINAD Meter Operation.

4-3 SCREEN COMMANDS

SCREEN commands renew and display Mode Operation Screen on the CRT. Many commands do not operate correctly unless the CRT displays the applicable Mode Operation Screen.

SCREEN:

AF

Displays Audio Frequency Meter Operation Screen.

ANLZ

Displays Spectrum Analyzer Operation Screen.

BER

Displays Bit Error Rate Meter Operation Screen.

CELL

Displays Forward Control Channel Screen of the AMPS Cell Site Monitor (AMPS option installed).

DEViation

Displays Deviation Meter (Peak) Operation Screen.

DISTortion

Displays Distortion Meter Operation Screen.

DMM

Displays Digital Multimeter Operation Screen.

DRMS

Displays Deviation Meter (RMS) Operation Screen.

DUPlex

Displays Duplex Operation Screen.

DUPRX

Displays Duplex Receiver Operation Screen.

DUPTX

Displays Duplex Transmitter Operation Screen.

FREQuency

Displays Frequency Error Meter Operation Screen.

FUNC

Displays AF Generator Operation Screen.

GENCELLular

Displays Main Menu of AMPS Mobile Simulator (AMPS option installed).

GENerator

Displays RF Generator Operation Screen.

GENRECC

Displays Reverse Control Channel Simulation Screen of AMPS Mobile Simulator (AMPS option installed).

SCREEN:

GENRVC

Displays Reverse Voice Channel Simulation Screen of AMPS Mobile Simulator (AMPS option installed).

MODulation

Displays Modulation Meter Operation Screen.

PM

Displays Phase Meter Operation Screen.

PMRMS

Displays Phase Meter (RMS) Operation Screen.

POWer

Displays Power Meter Operation Screen.

RECeiver

Displays Receiver Operation Screen.

SCOPe

Displays Oscilloscope Operation Screen.

SIGnal

Displays Signal Strength Meter Operation Screen.

SINAD

Displays SINAD Meter Operation Screen.

USER

Displays blank User Screen without changing routing. User Screen has no readings to update, decreasing run time when inside a macro. Following this command with other graphic, window and keypad commands creates customized menu screens (see 3-13).

4-4 AUXILIARY TEST SET COMMANDS

Auxiliary Test Set commands are used to communicate with an attached Auxiliary Test Set through the SCSI Connector. The Auxiliary Test Set holds certain options available with the FM/AM-1600S and may or may not be installed. Because of the vast command possibilities, the FM/AM-1600S does not check the Auxiliary Test Set command for correct string syntax.

AHIT?

Returns a 1 if there is input waiting from the Auxiliary Test Set.

AUX "string"

Issues commands, as strings, to the Auxiliary Test Set.

```
Example: AUX "DELAY 200" // The DELAY 200 command is passed to and // executed by the Auxiliary Test Set.
```

AUX? "string?"

Issues queries, as strings, to the Auxiliary Test Set.

```
Example: AUX? "PEEK? 1250" // The PEEK? 1250 query is passed to the // Auxiliary Test Set. The Auxiliary Test // Set executes the query and returns the result.
```

4-5 RF GENERATOR

4-5-1 RF GENERATOR COMMANDS

GENerator:

AF

Displays AF Level Meter on the RF Generator Operation Screen when followed by SCREEN:GENerator command.

CHANnel n

Sets Frequency to cellular channel n (1 to 1023) in the format selected using the **GEN:CHAN:FORM** command. RF Generator Operation Screen displays selected cellular channel when RF Generator is in Channel Mode (**GEN:MODE CHAN** command).

CHANnel:

FORMat:

AMPS:

FORward

Selects AMPS Forward channels.

REVerse

Selects AMPS Reverse channels.

ETACS:

FORward

Selects ETACS Forward channels.

REVerse

Selects ETACS Reverse channels.

NAMPS:

FORward

Selects NAMPS Forward channels.

REVerse

Selects NAMPS Reverse channels.

NT400:

FORward

Selects NT400 Forward channels.

REVerse

Selects NT400 Reverse channels.

FORMat?

Returns channel format setting (AMPS:FORWARD, AMPS:REVERSE, ETACS:FORWARD, ETACS:REVERSE, NAMPS:FORWARD, NAMPS:REVERSE, NT400:FORWARD or NT400:REVERSE).

DCS:

INVert nnn

Generates the three digit octal Digital Coded Squelch (DCS) code in inverted mode. Range of *nnn* is 000 to 777.

NORMal nnn

Generates the three digit octal DCS code. Range of nnn is 000 to 777. See 4-5-1G.

STOP

Stops generating the continuous DCS code.

```
Example: GEN:DCS:NORM 411 // Generates a continuous DCS code of 411.

DELAY 200 // Waits for 200 ms before next command.

GEN:DCS:STOP // Stops generating the DCS code.
```

DIAL "sequence"

Generates sequence with a maximum of 16 digits (0 through 9 allowed) as 2805 Pulse code. See 4-5-11.

DIAL:

FREQuency f

Sets 2805 Tone frequency to f Hz. Range of f is 0.0 to 40000.0.

FREQuency?

Returns the current 2805 Tone frequency in Hz.

```
Example: GEN:DIAL:FREQ 3000 // Sets 2805 Tone frequency to 3000 Hz.
GEN:DIAL:FREQ? // Returns 2805 Tone frequency setting.
GEN:DIAL "5552424" // Generates a 2805 Tone frequency message // of 5552424.
```

DISTortion

Displays Distortion Meter on the RF Generator Operation Screen after the screen is updated by a SCREEN:GENerator command.

DMM

Displays Digital Multimeter on the RF Generator Operation Screen after the screen is updated by a SCREEN:GENerator command.

DSAT n

(NAMPS option installed) Generates the Digital Supervisory Audio Tone (DSAT) code specified by n. Range of n is 0 to 6.

DSAT:STOP

(NAMPS option installed) Stops generating the continuous DSAT code.

DST n

(NAMPS option installed) Generates the Digital Signal Tone (DST) code specified by n. Range of n is 0 to 6.

DST:STOP

(NAMPS option installed) Stops generating the continuous DST code.

DTMF "sequence", mark, space

Generates a DTMF coded sequence. sequence has a maximum of 16 digits. Range of optional mark and space time is from 25 to 9999 ms. Default for mark time is 74 ms. Default for space time is 67 ms. See 4-5-1D.

FREQuency n [units]

Sets RF Generator Frequency. Range of n is 250.0 kHz to 999.9999 MHz. Select HZ, KHZ, MHZ for units. Default for optional units is KHZ.

FREQuency?

Returns RF Generator Frequency in kHz (250.0 to 999999.9).

```
Example: GEN:FREQ 100 MHZ // Set RF Generator Frequency to 100 MHz.

GEN:FREQ? // Query the RF Generator Frequency.

// 100000 is returned (100000 kHz).
```

IMTS "sequence"

Generates sequence as a DCS IMTS code. sequence has a maximum of 16 digits (0 through 9 allowed).

LEVel n [units]

Sets RF Generator Level. Range of n is -137.0 to 0.0 dBm or 0.031 μV to 0.224 V. Select DBm, V, MV (mV) or UV (μV) for units. units is optional with the default being the current units. Specifying units does not change unit selection of Test Set.

LEVel:UNIT?

Returns the current units for the RF Generator Level.

LEVel?

Returns the RF Generator Level in the current units.

```
Example: GEN:LEV -65 DB // Sets RF Generator Level to -65 dBm.

GEN:LEV:UNIT? // Queries the units for the RF Generator // Level. DBM is returned.

GEN:LEV? // Queries the RF Generator Level. -65 // is returned.

GEN:LEV -30 // Sets RF Generator Level to -30 dBm (units // default to dBm, the current units).
```

MODE type

Selects the RF Generator Mode (DIRect [Direct Mode] or CHANnel [Channel Mode]). Channel Mode displays cellular channel frequency according to **GEN:CHAN** commands.

MTS "sequence"

Generates sequence as a DCS MTS code. sequence has a maximum of 16 digits (0 through 9 allowed).

OUTput:

AUDio b

Routes AF Generator Output to the AUDIO OUT Connector if b is 1. Disconnects the AUDIO OUT Connector if b is 0.

OUTput:

DEMOD b

Routes AF Generator Output to the DEMOD OUT Connector if b is 1. Disconnects the DEMOD OUT Connector if b is 0.

POCSAG:

ALPHA:

LOWer capcode

Generates a lower case Alpha message for the capcode specified. Range of the capcode is 0 to 2097151.

NUMeric capcode

Generates an Alphanumeric message for the capcode specified. Range of the capcode is 0 to 2097151.

Example:

```
GEN: POCSAG: NUMeric 4000 // Generates an Alphanumeric message at a // capcode of 4000 at the current rate.
```

SPECial capcode

Generates an Alpha special message for the capcode specified.

UPPer capcode

Generates an upper case Alpha message for the *capcode* specified. Range of the *capcode* is 0 to 2097151. See 4-5-1H.

BEEP n. capcode

Generates n Tone Beep POCSAG message for *capcode* specified. Select 1, 2, 3 or 4 for n. Range of the *capcode* is 0 to 2097151.

NUMeric capcode

Generates Numeric message for the capcode specified. Range of capcode is 0 to 2097151.

RATe

Sets POCSAG rate to high if b is 1, low if b is 0.

RATe?

Returns 1 if POCSAG rate is high, returns 0 if rate is low.

```
Example: *DMC "POCSAG", BEGIN // Defines a macro named POCSAG.
                             // Sets POCSAG rate to High.
        GEN: POCSAG: RATE 1
                             // Starts FOR loop of X to loop 5 times.
        FOR X=1 TO 5
        GEN: POCSAG: BEEP 2, X+5030 // Generates a POCSAG Tone - 2 beeps
                                  // message
                              // using the capcode specified by X.
        DELAY 3000
                              // Delays 3 seconds (for POCSAG generation).
                              // Wait for the last command to be executed.
        *WAI
                             // Loops X to the top of the loop until X=5.
        NEXT X
                             // Queries the POCSAG rate. 1 is returned
        GEN: POCSAG: RATE?
                              // Ends the macro named POCSAG.
        END
```

RCL n

Recalls RF Generator environment (routings and settings) stored in memory location n. Range of n is 1 to 9.

SINAD

Displays SINAD Meter on the RF Generator Operation Screen when followed by a **SCREEN:GENerator** command.

SPEAKer:SOURce type

Selects Test Set Speaker Input. Select OFF, FGEN (Function Generator), SINAD (SINAD/BER IN Connector) or EXTMOD (EXT MOD IN Connector) for type. This command takes effect when the RF Generator Operation Screen is updated.

Example: GEN:SPEAK:SOUR EXTMOD // Routes EXT MOD IN Connector to the // Test Set Speaker.

STORe n

Stores current RF Generator environment (routings and settings) in memory location n. Range of n is 1 to 9.

TONE "sequence"

Generates given sequence once the Audio code is selected using the GENerator:TONE:TYPE command. If selected Audio code is USER, characters contained in the sequence must be previously defined using the GENerator:TONE:USER:DEFine command. Valid sequence characters are the digits 0 through 9 and characters A, G, R and - (to signify a gap). Valid sequence characters for the USER code are the digits 0 through 9 and characters A through T.

TONE:

TYPE code

Selects the Audio code to generate. Enter one of the following for code:

CCIR	EEA	EIA (U.S).
ZVEI	DDZVEI	DZVÈI ´
NATEL	EURO	TONE56
CCIRH	CCIRH4	USER

See 4-5-1E and F.

USER:DEFine "id", freq, duration

The *id* character is assigned a *freq* in Hz and a *duration* in ms. Range of *freq* is 0.0 to 9999.9. Range of *duration* is 20.0 to 9999.9. Valid characters for the *id* are the digits 0 through 9 and characters A through T. See 4-5-1E and 4-5-1F.

```
Example: GEN:TONE:TYPE CCIRH // Selects CCIRH as RF Generator Audio Code.

GEN:TONE "5553434" // Generates 5552424 as CCIRH Audio Signal.
```

TREMote

Generates the Tone-remote sequence for the specified function tone frequency given by f in Hz. Select one of the following:

2050	1950	1850
1750	1650	1550
1450	1350	1250
1150	1050	

TREMote:STOP

Stops the Tone remote Guard Tone generated by a previous GENerator:TREMote command.

```
Example: GEN:TREM 1350 // Generates a Tone Remote 1350 message.

GEN:TREM:STOP // Stops the generating of the Tone Remote // Guard Tone.
```

4-5-2 REMOTE RF GENERATOR EXAMPLES

A. GENERATING FM MODULATED RF SIGNALS

The following command sequence generates a 1 MHz RF signal FM modulated (5 kHz deviation) with a 1 kHz sine wave and routes the signal to the DEMOD OUT Connector:

```
SCREEN: GEN
                               // Displays RF Generator Operation Screen.
GEN: FREQ 1000000
                               // Sets RF Generator Frequency to 1 MHz.
GEN:LEVEL 0 DB
                               // Sets the RF Generator Level to 0 dBm.
GEN:OUTPUT:DEMOD 1
                               // Routes the RF Generator output to the
                              // DEMOD OUT Connector.
FGEN: GEN1: STATE 1
                              // Activates SOURCE 1 (AF Generator 1).
FGEN: GEN1: FREQ 1000
                              // Sets SOURCE 1 Frequency to 1000 Hz.
FGEN: GEN1: MODULATION: FM
                              // Sets SOURCE 1 Modulation to FM.
FGEN: GEN1: MODL 5
                              // Sets SOURCE 1 Deviation to 5 kHz.
FGEN:GEN1:SHAPE:SIN
                              // Sets SOURCE 1 Wave Shape to a sine wave.
```

B. GENERATING AM MODULATED RF SIGNALS

The following command sequence generates a 10 MHz RF signal, AM modulated (80% modulation), with a 2.5 kHz sine wave and routes the signal to the AUDIO OUT Connector:

```
SCREEN: GEN
                               // Displays RF Generator Operation Screen.
GEN: FREQ 10 MHZ
                               // Sets RF Generator Frequency to 10 MHz.
                               // Sets the RF Generator Level to 0.0 dBm.
GEN:LEVEL 0 DB
                               // Routes the RF Generator output to the
GEN:OUTPUT:AUDIO 1
                               // AUDIO OUT Connector.
FGEN: GEN1: STATE 1
                               // Activates SOURCE 1 (AF Generator 1).
FGEN:GEN1:FREQ 2500
                              // Sets SOURCE 1 Frequency to 2500 Hz.
FGEN: GEN1: MODULATION: AM
                               // Sets SOURCE 1 Modulation to AM.
FGEN: GEN1: MODL 80
                               // Sets SOURCE 1 Modulation to 80%.
FGEN: GEN1: SHAPE: SIN
                               // Sets SOURCE 1 Wave Shape to a sine wave.
```

C. GENERATING EXTERNALLY MODULATED RF SIGNALS

The following command sequence generates a RF 15 MHz signal, AM modulated (80% modulation), with an external signal applied to the EXT MOD IN Connector and sends the signal to the AUDIO OUT Connector:

```
SCREEN: GEN
                               // Displays RF Generator Operation Screen.
                               // Sets RF Generator Frequency to 15 MHz.
GEN: FREQ 15000
GEN:LEV -20
                               // Sets the RF Generator Level to -20 dBm.
GEN:OUT:AUD 1
                               // Routes the RF Generator Output to the
                               // AUDIO OUT Connector.
FGEN: EXT: STATE 1
                               // Activates SOURCE EXT (for external
                               // modulation).
FGEN: EXT: MOD: AM
                               // Sets SOURCE EXT Modulation to AM.
FGEN: EXT: MODL 80
                               // Sets SOURCE EXT Modulation Level to 80%.
```

D. GENERATING A DTMF CODED SIGNAL

The following command sequence generates a 450 MHz signal FM modulated with a DTMF Code. The modulation level is 4 kHz and the RF Output Level is -60 dBm.

```
SCREEN: GEN
                               // Displays RF Generator Operation Screen.
*WAI
                               // Waits for previous commands to execute.
GEN: FREQ 450 MHZ
                               // Sets RF Generator Frequency to 450 MHz.
GEN:LEV -60 DB
                               // Sets the RF Generator Level to -60 dBm.
FGEN:GEN3:ENCODE DTMF
                               // Selects DTMF as the signaling format.
SCREEN: GEN
                               // Renews RF Generator Operation Screen.
*WAT
                               // Waits for previous commands to execute.
FGEN: GEN3: MOD: FM
                              // Sets SOURCE 3 Modulation to FM.
FGEN:GEN3:MODL 4
                               // Sets SOURCE 3 Modulation Level to 4 kHz.
GEN:DTMF "55523*#",80,70
                               // Generates 55523*# DTMF coded signal with
                               // 80 ms mark time and a 70 ms space time.
```

E. GENERATING AUDIO TWO TONE CODING

The following command sequence generates a 150 MHz signal FM modulated with an Audio Two Tone Code. The modulation level is 4 kHz and the RF Output Level is 0 dBm.

```
SCREEN: GEN
                              // Displays RF Generator Operation Screen.
*WAI
                              // Waits for previous commands to execute.
                              // Sets RF Generator Frequency to 150 MHz.
GEN: FREQ 150 MHZ
GEN:LEV 0 DB
                              // Sets the RF Generator Level to 0 dBm.
FGEN:GEN3:ENCODE TONE
                              // Selects Audio as the signaling format.
                              // Renews RF Generator Operation Screen.
SCREEN: GEN
*WAI
                              // Waits for previous commands to execute.
FGEN:GEN3:MOD:FM
                              // Sets SOURCE 3 Modulation to FM.
FGEN:GEN3:MODL 4
                              // Sets SOURCE 3 Modulation Level to 4 kHz.
GEN: TONE: TYPE USER
                              // Selects User Defined for the Audio Code.
GEN:TONE:USER:DEF "0,0,100"
                              // Defines 0 Tone as 0 Hz, 100 ms.
GEN:TONE:USER:DEF "1,880,500" // Defines 1 Tone as 880 Hz, 500 ms.
GEN:TONE:USER:DEF "2,2200,500"// Defines 2 Tone as 2200 Hz, 500 ms.
GEN: TONE 102
                              // Generates the User Defined Audio Code
                              // defined in the 3 previous commands.
```

F. GENERATING A 5/6 AUDIO TONE SEQUENCE

The following command sequence generates a 162 MHz signal FM modulated with an Audio 5/6 Tone Code. The modulation level is 4 kHz and the RF Output Level is 0 dBm.

```
SCREEN: GEN
                               // Displays RF Generator Operation Screen.
*WAI
                               // Waits for previous commands to execute.
GEN: FREQ 162 MHZ
                              // Sets RF Generator Frequency to 162 MHz.
GEN:LEV 0 DB
                              // Sets the RF Generator Level to 0 dBm.
FGEN:GEN3:ENCODE TONE
                              // Selects Audio as the signaling format.
SCREEN: GEN
                              // Renews RF Generator Operation Screen.
*WAI
                              // Waits for previous commands to execute.
FGEN:GEN3:MOD:FM
                              // Sets SOURCE 3 Modulation to FM.
                              // Sets SOURCE 3 Modulation Level to 4 kHz.
FGEN:GEN3:MODL 4
                              // Selects User Defined for the Audio Code.
GEN: TONE: TYPE: USER
GEN:TONE:USER:DEF 0,900,150
                              // Defines 0 Tone at 900 Hz and 150 ms.
GEN: TONE: USER: DEF 1,1100,80
                              // Defines 1 Tone at 1100 Hz and 80 ms.
GEN:TONE:USER:DEF 2,1200,80
                              // Defines 2 Tone at 1200 Hz and 80 ms.
GEN:TONE:USER:DEF 3,1300,80
                              // Defines 3 Tone at 1300 Hz and 80 ms.
GEN:TONE:USER:DEF 4,1400,80
                              // Defines 4 Tone at 1400 Hz and 80 ms.
GEN:TONE:USER:DEF A,0,40
                              // Defines A Tone at 0 Hz and 40 ms.
GEN: TONE 0A1234
                              // Generates the User Defined Audio Code.
                              // defined in the 6 previous commands.
```

G. GENERATING DCS CODE

The following command sequence generates a 162.450 MHz signal FM modulated with a DCS Code of 456. The modulation level is 1 kHz and the RF Output Level is 0 dBm.

```
SCREEN: GEN
                              // Displays RF Generator Operation Screen.
*WAI
                              // Waits for previous commands to execute.
GEN: FREQ 162450
                              // Sets 162.450 MHz RF Generator Frequency.
GEN:LEV 0 DB
                              // Sets the RF Generator Level to 0 dBm.
FGEN: GEN3: ENCODE DIG
                              // Selects Digital as the signaling format.
SCREEN: GEN
                              // Renews RF Generator Operation Screen.
*WAI
                              // Waits for previous commands to execute.
FGEN:GEN3:MOD:FM
                              // Sets SOURCE 3 Modulation to FM.
                              // Sets SOURCE 3 Modulation Level to 1 kHz.
FGEN:GEN3:MODL 1
GEN:DCS:NORM 456
                              // Generates a 456 DCS Code.
GEN:DCS:STOP
                              // Stops the generating of the DCS Code.
```

H. GENERATING POCSAG CODE

The following command sequence generates a 930 MHz signal FM modulated with a POCSAG Code. The modulation level is 4 kHz and the RF Output Level is 0 dBm.

```
SCREEN: GEN
                              // Displays RF Generator Operation Screen.
≭WAI
                              // Waits for previous commands to execute.
GEN: FREQ 450 MHZ
                              // Sets RF Generator Frequency to 450 MHz.
GEN:LEV 0 DB
                              // Sets the RF Generator Level to 0 dBm.
                              // Selects Digital as the signaling format.
FGEN:GEN3:ENCODE DIG
SCREEN: GEN
                              // Renews RF Generator Operation Screen.
*WAI
                             // Waits for previous commands to execute.
FGEN:GEN3:MOD:FM
                             // Sets SOURCE 3 Modulation to FM.
FGEN:GEN3:MODL 4
                              // Sets SOURCE 3 Modulation Level to 4 kHz.
                              // Sets POCSAG rate to Low.
GEN:POCSAG:RATE 0
FOR Y=1 TO 5
                              // Starts loop. Y to be looped 5 times.
   GEN: POCSAG: ALPHA: UPPER Y+5130 // Generates an Alpha upper POCSAG
                                  // message using the specified capcode.
   DELAY 3000
                              // Delays 3 seconds (for POCSAG generation).
   *WAI
                              // Wait for the last command to be executed.
NEXT Y
                              // Loops to top of the loop until Y is 5.
```

GENERATING 2805 CODE

The following command sequence generates a 155 MHz signal FM modulated with a 2805 Tone (with frequency reset to 1500 Hz). The modulation level is 4 kHz and the RF Output Level is -60 dBm.

```
SCREEN: GEN
                              // Displays RF Generator Operation Screen.
*WAI
                              // Waits for previous commands to execute.
GEN: FREQ 155 MHZ
                             // Sets RF Generator Frequency to 155 MHz.
GEN:LEV -60 DB
                             // Sets the RF Generator Level to -60.0 dBm.
FGEN: GEN3: ENCODE RCC
                             // Selects RCC as the signaling format.
SCREEN: GEN
                              // Renews RF Generator Operation Screen.
*WAI
                             // Waits for previous commands to execute.
FGEN:GEN3:MOD:FM
                             // Sets SOURCE 3 Modulation to FM.
                             // Sets SOURCE 3 Modulation Level to 4 kHz.
FGEN:GEN3:MODL 4
                             // Sets 2805 Tone Frequency to 1500 Hz.
GEN:DIAL:FREQ 1500
GEN:DIAL 5551234
                              // Generates a 5551234 2805 Tone signal.
```

4-6 RECEIVER

4-6-1 RECEIVER COMMANDS

RECeive:

AGC:

AUTO

Sets Automatic Gain Control to automatic setting.

MANual n

Sets Automatic Gain Control to manual setting and sets level to n. Range of n is 0 to 255.

```
Example: REC:AGC:MAN 130 // Sets AGC setting to Manual and sets // Manual AGC setting to 130.
```

USER:XXX

Sets Automatic Gain Control to User. Select one of the following for xxx: MEASure, SPeech, DATA, HIGH, TYPE1, TYPE2 or TYPE3.

```
Example: REC:AGC:USER:HIGH // Sets AGC setting to User Defined High.
```

CHANnel n

Sets Receive Frequency to cellular channel *n* (1 to 1023) in the format selected using the **REC:CHAN:FORM** command. The Receiver Operation Screen displays selected cellular channel when Receiver is in Channel Mode (**REC:MODE CHAN** command).

CHANnel:

FORMat:

AMPS:

FORward

Selects AMPS Forward channels.

REVerse

Selects AMPS Reverse channels.

ETACS:

FORward

Selects ETACS Forward channels.

REVerse

Selects ETACS Reverse channels.

NAMPS:

FORward

Selects NAMPS Forward channels.

REVerse

Selects NAMPS Reverse channels.

CHANnel:

FORMat:

NT400:

FORward

Selects NT400 Forward channels.

REVerse

Selects NT400 Reverse channels.

FORMat?

Returns channel format setting (AMPS:FORWARD, AMPS:REVERSE, ETACS:FORWARD, ETACS:REVERSE, NAMPS:FORWARD, NAMPS:REVERSE, NT400:FORWARD or NT400:REVERSE).

DCS:

INVert?

Returns the three octal digits in inverted mode, decoded from the Digital Coded Squelch (DCS) code. Returns -1 if none available or if invalid for inverted DCS.

NORMal?

Returns the three octal digits decoded from the DCS code. Returns -1 if none available or if invalid for normal DCS. See 4-6-1F.

STATe b

Enables DCS decoding if b is 1, disables if b is 0. **RECeive:DECode DIGITAL** and **RECeive:DIGITAL DCS** (or **DCSINV**) commands must be initiated prior to enabling DCS decoding. DCS decoding must be disabled after decoding is finished.

```
Example: REC:DEC DIG // Sets Receiver for decoding digital data.

REC:DIG DCS // Prepares Receiver for decoding DCS.

REC:DCS:STAT 1 // Enables DCS decoding.

REC:DCS:NORM? // Returns decoded Normal DCS digits.

REC:DCS:STAT 0 // Disables DCS decoding.
```

DECode type

Sets Receiver for decoding type. The setting for type is DTMF, TONE or DIGital.

DEVRms

Displays Deviation Meter (RMS) reading on Receiver Operation Screen when followed by SCREEN:RECeive command.

DiGital type

Sets digital type. Used with the RECeive: DECode DIGITAL command to prepare the Receiver for decoding. The setting for type is DCS, DCSINV, POCSAG, DSAT or DST.

DISTortion

Displays Distortion Meter reading on Receiver Operation Screen when followed by SCREEN:RECeive command.

DMM

Displays Digital Multimeter reading on Receiver Operation Screen when followed by **SCREEN:RECeive** command.

DSAT:

STATe b

(NAMPS option installed) Enables DSAT Decoding Function if b is 1, disables if b is 0. **RECeive:DECode DIGITAL** and **RECeive:DIGITAL DSAT** commands must be initiated prior to enabling DSAT decoding. DSAT decoding must be disabled after decoding is finished.

DSAT?

(NAMPS option installed) Returns DSAT reading. Returns -1 if none available or invalid for normal transmission.

DST:

STATe b

(NAMPS option installed) Enables DST Decoding Function if b is 1, disables if b is 0. **RECeive:DECode DIGITAL** and **RECeive:DIGITAL DST** commands must be initiated prior to enabling DST decoding. DST decoding must be disabled after decoding is finished.

DST2

(NAMPS option installed) Returns DST reading. Returns -1 if none available or invalid for normal transmission.

DTMF:

STATe b

Enables DTMF Decoding Function if b is 1, disables if b is 0. See 4-6-1D.

DTMF?

Returns string of decoded digits or -1 if nothing decoded.

```
Example: SCREEN:REC // Displays Receiver Operation Screen.

REC:DEC DTMF // Sets Receiver for decoding DTMF signals.

REC:DTMF:STAT 1 // Enables DTMF decoding.

REC:DTMF:STAT 0 // Disables DTMF decoding.
```

FIND:

FREQuency?

Returns frequency of first signal with amplitude larger than Find reference level. Returns 0 if no signal is found.

REFerence n

Sets Find reference level to n dBm (-110 to -5).

REFerence?

Returns Find reference level in dBm (-110 to -5).

FREQuency n [units]

Sets Receiver Frequency. Range of *n* is 250.0 kHz to 999.9999 MHz. Select HZ, KHZ or MHZ for *units*. *units* is optional with a default of KHZ.

FREQuency?

Returns Receiver Frequency in kHz (250.0 to 999999.9).

```
Example: REC:FREQ 100 MHZ // Sets Receiver Frequency to 100 MHz.

REC:FREQ? // Queries the Receiver Frequency.

// Returns 100000 (100000 kHz).
```

INPut:

ANTenna

Selects ANTENNA IN Connector as the Receiver Input Source. Displays Signal Strength Meter reading on the Receiver Operation Screen.

ATTenuation n

Sets Input Attenuation to n dB. Select 0, 20 or 40.

TR

Selects T/R Connector as the Receiver Input Source. Displays Power Meter reading on the Receiver Operation Screen.

MODE type

Selects Receiver Mode (DIRect, CHANnel or SCAN [Frequency Scan]). Channel Mode displays the cellular channel frequency according to **REC:CHAN** commands.

```
Example: REC:INP:TR // Selects TR Connector for Receiver Input.

REC:INP:ATT 20 // Sets Receiver Input Attenuation to 20 dB.

REC:MODE CHAN // Selects Receiver Channel Mode.
```

MODMeter

Displays Modulation Meter reading on the Receiver Operation Screen when followed by a **SCREEN:RECeive** command and AM is selected modulation.

MODulation:

AMn

Selects Amplitude Modulation. Select 1 or 2 for n.

BFO

Selects Beat Frequency Oscillation.

FM_n

Selects Frequency Modulation. Select 1, 2, 3 or 4 for n.

Example: REC:MOD:FM4 // Selects FM4 as Receiver Modulation.

MODulation:

LSB

Selects Lower Sideband Modulation.

PM

Selects Phase Modulation.

USB

Selects Upper Sideband Modulation.

USER:

FILTer f

Sets User Defined Modulation IF Filter to f kHz. Select 3, 30 or 300 for f.

MODulation:type

Selects User Defined Modulation type (FM, AM, USB, LSB, BFO, PM or DATA [FM]).

POST:

APASs

Selects All Pass Post Detection Filter for User Defined Modulation.

BPASs fl.fh

Selects Bandpass Post Detection Filter for the User Defined Modulation. Lower cutoff frequency is set to fl kHz with a range of 0.5 to 20. Higher cutoff frequency is set to fh kHz with a range of 0.1 to 30.

CWEight

Selects C-Weighted Post Detection Filter (C-message noise weighting curve response) for the User Defined Modulation. Refer to MIL-STD-188-200.

HPASs f

Selects High-Pass Post Detection Filter for the User Defined Modulation. Cutoff frequency is set to f kHz with a range of 0.5 to 20.

LPASs f

Selects Low-Pass Post Detection Filter for the User Defined Modulation. Cutoff frequency is set to f kHz with a range of 0.1 to 30.

Example:

```
REC:MOD:USER:FILT 30  // Selects the 30 kHz IF Filter.

REC:MOD:USER:MOD:DATA  // Selects User Defined FM DATA for Receiver  // Modulation.

REC:MOD:USER:POST:BPAS 10,20  // Selects a Bandpass Post Detection  // Filter with 10 kHz lower cutoff and 20 kHz  // higher cutoff frequencies.

REC:MOD?  // Queries the Receiver Modulation. USER is  // returned.
```

MODulation?

Returns Receiver Modulation (FM, AM, USB, LSB, BFO, PM, DATA or USER).

OUTput:

AUDIO b

Routes Demodulated Audio to the AUDIO OUT Connector if b is 1. Disconnects the AUDIO OUT Connector if b is 0.

DEMOD b

Routes Demodulated Audio to the DEMOD OUT Connector if b is 1. Disconnects the DEMOD OUT Connector if b is 0.

SPEAKer b

Routes Demodulated Audio to the Speaker if b is 1. Disconnects Speaker if b is 0.

PMRms

Displays Phase Meter (RMS) reading when followed by a SCREEN:RECeive command.

POCSAG:

CAPcode?

Returns the received capcode or -1 if a capcode is not received.

MESSage?

Returns message from the decoded POCSAG signal or -1 if none available.

RATe !

Sets POCSAG rate to high if b is 1, low if b is 0.

RATe?

Returns 1 if POCSAG rate is high, 0 if rate is low.

TONE 1 BEEP

TONE 4 BEEPS

STATe b

Enables POCSAG decoding if b is 1, disables if b is 0. **RECeive:DECode DIGITAL** and **RECeive:DIGITAL POCSAG** commands must be initiated prior to enabling POCSAG decoding. POCSAG decoding must be disabled after decoding is finished.

NOTE: Do not change screens with POCSAG enabled or Test Set may lock up.

NUMERIC

TONE 2 BEEPS

TYPE?

Returns POCSAG Function Type. One of the following is returned:

NO MESSAGE	
Example: REC:DEC DIG	// Sets Receiver for decoding digital data.
REC:DIG POCSAG	<pre>// Prepares Receiver for decoding POCSAG.</pre>
REC:POCSAG:STAT 1	// Enables POCSAG decoding.
REC: POCSAG: RATE 1	// Selects High rate to decode.
REC: POCSAG: MESS?	<pre>// Queries for the decoded message.</pre>
REC: POCSAG: CAP?	<pre>// Queries for the decoded capcode.</pre>
REC: POCSAG: TYPE?	<pre>// Queries for the decoded message type.</pre>
REC: POCSAG: RATE?	<pre>// Queries for the current rate setting.</pre>
	<pre>// 1 is returned (for High).</pre>
REC:POCSAG:STAT 0	// Disables POCSAG decoding.

TONE 3 BEEPS ALPHANUMERIC

RCL n

Recalls Receiver environment (routings and settings) stored in memory location n. Range of n is 1 to 9.

SCAN:

ABORt

Stops Receiver Scan Function.

CONTinue

Starts or if paused, continues Scan Function.

FREQuency?

Returns frequency currently being scanned in kHz.

INCrement f

Sets Receiver Scan increment to f kHz. Range of f is 0.0 to 999999.9.

PAUSe t

Sets Receiver Pause rate to t sec. Range of t is 0.0 to 99.9. Receiver Scan pause time is length of time Scan Function pauses at frequency with broken squelch. Scan Function stops permanently on squelch broken frequency if pause set to 0.

PAUSe?

Returns 1 if Scan Function is paused, 0 if not paused.

RATe i

Sets Receiver Scan rate to t sec. Range of t is 0.00 to 99.99. Receiver Scan rate is the time each frequency is scanned with squelch unbroken.

STARt f

Sets Receiver Scan starting frequency to f kHz. Range of f is 250.0 to 999999.9.

STOP /

Sets Receiver Scan stopping frequency to fkHz. Range of f is 250.0 to 999999.9.

```
Example: REC:SCAN:STAR 1000
                              // Sets Receiver Scan starting frequency to
                              // 1 MHz
        REC:SCAN:STOP 100000
                              // Sets Receiver Scan stopping frequency to
                              // 100 MHz
        REC:SCAN:INC 250
                              // Sets Receiver Scan increment to 250 kHz.
        REC:SCAN:RAT 1.5
                              // Sets Receiver Scan rate to 1.5 sec.
                              // Sets Receiver Scan pause time to 10 sec.
        REC:SCAN:PAUS 10
        REC:SCAN:CONT
                              // Starts Receiver Scan.
                              // Stops Receiver Scan.
        REC:SCAN:ABOR
```

SINAD

Displays SINAD Meter reading when followed by a SCREEN:RECeive command.

SQUelch n

Sets squelch to n. Range of n is 0.0 to 1.0.

SQUeich?

Returns squelch level (0.0 to 1.0).

```
Example: SQU .3 // Sets Squelch level to 3/10 of total // allowable setting.

SQU? // Queries Squelch level. .3 is returned.
```

STORe n

Stores current Receiver environment (routings and settings) in memory location n. Range of n is 1 to 9.

TONE:

STATe b

Enables Audio Tone decoding if b is 1, disables if b is 0. **RECeive:DECode TONE** command must be initiated prior to enabling Audio Tone decoding. Audio Tone decoding must be disabled after decoding is finished.

TYPE XXX

Selects Audio Tone to be decoded. Choose one of the following for xxx:

CCIR	EEA	EIA
ZVEI	DDZVEI	DZVEI
NATEL	EURO	TONE56
CCIRH	CCIRH4	USER

See 4-6-1E and G.

TONE?

Returns the decoded Audio Tone sequence or -1 if not available.

```
Example: REC:DEC TONE // Sets Receiver for decoding Audio Tones.

REC:TONE:STAT 1 // Enables Audio Tone decoding.

REC:TONE:TYPE CCIR // Selects CCIR as the Audio Tone type.

REC:TONE: // Returns the decoded Audio Tone sequence.

REC:TONE:STAT 0 // Disables Audio Tone decoding.
```

VOLume n

Sets volume to n. Range of n is 0.0 to 1.0.

VOLume?

Returns the volume level (0.0 to 1.0).

VOLume:

AUTO b

Enables Automatic Volume Control if b is 1, disables if b is 0.

AUTO?

Returns Automatic Volume Control state. 1 is returned if enabled, 0 if disabled.

CALibration: FMZ n

Zeros FM Deviation Meter. Displays the Receiver Operation Screen and selects FMn Modulation. Range of n is from 1 to 4.

4-6-2 REMOTE RECEIVER EXAMPLES

A. RECEIVING FM SIGNALS

The following command sequence receives a 96 MHz FM signal through the ANTENNA IN Connector and outputs the audio signal through the Test Set Speaker.

```
*DMC "REC FM", BEGIN
                               // Define a macro named REC FM.
SCREEN: REC
                               // Display the Receiver Operation Screen.
REC: FREO 96000
                               // Set Receiver Frequency to 96 MHz.
REC:MODULATION:FM1
                               // Select FM1 for Receiver Modulation.
REC: INPUT: ANTENNA
                              // Select the ANTENNA IN Connector for
                               // Receiver Input.
REC: INPUT: ATTENUATION 0
                              // Select 0 dB for the Receiver Input
                              // Attenuation Level.
N=1, X=0
                              // Set variables to initial values.
WHILE X=0
                              // Start WHILE loop to loop as long as
                              // squelch is not broken.
   REC:SQU N
                              // Set squelch 0.02 lower than last setting.
  DELAY 25
                              // Allow time for squelch to settle.
  N=N-0.02
                              // Decrement variable N (use to set squelch).
  X=:MEAS:SOU?
                              // Set X to 1 when squelch breaks (see 4-15).
WEND
                              // End of WHILE loop. X loops to the top as
                              // long as X=0 (squelch unbroken).
REC:OUTPUT:SPEAKER 1
                              // Routes Receiver Output to the Test Set
                              // Speaker.
END
                              // End of macro REC FM.
```

B. RECEIVING AM SIGNALS

The following command sequence receives a 1240 kHz AM signal through the ANTENNA IN Connector and outputs the audio signal through the DEMOD OUT Connector.

```
*DMC "REC AM", BEGIN
                               // Define a macro named REC AM.
SCREEN: REC
                              // Display the Receiver Operation Screen.
REC:FREQ 1240
                              // Set Receiver Frequency to 96 MHz.
REC: MODULATION: AM1
                              // Select AM1 for Receiver Modulation.
REC: INPUT: ANTENNA
                              // Select the ANTENNA IN Connector for
                              // Receiver Input.
REC: INPUT: ATTENUATION 0
                              // Select 0 dB for the Receiver Input
                              // Attenuation Level.
N=1, X=0
                              // Set variables initially.
WHILE X=0
                              // Start WHILE loop to loop as long as
                              // squelch is not broken.
   REC:SQU N
                             // Set squelch 0.02 lower than last setting.
   DELAY 25
                             // Allow time for squelch to settle.
   N=N-0.02
                             // Decrement variable N (use to set squelch).
                             // Set X to 1 when squelch breaks (see 4-15).
   X=:MEAS:SQU?
WEND
                             // End of WHILE loop. X loops to the top as
                             // long as X=0 (squelch unbroken).
REC:OUTPUT:DEMOD 1
                             // Route Receiver Output to the DEMOD OUT
                              // Connector.
END
                              // End of macro REC_AM.
```

C. RECEIVING SSB SIGNALS

The following command sequence receives a 14 MHz LSB signal through the T/R Connector and routes the demodulated signal to the AUDIO OUT Connector.

```
*DMC "REC SSB", BEGIN
                              // Define a macro named REC SSB.
                              // Display the Receiver Operation Screen.
SCREEN: REC
                              // Set Receiver Frequency to 14 MHz.
REC:FREO 14000
                              // Select LSB for Receiver Modulation.
REC: MODULATION: LSB
                              // Select the T/R Connector for Receiver
REC: INPUT: TR
                              // Input.
                              // Select 0 dB for the Receiver Input
REC: INPUT: ATTENUATION 0
                              // Attenuation Level.
                              // Set variables initially.
N=1, X=0
                              // Start WHILE loop to loop as long as
WHILE X=0
                              // squelch is not broken.
   REC:SQU N
                              // Set squelch 0.02 lower than last setting.
   DELAY 25
                              // Allow time for squelch to settle.
   N=N-0.02
                              // Decrement N (use to set squelch).
                              // Set X to 1 when squelch breaks (see 4-15).
   X=:MEAS:SQU?
                              // End of WHILE loop. X loops to the top as
                              // long as X=0 (squelch unbroken).
                              // Routes Receiver Output to the AUDIO OUT
REC:OUTPUT:AUDIO 1
                              // Connector.
                               // End of macro REC SSB.
END
```

D. DECODING DTMF CODED SIGNALS

The following command sequence receives a 450 MHz FM modulated DTMF signal and routes the demodulated signal to the AUDIO OUT Connector and the Test Set Speaker.

```
// Define a macro named REC DTMF.
*DMC "REC DTMF", BEGIN
                              // Display Receiver Operation Screen.
SCREEN: REC
                              // Set Receiver Frequency to 450 MHz.
REC:FREQ 450000
REC:MODULATION:FM1
                              // Select FM1 for Receiver Modulation.
REC: INPUT: TR
                              // Select T/R Connector for Receiver Input.
                              // Select 0 dB for Receiver Input
REC: INPUT: ATTENUATION 0
                              // Attenuation Level.
                              // Set variables initially.
N=1, X=0
                              // Start WHILE loop to loop as long as
WHILE X=0
                              // squelch is not broken.
                              // Set squelch 0.02 lower than last setting.
   REC:SQU N
   DELAY 25
                              // Allow time for squelch to settle.
                              // Decrement N (use to set squelch).
   N=N-0.02
                              // Set X to 1 when squelch breaks (see 4-15).
   X=:MEAS:SQU?
                              // End of WHILE loop. X loops to the top as
WEND
                              // long as X=0 (squelch unbroken).
                              // Route the demodulated signal to the
REC:OUTPUT:AUDIO 1
                              // AUDIO OUT Connector.
REC:OUTPUT:SPEAKER 1
                              // Route Receiver Output to the Test Set
                              // Speaker.
                              // Set Receiver for decoding DTMF signals.
REC:DEC DTMF
                              // Enable DTMF decoding.
REC:DTMF:STAT 1
                              // Return DTMF decoded digits.
REC: DTMF?
                              // End of macro REC DTMF.
END
```

E. DECODING CCIR CODED SIGNALS

The following command sequence receives a 450 MHz FM modulated Audio signal and routes the demodulated signal to the AUDIO OUT Connector and the Test Set Speaker.

```
*DMC "REC CCIR", BEGIN
                              // Define a macro named REC CCIR.
SCREEN: REC
                              // Display the Receiver Operation Screen.
REC:FREQ 450000
                              // Set Receiver Frequency to 450 MHz.
REC:MODULATION:FM1
                              // Select FM1 for Receiver Modulation.
REC: INPUT: ANT
                              // Select the ANTENNA IN Connector for the
                              // Receiver Input.
REC: INPUT: ATTENUATION 0
                              // Select 0 dB for the Receiver Input
                              // Attenuation Level.
N=1.X=0
                              // Set variables initially.
WHILE X=0
                              // Start WHILE loop to loop as long as
                              // squelch is not broken.
   REC:SQU N
                              // Set squelch 0.02 lower than last setting.
   DELAY 25
                             // Allow time for squelch to settle.
   N=N-0.02
                             // Decrement N (use to set squelch).
   X=:MEAS:SQU?
                              // Set X to 1 when squelch breaks (see 4-15).
                              // End of WHILE loop. X loops to the top as
WEND
                              // long as X=0 (squelch unbroken).
REC:OUTPUT:AUDIO 1
                             // Routes the demodulated signal to the
                              // AUDIO OUT Connector.
REC:OUTPUT:SPEAKER 1
                              // Routes Receiver Output to the Test Set
                              // Speaker.
REC:TONE:TYPE CCIR
                             // Selects CCIR for the Audio Code Type.
REC:DEC TONE
                             // Sets Receiver for decoding Audio Tones.
                             // Enables Audio decoding.
REC: TONE: STAT 1
                             // Returns the decoded Audio Tone sequence.
REC: TONE?
REC:TONE:STAT 0
                             // Disables Audio decoding.
END
                              // End of macro REC_CCIR.
```

F. DECODING DCS CODED SIGNALS

The following command sequence receives a 450 MHz FM modulated DCS signal and decodes the signal until Soft Function key F1 is pressed. The decoded DCS digits are printed to the Host.

```
*DMC "REC DCS", BEGIN
                              // Define a macro named REC DCS.
                              // Defines variable to hold decoded DCS.
VAR CODE
                              // Displays the Receiver Operation Screen.
SCREEN: REC
                              // Sets Receiver Frequency to 450 MHz.
REC: FREQ 450000
                              // Selects FM1 for Receiver Modulation.
REC:MODULATION:FM1
REC: INPUT: ANT
                              // Selects the ANTENNA IN Connector for the
                              // Receiver Input.
REC: INPUT: ATTENUATION 0
                              // Selects 0 dB for the Receiver Input
                              // Attenuation Level.
                              // Set variables initially.
N=1, X=0
                              // Start WHILE loop to loop as long as
WHILE X=0
                              // squelch is not broken.
                              // Set squelch 0.02 lower than last setting.
   REC:SQU N
                              // Allows time for squelch to settle.
   DELAY 25
   N=N-0.02
                              // Decrement N (used to set squelch).
   X=:MEAS:SQU?
                              // Set X to 1 when squelch breaks (see 4-15).
                              // End of WHILE loop. X loops to the top as
WEND
                              // long as X=0 (squelch unbroken).
                              // Directs all Keyboard Input to TMAC so
KEYPAD: CLAIM
                              // Operation Screen is not changed.
                              // Sets Receiver for decoding digital data.
REC:DEC DIG
                              // Prepares Receiver for decoding DCS.
REC:DIG DCS
                              // Enable DCS decoding.
REC:DCS:STAT 1
WHILE (SYSTEM: KEY? != F1)
                              // Loop until F1 Key is pressed.
  TPAUSE
                              // Allow TMAC to share processor time with
                              // Test Set (see 3-12).
                              // Decode a Normal DCS digits, if received.
  CODE=REC:DCS:NORM?)
                              // If DCS digits are decoded,
  IF (CODE != "-1")
    PPRINT CODE
                              // print them to the Host.
                              // End of IF statement.
  ENDIF
WEND
                              // End of While loop.
                              // Disable DCS decoding.
REC:DCS:STAT 0
                              // Release Keyboard for normal use.
KEYPAD: UNCLAIM
                              // End of macro REC DCS.
END
```

Latin kang ang ing kanggan ing panggan ng palatan kang na panggan ng panggan ng kanggan ng panggan ng panggang

G. DECODING AUDIO USER DEFINED CODED SIGNALS

The following command sequence receives a 450 MHz FM modulated Audio signal, decodes the signal using the RF Generator Audio User Defined Tones and routes the demodulated signal to the AUDIO OUT Connector and the Test Set Speaker.

```
*DMC "REC AUDIO USER"
                               // Define a macro named REC AUDIO USER.
                               // DEFINE THE TONES TO BE DECODED
SCREEN: GEN
                               // Displays RF Generator Operation Screen.
GEN: TONE: TYPE: USER
                               // Selects User Defined for the Audio Code.
                               // Defines 0 Tone at 900 Hz and 150 ms.
GEN:TONE:USER:DEF 0,900,150
GEN:TONE:USER:DEF 1,1100,80
                               // Defines 1 Tone at 1100 Hz and 80 ms.
GEN:TONE:USER:DEF 2,1200,80
                               // Defines 2 Tone at 1200 Hz and 80 ms.
GEN:TONE:USER:DEF 3,1300,80
                               // Defines 3 Tone at 1300 Hz and 80 ms.
GEN:TONE:USER:DEF 4,1400,80
                               // Defines 4 Tone at 1400 Hz and 80 ms.
GEN:TONE:USER:DEF A,0,40
                               // Defines A Tone at 0 Hz and 40 ms.
                               11
                               // DECODE THE DEFINED TONES
                               11
SCREEN: REC
                               // Displays the Receiver Operation Screen.
REC: FREQ 450000
                               // Sets Receiver Frequency to 450 MHz.
REC: MODULATION: FM1
                               // Selects FM1 for Receiver Modulation.
REC: INPUT: ANT
                               // Selects the ANTENNA IN Connector for the
                               // Receiver Input.
REC: INPUT: ATTENUATION 0
                               // Selects 0 dB for the Receiver Input
                               // Attenuation Level.
N=1, X=0
                               // Set variables initially.
WHILE X=0
                               // Start WHILE loop to loop as long as
                               // squelch is not broken.
                               // Set squelch 0.02 lower than last setting.
   REC:SQU N
   DELAY 25
                               // Allows time for squelch to settle.
   N=N-0.02
                               // Decrement variable N (used to set
                               // squelch).
   X=:MEAS:SQU?
                               // Set X to 1 when squelch breaks (see 4-15).
                               // End of WHILE loop. X loops to the top as
WEND
                               // long as X=0 (squelch unbroken).
REC:OUTPUT:AUDIO 1
                               // Routes the demodulated signal to the
                               // AUDIO OUT Connector.
                               // Routes Receiver Output to the Test Set
REC:OUTPUT:SPEAKER 1
                               // Speaker.
REC: TONE: TYPE USER
                               // Selects User Defined for the Audio Code
                               // Type.
REC:DEC TONE
                               // Sets Receiver for decoding Audio Tones.
REC:TONE:STAT 1
                               // Enables Audio decoding.
REC: TONE?
                              // Returns the decoded Audio Tone sequence.
REC:TONE:STAT 0
                               // Disables Audio decoding.
END
                               // End of macro REC AUDIO USER.
```

H. DECODING POCSAG CODED SIGNALS

The following command sequence receives a 450 MHz FM modulated POCSAG signal, decodes the signal and prints the POCSAG messages to the Host until Soft Function Key F1 is pressed.

```
*DMC "REC POCSAG", BEGIN
                              // Define a macro named REC_POCSAG.
STRING CODE
                              // Define a string variable to hold decoded
                              // POCSAG message.
SCREEN: REC
                              // Displays the Receiver Operation Screen.
                              // Sets Receiver Frequency to 450 MHz.
REC:FREQ 450000
REC:MODULATION:FM1
                              // Selects FM1 for the Receiver Modulation.
REC: INPUT: ANT
                              // Selects the ANTENNA IN Connector for the
                              // Receiver Input.
REC: INPUT: ATTENUATION 0
                              // Selects 0 dB for the Receiver Input
                              // Attenuation Level.
                              // Set variables initially.
N=1, X=0
WHILE X=0
                              // Start WHILE loop to loop as long as
                              // squelch is not broken.
                              // Set squelch 0.02 lower than last setting.
   REC:SQU N
                              // Allows time for squelch to settle.
   DELAY 25
   N=N-0.02
                              // Decrement variable N (used to set
                              // squelch).
   X=:MEAS:SQU?
                              // Set X to 1 when squelch breaks (see 4-15).
                              // End of WHILE loop. X loops to the top as
WEND
                              // long as X=0 (squelch unbroken).
REC:OUTPUT:SPEAKER 1
                              // Routes Receiver Output to the Test Set
                              // Speaker.
                              // Sets POCSAG rate to be decoded to High.
REC: POCSAG: RAT 1
                              // Directs all Keyboard Input to TMAC so
KEYPAD:CLAIM
                              // Operation Screen is not changed.
REC:DEC DIG
                              // Sets Receiver for decoding digital data.
                              // Prepares Receiver for decoding POCSAG.
REC:DIG POCSAG
                              // Enable POCSAG decoding.
REC:POCSAG:STAT 1
                              // Loop until F1 Key is pressed.
WHILE (SYSTEM: KEY? != F1)
                               // Allow TMAC to share processor time with
  TPAUSE
                              // Test Set (see 3-12).
  CODE=STR(REC:POCSAG:MESS?) // Decode a POCSAG message, if received.
  IF (CODE != \pi-1\pi)
                              // If a POCSAG message was decoded,
    PPRINT CODE
                              // print message to the Host.
                              // End of IF statement.
  ENDIF
WEND
                              // End of While loop.
                              // Disable POCSAG decoding.
REC:POCSAG:STAT 0
                              // Release Keyboard for normal use.
KEYPAD: UNCLAIM
END
                              // End of macro REC_POCSAG.
```

I. RECEIVER SETUP FOR CELLULAR OPERATION

The following command sequence configures the Receiver Mode for receiving Cellular signals through the ANTENNA IN Connector.

```
SCREEN: REC
                               // Displays the Receiver Operation Screen.
REC:MOD:USER:MOD:DATA
                               // Selects User Defined FM Data for the
                               // Receiver Modulation.
REC:MOD:USER:FILT 30
                               // Selects the 30 kHz IF Filter.
REC:MOD:USER:POST:LPAS 15
                              // Selects Low-Pass Post Detection Filter
                               // with a cutoff frequency of 15 kHz.
REC:AGC:USER:HIGH
                               // Selects User Defined High Speed for the
                              // AGC setting.
REC: INPUT: ANTENNA
                              // Selects the Antenna for Receiver Input.
M DEV:RANG:UPP 10
                              // Sets Deviation Meter Range to 10 kHz.
                              // Sets AF Meter Gate Time to .1 sec (1 Hz).
M AF: RES 1
```

4-7 DUPLEX

4-7-1 DUPLEX GENERAL COMMANDS

DUPlex:

METER:

DISTortion

Displays Distortion Meter on Duplex Operation Screen.

MODMeter

Displays Modulation Meter on Duplex Operation Screen.

OFF

Disables Modulation, Distortion and SINAD Meters.

SINAD

Displays SINAD Meter on Duplex Operation Screen.

SPEAKer:SOURce type

Selects Test Set Speaker Input. Select OFF, FGEN (Function Generator), SINAD (SINAD/BER IN Connector) or EXTMOD (EXT MOD IN Connector) for type. Command takes effect when RF Generator Operation Screen is updated.

STORe n

Stores current Duplex environment (routings and settings) in memory location n. Range of n is 1 to 9.

RCL n

Recalls Duplex environment (routings and settings) stored in memory location n. Range of n is 1 to 9.

4-7-2 DUPLEX TRANSMITTER COMMANDS

DUPlex:

INPut:

AGC:

AUTO

Sets Automatic Gain Control to automatic setting.

MANual n

Sets Automatic Gain Control to manual setting and sets level to n. Range of n is 0 to 255.

USER:XXX

Sets Automatic Gain Control to User setting. Select one of the following for XXX: MEASure, SPeech, DATA, HIGH, TYPE1, TYPE2 or TYPE3.

Example: DUP:INP:AGC:USER:DATA // Sets AGC setting to User Defined Data.

INPut:

ANTenna

Selects ANTENNA IN Connector as Transmitter Input Source. Displays Signal Strength Meter reading on the Duplex Transmitter Operation Screen.

ATTenuation n

Sets Input Attenuation to n dB. Select 0, 20 or 40.

CHANnel n

Sets Duplex Transmitter Frequency to cellular channel n (1 to 1023) in the format selected using the **DUPlex:INPut:CHANnel:FORMat** command. The Duplex Transmitter Operation Screen displays selected cellular channel when Duplex Transmitter is in Channel Mode (**DUPlex:INPut:MODE CHAN** command).

CHANnel:

FORMat:

AMPS:

FORward

Selects AMPS Forward channels.

REVerse

Selects AMPS Reverse channels.

ETACS

FORward

Selects ETACS Forward channels.

REVerse

Selects ETACS Reverse channels.

NAMPS:

FORward

Selects NAMPS Forward channels.

REVerse

Selects NAMPS Reverse channels.

NT400:

FORward

Selects NT400 Forward channels.

REVerse

Selects NT400 Reverse channels.

INPut:

CHANnel:FORMat?

Returns channel format setting (AMPS:FORWARD, AMPS:REVERSE, ETACS:FORWARD, ETACS:REVERSE, NAMPS:FORWARD, NAMPS:REVERSE, NT400:FORWARD or NT400:REVERSE).

FIND:

FREQuency?

Returns frequency of first signal with amplitude larger than the Find reference level.

REFerence n

Sets Find reference level to n dB.

REFerence?

Returns Find reference level in dB.

Example:

FREQuency n [units]

Sets Duplex Transmitter Frequency. Range of n is 250.0 kHz to 999.9999 MHz. Select HZ, KHZ, MHZ for units. units is optional with a default of KHZ.

FREQuency?

Returns RF Generator Frequency in kHz.

```
Example: DUP:INP:FREQ 145 MHZ // Set RF Generator Frequency to 145 MHz.

DUP:INP:FREQ? // Query the RF Generator Frequency.

// 145000 is returned (145000 kHz).
```

METER:

DEVRms

Displays Deviation Meter (RMS) when followed by a SCREEN: DUPlex command.

DISTortion

Displays Distortion Meter when followed by a SCREEN: DUPlex command.

MODMeter

Displays Modulation Meter when followed by a SCREEN: DUPlex command.

PMRms

Displays Phase Meter (RMS) when followed by a SCREEN: DUPlex command.

SINAD

Displays SINAD Meter when followed by a SCREEN: DUPlex command.

INPut:

MODE type

Selects the Duplex Transmitter Mode (DIRect or CHANnel). Channel Mode displays cellular channel frequency according to **DUP:INP:CHAN** commands.

MODulation:

AMn

Selects Amplitude Modulation. Select 1 or 2 for n.

```
Example: DUP:INP:MOD:AM1 // Selects AM1 for Duplex Transmitter // Modulation.
```

BFO

Selects Beat Frequency Oscillation.

FMr

Selects Frequency Modulation. Select 1, 2, 3 or 4 for n.

LSB

Selects Lower Side Band Modulation.

PM

Selects Phase Modulation.

ISR

Selects Upper Side Band Modulation.

USER:

FILTer f

Sets User Defined Modulation IF Filter to f kHz. Select 3, 30 or 300 for f.

MODulation: type

Selects User Defined Modulation. Enter one of the following for *type*: FM, AM, USB, LSB, BFO, PM or DATA (FM DATA).

POST:

APASs

Selects All Pass Post Detection Filter for User Defined Modulation.

BPASs fl.fh

Selects Bandpass Post Detection Filter for User Defined Modulation. Lower cutoff frequency is set to fl kHz with range of 0.5 to 20. Higher cutoff frequency is set to fh kHz with a range of 0.1 to 30.

CWEight

Selects C-Weighted Post Detection Filter (C-message noise weighting curve response) for the User Defined Modulation. Refer to MIL-STD-188-200.

INPut:

MODulation:

USER:

HPASs f

Selects High-Pass Post Detection Filter for User Defined Modulation. Cutoff frequency is set to f kHz with a range of 0.5 to 20.0.

LPASs f

Selects Low-Pass Post Detection Filter for User Defined Modulation. Cutoff frequency is set to f kHz with a range of 0.1 to 30.0.

MODulation?

Returns the current Duplex Transmitter Modulation (FM, AM, USB, LSB, BFO, PM, DATA or USER).

TO:

AUDIO b

Routes demodulated Receiver Input to the AUDIO OUT Connector if b is 1. Disconnects the AUDIO OUT Connector if b is 0.

DEMOD b

Routes demodulated Receiver Input to the DEMOD OUT Connector if b is 1. Disconnects the DEMOD OUT Connector if b is 0.

SPEAKer b

Routes demodulated Receiver Input to the Test Set Speaker if b is 1. Disconnects the Test Set Speaker if b is 0.

TR

Selects T/R Connector as Duplex Transmitter Input Source. Displays Power Meter on the Duplex Transmitter Operation Screen.

VOLume:

AUTO b

Enables Automatic Volume Control if b is 1, disables if b is 0.

AUTO:

Returns Automatic Volume Control state. 1 is returned if enabled, 0 if disabled.

4-7-3 DUPLEX RECEIVER COMMANDS

DUPlex:

OUTput:

AUDio b

Routes AF Generator Output to the AUDIO OUT Connector if b is 1. Disconnects the AUDIO OUT Connector if b is 0.

CHANnel n

Sets Duplex Receiver Frequency to cellular channel n (1 to 1023) in the format selected using the **DUPlex:OUTut:CHANnel:FORMat** command. The Duplex Receiver Operation Screen displays selected cellular channel when Duplex Receiver is in Channel Mode (**DUPlex:OUTput:MODE CHAN** command).

CHANnel:

FORMat:

AMPS:

FORward

Selects AMPS Forward channels.

REVerse

Selects AMPS Reverse channels.

ETACS

FORward

Selects ETACS Forward channels.

REVerse

Selects ETACS Reverse channels.

NAMPS:

FORward

Selects NAMPS Forward channels.

REVerse

Selects NAMPS Reverse channels.

NT400:

FORward

Selects NT400 Forward channels.

REVerse

Selects NT400 Reverse channels.

OUTput:

CHANnel:FORMat?

Returns channel format setting (AMPS:FORWARD, AMPS:REVERSE, ETACS:FORWARD, ETACS:REVERSE, NAMPS:FORWARD, NAMPS:REVERSE, NT400:FORWARD or NT400:REVERSE).

DEMOD b

Routes AF Generator Output to the DEMOD OUT Connector if b is 1. Disconnects the DEMOD OUT Connector if b is 0.

DUPlex

Routes RF Generator Output to the DUPLEX OUT Connector and disconnects the T/R Connector.

FREQuency n [units]

Sets Duplex Receiver Frequency. Range of n is 250.0 kHz to 999.9999 MHz. Select HZ, KHZ, MHZ for units. units is optional with a default of KHZ.

FREQuency?

Returns Duplex Receiver Frequency in kHz.

```
Example: DUP:OUT:FREQ 900 // Set RF Generator Frequency to 900 kHz.

DUP:OUT:FREQ? // Query the RF Generator Frequency.

// 900 is returned (900 kHz).
```

LEVel:

DBm n

Sets RF Level to n dBm. Range of n is 0.0 to -137.0

DBm?

Returns RF Level in dBm.

```
Example:DUP:OUT:LEV:DB -40 // Sets Duplex Receiver Output Level to // -40 dBm.

DUP:OUT:DB? // Queries Duplex Receiver Output Level. // -40 is returned.
```

OUTput:

METER:

NOTE: DUPlex:METER commands were created to avoid meter operation and display conflicts due to measurement signal routings and overlapping applications.

AF

Displays AF Meter on the Duplex Receiver Operation Screen.

DISTortion

Displays Distortion Meter on the Duplex Receiver Operation Screen.

DMM

Displays Digital Multimeter on the Duplex Receiver Operation Screen.

SINAD

Displays SINAD Meter on the Duplex Receiver Operation Screen.

MODE type

Selects the Duplex Receiver Mode (DIRect [Direct Mode] or CHANnel [Channel Mode]). Channel Mode displays cellular channel frequency according to **DUP:OUT:CHAN** commands.

OFFSet f

Sets Offset Frequency to fkHz. Range of f is -999749.9 to 999749.9.

OFFSet?

Returns Offset Frequency in kHz.

TR

Routes Duplex Receiver Output to the T/R Connector and disconnects DUPLEX OUT Connector.

4-7-4 REMOTE DUPLEX EXAMPLES

A. GENERATING AND RECEIVING FM SIGNALS

The following sequence of commands generates a 160 MHz FM modulated signal routed to the DUPLEX OUT Connector and receives a 165 MHz FM modulated signal through the ANTENNA IN Connector:

```
// Displays the Duplex Operation Screen
SCREEN: DUPLEX
                                                                                                                     // Sets 160 MHz Duplex Receiver Frequency.
DUP:OUT:FREQ 160000
                                                                                                       JOE for July 1.

July 1 extended to Computation of the Computation of 
                                                                                                                     // Routes the DUPLEX OUT Connector for
DUP:OUT:DUP
DUP:OUT:LEV:DB -30
FGEN:GEN1:STATE 1
FGEN:GEN1:FREO 2000
FGEN:GEN1:MOD:FM
                                                                                                                   // Sets SOURCE 1 Modulation Level to 5 kHz.
FGEN:GEN1:MODL 5
                                                                                                                   // Sets SOURCE 1 Wave Shape to a sine wave.
FGEN:GEN1:SHAPE:SIN
DUP:INP:FREQ 165000
                                                                                                                    // 165 MHz.
                                                                                                                    // Selects ANTENNA IN Connector for Duplex
DUP: INP: ANT
                                                                                                                    // Transmitter Input.
                                                                                                                    // Sets Duplex Transmitter Input Attenuation
DUP: INP: ATT 0
                                                                                                                   // Level to 0 dB.
DUP: INP: MOD: FM1
                                                                                                                    // Selects FM1 for the Duplex Transmitter
                                                                                                                      // Modulation type.
```

B. GENERATING AND RECEIVING AM SIGNALS

The following sequence of commands generates a 1.4 MHz AM signal (50% modulation) modulated with input from the MIC/ACC IN/OUT Connector and receives a 1 MHz AM modulated signal through the ANTENNA IN Connector:

```
SCREEN: DUPLEX
                                // Displays the Duplex Operation Screen
DUP:OUT:FREQ 140000
                                // Sets 140 MHz Duplex Receiver Frequency.
                                // Selects the DUPLEX OUT Connector for
DUP:OUT:DUP
                                // the Duplex Receiver Output.
                               // Sets Duplex Receiver Output Level to
DUP:OUT:LEV:DB -30
                               // -30 \, dBm.
                               // Activates SOURCE 1 (AF Generator 1).
FGEN:MIC:STATE 1
                               // Sets SOURCE 1 Modulation to AM1.
                              // Sets SOURCE 1 Modulation to 50%.
// Sets SOURCE 1 Modulation Level to 50%.
FGEN:MIC:MOD:AM1
FGEN:MIC:MODL 50
PTT:STATE 1
                               // Sets Duplex Transmitter Frequency to
DUP: INP: FREQ 1 MHZ
                               // 1 MHz.
                               // Selects ANTENNA IN Connector for Duplex
DUP: TNP: ANT
                               // Transmitter Input.
                               // Sets Duplex Transmitter Input Attenuation
DUP: INP: ATT 0
                              // Level to 0 dB.
// Selects AM1 for the Duplex Transmitter
DUP: INP: MOD: AM1
                                // Modulation type.
```

4-8 AF GENERATOR

4-8-1 AF GENERATOR COMMANDS

FGEN:

DATA:

(Data Generator is used for BER Meter tests.)

MODulation:type

Sets Data Generator Modulation to type. Select OFF, AM, FM or PM.

MODulation?

Returns Data Generator Modulation.

MODL n

Sets Data Generator to n Modulation level. Range of n for AM is 0.0 to 100.0 (%), FM is 0.0 to 25.0 (kHz) and PM is 0.0 to 10.0 (radians).

MODL?

Returns Data Modulation level setting.

STATe b

Sets Data Modulation on if b is 1 or off if b is 0.

```
Example: FGEN:DATA:MOD:FM
FGEN:DATA:MODL 4

// Sets Data Generator Modulation to FM.
// Sets Data Generator Modulation Level to
// 4 kHz.

FGEN:DATA:STAT 1
FGEN:DATA:MOD?
FGEN:DATA:MODL?

// Returns Data Generator Modulation (FM).
// Returns Data Generator Modulation Level.
// 4 (kHz) is returned.
```

EXT:

(External modulation is input through EXT MOD IN Connector.)

LEVel n

Sets External Modulation Proportional output level to n%. Range of n is 0 to 100. Sources are adjusted so that proportional output levels of sources combine to equal Function Generator Output Level. Command has no effect if Proportional Mode off.

LEVel?

Returns External Modulation Proportional output level setting in %.

MODL r

Sets External Modulation level to n. Range of n for AM is 0 to 100 (%), FM is 0.0 to 10.0 (kHz) and PM is 0.0 to 10.0 (radians).

MODL?

Returns External Modulation level setting.

MODulation: type

Sets External Modulation to type. Select OFF, AM, FM or PM.

NOTE: Do not set different AF Generators to FM and PM simultaneously because hardware limitations may cause ambiguous readings.

EXT:

MODulation?

Returns External Modulation type (OFF, AM, FM or PM).

STATe b

Sets External Modulation on if b is 1 or off if b is 0.

```
Example: FGEN:EXT:MOD:AM
                              // Sets External (EXT MOD) Modulation Type
                              // to AM.
        FGEN: EXT: MODL 50
                              // Sets External Modulation Level to 50%.
        FGEN: PROP 1
                              // Selects Proportional Mode for the AF
                              // Generator.
                              // Sets External Output Level to 30%.
        FGEN: EXT: LEV 30
        FGEN: EXT: STAT 1
                              // Enables External (EXT MOD) Modulation.
        FGEN: EXT: MOD?
                              // Queries External (EXT MOD) Modulation
                              // Type. AM is returned.
        FGEN: EXT: MODL?
                              // Queries External (EXT MOD) Modulation
                              // Level. 50\% is returned.
                              // Queries External (EXT MOD) Output Level.
        FGEN: EXT: LEV?
                              // 30 is returned.
```

Commands for Generator 1 and Generator 2 are identical and are listed as **FGEN:GEN**x. Parameter x is specified as 1 or 2 when the command is entered.

GENx:

FREQuency f

Sets AF Generator to f Hz. Range of f is 0.0 to 40000.0.

FREQuency?

Returns AF Generator in Hz.

LEVel n

Sets Proportional output level of AF Generator to n%. Range of n is 0 to 100. Sources are adjusted so that proportional output levels of sources combine to equal Function Generator Output Level. Command has no effect if Proportional Mode off.

LEVel?

Returns Proportional output level setting of AF Generator in %.

MODL n

Sets Modulation level to n. Range of n for AM is 0 to 100 (%), FM is 0.0 to 100.0 (kHz) and PM is 0.0 to 10.0 (radians).

MODL?

Returns AF Generator Modulation level setting.

MODulation: type

Sets AF Generator Modulation to type. Select OFF, AM, FM or PM for type.

NOTE: Do not set different AF Generators to FM and PM simultaneously because hardware limitations may cause ambiguous readings.

GENx:

MODulation?

Returns AF Generator Modulation Type.

SHAPE: type

Sets AF Generator wave shape to type. Select from SIN (Sine), SQU (Square Wave), RAMP or TRI (Triangle).

SHAPE:

DC n

Sets wave shape to DC at n level. Select -1, 0 or 1 for n.

PULse: DCYCLe 50

Sets AF Generator wave shape to Pulse with 50% duty cycle.

STATe b

AF Generator is enabled if b is 1, disabled if b is 0.

```
Example:
                                // AF Generator setup as RF Generator
                                // Modulation Source (AF Generator 1 and 2).
        FGEN: GEN1: FREQ 1000
                                // Sets AF Generator 1 frequency to 1000 Hz.
        FGEN: GEN1: MOD: FM
                                // Selects FM for AF Generator 1 Modulation
                                // Type.
        FGEN: GEN1: MODL 5
                                // Sets AF Generator 1 Modulation Level to
                                // 5 kHz.
        FGEN: GEN1: SHAPE: SIN
                                // Selects a sine wave for AF Generator 1
                                // Wave Form.
        FGEN:GEN1:STAT 1
                                // Enables AF Generator 1.
        FGEN:GEN2:FREQ 2500
                               // Sets AF Generator 2 frequency to 2500 Hz.
        FGEN: GEN2: MOD: AM
                                // Selects AM for AF Generator 2 Modulation
                               // Type.
        FGEN: GEN2: MODL 25
                               // Sets AF Generator 2 Modulation Level to
                               // 25%,
        FGEN:GEN2:SHAPE:SIN
                               // Selects a sine wave for AF Generator 2
                               // Wave Form.
        FGEN: GEN2: STAT 1
                               // Enables AF Generator 2.
Example:
                               // AF Generator setup as AF Signal Generator
        FGEN: GEN1: FREQ 1000
                               // Sets AF Generator 1 frequency to 1000 Hz.
        FGEN: OUT: PROP 1
                               // Enables AF Generator Proportional Mode.
        FGEN: GEN1: LEV 50
                               // Sets AF Generator 1 Proportion Level to
                               // 50%.
                               // Selects a sine wave for AF Generator 1
        FGEN: GEN1: SHAPE: SIN
                               // Wave Form.
        FGEN: GEN1: STAT 1
                               // Enables AF Generator 1.
                               // Sets AF Generator 2 frequency to 2500 \rm Hz.
        FGEN: GEN2: FREO 2500
        FGEN:GEN2:LEV 100
                               // Sets AF Generator 2 Proportion Level to
                               // 100%.
        FGEN: GEN2: SHAPE: SIN
                               // Selects a sine wave for AF Generator 2
                               // Wave Form.
                               // Enables AF Generator 2.
        FGEN:GEN2:STAT 1
```

GEN3:

DIGital type

Sets digital type. Used with the **FGEN:ENCode DIGITAl** command to prepare Generator 3 encoding. The setting for type is DCS, DCSINV, POCSAG, DSAT or DST.

ENCode type

Selects a signalling format to encode. Select DTMF, TONE, DIGital or RCC for type. Must be followed with a SETUP:GEN or SCREEN:GEN command.

MODL n

Sets AF Generator 3 Modulation level. Range of n for AM is 0 to 100.0 (%), PM is 0.0 to 10.0 (radians), FM is 0.0 to 100.0 (kHz)-Tone or RCC signalling format, FM is 0.0 to 10.0 (kHz)-DTMF signalling format or FM is 0.0 to 25.0 (kHz)-Digital signalling format.

MODL?

Returns AF Generator 3 Modulation level setting.

MODulation:type

Sets AF Generator 3 Modulation to type. Select OFF, AM, FM or PM.

NOTE: Do not set different AF Generators to FM and PM simultaneously because hardware limitations may cause ambiguous readings.

MODulation?

Returns AF Generator 3 Modulation type.

Example: FGEN:GEN3:MOD:FM // Selects FM for AF Generator 3 Modulation type. FGEN:GEN3:MODL 4 // Sets AF Generator 3 Modulation Level to 4 kHz. FGEN:GEN3:STAT 1 // Enables AF Generator 3.

MIC:

(External audio modulation is input through MIC/ACC Connector.)

LEVel n

Sets Proportional output level of MIC/ACC Connector input to n%. Range of n is 0 to 100. Sources are adjusted so that proportional output levels of sources combine to equal Function Generator Output Level. Command has no effect if Proportional Mode off.

LEVel?

Returns Proportional output level setting for MIC/ACC Connector input.

MODL /

Sets MIC/ACC Connector input Modulation level to n. Range of n for AM is 0 to 100 (%), FM is 0.0 to 25.0 (kHz) and PM is 0.0 to 10.0 (radians).

MODL?

Returns MIC/ACC Connector input Modulation level setting.

MODulation: type

Sets MIC/ACC Connector input Modulation to type. Select OFF, AM, FM or PM.

NOTE: Do not set different AF Generators to FM and PM simultaneously because hardware limitations may cause ambiguous readings.

MIC:

MODulation?

Returns MIC/ACC Connector input Modulation type.

STATe b

Enables external modulation through MIC/ACC Connector if b is 1, disables if b is 0.

PTT:STATe b

Sets the push to talk pin on the MIC/ACC Connector high (keys the mic) if b is 1, sets the push to talk pin low if b is 0.

```
Example:
                              // Sets External (MIC/ACC) Modulation Type
         FGEN:MIC:MOD:AM
                              // to AM.
                              // Sets External (MIC/ACC) Modulation Level
         FGEN:MIC:MODL 25
                              // to 25%.
         FGEN: OUT: PROP 1
                              // Selects Proportional Mode for the AF
                              // Generator.
         FGEN:MIC:LEV 50
                              // Sets External (MIC/ACC) Output Level
                              // to 50%
         FGEN:MIC:STAT 1
                              // Enables External (MIC/ACC) Modulation.
         FGEN: MIC: MOD?
                              // Queries External (MIC/ACC) Modulation
                              // Type. AM is returned.
         FGEN:MIC:MODL?
                              // Queries External (MIC/ACC) Modulation
                              // Level. 25% is returned.
         FGEN:MIC:LEV?
                              // Queries External (MIC/ACC) Output Level.
                              // 50 is returned.
```

FGEN:

OUTput:

AUDIO b

Routes AF Generator Output to the AUDIO OUT Connector if b is 1, disconnects AUDIO OUT Connector from Output if b is 0.

AUDio?

Returns 1 if AF Generator Output is routed to the AUDIO OUT Connector, 0 if AUDIO OUT Connector is disconnected.

DEMOD b

Routes AF Generator Output to DEMOD OUT Connector if b is 1, disconnects DEMOD OUT Connector from Output if b is 0.

DEMOD?

Returns 1 if AF Generator Output is routed to DEMOD OUT Connector, 0 if DEMOD OUT Connector is disconnected.

LEVel v

Sets AF Generator output level to v volts. Range for v is 0.0000 to 3.1000.

OUTput:

LEVel?

Returns AF Generator output level in volts.

SPEAKer b

Routes AF Generator to Speaker if b is 1, disconnects Speaker from Output if b is 0.

SPEAKer?

Returns 1 if AF Generator Output is routed to Speaker, 0 if Speaker is disconnected.

PROPortional b

Selects Proportional mode for AF Generator if b is 1. Takes AF Generator out of Proportional mode if b is 0.

PROPortional?

Returns 1 if AF Generator is in Proportional mode; 0 otherwise.

```
Example: FGEN:GEN1:FREQ 500
                             // Sets AF Generator 1 frequency to 500 Hz.
        FGEN:OUT:PROP 1
                             // Enables Proportional Mode of AF Generator.
        FGEN:GEN1:LEV 100
                             // Sets AF Generator 1 Proportion Level to
                             // 100%.
        FGEN:GEN1:SHAPE:RAMP // Selects ramp for the AF Generator 1
                             // Wave Form.
       FGEN:GEN1:STAT 1
                             // Enables AF Generator 1.
       FGEN:GEN2:FREQ 2000
                             // Sets AF Generator 2 frequency to 2000 Hz.
       FGEN:GEN2:LEV 100
                             // Sets AF Generator 2 Proportion Level to
                             // 100%.
        FGEN: GEN2: SHAPE: SIN
                             // Selects a sine wave for AF Generator 2
                             // Wave Form.
                             // Enables AF Generator 2.
        FGEN:GEN2:STAT 1
        FGEN:OUT:LEV 1.5
                             // Sets AF Generator Output Level to 1.5 V.
        FGEN:OUT:AUDIO 1
                             // Routes AF Generator Output to AUDIO OUT
                             // Connector.
```

RCL n

Recalls AF Generator environment (routings and settings) stored in memory location n. Range of n is 1 to 9.

STORe n

Stores current AF Generator environment (routings and settings) in memory location n. Range of n is 1 to 9.

4-8-2 REMOTE AF GENERATOR EXAMPLES

The following command sequence generates a 1 kHz sine wave, with 1 V level, and routes the Output to the DEMOD OUT Connector:

```
SCREEN: FUNC

// Displays the AF Generator Operation Screen.

FGEN: GEN1: STATE 1

// Enables AF Generator 1.

FGEN: GEN1: FREQ 1000

// Sets AF Generator 1 frequency to 1000 Hz.

FGEN: GEN1: SHAPE: SIN

// Selects a sine wave for the AF Generator 1

// wave form.

FGEN: LEVEL 1

// Sets AF Generator 1 Output Level to 1 V.

FGEN: OUTPUT: DEMOD 1

// Connector.
```

The following command sequence generates the sum of a 1 kHz and 2.5 kHz sine wave in equal proportions and routes this Output to the AUDIO OUT Connector:

```
SCREEN: FUNC
                             // Displays the AF Generator Operation Screen.
FGEN: PROPORTIONAL 1
                             // Selects Proportional Mode for the AF Generator.
FGEN: OUTPUT: LEVEL 1
                             // Sets AF Generator 1 Output Level to 1 V.
FGEN:GEN1:STATE 1
                             // Enables AF Generator 1.
FGEN: GEN1: FREQ 1000
                             // Sets AF Generator 1 frequency to 1000 Hz.
FGEN: GEN1: SHAPE: SIN
                             // Selects a sine wave for the AF Generator 1
                             // wave form.
FGEN:GEN1:LEVEL 100
                             // Sets AF Generator 1 Proportional Level to 100%.
FGEN:GEN2:STATE 1
                             // Enables AF Generator 2.
FGEN:GEN2:FREQ 2500
                             // Sets AF Generator 2 frequency to 2500 Hz.
FGEN: GEN2: SHAPE: SIN
                             // Selects a sine wave for the AF Generator 2
                             // wave form.
GEN:GEN2:LEVEL 100
                             // Sets AF Generator 2 Proportional Level to 100%.
FGEN: OUTPUT: AUDIO 1
                             // Routes AF Generator Output to the AUDIO OUT
                             // Connector.
```

4-9 OSCILLOSCOPE

4-9-1 OSCILLOSCOPE COMMANDS

SCOPe:

ARM

Arms Oscilloscope. Sets Oscilloscope for one sweep. Command ignored unless Trigger is set to One Shot (see SCOPe:TRIGger commands).

AVErage n

Selects Oscilloscope Average Mode using n samples. Range of n is 1 to 100 (default is 100).

COMPare n

Selects Compare Mode for Oscilloscope. Trace stored at n memory location is compared to the current Live Trace. If n is not specified, the lowest numbered memory location with a stored Trace is used.

```
Example: SCOP:COMP 2 // Displays the Trace stored in memory location 2 on // the CRT with the current live Trace. All // Oscilloscope settings affect the live Trace only.
```

COUPling type

Selects type for External coupling. Select AC, DC or GROund.

FULL

Selects a full size Oscilloscope display for the RF Generator, Receiver and Duplex Operation Screens.

HORIZontal n

Sets Horizontal Time Offset to n major divisions. n is an integer from -12 to 12. -12 to -1 are major divisions before the trigger. 1 to 12 are major divisions after the trigger.

INPut:

FILTer:

CWEight:STATe b

Enables Internal C-Weight filter if b is 1, disables if b is 0.

HPASs:

FREQuency f

Sets Internal High-Pass frequency to f kHz. Range of f is 0.2 to 100.

STATe b

Enables Internal High-Pass filter if b is 1, disables if b is 0.

LPASs:

FREQuency f

Sets Internal Low-Pass frequency to fkHz. Range of f is 0.2 to 50.

STATe b

Enables Internal Low-Pass filter if b is 1, disables if b is 0.

INPut:

FILTer:

NOTch:

FREQuency f

Sets Notch center frequency to fkHz. Range of f is 0.5 to 1.5.

STATE h

Enables Internal Notch Filter if b is 1, disables if b is 0.

Example:

```
SCOP:INP:FILT:NOT:FREQ 1.5 // Sets Oscilloscope Input Notch Filter // center frequency to 1.5 kHz. SCOP:INP:FILT:NOT:STAT 1 // Enables Internal Notch Filter.
```

INTernal type

Selects type as Internal Oscilloscope Input. Select from:

```
IF (Rcvr IF) DEMOD (Demod Audio) POWer (RF Pwr LvI)
SINAD (SINAD/BER) FUNCtion (Func Gen) XAUDIO (Ext Mod)
```

LEVel n

Sets Trigger level to n. Range of n is 0 to 255 with 0 corresponding to the bottom of the Oscilloscope Display and 255 corresponding to the top.

LIVe b

Selects Live Trace Mode for the Oscilloscope. If b is 1, a SCREEN:SCOPE command is performed. If b is 0, no SCREEN:SCOPE command is performed. Default of optional b is 1.

MARKer:

AOFF

Disables both Markers.

DELTA:

AMPLitude?

Returns voltage difference of the Trace Marker 1 and Trace Marker 2 crossings in volts. Valid only for Oscilloscope Inputs AC, DC and GND.

POINt?

Returns the difference of Marker positions in graticules with 100 graticules equal to the Oscilloscope display width.

TIME?

Returns the difference of the two Marker positions in ms.

TRACK b

Enables Marker Tracking if b is 1, disables Marker Tracking if b is 0. Tracking feature keeps Markers a constant distance apart.

Commands for Marker 1 and Marker 2 are identical and are listed as SCOPe:MARKER x commands. Parameter x is specified as 1 or 2 when the command is entered.

SCOPe:

MARKERx:

AMPLitude?

Returns voltage of live Trace at Marker x crossing in volts. Valid only for Oscilloscope Inputs AC, DC and GND.

POINt n

Sets Marker x position to n graticules. Range of n is 1 to 100 with 100 graticules equal to Oscilloscope display width.

POINt?

Returns Marker x position in graticules.

STATe b

Enables Marker x if b is 1, disables Marker x if b is 0.

NOTE: Both Markers are displayed when one or both are active.

STATe?

Returns 1 if Marker x is active, 0 if Marker x is not active.

TIME?

Returns Marker x position in ms from left edge of Oscilloscope display.

```
Example: SCOP:MARKER1:STAT 1
                             // Enables Marker 1.
        SCOP:MARKER2:STAT 1
                             // Enables Marker 2.
        SCOP:MARKER1:POIN 20 // Positions Marker 1 two major divisions
                             // from left edge of CRT.
        SCOP:MARKER2:POIN 40 // Positions Marker 2 four major divisions
                             // from left edge of CRT.
        SCOP:MARK:TRACK 1
                             // Enables Marker Tracking.
        SCOP:MARKER1:POIN 30 // Positions Marker 1 three divisions from
                              // left edge of CRT (and Marker 2 five
                              // divisions from left edge of CRT).
        SCOP:MARK:DELTA:AMPL? // Queries amplitude difference of Trace
                              // Marker crossings in volts.
        SCOP:MARK:DELTA:POIN? // Queries position difference of markers
                              // in graticules.
        SCOP:MARK:DELTA:TIME? // Queries position difference of markers
                              // in ms.
        SCOP:MARK:TRACK 0
                             // Disables Marker Tracking.
        SCOP:MARKER2:AMPL?
                             // Queries the amplitude of the Trace at
                              // Marker 2 position.
                             // Queries Marker 2 position in graticules.
        SCOP: MARKER2: POIN?
                             // 50 is returned.
                             // Queries Marker 2 position in ms.
        SCOP:MARKER2:TIME?
        SCOP:MARK:AOFF
                             // Disables both Markers.
```

QTR

Selects a 1/4 size Oscilloscope display for the RF Generator, Receiver and Duplex Operation Screens.

RCL n

Recalls Oscilloscope Trace and environment (routings and settings) stored in memory location n. Range of n is 1 to 9.

NOTE: Recalled Trace reflects the stored Trace parameters. Changing current settings does not alter the recalled Trace.

```
Example: SCOP:RCL 4 // Recalls Oscilloscope trace and environment // stored in memory location 4.

SCOP:SCAL 500 // Change current scale to 500 mV/div.

// Recalled Trace does not change position.
```

SCALe n

Sets Oscilloscope scale to n mV/div for AC, DC or GND Input. Select from:

1	2	5
10	20	50
100	200	500
1000	2000	5000
10000	20000	50000
100000		

Sets Oscilloscope scale to n kHz/div for Demod Audio Input with FM. Select from:

2 20	4	10
20		

Sets Oscilloscope scale to n mV/div for Func Gen or Ext Mod Input. Select from:

500	1000	2500
~~~		

SCALe?

Returns Oscilloscope scale in mV/div if input is AC, DC, GND, SINAD/BER, Func Gen or Ext Mod. Returns Oscilloscope scale in kHz/div if input is Demod Audio. Returns Oscilloscope scale in W if input is RF Pwr LvI.

SOURce EXTernal

Routes Oscilloscope Input from the SCOPE IN Connector.

SOURce INTernal

Disconnects SCOPE IN Connector and selects Internal Oscilloscope Input.

STATe b

Displays an Oscilloscope display in the RF Generator, Receiver and Duplex Operation Screens if b is 1. Oscilloscope display is not displayed if b is 0.

STORe n

Stores current Oscilloscope Trace and environment (routings and settings) in memory location n. Range of n is 1 to 9.

SWEep t

Sets Oscilloscope sweep rate to $t \mu s/div$. Select from:

1	2	5
10	20	50
100	200	500
1000	2000	5000
10000	20000	50000
100000		

SWEep?

Returns Oscilloscope sweep rate in µs/div.

```
Example: SCOP:INT FUNC // Selects AF Generator as the Oscilloscope // Input.

SCOP:LIV // Selects Live for Oscilloscope Mode.

SCOP:TRIG:AUTO // Selects Auto for Oscilloscope Trigger // Mode.
```

For the following SCOPe:TRACE commands, the Oscilloscope display is divided into 400 positions horizontally (0 signifying the left edge of the display, 399 signifying the right edge of the display) and 255 values vertically (0 signifying the bottom of the display, 255 signifying the top of the display):

TRACE:

DATA n.offset.value.value....,value

Replaces points of a stored Trace *n* with specified *values* starting after *offset*. Optional *Offset* is given in number of positions from the left edge of the display with a default of 0. Range of *n* is 1 to 9. Multiple *values* are separated by commas. Only one *value* can be displayed for each horizontal position of the Trace. Intended for remote GPIB or RS-232 use only.

DATA? n, offset, points

Sends the specified number of data points of Trace n to the Host. Trace n can be the live Trace or a Trace stored in memory. The affected points start after the optional offset with an offset default of 0. Range of offset is 0 to 399. Range of n is 0 to 9 with 0 signifying the Live Trace. Range of the number of points is 1 to 400 with a default of 400. Intended for remote GPIB or RS-232 use only.

GET name, n

Assigns values of trace n (in graticules) to a declared array. Parameter name is the name of the declared array. Range of n is 0 to 9, 0 signifying the live trace and 1 to 9 signifying stored traces. If array is less than 400 values in length (stored trace length), the array values are assigned for the length of the array, leaving the rest of the stored trace intact.

GET? n,offset

Returns value of a point in Trace n located the *offset* number of positions from the left edge of the Display. Trace n can be the live Trace or a Trace stored in memory. Range of n is 0 to 9 with 0 signifying the Live Trace. Range of *offset* is 0 to 399.

TRACE:

MAX? n, offset, points

Returns the maximum point of Trace n within the specified number of *points* starting after the given *offset*. Result is returned in x,y format with x being the number of positions from the left edge and y being the number of values from the bottom. Trace n can be the live Trace or a Trace stored in memory. Range of n is 0 to 9 with 0 signifying the Live Trace. Range of the optional *offset* is 0 to 399 with a default of 0. Range of optional number of *points* is 1 to 400 with a default of 400. Intended for remote GPIB or RS-232 use only.

MIN? n, offset, points

Returns the minimum point of Trace n within the specified number of *points* starting after the given *offset*. Result is returned in x,y format with x being the number of positions from the left edge and y being the number of values from the bottom. Trace n can be the Live Trace or a Trace stored in memory. Range of n is 0 to 9 with 0 signifying the Live Trace. Range of the optional *offset* is 0 to 399 with a default of 0. Range of optional number of *points* is 1 to 400 with a default of 400. Intended for remote GPIB or RS-232 use only.

PUT name, n

Assigns values of an array to trace n (in graticules). Parameter name is the array name. Range of n is 1 to 9, signifying stored traces. If array is less than 400 values in length (stored trace length), the array values are assigned for the length of the array, leaving the rest of the stored trace intact.

```
Example: SCOP:TRACE:DATA 3,40,128
                                      // Changes a single Trace value,
                                      // located one division from the
                                      // left edge, to the midway point
                                      // (on the axis).
        SCOP:TRACE:GET? 0,200
                                      // Queries the value of the live
                                      // Trace at the point 200 (center
                                      // of oscilloscope display).
        SCOP:TRACE:DATA? 3,200,200
                                      // Returns the Trace values of the
                                      // right half of the Trace stored
                                      // in memory location 3.
        SCOP:TRACE:MAX? 0,200
                                      // Queries the maximum Trace value
                                      // of the left half of the live
                                      // Trace.
        SCOP:TRACE:MIN? 0,40,80
                                      // Queries the minimum Trace value
                                      // of the live Trace for the second
                                      // and third divisions.
```

TRIGger:

AUTO

Sets Trigger to Auto Sweep.

IMMediate

Triggers Oscilloscope as soon as command is interpreted or sequenced in a macro.

NORM

Sets Trigger to Normal Sweep.

ONE

Sets Trigger to One Shot. Causes oscilloscope to sweep once when trigger is received and after setting arm function (SCOPe:ARM command).

SOURce type

Selects source to trigger on. Select EXTernal (for external trigger, AC or DC Input only), INTernal (for internal trigger, AC or DC Input only) or BUS (triggered by *TRG or IEEE-488.1 GET [Get Execute Trigger] command).

VERTical n

Sets Vertical Offset voltage to n graticules. Range of n is 0 to 255. Setting is not linear. For AC, DC or GND, middle setting is approximately 150 to 170. For other inputs, middle setting is approximately 160 to 180.

4-9-2 REMOTE OSCILLOSCOPE EXAMPLES

The following example is a macro that centers a trace in the middle of the CRT display. If the trace centered has AC, DC or GND Input, GND Input should be selected before executing this macro. If the trace centered has other Input, RF Pwr LvI Input should be selected before executing this macro. The Oscilloscope Operation Screen must be displayed for this macro to operate.

```
*DMC "Center", BEGIN
                             // Defines macro names Center.
                             // Declares variables needed.
VAR HOLD, CENTER LINE, X
CENTER LINE = 0
                             // Initializes Center line variable.
FOR X = 0 TO 255
                             // Loops for every possible vertical trace
                             // position.
  SCOPE: VERT X
                             // Moves trace to vertical position x.
  DELAY 50
                             // Pause allows SCOPE: VERT command to finish.
  HOLD = SCOP:TRACE:GET? 0,200
                                          // Trace's actual vertical
                                          // position is stored in HOLD.
  IF (HOLD >= (128-3)) AND (HOLD <= (128+3)) // If HOLD is close to center
                                          // of CRT display,
    CENTER LINE = X
                                          // store x value into
                                          // CENTER LINE.
  ENDIF
                             // End of IF statement.
NEXT X
                             // End of FOR loop.
                             // Trace is moved to point previously found
SCOPE: VERT CENTER LINE
                             // that centers trace.
END
                             // End of macro Center.
```

The following example is a macro that finds the maximum of the live trace starting from a given offset. Range of the offset is 0 to 400. This macro returns the horizontal position of the maximum point. If there are multiple maximum points, the first one is returned. With the **RETURN** command included, this macro is executed as a function (ex. X = FINDMAX 0).

```
*DMC "FINDMAX", BEGIN
                             // Define macro named FINDMAX
VAR NEW, OLD=0, OLD X=0
                             // Declare and initialize variables: NEW hold
                             // latest amplitude reading, OLD holds
                             // highest amplitude reading yet found and
                             // OLD X holds position of OLD.
FOR X=$1 TO 400
                             // Loop from offset given to end of CRT.
 NEW=SCOPE:TRACE:GET? 0,X
                             // Read 1 point and store in NEW.
  IF NEW > OLD+3
                             // If current amplitude is greater than last
   OLD = NEW
                             // store new max into old max and,
                             // store new max location into old max
   OTD X = X
                             // location.
  ENDIF
                            // End of IF statement.
NEXT X
                            // End of looping.
RETURN OLD X
                            // Return location of maximum value found.
                             // End of FINDMAX macro.
END
```

The following command sequence compares a stored Trace (1 kHz sine wave) with a live Trace (2 kHz square wave). This example assumes the previous macro "Center" already resides in Test Set memory.

```
// AF Generator is setup to create first
                             // signal.
                             // Sets AF Generator Output Level to 1 V.
FGEN:OUTPUT:LEVEL 1
                            // Enables AF Generator 1.
FGEN:GEN1:STATE 1
                            // Sets AF Generator 1 frequency to 1000 Hz.
FGEN: GEN1: FREQ 1000
                            // Selects a sine wave for AF Generator 1
FGEN:GEN1:SHAPE:SIN
                             // Wave Form.
                             // Oscilloscope parameters are set and first
                             // Trace is stored.
                             // Displays Oscilloscope Operation Screen.
SCREEN: SCOPE
SCOPE: SOURCE INTERNAL
                             // Sets Oscilloscope to be triggered
                             // internally.
                             // Selects Normal as Oscilloscope Trigger
SCOPE: TRIGGER: NORM
                             // Mode.
                             // Sets Trigger Level to the midpoint.
                             // Sets Oscilloscope Mode to live.
SCOPE:LIVE
                             // Sets Oscilloscope Input to RF Pwr Lvl.
SCOPE: INTERNAL POWER
                             // Executes macro Center which centers trace
Center
                             // on CRT (see example above).
SCOPE: INTERNAL FUNC
                             // Selects AF Generator as Oscilloscope
                             // Input.
                            // Sets Scale to 1 volt/div.
SCOPE:SCALE 1000
                            // Sets Sweep rate to 200 \muV/div.
SCOPE:SWEEP 200
                             // Stores Trace in memory location 1.
SCOPE:STORE 1
                             // Second signal is created.
                             // Changes AF Generator 1 frequency to 2 kHz.
FGEN:GEN1:FREQ 2000
                             // Changes AF Generator 1 Wave Shape to a
FGEN:GEN1:SHAPE:SQU
                             // square wave.
                             // The first and second signals are
                             // compared.
                             // Selects Compare mode for Oscilloscope.
SCOPE: COMPARE 1
                             // Trace stored in memory location 1 is
                             // displayed on the Oscilloscope display
                             // with the current live Trace.
```

The following command sequence displays the sum of a 1 kHz and 2.5 kHz sine wave on the Oscilloscope display and returns the period of the signals. This example assumes the macro FINDMAX (see second example) is already loaded into Test Set memory.

```
// Setup AF Generator 1 and 2 to generate
                                      // the signal to be measured.
FGEN: PROPORTIONAL 1
                                      // Enable AF Generator Proportional Mode.
FGEN: OUTPUT: LEVEL 1
                                      // Set AF Generator Output Level to 1 V.
FGEN:GEN1:STATE 1
                                      // Enable AF Generator 1.
                                      // Set AF Generator 1 Frequency to 1000 Hz.
FGEN: GEN1: FREQ 1000
FGEN:GEN1:SHAPE:SIN
                                     // Select a sine wave for the AF
                                     // Generator 1 Wave Form.
FGEN: GEN1: LEVEL 100
                                      // Set AF Generator 1 Proportional Level
                                      // to 100%.
                                      // Enable AF Generator 2.
FGEN: GEN2: STATE 1
FGEN:GEN2:FREQ 2500
                                      // Set AF Generator 2 Frequency to 2500 Hz.
FGEN: GEN2: SHAPE: SIN
                                      // Select a sine wave for the AF
                                      // Generator 1 Wave Form.
                                      // Set AF Generator 2 Proportional Level
FGEN: GEN2: LEVEL 100
                                      // to 100%.
                                      // MEAS_PER macro measures the period of
                                      // the AF Generator signal.
*DMC "MEAS PER", BEGIN
                                      // Define macro named MEAS PER.
VAR MAX1, MAX2
                                      // Declare variables: MAX1 holds location
                                      // of first maximum, MAX2 holds location
                                      // of second maximum.
                                     // Display the Oscilloscope Screen.
SCREEN: SCOPE
SCOPE: SOURCE INTERNAL
                                     // Select Internal Oscilloscope Input.
SCOPE: INTERNAL FUNC
                                     // Select the AF Generator as the
                                     // Oscilloscope Input.
SCOPE:LIVE
                                     // Select Live Mode for the Oscilloscope.
SCOPE:SCALE 500
                                     // Set Oscilloscope Scale to 0.5 V/dív.
SCOPE:SWEEP 500
                                      // Set Oscilloscope Sweep Rate to
                                      // 500 µs/div.
SCOPE: TRIGGER: ONE
                                     // Select One Shot Trigger Mode.
                                     // trace still.
                                     // Allow time to set for arming function.
DELAY 600
SCOPE: ARM
                                     // Display and hold trace when triggered.
MAX1 = FINDMAX 0
                                     // MAX! is set to first maximum using
                                     // macro of second example.
MAX2 = FINDMAX (MAX1+5)
                                     // MAX2 is set to second maximum using
                                     // macro of second example.
SCOPE:MARKER1:STATE 1
                                     // Enables Marker 1.
SCOPE:MARKER1:POINT FLOOR (MAX1/4)
                                     // Position Marker 1 on the first maximum.
SCOPE: MARKER2: STATE 1
                                     // Enables Marker 2.
SCOPE: MARKER2: POINT FLOOR (MAX2/4)
                                      // Positions Marker 2 on the second
                                     // maximum.
T=SCOPE:MARKER:DELTA:TIME?
                                     // Query the difference in Marker
                                     // positions in ms.
PPRINT "PERIOD IS ",1000/T
                                     // Figure and print period to Host.
END
                                     // End macro MEAS PER.
```

4-10 SPECTRUM ANALYZER

4-10-1 SPECTRUM ANALYZER COMMANDS

ANLZ:

AVErage n

Selects Average Mode for Analyzer using n samples. Range of n is 1 to 100. Default is 100.

CHANnel n

Sets RF Frequency to cellular channel *n* (1 to 1023) in the format selected using the **ANLZ:CHANnel:FORMat** command. The Spectrum Analyzer Operation Screen displays selected cellular channel when Analyzer is in Channel Mode (**ANLZ:MODE CHAN** command).

CHANnel:

FORMat:

AMPS:

FORward

Selects AMPS Forward channels.

REVerse

Selects AMPS Reverse channels.

ETACS:

FORward

Selects ETACS Forward channels.

REVerse

Selects ETACS Reverse channels.

NAMPS:

FORward

Selects NAMPS Forward channels.

REVerse

Selects NAMPS Reverse channels.

NT400:

FORward

Selects NT400 Forward channels.

REVerse

Selects NT400 Reverse channels.

FORMat?

Returns channel format setting (AMPS:FORWARD, AMPS:REVERSE, ETACS:FORWARD, ETACS:REVERSE, NAMPS:FORWARD, NAMPS:REVERSE, NT400:FORWARD or NT400:REVERSE).

COMPare n

Selects Compare Mode for Analyzer. Trace stored at n memory location is compared with Live Trace.

```
Example: ANLZ:COMP 1 // Selects Compare mode for Analyzer. // Trace stored in memory location 1 is // displayed on the Analyzer display // with the current live Trace.
```

FIND:

FREQuency?

Returns frequency of first signal with amplitude larger than Find reference level. Returns 0 if no signal is found.

REFerence n

Sets Find reference level to n dB.

REFerence?

Returns Find reference level in dB.

FREQuency f

Sets Analyzer Frequency to fkHz. Range for f is 250.0 to 999999.9.

FREQuency?

Returns Analyzer Frequency in kHz.

```
Example: ANLZ:FREQ 135 MHZ // Set Analyzer Frequency to 135 MHz.

ANLZ:FREQ? // Query the Analyzer Frequency.

// 135000 is returned (135000 kHz).
```

FULL

Selects a full size Analyzer display for the RF Generator, Receiver and Duplex Operation Screens.

INPut:

ANTenna

Selects ANTENNA IN Connector for the Analyzer Input.

ATTenuation n

Sets Analyzer Input Attenuation to n dB. Select 0, 20 or 40.

ATTenuation?

Returns Analyzer Input attenuation in dB.

TR

Selects T/R Connector for the Analyzer Input.

INPut?

Returns Analyzer Input setting.

```
Example: ANLZ:INP:TR // Selects T/R Connector for Analyzer Input.

ANLZ:INP:ATT 20 // Sets Analyzer Input Attenuation to 20 dB.

ANLZ:INP? // Queries Analyzer Input Connector. TR is

// returned.

ANLZ:INP:ATT? // Queries Analyzer Input Attenuation.

// 20 is returned.
```

LIVe

Selects Live Trace mode for the Spectrum Analyzer.

MARKer:

AOFF

Disables both Markers.

DELTA:

AMPLitude?

Returns amplitude difference between the Trace Marker 1 and Trace Marker 2 crossings in dB.

FREQuency?

Returns the difference between the two Marker positions in MHz.

POINt?

Returns the difference between the Marker positions in graticules with 100 graticules equal to the Analyzer display width.

TRACK b

Enables Marker Tracking Feature if b is 1, disables Marker Tracking Feature if b is 0. Tracking feature keeps Markers a constant distance apart.

Commands for Marker 1 and Marker 2 are identical and are listed as **ANLZ:MARKER***x* commands. Parameter *x* is specified as 1 or 2 when the command is entered.

MARKERx:

AMPLitude?

Returns amplitude of the Trace at the Marker x crossing. Range and units depend on the current scale settings (ANLZ:SCALe commands).

FREQuency?

Returns Marker x position in kHz (250 to 999999.9).

POINt /

Sets Marker x position to n graticules. Range of n is 1 to 100 with 100 graticules equal to the Analyzer display width.

POINt?

Returns Marker x position in graticules.

MARKER:

STATe b

Enables Marker x if b is 1, disables Marker x if b is 0.

```
Example: ANLZ:MARKER1:STAT 1
                              // Enables Marker 1.
        ANLZ:MARKER2:STAT 2
                              // Enables Marker 2.
        ANLZ:MARKER1:POIN 10 // Positions Marker 1 one divisions from the
                              // left edge of the CRT.
        ANLZ:MARKER2:POIN 30
                              // Positions Marker 2 three divisions from
                              // the left edge of the CRT.
        ANLZ:MARK:TRACK
                              // Enables Marker Tracking.
        ANLZ:MARKER1:POIN 60
                             // Positions Marker 1 six divisions from
                              // the left edge of the CRT (and Marker 2
                              // eight divisions from the left edge of
                              // the CRT).
        ANLZ:MARK:DELTA:AMPL? // Queries amplitude difference of Trace
                              // Marker crossings in volts.
        ANLZ:MARK:DELTA:POIN? // Queries position difference of markers in
                              // graticules.
        ANLZ:MARK:DELTA:FREQ? // Queries position difference of markers
                              // in kHz.
        ANLZ:MARK:TRACK 1
                              // Disables Marker Tracking.
        ANLZ:MARKER2:AMPL?
                              // Queries the amplitude of the Trace at the
                              // Marker 2 position.
        ANLZ:MARKER2:POIN?
                              // Queries Marker 2 position in graticules.
                              // 80 is returned.
        ANLZ:MARKER2:FREQ?
                              // Queries Marker 2 position in kHz.
        ANLZ:MARK:AOFF
                              // Disables both Markers.
```

MODE type

Selects Analyzer RF Mode (DIRect [Direct Mode] or CHANnel [Channel Mode]). Channel Mode displays cellular channel frequency according to ANLZ:CHANnel commands.

NORMalize

Normalizes the Analyzer Trace to match the RF Generator Output.

PEAK

Selects Peak Hold Feature for the Analyzer.

QTF

Selects a 1/4 size Analyzer display for the RF Generator, Receiver and Duplex Operation Screens.

RCL n

Recalls Analyzer Trace and parameters stored in memory location n. Range of n is 1 to 9.

RI.EVel?

Returns offset value, in dB, used in 2 dB/div scale.

SCALe n

Sets Analyzer Units/Division Factor to n dB. Select 2 or 10.

SCALe:

UNIT:type

Sets Analyzer Scale Units to type. For T/R Analyzer Input, select DBM (dBm) or DBW (dBW). For ANTENNA Analyzer Input, select:

DBM (dBm)

DBMV (dBmV)

DBUV (dBuV)

DBV (dBV)

DBUW (dBµW)

If DBW is selected, the T/R Connector is selected for the Analyzer Input. If DBV, DBMV, DBUV or DBUW is selected, the ANTENNA IN Connector is selected for the Analyzer Input.

UNIT?

Returns Analyzer Scale Units.

SCALe?

Returns Analyzer Scale in dB.

SCAN n

Sets Analyzer Scan Width to n kHz. Select 0 for zero scan or one of the following:

1	2
10	20
100	200
1000	2000
10000	20000
100000	

SCAN?

Returns Analyzer Scan Width in kHz.

STATE b

Displays Analyzer display in the RF Generator, Receiver and Duplex Operation Screens if b is 1. Analyzer display is not displayed if b is 0.

STORe n

Stores the current Analyzer Trace and environment (routings and settings) in memory location n. Range of n is 1 to 9.

TOP?

Returns the top of screen value in current units. Spectrum Analyzer Operation Screen must be displayed.

```
Example:
        ANLZ:SCAL 2
                              // Selects 2 dB/div for Analyzer
                              // Units/Division Factor.
                              // Sets Analyzer Scan Width to 100 kHz.
         ANLZ:SCAN 100
                              // Selects dBm for Analyzer Scale Units.
         ANLZ:SCAL:UNIT:DBM
                              // Queries the amplitude value for the top
         ANLZ:TOP?
                              // of the Analyzer display (in the current
                              // units).
                              // Queries Analyzer Scan Width in kHz. 100
         ANLZ:SCAN?
                              // is returned.
                              // Queries Analyzer Scale Units.
         ANLZ:SCAL:UNIT?
```

For the following ANLZ:TRACE commands, the Analyzer display is divided into 400 positions horizontally (0 signifying the left edge of the display, 399 signifying the right edge of the display) and 255 values vertically (0 signifying the bottom of the display, 255 signifying the top of the display):

TRACE:

DATA n, offset, value, value, ..., value

Replaces points of a stored Trace *n* with specified *values* starting after *offset*. Optional *Offset* is given in number of positions from the left edge of the display with a default of 0. Range of *n* is 1 to 9. Multiple *values* are separated by commas. Only one *value* can be displayed for each horizontal position of the Trace. Intended for remote GPIB or RS-232 use only.

DATA? n, offset, points

Sends the specified number of data points of Trace n to the Host. Trace n can be the live Trace or a Trace stored in memory. The affected points start after the optional offset with an offset default of 0. Range of offset is 0 to 399. Range of n is 0 to 9 with 0 signifying the Live Trace. Range of the number of points is 1 to 400 with a default of 400. Intended for remote GPIB or RS-232 use only.

GET name, n

Assigns values of trace n (in graticules) to a declared array. Parameter name is the name of the declared array. Range of n is 0 to 9, 0 signifying the live trace and 1 to 9 signifying stored traces. If array is less than 400 values in length (stored trace length), the array values are assigned for the length of the array, leaving the rest of the stored trace intact.

GET? n, offset

Returns value of a point in Trace n located the *offset* number of positions from the left edge of the Display. Trace n can be the live Trace or a Trace stored in memory. Range of n is 0 to 9 with 0 signifying the Live Trace. Range of the *offset* is 0 to 399.

MAX? n, offset, points

Returns the maximum point of Trace n within the specified number of *points* starting after the given *offset*. Result is returned in x,y format with x being the number of positions from the left edge and y being the number of values from the bottom. Trace n can be the live Trace or a Trace stored in memory. Range of n is 0 to 9 with 0 signifying the Live Trace. Range of the optional *offset* is 0 to 399 with a default of 0. Range of optional number of *points* is 1 to 400 with a default of 400. Intended for remote GPIB or RS-232 use only.

ANLZ:

TRACE:

MIN? n.offset.points

Returns the minimum point of Trace *n* within the specified number of *points* starting after the given *offset*. Result is returned in x,y format with x being the number of positions from the left edge and y being the number of values from the bottom. Trace *n* can be the live Trace or a Trace stored in memory. Range of *n* is 0 to 9 with 0 signifying the Live Trace. Range of the optional *offset* is 0 to 399 with a default of 0. Range of optional number of *points* is 1 to 400 with a default of 400 Intended for remote GPIB and RS-232 use only.

PUT name.n

Assigns values of an array to trace n (in graticules). Parameter name is the array name. Range of n is 1 to 9, signifying stored traces. If array is less than 400 values in length (stored trace length), the array values are assigned for the length of the array, leaving the rest of the stored trace intact.

```
Example: ANLZ:TRACE:DATA 2,80,128
                                     // Changes a single Trace value,
                                     // located 2 divisions from the left
                                     // edge, to the midway point (on the
                                     // axis).
                                     // Queries the value of the live
        ANLZ:TRACE:GET? 0,240
                                     // Trace at the point 240 (\sin
                                     // divisions from the left edge of
                                     // the display).
        ANLZ:TRACE:DATA? 3,200,200
                                     // Returns the Trace values of the
                                     // right half of the Trace stored
                                     // in memory location 3 (200 values).
        ANLZ:TRACE:MAX? 0,200
                                    // Queries the maximum Trace value of
                                     // the left half of the live Trace.
        ANLZ:TRACE:MIN? 0,40,80
                                     // Queries the minimum Trace value
                                     // of the live Trace for the second
                                     // and third divisions.
```

TRACK:

BWIDth f

Sets Tracking Generator Bandwidth to fkHz. Select 0.3, 3, 30, 300 or 3000.

BWIDth?

Returns Tracking Generator Bandwidth in kHz.

LEVel n

Sets Tracking Generator Level to n dB. Range of n is 0.0 to -127.0.

LEVel?

Returns Tracking Generator Level in dB.

ANLZ:

TRACK:

OUTput:

TR

Selects T/R Connector as Tracking Generator Output Connector.

DUPlex

Selects DUPLEX OUT Connector as Tracking Generator Output Connector.

OUTput?

Returns current Tracking Generator Output Connector.

RESolution:

HIGH

Selects high for Tracking Generator Resolution.

LOW

Selects low for Tracking Generator Resolution.

MED

Selects medium for Tracking Generator Resolution.

RESolution?

Returns HIGH if Tracking Resolution is high, LOW if Tracking Resolution is low or MED if Tracking Resolution is medium.

STATe b

Enables Tracking Generator if b is 1, disables Tracking Generator if b is 0.

STATe?

Returns 1 if Tracking Generator is active; 0 if inactive.

```
Example: ANLZ:TRACK:LEV -10
                              // Sets Analyzer Tracking Generator Level
                              // to -10 dBm.
                              // Sets Analyzer Tracking Generator
        ANLZ:TRACK:RES:HIGH
                              // Resolution to high.
        ANLZ:TRACK:BWID 30
                              // Sets Analyzer Bandwidth to 30 kHz.
        ANLZ:TRACK:STAT 1
                              // Enables the Analyzer Tracking Generator.
                              // Queries the Analyzer Tracking Generator
        ANLZ:TRACK:LEV?
                              // Level.
                                         -10 is returned.
        ANLZ:TRACK:RES?
                              // Queries the Analyzer Tracking Generator
                              // Resolution.
                                              HIGH is returned.
        ANLZ:TRACK:BWID?
                              // Queries the Analyzer Bandwidth in kHz.
                              // 30 is returned.
        ANLZ:TRACK:STAT?
                              // Queries the current status of the
                              // Analyzer Tracking Generator.
                              // returned.
```

4-10-2 REMOTE SPECTRUM ANALYZER EXAMPLE

The following command sequence measures a 96 MHz signal received at the ANTENNA IN Connector and returns the amplitude in dB:

```
SCREEN: ANLZ
                             // Displays the Analyzer Operation Screen.
ANLZ:SCAN 20
                             // Sets the Analyzer Scan Width to 20 kHz.
ANLZ:FREQ 96000
                             // Sets Analyzer RF Frequency to 96 MHz.
ANLZ:LIVE
                             // Selects the Live Analyzer Mode.
ANLZ:SCALE 10
                             // Selects the 10 Units/Division Factor.
                             // Selects dBm for the Analyzer Scale Units.
ANLZ:SCALE:UNIT:DBM
ANLZ: INPUT: ANTENNA
                             // Selects the ANTENNA IN Connector for the
                             // Analyzer Input.
ANLZ: INPUT: ATTENUATION 0
                             // Sets Analyzer Input Attenuation to 0 dB.
ANLZ:MARKER1:STATE 1
                             // Enables Marker 1.
ANLZ:MARKER1:POINT 50
                             // Positions Marker 1 at the Analyzer RF
                             // Frequency.
ANLZ:MARKER1:AMPLITUDE?
                            // Queries the amplitude of the Trace at the
                             // Marker 1 position.
```

4-11 METER COMMANDS

4-11-1 AF METER COMMANDS

M_AF:

ALARM b

Enables Alarm if b is 1, disables if b is 0. Enabled Alarm sounds when Upper or Lower Limit is surpassed.

FILTer:

HPASs:

FREQuency f

Sets High-Pass cutoff frequency to f kHz. Range of f is 0.5 to 20.0.

FREQuency?

Returns High-Pass cutoff frequency in kHz.

STATe b

Enables High-Pass Filter if b is 1, disables if b is 0.

STATe?

Returns 1 if High-Pass Filter is enabled, 0 if disabled.

LPASs:

FREQuency f

Set Low-Pass cutoff frequency to f kHz. Range of f is 0.1 to 30.0.

FREQuency?

Returns Low-Pass cutoff frequency in kHz.

STATe b

Enables Low-Pass Filter if b is 1, disables if b is 0.

STATe?

Returns 1 if Low-Pass Filter is enabled, 0 if disabled.

Example:

INPut:type

Selects the Audio Frequency Meter Input. Select from the following for type:

XAUDIO (Ext Mod) SINAD (SINAD/BER) DEMOD (Demod Audio) FO POWer (RF Power)

FGEN (Func Gen Out)

M_AF:

LL:

LEVel f

Sets Lower Limit to f kHz. Range of f is 0.0000 to 0.2000 for an upper range of 0.2. Range of f is 0.000 to 200.000 for upper ranges of 2, 20 and 200.

STATE b

Enables Audio Frequency Meter Lower Limit if b is 1, disables if b is 0. When enabled, exceeding the Lower Limit sets bit 3 of the Instrument Status Register to one (activating bit 13 of the Questionable Status Register and bit 3 of the Status Byte) (see 3-16). When the Lower Limit and Alarm (M_AF:ALARM 1) are enabled, exceeding the Lower Limit activates an audio alarm.

PEAK?

Returns Audio Frequency Meter Peak reading in Hz (0.0 to 200000.0).

PH b

Enables Peak Hold Feature when b is 1, disables Peak Hold Feature when b is 0.

RANGe:

AUTO

Sets frequency range to Autorange.

UPPer f

Sets frequency range to f kHz. Select 0.2, 2, 20 or 200.

RCL n

Recalls Audio Frequency Meter environment (routings and settings) stored in memory location n. Range of n is 1 to 9.

RESolution n

Sets Audio Frequency Meter Resolution (Gate Time) to n Hz. Select 0.1 (Gate Time of 10 s) or 1 (Gate Time of 1 s).

STORe n

Stores current Audio Frequency Meter environment (routings and settings) in memory location n. Range of n is 1 to 9.

M_AF:

UL:

LEVel f

Sets Upper Limit to f kHz. Range of f is 0.0000 to 0.2000 for an upper range of 0.2. Range of f is 0.000 to 200.000 for upper ranges of 2, 20 and 200.

STATe b

Enables Audio Frequency Meter Upper Limit if b is 1, disables if b is 0. When enabled, exceeding the Upper Limit sets bit 2 of the Instrument Status Register to one (activating bit 13 of the Questionable Status Register and bit 3 of the Status Byte) (see 3-16). When the Upper Limit and Alarm ($M_AF:ALARM$ 1) are enabled, exceeding the Upper Limit activates an audio alarm.

M AF?

Returns an Audio Frequency Meter reading in Hz (0.0 to 200000.0). See also **MEASure: AUDio?** query (4-15).

NOTE: Reading is invalid if squelch is not broken for some internal routings.

```
Example:
         SCREEN: AF
                             // Displays AF Meter Operation Screen.
         M AF: RANG: AUTO
                             // Sets AF Meter Range to Autorange.
         M AF:UL:LEV 100
                             // Sets AF Meter Upper Limit to 100 kHz.
         M AF:UL:STAT 1
                             // Enables Upper Limit.
                             // Sets AF Meter Lower Limit to 25 kHz.
         M AF:LL:LEV 25
         M AF:LL:STAT 1
                             // Enables Lower Limit.
         M AF: INP: XAUDIO
                             // Selects EXT MOD IN Connector for AF Meter
                             // Input.
         M AF:FILT:LPAS:FREQ 10
                                // Sets Low-Pass Filter cutoff frequency to
                                 // 10 kHz.
                                 // Enables Low-Pass Filter.
         M AF:FILT:LPAS:STAT 1
         M AF:ALARM 1
                            // Enables Alarm.
         M AF:PH 1
                             // Enables Peak Hold feature.
                            // Queries AF Meter Peak reading.
         M AF:PEAK?
         M AF?
                             // Queries AF Meter reading.
```

4-11-2 FREQUENCY ERROR METER COMMANDS

M_RF:

ALARM b

Enables Alarm if b is 1, disables if b is 0. Enabled Alarm sounds when Upper or Lower Limit is surpassed.

LL:

LEVel f

Sets Lower Limit to f kHz. Range of f is 0.0000 to 0.1000 for an upper range of 0.1. Range of f is 0.000 to 100.000 for upper ranges of 1, 10 and 100.

STATe b

Enables Lower Limit if b is 1, disables if b is 0. When enabled, exceeding the Lower Limit sets bit 5 of the Instrument Status Register to one (activating bit 13 of the Questionable Status Register and bit 3 of the Status Byte) (see 3-16). When the Lower Limit and Alarm (M_RF:ALARM 1) are enabled, exceeding the Lower Limit activates an audio alarm.

PEAK?

Returns Frequency Error Meter Peak reading in Hz (0.0 to 100000.0).

PH b

Enables Peak Hold Feature if b is 1, disables Peak Hold Feature if b is 0.

RANGe:

AUTO

Sets Frequency Error Meter range to Autorange.

UPPer f

Sets Frequency Error Meter range to f kHz. Select 0.1, 1, 10 or 100.

$\mathsf{RCL}\ n$

Recalls Frequency Error Meter environment (routings and settings) stored in memory location n. Range of n is 1 to 9.

RESolution f

Sets Frequency Error Resolution (Gate Time) to f Hz. Select 1 (Gate Time of 1 sec) or 10 (Gate Time of 0.1 sec).

STORe n

Stores current Frequency Error Meter environment (routings and settings) in memory location n. Range of n is 1 to 9.

M RF:

UL:

LEVel f

Sets Upper Limit to f kHz. Range of f is 0.0000 to 0.1000 for an upper range of 0.1. Range of f is 0.000 to 100.000 for upper ranges of 1, 10 and 100.

STATe b

Enables Upper Limit if b is 1, disables if b is 0. When enabled, exceeding the Upper Limit sets bit 4 of the Instrument Status Register to one (activating bit 13 of the Questionable Status Register and bit 3 of the Status Byte) (see 3-16). When the Upper Limit and Alarm ($M_RF:ALARM$ 1) are enabled, exceeding the Upper Limit activates an audio alarm.

M RF?

Returns Frequency Error Meter reading in Hz (-100000.0 to +100000.0). Actual signal frequency can be calculated by converting the Receiver Frequency setting (**RECeive:FREQuency?** query) from kHz to Hz and adding the Frequency Error Meter reading. For an actual measured frequency reading, see **MEASure:FREQuency?** query (4-15).

NOTE: Reading is invalid if squelch is not broken for some internal routings.

```
Example:
         SCREEN: FREQ
                               // Displays Frequency Error Meter Operation
                               // Screen.
         M RF: RANG: AUTO
                               // Sets Frequency Error Meter Range to Autorange.
         M RF:UL:LEV 100
                              // Sets Frequency Error Meter Upper Limit to
                              // 100 kHz.
                              // Enables Upper Limit.
         M RF:UL:STAT 1
         M RF:LL:LEV 25
                              // Sets Frequency Error Meter Lower Limit to
                              // 25 kHz.
         M RF:LL:STAT 1
                              // Enables Lower Limit.
         M RF:ALARM 1
                              // Enables Alarm.
         M RF:PH 1
                              // Enables Peak Hold feature.
         M RF:PEAK?
                              // Queries Frequency Error Meter Peak reading.
         M RF?
                              // Queries Frequency Error Meter reading.
```

4-11-3 POWER METER COMMANDS

M_PWR:

ALARM b

Enables Power Meter Alarm if b is 1, disables if b is 0. Enabled Power Meter Alarm sounds when Upper or Lower Limit is surpassed.

EXT:

STATe b

Enables External Loss/Gain Offset if b is 1, disables if b is 0. External Loss/Gain Offset compensates Power Meter readings for external gains or losses.

STATe?

Returns External Loss/Gain Offset state setting.

OFFSet n

Sets External Loss/Gain Offset value to n dBm. Range of n is -99.9 to 99.9. Positive values lower Power Meter readings and compensate for external gains. Negative values raise Power Meter readings and compensate for external losses.

OFFSet?

Returns External Loss/Gain Offset value in dBm.

LL:

LEVel n

Sets Power Meter Lower Limit to n W. Range of n is 0.0000 to 0.5000 for ranges: 0.02, 0.05, 0.1, 0.2 and 0.5. Range of n is 0.00 to 200.00 otherwise.

STATe b

Enables Power Meter Lower Limit if b is 1, disables if b is 0. When enabled, exceeding the Lower Limit sets bit 7 of the Instrument Status Register to one (activating bit 13 of the Questionable Status Register and bit 3 of the Status Byte) (see 3-16). When the Lower Limit and Alarm (M_PWR:ALARM 1) are enabled, exceeding the Lower Limit activates an audio alarm.

PEAK?

Returns Power Meter Peak reading in mW (0.0 to 200000.0).

PH h

Enables Power Meter Peak Hold Feature if b is 1, disables if b is 0.

RANGe:

AUTO

Sets Power Meter range to Autorange.

UPPer n

Sets Power Meter range to n W. Select from:

0.02	0.05	0.1
0.2	0.5	1
2	5	10
_ 20	50	100
200		

M PWR:

RCL n

Recalls Power Meter environment (routings and settings) stored in memory location n. Range of n is 1 to 9.

```
Example: M_PWR:RANG:UPP 2 // Sets Power Meter Range to 2 W.
M_PWR:PH 1 // Enables Power Meter Peak Hold.
M_PWR:LL:LEV 0.75 // Sets a Lower Limit of 0.75 W.
M_PWR:LL:STAT 1 // Enables Lower Limit.
M_PWR:ALARM 1 // Enables Alarm.
```

STORe n

Stores current Power Meter environment (routings and settings) in memory location n. Range of n is 1 to 9.

TYPE:

CW

Selects Average Power Measurement Type for Power Meter.

PEAK

Selects Peak Power Measurement Type for Power Meter.

RMS

Selects RMS Power Measurement Type for Power Meter.

UL:

LEVel n

Sets Power Meter Upper Limit to n W. Range of n is 0.0000 to 0.5000 for upper ranges: 0.02, 0.05, 0.1, 0.2 and 0.5. Range of n is 0.00 to 200.00 otherwise.

STATe b

Enables Power Meter Upper Limit if b is 1, disables if b is 0. When enabled, exceeding the Upper Limit sets bit 6 of the Instrument Status Register to one (activating bit 13 of the Questionable Status Register and bit 3 of the Status Byte) (see 3-16). When the Upper Limit and Alarm ($M_PWR:ALARM$ 1) are enabled, exceeding the Upper Limit activates an audio alarm.

M_PWR?

Returns a Power Meter reading in mW (0.0 to 200000.0). See also **MEASure:POWer?** query (4-15).

```
Example:
         SCREEN: POW
                              // Displays Power Meter Operation Screen.
         M PWR:RANG:AUTO
                              // Sets Power Meter Range to Autorange.
         M PWR:UL:LEV 3
                             // Sets Power Meter Upper Limit to 3 W.
         M PWR:UL:STAT 1
                             // Enables Upper Limit.
         M_PWR:LL:LEV .5
                             // Sets Power Meter Lower Limit to 0.5 W.
         M_PWR:LL:STAT 1
                             // Enables Lower Limit.
         M PWR:ALARM 1
                            // Enables Alarm.
         M PWR:PH 1
                             // Enables Peak Hold feature.
         M PWR: PEAK?
                            // Queries Power Meter Peak reading.
         M PWR?
                             // Queries Power Meter reading.
```

4-11-4 DEVIATION METER (Peak) COMMANDS

M_DEV:

ALARM b

Enables Deviation Meter Alarm if b is 1, disables if b is 0. Enabled Alarm sounds when Upper or Lower Limit is surpassed.

AVErage b

Enables Deviation Meter Averaging if b is 1, disables if b is 0.

LL:

LEVel f

Sets the Deviation Meter Lower Limit to f kHz. f can vary from 0.00 to 20.00 for range values of 2, 5, 10 or 20 kHz. f varies from 0 to 100 otherwise.

STATe b

Enables Deviation Meter Lower Limit if b is 1, disables if b is 0. When enabled, exceeding the Lower Limit sets bit 9 of the Instrument Status Register to one (activating bit 13 of the Questionable Status Register and bit 3 of the Status Byte) (see 3-16). When the Lower Limit and Alarm ($M_DEV:ALARM$ 1) are enabled, exceeding the Lower Limit activates an audio alarm.

MODE:

BOTH

Selects Both Mode for Deviation Meter, reading positive and negative deviation. Use M_DEV:POS? and M_DEV:NEG? to query meter readings.

NEGative

Selects Negative Mode for Deviation Meter, reading negative deviation. Use **M_DEV:NEG?** to query meter readings.

NORMalize

Selects Normalized Mode for Deviation Meter, reading (positive + negative)/2 deviation. Use M DEV:POS? to query meter readings.

POSITIVE

Selects Positive Mode for Deviation Meter, reading positive deviation. Use **M DEV:POS?** to query meter readings.

NOTE: Deviation Meter Screen must be updated for a Deviation Meter Mode change to take effect.

NEG?

Returns a negative Deviation Meter reading as an absolute value in kHz (0.00 to 100.00).

M_DEV:

PEAK:

NEG?

Returns a negative Deviation Meter Peak reading as an absolute value in kHz (0.00 to 100.00).

POS?

Returns a positive Deviation Meter Peak reading as an absolute value in kHz (0.00 to 100.00).

PH b

Enables the Deviation Meter Peak Hold Feature if b is 1, disables if b is 0.

POS?

Returns a positive Deviation Meter reading as an absolute value in kHz (0.00 to 100.00).

RANGe:

AUTO

Sets Deviation Meter range to Autorange.

UPPer f

Sets Deviation Meter range to fkHz. Settings for f are: 2, 5, 10, 20, 50 or 100.

RCL n

Recalls Deviation Meter environment (routings and settings) stored in memory location n. Range of n is 1 to 9.

STORe n

Stores current Deviation Meter environment (routings and settings) in memory location n. Range of n is 1 to 9.

M_DEV:

UL:

LEVel f

Sets Deviation Meter Upper Limit to f kHz. f can vary from 0.00 to 20.00 for range values of 2, 5, 10 or 20 kHz. f varies from 0 to 100 otherwise.

STATe b

Enables Deviation Meter Upper Limit if b is 1, disables if b is 0. When enabled, exceeding the Upper Limit sets bit 8 of the Instrument Status Register to one (activating bit 13 of the Questionable Status Register and bit 3 of the Status Byte) (see 3-16). When the Upper Limit and Alarm ($\mathbf{M_DEV:ALARM\ 1}$) are enabled, exceeding the Upper Limit activates an audio alarm.

```
Example: SCREEN:DEV
                              // Displays Deviation (Peak) Meter
                              // Operation Screen.
                              // Sets Range to Autorange.
        M DEV:RANG:AUTO
                             // Sets Upper Limit to 30 kHz.
        M DEV:UL:LEV 30
                              // Enables Upper Limit.
        M DEV:UL:STAT 1
        M DEV:LL:LEV 5
                              // Sets Lower Limit to 5 kHz.
                              // Enables Lower Limit.
        M DEV:LL:STAT 1
                             // Enables Alarm.
        M DEV:ALARM 1
                             // Enables Peak Hold feature.
        M DEV:PH 1
                             // Enables Deviation (Peak) Meter averaging.
        M DEV: AVE 1
        M DEV:MODE:NEG
                             // Selects the Negative Mode.
                             // Updates the Deviation (Peak) Meter
        SCREEN: DEV
                             // Operation Screen.
                              // Queries Negative Deviation (Peak) Meter
        M DEV:NEG?
                              // reading.
```

4-11-5 MODULATION METER COMMANDS

The Modulation Meter measures AM.

M_MOD:

ALARM b

Enables Modulation Meter Alarm if b is 1, disables if b is 0. Enabled Alarm sounds when Upper or Lower Limit is surpassed.

LL:

LEVel n

Sets Modulation Meter Lower Limit to n%. Range of n is 0.0 to 100.0.

STATe b

Enables Modulation Meter Lower Limit if b is 1, disables if b is 0. When enabled, exceeding the Lower Limit sets bit 11 of the Instrument Status Register to one (activating bit 13 of the Questionable Status Register and bit 3 of the Status Byte) (see 3-16). When the Lower Limit and Alarm (M_MOD:ALARM 1) are enabled, exceeding the Lower Limit activates an audio alarm.

PEAK?

Returns Modulation Meter Peak reading as a percentage (0.0 to 100.0).

PH b

Enables Modulation Meter Peak Hold Feature if b is 1, disables if b is 0.

RANGe:

AUTO

Sets Modulation Meter range to Autorange.

UPPer n

Sets Modulation Meter range to n%. Select 40 or 100.

```
Example: M_MOD:RANG:UPP 100 // Sets AM Modulation Meter Range to 100%.

M_MOD:PH 1 // Enables AM Modulation Meter Peak Hold.

M_MOD:LL:LEV 20.5 // Sets a Lower Limit of 20.5%.

M_MOD:LL:STAT 1 // Enables Lower Limit.

M_MOD:ALARM 1 // Enables Alarm.
```

RCI n

Recalls Modulation Meter environment (routings and settings) stored in memory location n. Range of n is 1 to 9.

STORe n

Stores current Modulation Meter environment (routings and settings) in memory location n. Range of n is 1 to 9.

M_MOD:

UL:

LEVel n

Sets Modulation Meter Upper Limit to n%. Range of n is 0.0 to 100.0.

STATe b

Enables Modulation Meter Upper Limit if b is 1, disables if b is 0. When enabled, exceeding the Upper Limit sets bit 10 of the Instrument Status Register to one (activating bit 13 of the Questionable Status Register and bit 3 of the Status Byte) (see 3-16). When the Upper Limit and Alarm (M_MOD:ALARM 1) are enabled, exceeding the Upper Limit activates an audio alarm.

M MOD?

Returns a Modulation Meter reading as a percentage (0.0 to 100.0).

```
Example:
         SCREEN: MOD
                              // Displays Modulation Meter Operation Screen.
         M MOD:RANG:AUTO
                              // Sets Modulation Meter Range to Autorange.
         M MOD:UL:LEV 30
                             // Sets Modulation Meter Upper Limit to 30%.
         M MOD:UL:STAT 1
                             // Enables Upper Limit.
                             // Sets AM Modulation Meter Lower Limit to 5%.
         M MOD:LL:LEV 5
         M MOD:LL:STAT 1
                             // Enables Lower Limit.
         M MOD:ALARM 1
                             // Enables Alarm.
         M MOD:PH 1
                             // Enables Peak Hold feature.
         M MOD: PEAK?
                             // Queries Modulation Meter Peak reading.
                             // Queries Modulation Meter reading.
         M_MOD?
```

4-11-6 DISTORTION METER COMMANDS

M_DIST:

ALARM b

Enables Distortion Meter Alarm if b is 1, disables if b is 0. Enabled Alarm sounds when Upper or Lower Limit is surpassed.

AVErage b

Enables Average Feature if b is 1, disables if b is 0.

FILTer f

Sets Notch Filter frequency to f Hz. Range of f is 600 to 1400.

INPut:type

Sets Distortion Meter Input to type. Select DEMOD (Demod Audio), SINAD (SINAD/BER), XAUDio (Ext Mod) or FGEN (Func Gen).

LL:

LEVel n

Sets Lower Limit to n%. Range of n is 0.0 to 20.0.

STATe b

Enables Distortion Meter Lower Limit if b is 1, disables if b is 0. When enabled, exceeding the Lower Limit sets bit 13 of the Instrument Status Register to one (activating bit 13 of the Questionable Status Register and bit 3 of the Status Byte) (see 3-16). When the Lower Limit and Alarm (M_DIST:ALARM 1) are enabled, exceeding the Lower Limit activates an audio alarm.

PEAK?

Returns a Distortion Meter Peak reading as a percentage (0.0 to 20.0).

PH b

Enables Distortion Meter Peak Hold Feature if b is 1, disables if b is 0. Peak Hold takes effect only after SCREEN:DISTortion command.

RCL n

Recalls Distortion Meter environment (routings and settings) stored at memory location n. Range of n is 1 to 9.

M_DIST:

SELECT:

CWEight

Selects the C-Weight Filter.

LPASs f

Selects a Low-Pass Filter with cutoff frequency of f Hz. Range of f is 100 to 30000.

```
Example: M_DIST:SELECT:LPAS 15000 // Selects a Low-Pass Filter with a // 15 kHz cutoff frequency.
```

STORe n

Stores current Distortion Meter environment (routings and settings) in memory location n. Range of n is 1 to 9.

UL:

I FVel n

Sets Upper Limit to n%. Range of n is 0.0 to 20.0.

STATe b

Enables Distortion Meter Upper Limit if b is 1, disables if b is 0. When enabled, exceeding the Upper Limit sets bit 12 of the Instrument Status Register to one (activating bit 13 of the Questionable Status Register and bit 3 of the Status Byte) (see 3-16). When the Upper Limit and Alarm (M_DIST:ALARM 1) are enabled, exceeding the Upper Limit activates an audio alarm.

M DIST?

Returns a Distortion Meter reading as a percentage (0.0 to 20.0).

```
Example:
         SCREEN:DIST
                              // Displays Distortion Meter Operation Screen.
         M DIST: INP: DEMOD
                              // Selects Demodulated Audio as the Distortion
                              // Meter Input.
                              // Sets Notch Filter frequency to 1 kHz.
         M DIST:FILT 1000
         M DIST:UL:LEV 15
                             // Sets Distortion Meter Upper Limit to 15%.
         M DIST:UL:STAT 1
                             // Enables Upper Limit.
         M DIST:LL:LEV 4
                             // Sets Distortion Meter Lower Limit to 4%.
         M DIST:LL:STAT 1
                             // Enables Lower Limit.
         M DIST:ALARM 1
                              // Enables Alarm.
                                    // Selects a Low-Pass Filter with a 20 kHz
         M DIST:SELECT:LPAS 20000
                                    // cutoff frequency.
         M DIST: AVE 1
                             // Enables Averaging.
         M DIST:PH 1
                             // Enables Peak Hold feature.
         M DIST: PEAK?
                             // Queries Distortion Meter Peak reading.
         M DIST?
                             // Queries Distortion Meter reading.
```

4-11-7 SINAD METER COMMANDS

M_SINAD:

ALARM b

Enables SINAD Meter Alarm if b is 1, disables if b is 0. Enabled Alarm sounds when Upper or Lower Limit is surpassed.

AVErage b

Enables Average Feature if b is 1, disables if b is 0.

FILTer f

Sets Notch frequency to f Hz. Range of f is 600 to 1400.

INPut:type

Selects type as the SINAD Meter Input. Select DEMOD (Demod Audio), SINAD (SINAD/BER), XAUDio (Ext Mod) or FGEN (Func Gen).

LL:

LEVel n

Sets SINAD Meter Lower Limit to n dB. Range of n is 3.0 to 40.0.

STATe b

Enables SINAD Meter Lower Limit if b is 1, disables if b is 0. When enabled, exceeding Lower Limit sets bit 1 of the Instrument Summary Status Register to one (activating bit 1 of the Instrument Status Register, bit 13 of the Questionable Status Register and bit 3 of the Status Byte) (see 3-16). When the Lower Limit and Alarm (M_SINAD:ALARM 1) are enabled, exceeding the Lower Limit activates an audio alarm.

PEAK?

Returns a SINAD Meter Peak reading in dB (3.0 to 40.0).

PH b

Enables SINAD Meter Peak Hold Feature if b is 1, disables if b is 0.

RCL n

Recalls SINAD Meter environment (routings and settings) stored in memory location n. Range of n is 1 to 9.

RESolution n

Sets SINAD Meter readout resolution to n dB. n is 0.1 or 0.5.

RESolution?

Returns current resolution setting in dB (0.1 or 0.5).

M SINAD:

SELECT:

CWEight

Selects C-Weight Filter.

LPASs f

Selects Low-Pass Filter with cutoff frequency of f Hz. Range of f is 100 to 30000.

STORe n

Stores current SINAD Meter environment (routings and settings) in memory location n. Range of n is 1 to 9.

UL:

LEVel n

Sets SINAD Meter Upper Limit to n dB. Range of n is 3.0 to 40.0.

STATe b

Enables SINAD Meter Upper Limit if b is 1, disables if b is 0. When enabled, exceeding Upper Limit sets bit 0 of the Instrument Summary Status Register to one (activating bit 1 of the Instrument Status Register, bit 13 of the Questionable Status Register and bit 3 of the Status Byte) (see 3-16). When the Upper Limit and Alarm (M_SINAD:ALARM 1) are enabled, exceeding the Upper Limit activates an audio alarm.

M SINAD?

Returns a SINAD Meter reading in dB (3.0 to 40.0).

```
Example:
         SCREEN: SINAD
                              // Displays SINAD Meter Operation Screen.
         M SINAD: INP: DEMOD
                              // Selects Demodulated Audio as the
                              // SINAD Meter.
                              // Sets Notch Filter frequency to 1100 Hz.
         M SINAD:FILT 1100
         M SINAD:UL:LEV 15
                              // Sets SINAD Meter Upper Limit to 15 dB.
                              // Enables Upper Limit.
         M SINAD:UL:STAT 1
                              // Sets SINAD Meter Lower Limit to 4 dB.
         M SINAD:LL:LEV 4
         M SINAD:LL:STAT 1 // Enables Lower Limit.
         M SINAD:SELECT:LPAS 15000 // Selects a Low-Pass Filter with a 15 KHz
                                     // cutoff frequency.
         M SINAD: AVE 1
                             // Enables Averaging.
         M SINAD:PH 1
                             // Enables Peak Hold feature.
         M SINAD: PEAK?
                             // Queries SINAD Meter Peak reading.
         M SINAD?
                             // Queries SINAD Meter reading.
```

4-11-8 SIGNAL STRENGTH METER COMMANDS

M_SIG:

PEAK?

Returns a Signal Strength Meter Peak reading (0 to 100).

PH b

Enables Peak Hold Feature if b is 1, disables if b is 0.

RCL n

Recalls Signal Strength Meter environment (routings and settings) stored in memory location n. Range of n is 1 to 9.

STORe n

Stores current Signal Strength Meter environment (routings and settings) in memory location n. Range of n is 1 to 9.

M SIG?

Returns a Signal Strength Meter reading (0 to 100).

```
Example: M-SIG:PH 1  // Enables Peak Hold feature.

M_SIG:PEAK?  // Queries Signal Strength Meter Peak reading.

M_SIG?  // Queries Signal Strength Meter reading.
```

4-11-9 BIT ERROR RATE (BER) METER COMMANDS

M_BER:

PATtern:

FIXED

Selects Fixed pattern for the BER Meter test data.

RANDom

Selects Random pattern for BER Meter test data.

USER nn

Selects a USER pattern (could be a variable or expression) for the BER Meter test data using the specified 8 bit pattern nn. Patterns entered that are not base 10 are preceded with # character and letter signifying the number base: H (Hexadecimal), B (Binary) or Q (Octal). Pattern is displayed on the CRT in Hexadecimal.

POLarity:

NEGative

Selects Negative Polarity for the BER Meter.

POSitive

Selects Positive Polarity for the BER Meter.

M BER:

RATE n

Sets BER Meter rate to n. Select from:

75	150	300
600	1200	2400
4800	16000	

RATE?

Returns the BER Meter Rate setting.

RCL

Recalls the BER Meter environment (routings and settings) stored in memory location n. Range of n is 1 to 9.

SIZE n

Sets BER Meter block size in bits to n. Range of n is 100 to 100000.

```
Example: M_BER:POL:NEG // Selects Negative Polarity for the BER Meter.
M_BER:RATE 1200 // Sets the data rate to 1200 bps.
M_BER:SIZE 1000 // Sets the data pattern size to 1000 bits.
```

SIZE?

Returns the BER Meter block size setting.

STORe n

Stores current BER Meter environment (routings and settings) in memory location n. Range of n is 1 to 9.

TYPE:XXX

Selects xxx for the Bit Error Rate Type. Select GENerator, RECeiver, DUPlex or BASEband.

M_BER?

Returns the number of errors for the last pass.

```
Example: M_BER:TYPE:DUP // Selects Duplex for BER Meter Type.

M_BER:RATE 2400 // Sets BER Meter data rate to 2400 bps.

M_BER:SIZE 10000 // Sets BER Meter Pattern Size to 10,000 bits.

M_BER:POL:POS // Sets BER Meter Polarity to Positive.

M_BER:PAT:RAND // Selects the Random Pattern Type for the BER // Meter test.

M_BER? // Queries a bit error rate reading.
```

4-11-10 DIGITAL MULTIMETER COMMANDS

M_DMM:

ALARM b

Enables Multimeter Alarm if b is 1, disables if b is 0. Enabled Alarm sounds when Upper or Lower Limit is surpassed.

FUNCtion:

CURRent:

AC

Selects the AC Ammeter for the Multimeter Function.

DC

Selects the DC Ammeter for the Multimeter Function.

RESistance

Selects the Ohmmeter for the Multimeter Function.

VOLTage:

AC

Selects the AC Voltmeter for the Multimeter Function.

DC

Selects the DC Voltmeter for the Multimeter Function.

FUNCtion?

Returns active Multimeter Function (CURR:AC, CURR:DC, RES, VOLT:AC or VOLT:DC).

INPut:IMPedance n

Sets Input Impedance to *n* ohms. Select 150, 600 or 1e6. Command ignored if not in AC Voltmeter Function.

LL:

LEVel n

Sets the Multimeters Lower Limit to n. Table 4-1 lists units and ranges for n.

STATe b

Enables the Multimeters Lower Limit if b is 1, disables if b is 0. When enabled, exceeding Lower Limit sets bit 3 of the Instrument Summary Status Register to one (activating bit 1 of the Instrument Status Register, bit 13 of the Questionable Status Register and bit 3 of the Status Byte) (see 3-16). When the Lower Limit and Alarm (M_DMM:ALARM 1) are enabled, exceeding the Lower Limit activates an audio alarm.

M_DMM:

Function	n ACC, DCC		ACV, DCV		Ohmmeter	
Range	20 and 200 mA	2 A and 20 A	200 mV	2, 20, 200, 2000 V	200 Ω	$2~\text{k}\Omega$ to $20~\text{M}\Omega$
n Units	Α		V		kΩ	
Range of n	0.00000 to 0.19990	0.000 to 19.990	0.0000 to 0.1999	0.00 to 1000.00	0.0000 to 0.1999	0.000 to 19990

Table 4-1 DMM Upper and Lower Limit Ranges and Units

PH b

Enables Multimeter Peak Hold feature if b is 1, disables if b is 0.

RANGe:

AUTO

Sets the Multimeter range to Autorange.

UPPer n

For AC or DC Voltmeter, sets range to *n* volts. Settings for *n* are: 0.2, 2, 20, 200 or 2000.

For AC or DC Ammeter, sets range to n amps. Settings for n are: 0.02, 0.2, 2 or 20.

For Ohmmeter, sets range to $n k\Omega$. Settings for n are: 0.2, 2, 20, 200, 2000 or 20000.

NOTE: M_DMM:RANGe:AUTO and M_DMM:RANGe:UPPer commands must be followed by a SCREEN:DMM command.

RCL n

Recalls Digital Multimeter environment (routings and settings) stored in memory location n. Range of n is 1 to 9.

STORe n

Stores current Digital Multimeter environment (routings and settings) in memory location n. Range of n is 1 to 9.

UL:

LEVel r

Sets Multimeters Upper Limit to n. Table 4-1 lists units and ranges for n.

STATe b

Enables Multimeters Upper Limit if b is 1, disables if b is 0. When enabled, exceeding Upper Limit sets bit 2 of the Instrument Summary Status Register to one (activating bit 1 of the Instrument Status Register, bit 13 of the Questionable Status Register and bit 3 of the Status Byte) (see 3-16). When the Upper Limit and Alarm (M_DMM:ALARM 1) are enabled, exceeding the Upper Limit activates an audio alarm.

M DMM?

Returns a Multimeter reading in the current Function units according to Table 4-1. See also **MEASure:** commands (4-15).

```
Example:
         M DMM:FUNC:CURR:DC
                              // Selects DC Ammeter for the Multimeter
                              // Function.
         M DMM:RANG:LEV 0.2
                              // Sets Ammeter range to 200 mA.
         M DMM:PH 1
                              // Enables Peak Hold feature.
         M DMM:ALARM 1
                              // Enables Alarm.
         M DMM:UL:LEV 150
                              // Sets Upper Limit to 150 mA.
         M DMM:UL:STAT 1
                              // Enables Upper Limit.
         M DMM:LL:LEV 30
                              // Sets Lower Limit to 30 mA.
         M DMM:LL:STAT 1
                              // Enables Lower Limit.
```

4-11-11 PHASE METER COMMANDS

M_PM:

ALARM b

Enables Phase Meter Alarm if b is 1, disables if b is 0. Enabled Alarm sounds when a limit is surpassed.

LL:

LEVel n

Sets the Phase Meter Lower Limit to n radians. Range of n is 0.00 to 10.00.

STATe b

Enables the Phase Meter Lower Limit if b is 1, disables if b is 0. When enabled, exceeding Lower Limit sets bit 5 of the Instrument Summary Status Register to one (activating bit 1 of the Instrument Status Register, bit 13 of the Questionable Status Register and bit 3 of the Status Byte) (see 3-16). When the Lower Limit and Alarm (M_PM:ALARM 1) are enabled, exceeding the Lower Limit activates an audio alarm.

PH b

Enables the Phase Meter Peak Hold Feature if b is 1, disables if b is 0.

RANGe:

AUTO

Sets Phase Meter range to Autorange.

UPPer n

Sets Phase Meter range to n radians. Select 1, 5 or 10.

RCL n

Recalls Phase Meter environment (routings and settings) stored in memory location n. Range of n is 1 to 9.

M PM:

STORe n

Stores current Phase Meter environment (routings and settings) in memory location n. Range of n is 1 to 9.

UL:

LEVel n

Sets Phase Meter Upper Limit to n radians. Range of n is 0.00 to 10.00.

STATe b

Enables Phase Meter Upper Limit if b is 1, disables if b is 0. When enabled, exceeding Upper Limit sets bit 4 of the Instrument Summary Status Register to one (activating bit 1 of the Instrument Status Register, bit 13 of the Questionable Status Register and bit 3 of the Status Byte) (see 3-16). When the Upper Limit and Alarm ($M_PM:ALARM$ 1) are enabled, exceeding the Upper Limit activates an audio alarm.

M PM?

Returns a Phase Meter reading in radians (0.00 to 10.00).

```
Example: SCREEN:PM // Displays Phase Meter Operation Screen.

M_PM:RANG:AUTO // Sets Phase Meter Range to Autorange.

M_PM:UL:LEV 7 // Sets Phase Meter Upper Limit to 7 radians.

M_PM:UL:STAT 1 // Enables Upper Limit.

M_PM:LL:LEV .5 // Sets Phase Meter Lower Limit to 0.5 radians.

M_PM:LL:STAT 1 // Enables Lower Limit.

M_PM:ALARM 1 // Enables Alarm.

M_PM:PH 1 // Enables Peak Hold feature.

M_PM:PEAK? // Queries Phase Meter Peak reading.

M_PM? // Queries Phase Meter reading.
```

4-11-12 DEVIATION METER (RMS) COMMANDS

M_DRMS:

ALARM b

Enables Deviation Meter (RMS) Alarm if b is 1, disables if b is 0. Enabled Alarm sounds when a limit is surpassed.

AVErage b

Enables Deviation Meter (RMS) Averaging if b is 1, disables if b is 0.

LL:

LEVel f

Sets Deviation (RMS) Lower Limit to f kHz. Range of f is 0.00 to 10.00.

STATe b

Enables Deviation (RMS) Meter Lower Limit if b is 1, disables if b is 0. When the Lower Limit and Alarm (M_DRMS:ALARM 1) are enabled, exceeding the Lower Limit activates an audio alarm.

PH F

Enables Deviation Meter (RMS) Peak Hold feature if b is 1, disables if b is 0.

RANGe:

AUTO

Sets Deviation Meter (RMS) range to Autorange.

UPPer f

Sets Deviation Meter (RMS) range to fkHz. Select 2, 5 or 10.

BCL n

Recalls Deviation Meter (RMS) environment (routings and settings) stored in memory location n. Range of n is 1 to 9.

STORe n

Stores current Deviation Meter (RMS) environment (routings and settings) in memory location n. Range of n is 1 to 9.

M DRMS:

UL:

LEVel f

Sets Deviation (RMS) Upper Limit to f kHz. Range of f is 0.00 to 10.00.

STATe b

Enables Deviation Meter (RMS) Upper Limit if b is 1, disables if b is 0. When the Upper Limit and Alarm (M_DRMS:ALARM 1) are enabled, exceeding the Upper Limit activates an audio alarm.

M DRMS?

Returns a Deviation Meter (RMS) reading in kHz (0.00 to 10.00).

```
// Displays Deviation Meter (RMS) Operation
Example:
         SCREEN: DRMS
                              // Screen.
                              // Sets Deviation Meter (RMS) Range to Autorange.
         M DRMS: RANG: AUTO
         M DRMS:UL:LEV 8.4
                              // Sets Deviation Meter (RMS) Upper Limit
                              // to 8.4 kHz.
                              // Enables Upper Limit.
         M DRMS:UL:STAT 1
                              // Sets Deviation Meter (RMS) Lower Limit
         M DRMS:LL:LEV 2
                              // to 2 kHz.
                              // Enables Lower Limit.
         M DRMS:LL:STAT 1
                             // Enables Alarm.
         M DRMS:ALARM 1
                             // Enables Peak Hold feature.
         M DRMS:PH 1
         M DRMS: AVE 1
                             // Enables Averaging.
                              // Queries Deviation Meter (RMS) reading.
         M DRMS?
```

4-11-13 PHASE METER (RMS) COMMANDS

M PMRMS:

ALARM b

Enables Phase Meter (RMS) Alarm if b is 1, disables Alarm if b is 0. Enabled Alarm sounds when a limit is surpassed.

LL:

LEVel n

Sets Phase Meter (RMS) Lower Limit to n radians. Range of n is 0.00 to 10.00.

STATe b

Enables Phase Meter (RMS) Lower Limit if b is 1, disables Lower Limit if b is 0. When the Lower Limit and Alarm (M_PMRMS:ALARM 1) are enabled, exceeding the Lower Limit activates an audio alarm.

PH b

Enables Phase Meter (RMS) Peak Hold feature if b is 1, disables Peak Hold feature if b is 0.

RANGe:

AUTO

Sets Phase Meter (RMS) range to Autorange.

IIPPer n

Sets Phase Meter (RMS) range to n radians. Select 1, 5 or 10.

RCL n

Recalls Phase Meter (RMS) environment (routings and settings) stored in memory location n. Range of n is 1 to 9.

STORe n

Stores current Phase Meter (RMS) environment (routings and settings) in memory location n. Range of n is 1 to 9.

```
Example: M_PMRMS:RANG:AUTO // Sets Phase Meter (RMS) range to Autorange.
M_PMRMS:PH 1 // Enables Phase Meter (RMS) Peak Hold.
M_PMRMS:STOR 3 // Stores state of Phase Meter (RMS) to
// Phase Meter (RMS) memory location 3.
```

UL:

I EVel n

Sets Phase Meter (RMS) Upper Limit to n radians. Range of n is 0.00 to 10.00.

STATe b

Enables Phase Meter (RMS) Upper Limit if b is 1, disables Upper Limit if b is 0. When the Upper Limit and Alarm (**M_PMRMS:ALARM 1**) are enabled, exceeding the Upper Limit activates an audio alarm.

M PMRMS?

Returns a Phase Meter (RMS) reading in radians (0.00 to 10.00).

```
Example: SCREEN:PMRMS // Displays Phase Meter (RMS) Operation Screen.

M_PMRMS:UPP 5 // Sets Phase Meter (RMS) Range to 5 radians.

M_PMRMS:UL:LEV 4.6 // Sets Phase Meter (RMS) Upper Limit to

// 4.6 radians.

M_PMRMS:UL:STAT 1 // Enables Phase Meter (RMS) Upper Limit.

M_PMRMS? // Queries Phase Meter (RMS) reading.
```

4-11-14 AF LEVEL METER

M_VRMS?

Returns a Voltage RMS reading of the received AF Level (0.00 to 10.00).

4-12 CELLULAR AMPS

4-12-1 CELLULAR AMPS COMMANDS

The AMPS Cell Site Monitor and Mobile Simulator is option 10 of the FM/AM-1600S and FM/AM-1600CSA. The following commands remotely control this option. Except for **CELL:CHAN** and **CELL:CHAN?**, these commands have no effect if the AMPS Cell Site Monitor is not installed.

CELL: commands remotely operate the Cell Site Monitor and require a Cell Site Monitor screen to be displayed on the CRT. **CELL:GEN** commands remotely operate the Mobile Simulator and require a Mobile Simulator screen to be displayed on the CRT.

NOTE: A Cellular query command (command with ?) returns the value once, returning -1 for further queries until additional data occurs.

CELL:

ACTion?

Returns the Global Action value or -1 if not available.

BIS?

Returns latest Busy-Idle Status bit value or -1 if not available.

B 1?

Returns the Busy-Idle bit value, 0 for busy, 1 for idle. -1 is returned if Busy-Idle bit is not available.

BOTH

Selects stream A and B words for decoding.

C12?

Returns latest C12 bit value or -1 if not available.

C13?

Returns latest C13 bit value or -1 if not available.

CAPTure:

MIN "xxx/xxx-xxxx"

Selects MIN to capture. Range of x is 0 to 9, A to D or a to d. An x, X, # or * can be used as a wildcard character. MIN string must be entered as shown. Does not select Capture Mode.

MIN?

Returns current MIN used for capture (string).

MODE:xxx

Selects xxx as Capture Mode. Select MIN, ORDer, BOTH or OFF for xxx.

MODE?

Returns the current Capture Mode.

CAPTure:

ORDer:xxx

Selects xxx as Order to capture. Does not select Capture Mode. Select one of the following for xxx:

PAGE ALER
REORDer SALE
SNDAddr INTER
POWer DRET
AINTERCEPT AREC
VCDES

ALERT RELease
SALERT AUDIT
INTERCEPT MAINTenance
DRETRY AUTREG
AREORDer AALERT

ORDer?

Returns current Order used for capture (string).

CHANnel n

Selects Cellular Channel n for testing. Range of n is 0 to 1023.

CHANnel?

Returns the current Cellular Channel.

CHANPOS1?

Returns Channel Position 1 (seven bit value) or -1 if not applicable.

CHANPOS2?

Returns Channel Position 2 (seven bit value) or -1 if not applicable.

CHANPOS3?

Returns Channel Position 3 (seven bit value) or -1 if not applicable.

CHANPOS4?

Returns Channel Position 4 (seven bit value) or -1 if not applicable.

CHANPOS5?

Returns Channel Position 5 (seven bit value) or -1 if not applicable.

CHANPOS6?

Returns Channel Position 6 (seven bit value) or -1 if not applicable.

CMAC?

Returns Control Mobile Attenuation Code (three bit value) or -1 if not available.

CMAX_1?

Returns Number of Access Channels minus one (seven bit value) or -1 if not available.

CPA?

Returns the Combined Paging/Access bit or -1 if not available.

DCC?

Returns Digital Color Code (two bit value) or -1 if not available.

DIGITs?

Returns the Call Address (16 character string) or -1 if not available.

DSCC?

Returns the Digital SAT Color Code (2 bit value) or -1 if not available.

DTX?

Returns the Discontinuous Transmission bit value or -1 if not available.

E?

Returns the Extended Address bit value or -1 if not available.

EF?

Returns the Expanded Protocol Forward Control Channel Indicator (one bit value) or -1 if not available.

END?

Returns the End Indication bit value or -1 if not available.

EP?

Returns the Extended Protocol Capable value (one bit value) or -1 if not available.

ESN?

Returns the Electronic Serial Number (32 bit value) or -1 if not available.

FORMat:

AMPS

Sets Channel Format to AMPS.

NT400

Sets Channel Format to NT400.

FORMat?

Returns the Channel Format setting.

LOCALCTRL1?

Returns the first position Local Control field (16 bit value) or -1 if not available.

LOCALCTRL2?

Returns the second position Local Control field (16 bit value) or -1 if not available.

MAXBusy:

OTHer?

Returns maximum number of busy occurrences for other than page responses (four bit value) or -1 if not available.

PGR?

Returns maximum number of busy occurrences for page responses (four bit value) or -1 if not available.

MAXSztr:

OTHer?

Returns maximum number of seizure tries for other than page responses (four bit value) or -1 if not available.

PGR?

Returns maximum number of seizure tries for page responses (four bit value) or -1 if not available.

MIN?

Returns the current MIN value in AAA/DDD-DDDD or BBB-BBBB format as a string or -1 if not available.

MSL?

Returns the Message Length (eight bit value) or -1 if not available.

MST?

Returns the Message Type (five bit value) or -1 if not available.

N 1?

Returns the Number of Paging Channels, minus one, to be scanned by the Mobile Equipment (five bit value) or -1 if not available.

NAWC?

Returns the Number of Additional Words Coming (three bit value) or -1 if not available.

NEWACC?

Returns the New Access Channel Starting point (11 bit value) or -1 if not available.

OLC?

Returns the Overload Control Class (15 bit value) or -1 if not available.

ORDer?

Returns the current Order as a string (PAGE, ALERT, RELEASE, REORDER, SALERT, AUDIT, SNDADDR, INTERCEPT, MAINTENANCE, POWER, DRETRY, AUTREG, AINTERCEPT, AREORDER, AALERT, VCDES) or -1 if not available.

PDSCC?

Returns the Present Digital SAT Color Code (two bit value) or -1 if not available.

PSCC?

Returns the Present SAT Color Code (two bit value) or -1 if not available.

RCF?

Returns the Read Control-Filler bit value or -1 if not available.

REGH?

Returns the Registration for Home Mobile Stations value (one bit value) or -1 if not available.

REGID?

Returns the Registration Identification value (20 bit value) or -1 if not available.

REGINCR?

Returns the Registration Increment (12 bit value) or -1 if not available.

REGR?

Returns the Registration for Roaming Mobile Stations (one bit value) or -1 if not available.

52

Returns the Serial Number bit value or -1 if not available.

SCC?

Returns the Supervisory Audio Tone Color Code (two bit value) or -1 if not available.

SID?

Returns the System Identification Number (14 bit value) or -1 if not available.

VCHAN?

Returns the Voice Channel (1 to 1023) from Channel field or -1 if not available.

VMAC?

Returns the Voice Mobile Attenuation Code (three bit value) or -1 if not available.

WFOM?

Returns the Wait for Overhead Message bit or -1 if not available.

WORD?

Returns the current decoding word selection (A or B).

WORDA

Selects the stream A words for decoding.

WORDB

Selects the stream B words for decoding.

CELL:GEN commands operate the AMPS Mobile Simulator (part of option 10).

CELL:GEN:RECC commands operate the Reverse Control Channel Screen and **CELL:GEN:RVC** commands operate the Reverse Voice Channel Screen.

CELL:

GEN:

CHANnel n

Selects an AMPS Reverse Channel to send messages to Cell Site. Range of n is 1 to 1023.

CHANnel?

Returns current selected channel.

DCC x

Selects Digital Color Code sent to Cell Site. Range of x is from 0 to 3.

DCC?

Returns current DCC setting.

GEN:

DIGITS "x"

DIGITs?

Returns current Called Address setting.

ESN:

DECimal x

Selects simulated Electronic Serial Number sent to Cell Site using decimal format. Range of x is 0 to 23116113919. ESN is displayed on screen in current format.

DECimal?

Returns current ESN setting in decimal format.

FORMat:

DECimal

Selects ESN decimal format.

HEX

Selects ESN hexadecimal format.

OCTal

Selects ESN octal format.

FORMat?

Returns current ESN format (DEC, HEX or OCT).

HEXadecimal x

Selects simulated ESN sent to Cell Site using hexadecimal format. Range of x is 0 to FFFFFFF. ESN is displayed on screen in current format.

HEXadecimal?

Returns current ESN setting in hexadecimal format.

OCTal x

Selects simulated ESN sent to Cell Site using octal format. Range of x is 0 to 3777777777. ESN is displayed on screen in current format.

OCTal?

Returns current ESN setting in octal format.

MIN "xxx/xxx-xxxx"

Selects simulated MIN sent to Cell Site. Range of x is 0 to 9.

MIN?

Returns current MIN setting (string).

GEN:

MODL f

Sets Cellular Deviation Level to f kHz. Range of f is 0.0 to 25.0.

MODL?

Returns current Cellular Deviation Level in kHz.

RECC:

CONTinuous

Sends the last order selected continuously to the Cell Site.

ONCE

Sends the last order selected to the Cell Site once.

ORDer:

AUDIT

Selects Audit for the Receive Control Channel Order field.

AUTREG

Selects Autonomous Registration for the RECC Order field.

ORIGIN

Selects Origination for the RECC Order field.

PAGE

Selects Page Response for the RECC Order field.

ORDer?

Returns current RECC Order field setting (AUDIT, AUTREG, ORIGIN or PAGE).

STOP

Stops transmission of RECC order sent continuously.

RVC:

CONTinuous

Sends the last order selected continuously to the Cell Site.

ONCE

Sends the last order selected to the Cell Site once.

CELL:

GEN:

RVC:

ORDer:

AUDIT

Selects Audit for the Reverse Voice Channel Order field.

POWer x

Selects Power Level order of power level x for the RVC Order field. Range of x is 0 to 7.

SENDCall

Selects Send Called Address for the RVC Order field.

SNREQuest

Selects Autonomous Registration for the RVC Order field.

ORDer?

Returns current RVC Order field setting (AUDIT, POWER, SENDCALL or SNREQUEST).

STOP

Stops transmission of RVC order sent continuously.

SCM:

BANDwidth x

Selects Mobile Phone Bandwidth sent to Cell Site. Select 20 or 25 (MHz).

BANDwidth?

Returns current Mobile Phone Bandwidth setting.

POWer x

Selects Power Level of simulated Mobile Phone. Range of x is 1 to 4 (4 reserved).

POWer?

Returns current Power Level setting.

TRANsmit:

CONTinuous

Selects Continuous Transmission for simulated Mobile Phone.

DISCONTInuous

Selects Discontinuous Transmission for simulated Mobile Phone.

TRANsmit?

Returns current Continuous/Discontinuous Transmission setting.

4-12-2 REMOTE AMPS CELL SITE MONITOR EXAMPLE

The following macro performs the Receiver Setup for AMPS Cell Site Operation:

```
*DMC "CELL SETUP", BEGIN
                             // Define a macro named CELL SETUP.
SCREEN: REC
                             // Displays the Receiver Operation Screen.
*WAI
                             // Waits for command to finish executing.
                             // Selects User Defined FM Data for Receiver
REC:MOD:USER:MOD DATA
                             // Modulation.
REC:MOD:USER:FILT 30
                             // Selects a Low-Pass IF Filter with a 30 kHz
                             // cutoff frequency.
                             // Selects a Low-Pass Post Detection Filter
REC:MOD:USER:POST:LPAS 15
                             // with a 15 kHz cutoff frequency.
                             // Selects User Defined High Speed for AGC.
REC:AGC:USER:HIGH
                             // Sets Deviation Meter Range to 10 kHz.
M DEV:RANG:UPP 10
M AF: RES 1
                             // Sets AF Meter Gate Time to 0.1 sec (1 Hz).
END
                             // End macro CELL SETUP.
```

The following macro queries cellular readings once a min number is received:

```
*DMC "CELL TEST", BEGIN
                              // Define macro named Cell Read.
STRING MIN, ORDER
                              // Declare strings needed.
                              // Declare variables needed.
VAR SCC, DCC, SID, VMAC
                              // Declare variables needed.
VAR CHN, CMX, N1, CMAC
SCREEN: CELL
                              // Display AMPS Cell Site Monitor Screen.
*WAI
                              // Wait for command execution to finish.
                              // Select Control Channel 327
CELL: CHAN 327
                              // Loop while no Min is received.
  $=STR(CELL:MIN?)
                              // Query for a MIN.
                              // Pauses macro to allow Test Set processing.
  TPAUSE
UNTIL $ != "-1"
                              // End of loop.
MIN=$
                              // Set MIN string equal to received MIN.
                              // Query Order.
ORDER=STR (CELL:ORDER?)
                              // Query SCC value.
SCC=CELL:SCC?
                              // Query DCC value.
DCC=CELL: DCC?
SID=CELL:SID?
                              // Query SID value.
VMAC=CELL:VMAC?
                              // Query VMAC value.
                              // Query Voice Channel.
CHN=CELL: VCHAN?
CMX=CELL:CMAX 1?
                              // Query CMAX value.
N1=CELL:N 1?
                              // Query N-1 value.
                              // Query CMAC value.
CMAC=CELL: CMAC?
PPRINT STR(MIN) +","+STR(ORDER)
                                  // Send MIN and Order to RS-232 Connector.
PPRINT SCC, DCC, SID, VMAC
                              // Send readings to RS-232 Connector.
PPRINT CHN, CMX, N1, CMAC
                              // Send readings to RS-232 Connector.
END
                              // End of macro CELL TEST.
```

4-13 PROGRAM COMMANDS

PROGram:STARTup:NAME "name"

Selects the macro name to execute at power up. The startup macro executes after the POWER Switch is pressed and the automatic self test is performed. The startup macro can be avoided by continually pressing STOP TEST CONTROL Key during the 2 beeps of the 1-2-4 beep startup procedure.

PROGram:STARTup:NAME?

Returns the name of the current power up macro designated by a PROGram:STARTup:NAME command.

PROGram:STARTup:DELETE

Deletes the power up designation of the power up macro. After this command is executed, there is no power up macro until a **PROGram:STARTup:NAME:** command is executed. This command does not delete the macro itself.

```
Example: PROG:START:NAME "Main_Menu" // Selects macro Main_Menu as the power // up macro. This macro will now // execute when the Test Set is turned on. PROG:START:NAME? // Queries the name of the current power // up macro. Main_Menu is returned. PROG:START:DELETE // Deletes the power up designation.
```

4-14 FLASH MEMORY FILE DIRECTORY OPERATION

The Flash Memory File Directory allows storage of various files including Calibration Data Sets and allows user to select a macro to be executed without remote instruction. Operate Flash Memory File Directory using following procedure:

STEP

PROCEDURE

 Press MTRS MODE Key. Press "AUX" Soft Function Key F6 to display Auxiliary Functions Menu. Press 7 DATA ENTRY Key to display File Directory Screen.

File Direc	tory	Free: 2551040			
Name	Туре	Size	Date		
SET11 SET10 STATE1 CAL1 TRACE1 VALUE01 STRING 12	M M S B T B	23342 23342 2304 440 406 13	06/23/92 06/23/92 06/23/92 06/23/92 06/23/92 06/23/92		
Delete	Pack	Init	Exec Ret		

8617099

- 2. To load a macro from Flash memory into Test Set memory and execute it, move cursor to macro. Press "Exec" Soft Function Key F5.
- 3. To load a Calibration Data Set or a stored Test Set State (Test Set settings at time of store), move cursor to file. Press "Load" Soft Function Key F5.
- 4. To delete a file, move cursor to file. Press "Delete" Soft Function Key F2. Flash Memory space is not released until Pack operation is done.
- 5. To perform Pack operation, press "Pack" Soft Function Key F3. Pack releases memory space taken by deleted files.

NOTE: Do not power off Test Set during Pack operation as files may be lost.

- 6. To Initialize Flash Memory, press "Init" Soft Function Key F4. Initializing clears Flash Memory and all files are lost.
- 7. To return to Auxiliary Functions Menu, press "Ret" Soft Function Key F6.

Files are stored in Flash Memory using remote commands only. Spectrum Analyzer and Oscilloscope Traces and variables are loaded into Test Set using remote commands. Table 4-2 contains remote commands used to operate Flash Memory File Directory.

COMMAND	RANGE/VALUE	DESCRIPTION
MMEMory:CATalog?		Returns Flash Memory status. First number returned is memory space used in bytes. Second number returned is memory space available in bytes. Remainder data is returned in sets of 3 consisting of file name, file type and file size for each file stored in Flash Memory.
MMEMory:CATalog:ENTRY? n	n is line number (index) in Flash Memory File Directory. Set n from 0 to 512.	Returns file entry (file name, file type, file size) for given index. Returns \$\$\$ if past end of directory or for deleted file.
MMEMory:CATalog:USED?		Returns file space used, in bytes.
MMEMory:CATalog:FREE?		Returns available file space, in bytes.
MMEMory:DELete "f"	f is Flash Memory file name.	Deletes file but does not release memory space until Pack operation is done.
MMEMory:INITialize		Erases all files stored in Flash Memory.
MMEMory:INITialize?		Returns 1 if file system has been initialized, 0 otherwise.
MMEMory:LOAD:MACRo "m","f"	m is name of designated macro. f is Flash Memory file name.	Loads macros and variables stored as the file name from Flash Memory into Test Set memory. If m is *, designated macro is executed. If m is macro name, that macro is executed. If m is omitted (""), no macro is executed.
MMEMory:LOAD:STATe n,"f"	n is number of stored state of Test Set. Set n from 0 to 9. f is Flash Memory file name.	Loads Test Set State stored as f from Flash Memory into Auxiliary Functions "Store Parameters Menu" as entry n. (n=0 loads current state.)
MMEMory:LOAD:TRACe:SCOPe n,"f"	n is number of stored trace. Set n from 0 to 9. f is Flash Memory file name.	Loads Oscilloscope trace stored as f into Oscilloscope "Store Parameters Menu" as entry n. (n=0 loads live trace.)
MMEMory:LOAD:TRACe:ANLZ n,"f"	n is number of stored trace. Set n from 0 to 9. f is Flash Memory file name.	Loads Spectrum Analyzer trace stored as f into Spectrum Analyzer "Store Parameters Menu" as entry n. (n=0 loads live trace.)
MMEMory:LOAD:DATA v,"f"	v is name of variable. f is Flash Memory file name.	Loads variable stored as f into Test Set memory with name v.
MMEMory:LOAD:CALibration "f"	f is Flash Memory file name.	Loads Calibration Data from Flash Memory into Test Set memory.
MMEMory:PACK		Packs Flash Memory and frees memory space from deleted files. Do not power off Test Set during Pack function (may lose files). Do not Pack with a WINDOW open.
MMEMory:STORe:MACRo "m","f"	m is name of designated macro. f is Flash Memory file name.	Stores all Test Set macros and variables (except free variables) in Flash Memory as f with macro specified as designated macro

Table 4-2 Flash Memory Remote Commands

COMMAND	RANGE/VALUE	DESCRIPTION
MMEMory:STORe:STATe n,"f"	n is number of stored state of Test Set. Set n from 0 to 9.	Stores entry n of Auxiliary Functions "Store Parameters Menu" as f in Flash Memory. (n=0 stores current state.)
MMEMory:STORe:TRACe:SCOPe n,"f"	n is number of stored trace. Set n from 0 to 9. f is Flash Memory file name.	Stores entry n (stored trace) of Oscilloscope "Store Parameters Menu" as f in Flash Memory. (n=0 stores live trace.)
MMEMory:STORe:TRACe:ANLZ n,"f"	n is number of stored trace. Set n from 0 to 9. f is Flash Memory file name.	Stores entry n (stored trace) of Spectrum Analyzer "Store Parameters Menu" as f in Flash Memory. (n=0 stores live trace.)
MMEMory:STORe:DATA v,"f"	v is name of variable. f is Flash Memory file name.	Stores variable v into Flash Memory as f.
MMEMory:STORe:CALibration "f"	f is Flash Memory file name.	Stores Test Set Calibration Data into Flash Memory.
MMEMory:TYPE? "f"	f is Flash Memory file name.	Returns file type. Returns null string if file does not exist.

Table 4-2 Flash Memory Remote Commands (continued)

Error messages are returned to Host when an error occurs. Refer to Table 4-3 for description of error messages.

ERROR NUMBER	ERROR DEFINITION	DESCRIPTION
220	Parameter Error	Incorrect number of parameters were entered with command.
224	Illegal Parameter Value	A parameter entered was not appropriate for command.
225	Out of Memory	Insufficient memory space to perform command.
250	Flash Storage Error	Indicates Flash Memory could not be erased or data could not be stored in Flash Memory.
253	Corrupt Media	Indicates Flash Memory not properly initialized. Initialize Flash Memory.
254	Media Full	Indicates insufficient Flash Memory space to perform command.
255	Directory Full	Indicates command not performed because 512 file names have been used.
256	File Name Not Found	Specified file not stored in Flash Memory.
257	File Name Error	Indicates command attempted to create file name already stored or file name syntax incorrect.

Table 4-3 Flash Memory Error Messages

4-15 GENERIC MEASURE COMMANDS

Generic commands use optional values, e to signify expected value and r to signify resolution. Expected values help determine Meter range. If r is omitted, the last resolution value is used.

MEASure:

AUDio? e, r

Returns an AF Meter frequency counter reading in Hz (0.0 to 200000.0).

CURRent:

AC? e

Returns a DMM ac current reading in amps (0.00000 to 19.990).

DC? e

Returns a DMM dc current reading in amps (0.00000 to 19.990).

FREQuency? e, r

Returns signal frequency reading in kHz (250.0 to 999999.9 kHz).

MIC?

Returns a 0 if receiving MIC/ACC Input or 1 otherwise.

PHASe? e

Returns a Phase Meter reading in radians (0.00 to 10.00).

POWer? e

Returns a Power Meter reading in mW (0.0 to 100000.0).

RESistance? e

Returns a DMM resistance reading in $k\Omega$ (0.0000 to 19990).

SINAD? r

Returns a SINAD Meter reading in dB (3.0 to 40.0). Select .1 or .5 as optional r in dB.

SQUelch?

Returns a 1 if squelch broken, 0 if squelch is unbroken.

TEMPerature:

AMBient?

Returns the ambient temperature in °C (0.00000 to 100.00000).

POWer?

Returns the Power Termination temperature in °C (0.00000 to 100.00000).

VOLTage:

ACT A

Returns a DMM ac voltage reading in volts (0.0000 to 1000.00).

DC?e

Returns a DMM dc voltage reading in volts (0.0000 to 1000.00).

MEASure:

VOLTage:SUPply? n

Returns a voltage measurement of n power supply in volts (0.00 to 20.00). Select -15, 5 or 15 for n.

4-16 INITIATE AND FETCH COMMANDS

INITiate and FETCh commands break the measure process into two commands. INITiate commands prepare the meter and FETCh commands return the reading. The event register of the Operation Instrument Status Register indicates when an INITiate command is completed (see example). Table 3-6 displays the Operation Instrument Status bits.

INITiate:

AF

Prepares the Audio Frequency Meter for a FETCh: command to take a reading.

DMM

Prepares the Audio Frequency Meter for a FETCh: command to take a reading.

RF

Prepares the Frequency Error Meter for a FETCh: command to take a reading.

FETCh:

AF?

Returns Audio Frequency Meter reading in kHz. Must be used with INITiate command.

DMM?

Returns Digital Multimeter reading. For ACV and DCV Multimeter Function, reading is returned in V. For ACC and DCC Multimeter Function, reading is returned in A. For Ohm Multimeter Function, reading is returned in $k\Omega$. Must be used with INITiate command.

RF?

Returns Frequency Error Meter reading in kHz. Must be used with INITiate command.

The following example reads the Operation Instrument Register until the RF Meter is ready to be read.

```
Example:
         *DMC "RF Read", BEGIN
                                      // Define macro named RF Read.
         N=0
                                      // Set variable equal to zero.
                                      // Display Frequency Error Meter Operation
         SCREEN: FREQ
                                      // Screen.
         SCREEN: USER
                                      // Display User Screen.
         *CLS
                                      // Clear all condition and event registers.
         INIT: RF
                                      // Initialize for a RF Meter reading.
         WHILE (N&8)=0
                                     // Loop until Frequency Error Meter bit of
           N=STAT:OPER:INSTR:EVENT? // Operation Instrument event register is
                                      // set to 1.
         WEND
         PRINT FETCH:RF?
                                      // Print Frequency Error Meter reading.
         END
                                      // End of macro RF Read.
```

SECTION 5 - 1600S QUICK REFERENCE LIST

The 1600S Quick Reference List is a brief listing of the Specific and most General TMAC commands used with the FM/AM-1600S. The Quick Reference List is an aid to the experienced TMAC user. If more detailed information is needed, refer to the specified page.

COMMAND RANGE PAGE DESCRIPTION

AF GENERATOR COMMANDS

GEN:			
DATA:			
MODL n	0.0 to 100.0, (%/AM) 0.0 to 25.0 (kHz/FM),	4-38	Sets Data Generator Modulation level.
	0.0 to 10.0 (radians/PM)		
MODL?		4-38	Returns Data Generator Modulation level setting.
MODulation:type	AM, FM, PM or OFF	4-38	Selects Data Generator Modulation type.
MODulation?	,		Returns selected Data Generator Modulation type.
STATe b	1 or 0		Enables/Disables Data Generator.
EXT:	, 0, 5		
	0 to 100 (%)	4.28	Sets External Modulation Proportional output level.
LEVel n	0 10 100 (76)	4.00	Returns External Modulation Proportional output level
LEVel?		4-30	
			setting.
MODL n	0.0 to 100.0, (%/AM)	4-38	Sets External Modulation level.
	0.0 to 25.0 (kHz/FM),		
	0.0 to 10.0 (radians/PM)		
MODL?		4-38	Returns External Modulation level setting.
MODulation:type	AM, FM, PM or OFF	4-38	Selects External Modulation type.
MODulation?	•	4-39	Returns selected External Modulation type.
STATe b	1 or 0		Enables/Disables External Modulation.
GEN1:	7 01 0	,	
	0.0 to 40000.0	4-20	Sets AF Generator 1 frequency in Hz.
FREQuency f	0.0 10 40000.0		Returns AF Generator 1 frequency setting in Hz.
FREQuency?	0 1 400 (0()	4-39	Och AC Occupant Department systems in 12.
LEVel n	0 to 100 (%)	4-39	Sets AF Generator 1 Proportional output level.
LEVel?			Returns set AF Generator 1 Proportional output level.
MODL n	0.0 to 100.0, (%/AM)	4-39	Sets AF Generator 1 Modulation level.
	0.0 to 25.0 (kHz/FM),		
	0.0 to 10.0 (radians/PM)		
MODL?	·	4-39	Returns AF Generator 1 Modulation level.
MODulation:type	AM, FM, PM or OFF	4-39	Selects AF Generator 1 Modulation type.
MODulation?	, , , , , , , , , , , , , , , , , , , ,	4-40	
SHAPE:			••
DC n	1, 0 or -1	4-40	Selects dc level for AF Generator 1 wave shape.
PULse:DCYCLe 50	1,00,-1	4-40	
		4-40	
RAMP			
SIN			Selects sine wave shape for AF Generator 1.
squ		4-40	
TRI		4-40	,
STATe b	1 or 0	4-40	Enables/Disables AF Generator 1.
GEN2:			
FREQuency f	0.0 to 40000.0	4-39	Sets AF Generator 2 frequency in Hz.
FREQuency?		4-39	Returns AF Generator 2 frequency setting in Hz.
LEVel n	0 to 100 (%)	4-39	Sets AF Generator 2 Proportional output level.
LEVel?		4-39	
MODL n	0.0 to 100.0, (%/AM)		Sets AF Generator 2 Modulation level.
WODL //	0.0 to 25.0 (kHz/FM),	7 00	Coto /// Conscience in a made and in the first
	0.0 to 10.0 (radians/PM)		
	0.0 to 10.0 (radians/FW)	4.00	Returns AF Generator 2 Modulation level.
MODL?		4-39	
MODulation: <i>type</i>	AM, FM, PM or OFF	4-39	Selects AF Generator 2 Modulation type.
MODulation?		4-40	Returns selected AF Generator 2 Modulation type.
SHAPE:			
DC n	1, 0 or -1	4-40	Selects dc level for AF Generator 2 wave shape.
PULse:DCYCLe 50		4-40	Selects Pulse (50% duty cycle) for AF Generator 2.
RAMP		4-40	Selects ramp wave shape for AF Generator 2.
SIN		4-40	
SQU		4-40	Selects square wave shape for AF Generator 2.
TRI		4-40	Selects triangle wave shape for AF Generator 2.
	1 0" 0	4-40	Enables/Disables AF Generator 2.
STATe b	1 or 0	4-40	Endures/Pisavies At Generalul L.

COMMAND	RANGE	PAGE	DESCRIPTION
FGEN:		, ,	
GEN3:			
DIGital type	DCSINV, POCSAG, DCS, DSAT or DST	4-41	Selects digital encoding type.
ENCODE type	DTMF, TONE, DIGital or RCC	4-41	Selects signalling format to encode.
MODL n	0.0 to 100.0, (%/AM) 0.0 to 100.0 (kHz/FM/ Tone or RCC), 0.0 to 10.0 (kHz/FM/DTMF), 0. to 25.0 (kHz/FM/Digital) 0.0 to 10.0 (radians/PM)	,	Sets AF Generator 3 Modulation level.
MODL?		4-41	Returns AF Generator 3 Modulation level setting.
MODulation: <i>type</i> MODulation?	AM, FM, PM or OFF	4-41 4-41	Selects AF Generator 3 Modulation type. Returns selected AF Generator 3 Modulation type.
MIC:			The state of the s
LEVel n LEVel?	0 to 100 (%)	4-41 4-41	The state of the s
MODL n	0.0 to 100.0, (%/AM) 0.0 to 25.0 (kHz/FM), 0.0 to 10.0 (radians/PM)	4-41	
MODL?	0.0 to 10.0 (ladialis/FM)	4-41	Returns set MIC/ACC Composter innut Madulation Local
MODulation:	AM, FM, PM or OFF	4-41	Returns set MIC/ACC Connector input Modulation level. Selects MIC/ACC Connector Modulation type.
MODulation?	,,		Returns selected MIC/ACC Connector Modulation type.
STATe b	1 or 0	4-42	Enables/Disables MIC/ACC Connector Modulation.
OUTput:			
AUDio b	1 or 0	4-42	Enables/Disables AF Generator output to AUDIO OUT Connector.
AUDio?		4-42	Returns AUDIO OUT Connector routing status.
DEMod b	1 or 0	4-42	Enables/Disables AF Generator output to DEMOD OUT Connector.
DEMod?		4-42	
LEVel v	0 to 3.1000	4-42	
LEVel? SPEAKer <i>b</i>	1 or 0	4-43 4-43	Returns AF Generator output level setting in volts. Enables/Disables AF Generator output to Test Set Speaker.
SPEAKer?		4-43	Returns Test Set Speaker routing status.
PROPortional b	1 or 0	4-43	Enables/Disables Proportional mode for AF Generator.
PROPortional?		4-43	Returns Proportional mode status.
RCL n	1 to 9	4-43	Recalls stored AF Generator environment.
STORe n	1 to 9	4-43	Stores current AF Generator environment.
PTT:STATe b	1 or 0	4-42	Sets push to talk pin on MIC/ACC Connector.
AF LEVEL METER COMMAN	NDS		
M_VRMS?		4-89	Returns voltage RMS reading of received AF level.
AF METER COMMANDS			
M_AF:			
ALARM <i>b</i> FILTer:	1 or 0	4-64	Enables/Disables Alarm for Upper or Lower Limit.
HPASs:			
FREQuency f	0.5 to 20.0	4-64	Sets High-Pass Filter cutoff frequency in kHz.
FREQuency?	4 6	4-64	Returns High-Pass Filter cutoff frequency setting (kHz).
STATe b STATe?	1 or 0		Enables/Disables High-Pass Filter.
LPASs:		4-64	Returns High-Pass Filter State.
FREQuency f FREQuency?	0.1 to 30.0	4-64	Selects Low-Pass Filter cutoff frequency in kHz.
STATe b	1 or 0	4-04 1-64	Returns Low-Pass Filter cutoff frequency setting (kHz).
STATe D	, 01 0	4-64 4-64	Enables/Disables Low-Pass Filter. Returns Low-Pass Filter State.
INPut: type	XAUDIO, SINAD, DEMOD, POWer or FGEN		Selects AF Meter Input.

COMMAND	RANGE	PAGE	DESCRIPTION
/_AF:			
LL:			
LEVel f	0.0000 to 200.0	4-65	Sets Lower Limit level in kHz.
STATe b	1 or 0	4-65	Enables/Disables Lower Limit.
PEAK?		4-65	Returns AF Meter Peak reading in Hz.
PH <i>b</i>	1 or 0		Enables/Disables AF Meter Peak Hold Feature.
RANGe:			
AUTO		4-65	Selects Autorange for AF Meter Range.
UPPer f	0.2, 2, 20 or 200		Sets AF Meter Range in kHz.
RCL n	1 to 9	4-65	Recalls stored AF Meter environment,
RESolution n	0.1 or 1		Selects AF Meter resolution in Hz.
STORe n	1 to 9		Stores current AF Meter environment.
UL:			
LEVel f	0,0000 to 200,0.	4-66	Sets Upper Limit Level in kHz.
STATe b	1 or 0	4-66	Enables/Disables Upper Limit.
1_AF?		4-66	Returns AF Meter reading in Hz.

ANALYZER COMMANDS (SEE SPECTRUM ANALYZER COMMANDS.)

AUXILIARY TEST SET COMMANDS

BIT ERROR RATE METER (BER) COMMANDS

M_BER: PATtern:			
FIXED		4-80	Selects Fixed pattern for BER Meter test data.
RANDom		4-80	
USER nn		4-80	
POLarity:			
NEĞative		4-80	Selects Negative polarity.
POSitive		4-80	, ,
RATE n	75, 150, 300, 600, 1200, 2400, 4800 or 16000	4-81	
RATE?	,	4-81	Returns BER Meter rate setting in bps.
RCL n	1 to 9	4-81	
SIZE n	100 to 100000	4-81	
SIZE?		4-81	
STORe n	1 to 9	4-81	
TYPE:xxx	BASEband, DUPlex, GENerator or RECeiver	4-81	Set Bit Error Rate Type.
M_BER?		4-81	Returns number of errors for last pass.

CELLULAR AMPS COMMANDS

NOTE: Queries for received data, return -1 if data is not available or has already been read.

CELL:			
ACTion?		4-90	Returns Global Action value.
BIS?		4-90	Returns Busy-Idle Status bit value.
B_I?			Returns Busy-Idle bit value.
вотн			Selects words from streams A and B, for decoding.
C12?			Returns C12 bit value.
C13?		4-90	Returns C13 bit value.
CAPTure:			
MIN "xxx/xxx-xx	x=0 to 9, A to D, a to d, x, X, # or *	4-90	Selects MIN to Capture.
MIN?		4-90	Returns MIN currently used for Capture.
MODE:xxx	MIN, ORDer, BOTH or OFF		Selects Capture Mode.
MODE?		4-90	Returns current Capture Mode.

OMMAND	RANGE	PAGE	DESCRIPTION
ELL:			
CAPTure:			
ORDer:xxx	PAGE, ALERT, RELease REORDer, SALERT, SNDAddr, INTERCEPT, MAINTenance, AALERT, DRETRY, AINTERCEPT, AUTREG, AREORDer, POWer, AUDIT, VCDES		Selects Order to capture.
ORDer?			Returns current Order used for capture.
CHANnel n	1 to 1023		Selects Cellular Frequency by channel number.
CHANnel?			Returns currently selected Cellular channel.
CHANPOS1?			Returns Channel Position 1. Returns Channel Position 2.
CHANPOS2? CHANPOS3?			Returns Channel Position 3.
CHANPOSS? CHANPOSS			Returns Channel Position 4.
CHANPOS5?			Returns Channel Position 5.
CHANPOS6?			Returns Channel Position 6.
CMAC?			Returns Control Mobile Attenuation Code.
CMAX_1?		4-91	Returns Number of Access Channels minus one.
CPA?		4-91	Returns Combined Paging/Access.
DCC?		4-91	Returns Digital Color Code.
DIGITs?			Returns Call Address.
DSCC?			Returns Digital SAT Color Code.
DTX?			Returns Discontinuous Transmission.
E?			Returns Extended Address.
EF?			Returns Expanded Protocol Forward Channel Indicato Returns End Indication.
END? EP?			Returns Extended Protocol Capable value.
ESN? FORMat:			Returns Electronic Serial Number.
AMPS		4-92	Sets Channel Format to AMPS.

NT400		4-92	Sets Channel Format to NT400.
NT400 FORMat?			Sets Channel Format to NT400. Returns Channel Format setting.
FORMat? OTE: CELL:GEN commands a	are part of option 10.		
FORMat? OTE: CELL:GEN commands a	are part of option 10.		
FORMat? DTE: CELL:GEN commands a	are part of option 10.	4-92	
FORMat? DTE: CELL:GEN commands a ELL: GEN:		4-92 4-94	Returns Channel Format setting.
FORMat? DTE: CELL:GEN commands a ELL: GEN: CHANnel n		4-92 4-94 4-94 4-94	Selects AMPS Reverse Channel. Returns AMPS Reverse Channel setting. Sets Digital Color Code.
FORMat? DTE: CELL:GEN commands a ELL: GEN: CHANnel n CHANnel? DCC x DCC?	1 to 1023 0 to 3	4-92 4-94 4-94 4-94	Selects AMPS Reverse Channel. Returns AMPS Reverse Channel setting. Sets Digital Color Code. Returns current Digital Color Code setting.
FORMat? OTE: CELL:GEN commands a ELL: GEN: CHANnel n CHANnel? DCC x DCC? DIGITS "x"	1 to 1023	4-94 4-94 4-94 4-95	Selects AMPS Reverse Channel. Returns AMPS Reverse Channel setting. Sets Digital Color Code. Returns current Digital Color Code setting. Sets simulated Called Address.
FORMat? DTE: CELL:GEN commands a ELL: GEN: CHANnel n CHANnel? DCC x DCC? DIGITS "x" DIGITS?	1 to 1023 0 to 3	4-94 4-94 4-94 4-95	Selects AMPS Reverse Channel. Returns AMPS Reverse Channel setting. Sets Digital Color Code. Returns current Digital Color Code setting.
FORMat? OTE: CELL:GEN commands a ELL: GEN: CHANnel n CHANnel? DCC x DCC? DIGITS "x" DIGITS? ESN: DECimal x DECimal?	1 to 1023 0 to 3	4-94 4-94 4-94 4-95	Selects AMPS Reverse Channel. Returns AMPS Reverse Channel setting. Sets Digital Color Code. Returns current Digital Color Code setting. Sets simulated Called Address. Returns current Called Address setting. Sets Electronic Serial Number (ESN) in decimal.
FORMat? OTE: CELL:GEN commands a ELL: GEN: CHANnel n CHANnel? DCC x DCC? DIGITs "x" DIGITs? ESN: DECimal x	1 to 1023 0 to 3 0 to 999999999999999	4-94 4-94 4-94 4-95 4-95 4-95	Selects AMPS Reverse Channel. Returns AMPS Reverse Channel setting. Sets Digital Color Code. Returns current Digital Color Code setting. Sets simulated Called Address. Returns current Called Address setting. Sets Electronic Serial Number (ESN) in decimal.
FORMat? DTE: CELL:GEN commands a ELL: GEN: CHANNel n CHANNel? DCC x DCC? DIGITS "x" DIGITS? ESN: DECimal x DECimal? FORMat:	1 to 1023 0 to 3 0 to 999999999999999	4-94 4-94 4-94 4-95 4-95 4-95	Selects AMPS Reverse Channel. Returns AMPS Reverse Channel setting. Sets Digital Color Code. Returns current Digital Color Code setting. Sets simulated Called Address. Returns current Called Address setting. Sets Electronic Serial Number (ESN) in decimal. Returns ESN setting in decimal.
FORMat? OTE: CELL:GEN commands a ELL: GEN: CHANnel n CHANnel? DCC x DCC? DIGITS "x" DIGITS? ESN: DECimal x DECimal FORMat: DECimal	1 to 1023 0 to 3 0 to 999999999999999	4-94 4-94 4-94 4-95 4-95 4-95 4-95	Selects AMPS Reverse Channel. Returns AMPS Reverse Channel setting. Sets Digital Color Code. Returns current Digital Color Code setting. Sets simulated Called Address. Returns current Called Address setting. Sets Electronic Serial Number (ESN) in decimal. Returns ESN setting in decimal.
FORMat? OTE: CELL:GEN commands a ELL: GEN: CHANnel n CHANnel? DCC x DCC? DIGITS "x" DIGITS? ESN: DECimal x DECimal FORMat: DECimal HEX	1 to 1023 0 to 3 0 to 999999999999999 0 to 23116113919	4-92 4-94 4-94 4-95 4-95 4-95 4-95 4-95 4-95 4-95	Selects AMPS Reverse Channel. Returns AMPS Reverse Channel setting. Sets Digital Color Code. Returns current Digital Color Code setting. Sets simulated Called Address. Returns current Called Address setting. Sets Electronic Serial Number (ESN) in decimal. Returns ESN setting in decimal. Sets ESN screen format to decimal. Sets ESN screen format to hexadecimal. Sets ESN screen format to octal. Returns current ESN format.
FORMat? OTE: CELL:GEN commands a ELL: GEN: CHANNel n CHANNel? DCC x DCC? DIGITS "x" DIGITS? ESN: DECimal x DECimal? FORMat: DECimal HEX OCTal FORMat? HEXadecimal x	1 to 1023 0 to 3 0 to 999999999999999	4-92 4-94 4-94 4-95 4-95 4-95 4-95 4-95 4-95 4-95 4-95 4-95 4-95 4-95 4-95	Selects AMPS Reverse Channel. Returns AMPS Reverse Channel setting. Sets Digital Color Code. Returns current Digital Color Code setting. Sets simulated Called Address. Returns current Called Address setting. Sets Electronic Serial Number (ESN) in decimal. Returns ESN setting in decimal. Sets ESN screen format to decimal. Sets ESN screen format to hexadecimal. Sets ESN screen format to cotal. Returns current ESN format. Sets ESN in hexadecimal format.
FORMat? OTE: CELL:GEN commands a ELL: GEN: CHANnel n CHANnel? DCC x DCC? DIGITS "x" DIGITS? ESN: DECimal x DECimal? FORMat: DECimal HEX OCTal FORMat? HEXadecimal x HEXadecimal?	1 to 1023 0 to 3 0 to 999999999999999 0 to 23116113919 0 to FFFFFFF	4-92 4-94 4-94 4-95 4-95 4-95 4-95 4-95 4-95 4-95 4-95 4-95 4-95 4-95 4-95 4-95 4-95 4-95 4-95 4-95	Selects AMPS Reverse Channel. Returns AMPS Reverse Channel setting. Sets Digital Color Code. Returns current Digital Color Code setting. Sets simulated Called Address. Returns current Called Address setting. Sets Electronic Serial Number (ESN) in decimal. Returns ESN setting in decimal. Sets ESN screen format to decimal. Sets ESN screen format to hexadecimal. Sets ESN screen format to octal. Returns current ESN format. Sets ESN in hexadecimal format. Returns current ESN setting in hexadecimal format.
FORMat? OTE: CELL:GEN commands a ELL: GEN: CHANNel n CHANnel? DCC x DCC? DIGITS "x" DIGITS? ESN: DECimal x DECimal x DECimal HEX OCTal FORMat? HEXadecimal x HEXadecimal? OCTal x	1 to 1023 0 to 3 0 to 999999999999999 0 to 23116113919	4-92 4-94 4-94 4-95	Selects AMPS Reverse Channel. Returns AMPS Reverse Channel setting. Sets Digital Color Code. Returns current Digital Color Code setting. Sets simulated Called Address. Returns current Called Address setting. Sets Electronic Serial Number (ESN) in decimal. Returns ESN setting in decimal. Sets ESN screen format to decimal. Sets ESN screen format to hexadecimal. Sets ESN screen format to octal. Returns current ESN format. Sets ESN in hexadecimal format. Returns current ESN setting in hexadecimal format. Sets ESN in octal format.
FORMat? OTE: CELL:GEN commands a ELL: GEN: CHANnel n CHANnel? DCC x DCC? DIGITS "x" DIGITS? ESN: DECimal x DECimal? FORMat: DECimal HEX OCTal FORMat? HEXadecimal x HEXadecimal? OCTal x OCTal x OCTal x	1 to 1023 0 to 3 0 to 999999999999999 0 to 23116113919 0 to FFFFFFF 0 to 377777777	4-92 4-94 4-94 4-95	Selects AMPS Reverse Channel. Returns AMPS Reverse Channel setting. Sets Digital Color Code. Returns current Digital Color Code setting. Sets simulated Called Address. Returns current Called Address setting. Sets Electronic Serial Number (ESN) in decimal. Returns ESN setting in decimal. Sets ESN screen format to decimal. Sets ESN screen format to hexadecimal. Sets ESN screen format to cotal. Returns current ESN format. Sets ESN in hexadecimal format. Returns current ESN setting in hexadecimal format. Sets ESN in octal format. Returns current ESN setting in hexadecimal format.
FORMat? OTE: CELL:GEN commands a ELL: GEN: CHANnel n CHANnel? DCC x DCC? DIGITS "x" DIGITS? ESN: DECimal x DECimal? FORMat: DECimal HEX OCTal FORMat? HEXadecimal x HEXadecimal? OCTal x OCTal x OCTal? MIN "xxx/xxx-xxxx"	1 to 1023 0 to 3 0 to 999999999999999 0 to 23116113919 0 to FFFFFFF	4-92 4-94 4-94 4-95	Selects AMPS Reverse Channel. Returns AMPS Reverse Channel setting. Sets Digital Color Code. Returns current Digital Color Code setting. Sets simulated Called Address. Returns current Called Address setting. Sets Electronic Serial Number (ESN) in decimal. Returns ESN setting in decimal. Sets ESN screen format to decimal. Sets ESN screen format to hexadecimal. Sets ESN screen format to cotal. Returns current ESN format. Sets ESN in hexadecimal format. Returns current ESN setting in hexadecimal format. Sets ESN in octal format. Returns current ESN setting in hexadecimal format. Sets ESN in octal format. Returns current ESN setting in octal format. Sets simulated MIN.
FORMat? OTE: CELL:GEN commands a ELL: GEN: CHANNel n CHANnel? DCC x DCC? DIGITS "x" DIGITS? ESN: DECimal x DECimal? FORMat: DECimal HEX OCTal FORMat? HEXadecimal x HEXadecimal? OCTal x OCTal x OCTal x OCTal? MIN "xxx/xxx-xxxx" MIN?	1 to 1023 0 to 3 0 to 9999999999999999 0 to 23116113919 0 to FFFFFFF 0 to 377777777 x=0 to 9	4-92 4-94 4-94 4-95	Selects AMPS Reverse Channel. Returns AMPS Reverse Channel setting. Sets Digital Color Code. Returns current Digital Color Code setting. Sets simulated Called Address. Returns current Called Address setting. Sets Electronic Serial Number (ESN) in decimal. Returns ESN setting in decimal. Sets ESN screen format to decimal. Sets ESN screen format to hexadecimal. Sets ESN screen format to octal. Returns current ESN format. Sets ESN in hexadecimal format. Returns current ESN setting in hexadecimal format. Sets ESN in octal format. Returns current ESN setting in octal format. Sets simulated MIN. Returns current MIN setting.
FORMat? DTE: CELL:GEN commands a ELL: GEN: CHANNel n CHANNel? DCC x DCC? DIGITS "x" DIGITS? ESN: DECimal x DECimal? FORMat: DECimal HEX OCTal FORMat? HEXadecimal? OCTal x	1 to 1023 0 to 3 0 to 999999999999999 0 to 23116113919 0 to FFFFFFF 0 to 377777777	4-92 4-94 4-94 4-95	Selects AMPS Reverse Channel. Returns AMPS Reverse Channel setting. Sets Digital Color Code. Returns current Digital Color Code setting. Sets simulated Called Address. Returns current Called Address setting. Sets Electronic Serial Number (ESN) in decimal. Returns ESN setting in decimal. Sets ESN screen format to decimal. Sets ESN screen format to hexadecimal. Sets ESN screen format to octal. Returns current ESN format. Sets ESN in hexadecimal format. Returns current ESN setting in hexadecimal format. Sets ESN in octal format. Returns current ESN setting in octal format. Sets simulated MIN. Returns current MIN setting. Sets Cellular Deviation Level in kHz.
FORMat? OTE: CELL:GEN commands a ELL: GEN: CHANNel n CHANNel? DCC x DCC? DIGITS "x" DIGITS? ESN: DECimal x DECimal? FORMat: DECimal HEX OCTal FORMat? HEXadecimal x HEXadecimal? OCTal x OCTal x OCTal? MIN "xxx/xxx-xxxx" MIN? MODL f MODL? RECC:	1 to 1023 0 to 3 0 to 9999999999999999 0 to 23116113919 0 to FFFFFFF 0 to 377777777 x=0 to 9	4-92 4-94 4-94 4-95	Selects AMPS Reverse Channel. Returns AMPS Reverse Channel setting. Sets Digital Color Code. Returns current Digital Color Code setting. Sets simulated Called Address. Returns current Called Address setting. Sets Electronic Serial Number (ESN) in decimal. Returns ESN setting in decimal. Sets ESN screen format to decimal. Sets ESN screen format to hexadecimal. Sets ESN screen format to octal. Returns current ESN format. Sets ESN in hexadecimal format. Returns current ESN setting in hexadecimal format. Sets ESN in octal format. Returns current ESN setting in octal format. Sets simulated MIN. Returns current MIN setting. Sets Cellular Deviation Level setting in kit
FORMat? DTE: CELL:GEN commands a ELL: GEN: CHANNel n CHANNel? DCC x DCC? DIGITS "x" DIGITS? ESN: DECimal x DECimal? FORMat: DECimal HEX OCTal FORMat? HEXadecimal? OCTal x	1 to 1023 0 to 3 0 to 9999999999999999 0 to 23116113919 0 to FFFFFFF 0 to 377777777 x=0 to 9	4-92 4-94 4-94 4-95	Selects AMPS Reverse Channel. Returns AMPS Reverse Channel setting. Sets Digital Color Code. Returns current Digital Color Code setting. Sets simulated Called Address. Returns current Called Address setting. Sets Electronic Serial Number (ESN) in decimal. Returns ESN setting in decimal. Sets ESN screen format to decimal. Sets ESN screen format to hexadecimal. Sets ESN screen format to octal. Returns current ESN format. Sets ESN in hexadecimal format. Returns current ESN setting in hexadecimal format. Sets ESN in octal format. Returns current ESN setting in octal format. Sets simulated MIN. Returns current MIN setting. Sets Cellular Deviation Level in kHz.
FORMat? OTE: CELL:GEN commands at ELL: GEN: CHANNel n CHANNel? DCC x DCC? DIGITS "x" DIGITS? ESN: DECimal x DECimal? FORMat: DECimal HEX OCTal FORMat? HEXadecimal x HEXadecimal? OCTal x OCTal x OCTal? MIN "xxx/xxx-xxxx" MIN? MODL f MODL f MODL? RECC: CONTinuous ONCE	1 to 1023 0 to 3 0 to 9999999999999999 0 to 23116113919 0 to FFFFFFF 0 to 377777777 x=0 to 9	4-92 4-94 4-94 4-95	Selects AMPS Reverse Channel. Returns AMPS Reverse Channel setting. Sets Digital Color Code. Returns current Digital Color Code setting. Sets simulated Called Address. Returns current Called Address setting. Sets Electronic Serial Number (ESN) in decimal. Returns ESN setting in decimal. Sets ESN screen format to decimal. Sets ESN screen format to hexadecimal. Sets ESN screen format to octal. Returns current ESN format. Sets ESN in hexadecimal format. Returns current ESN setting in hexadecimal format. Sets ESN in octal format. Returns current ESN setting in octal format. Sets simulated MIN. Returns current MIN setting. Sets Cellular Deviation Level in kHz. Returns current Cellular Deviation Level setting in kH. Sends last order selected continuously to Cell Site.

COMMAND	RANGE	PAGE	DESCRIPTION
CELL:			
GEN:			
RECC:			
ORDer:			
ORIGIN		4-96	Selects Origination as Order to send.
PAGE		4-96	Selects Page Response as Order to send.
ORDer?		4-96	Returns current Order selected to send to Cell Site.
STOP		4-96	
RVC:			·
CONTinuous		4-96	Sends last order selected continuously to Cell Site.
ONCE		4-96	Sends last order selected to Cell Site one time.
ORDer:			
AUDIT		4-97	Selects Audit as Order to send.
POWer x	0 TO 7	4-97	Selects Power Level x as Order to send.
SENDCall		4-97	Selects Send Called Address as Order to send.
SNREQuest		4-97	Selects Autonomous Registration as Order to send.
ORDer?		4-97	the service of the service to serie to dell offe.
STOP SCM:		4-97	Stops transmission of Order sent continuously.
	00 00		
BANDwidth x BANDwidth?	20 or 25	4-97	TOTAL MICE OF HOME DAMANIAN IN MILE.
	4 4 . 4	4-97	Returns current Mobile Phone Bandwidth setting.
POWer x	1 to 4	4-97	Selects Power Level of simulated Mobile Phone.
POWer?		4-97	Returns current Power Level setting.
TRANsmit:			
CONTinuous DISCONTinuous		4-97	
TRANsmit?			Selects Discontinuous Transmission.
LOCALCTRL1?		4-97	the state of the s
LOCALCTRL2?		4-92	
MAXBusy:		4-92	Returns second position Local Control field.
OTHer?			
PGR?		4-92	
MAXSztr:		4-92	Returns Max # of busy incidents (Page responses).
OTHer?		4.00	B.A. 14 W. 4 A. 1 B. 1
PGR?		4-93	Returns Max # of seizure tries (Non-Page responses).
MIN?		4-93	Returns Max # of seizure tries (Page responses).
MSL		4-93	Returns Mobile Identification Number as a string.
MST?		4-93	Returns Message Length.
N_1?			Returns Message Type.
NAWC?		4-93	
NEWACC?		4-93	Returns Number of Additional Words Coming.
OLC?		4.93	Returns New Access Channel starting point.
ORDer?		4-93 4 00	Returns Overload Control Class.
PDSCC?		4-93	Returns current Order as string.
PSCC?		4-93	Returns Present Digital SAT Color Code.
RCF?		4-93	Returns Present SAT Color Code.
REGH?		4-93 4-93	Returns Read Control-Filler,
REGID?		4-93 4-93	Returns Registration for Home Mobile Stations.
REGINCR?		4-94	Returns Registration Identification.
REGR?		4-94	Returns Registration Increment.
S?		4-94	Returns Registration for Roaming Mobile Stations.
SCC?		4-94	Returns Serial Number bit value.
SID?		4-94	Returns Supervisory Audio Tone Color Code.
VCHAN?		4-94	Returns System Identification Number. Returns Voice Channel
VMAC?		4-94	
WFOM?		4-94	Returns Voice Mobile Attenuation Code.
WORD?		4-94 4-94	Returns Wait For Overhead Message bit value.
WORDA		4-94	The same designation (it distants it distants of DO 111),
WORDB			Selects Stream A words for decoding.
		4-24	Selects Stream B words for decoding.

COMMAND	RANGE	PAGE	DESCRIPTION
DEFINE COMMANDS			
*DMC "name, command; CONST name,expression DATA name={expression,} FORMat X	BINary, OCTal,	3-54 3-55	
STRING name,,name STRING name[n],,name[n]	HEXadecimal or ASCii	3-84 3-84	Declares string variables. Declares string arrays with index [n] ([n] mandatory, not optional).
VAR name,,name VAR name[n],,name[n]		3-86 3-86	Declares variables.
DEVIATION METER (Peak)	COMMANDS		
M_DEV:			
ALARM b AVErage b LL:	1 or 0 1 or 0	4-71 4-71	
LEVel f STATe b MODE:	0.00 to 100.00 1 or 0	4-71 4-71	1 /
BOTH		4-71	Selects Both Mode (positive and negative).
NEGative		4-71	Selects Negative Mode.
NORMalize		4-71	
POSitive NEG?			Selects Positive Mode. Returns Negative Deviation in kHz.
PEAK:			
NEG?			Returns Negative Peak Deviation in kHz.
POS? PH <i>b</i>	1 or 0		Returns Positive Peak Deviation kHz. Enables/Disables Peak Hold Feature.
POS?	1 01 0		Returns Positive Deviation in kHz.
RANGe:		-7 , L	Trocards 1 dollars Bornards III M.Z.
AUTO			Selects Autorange for Deviation Meter Range.
UPPer f	2, 5, 10, 20, 50 or 100		Selects Deviation Meter Range in kHz.
RCL n STORe n UL:	1 to 9 1 to 9		Recalls stored Deviation Meter (Peak) environment. Stores current Deviation Meter (Peak) environment.
LEVel f STATe b	0.00 to 100.00 1 or 0	4-73 4-73	1 7
DEVIATION METER (RMS)	COMMANDS		
M_DRMS:			
ALARM b	1 or 0	4-86	• • • • • • • • • • • • • • • • • • •
AVErage b	1 or 0	4-86	Enables/Disables Averaging.
LL: LEVel f	0.00 to 10.00	4-86	Sets Lower Limit Level in kHz.
STATe b	1 or 0	87	Enables/Disables Lower Limit.
PH b	1 or 0	87	Enables/Disables Peak Hold Feature.
RANGE:		0.7	Solosto Autorango for Motor Pango
AUTO UPPer n	2, 5 or 10	87 87	Selects Autorange for Meter Range. Sets Meter Range in kHz.
RCL n	1 to 9	4-86	
STORe n	1 to 9	4-86	
UL:	0.00 to 10.00	1 07	Sate Hanar Limit Laval in EU-
LEVel <i>f</i> STATe <i>b</i>	0.00 to 10.00 1 or 0	4-87 4-87	
M_DRMS?	, 51 0	4-87	
DIGITAL MULTIMETER (DM	M) COMMANDS		
M_DMM: ALARM <i>b</i>	1 or 0	4-82	Enables/Disables Alarm for Upper or Lower Limit.

COMMAND	RANGE	PAGE	DESCRIPTION
M_DMM: FUNCtion:			
CURRent;		4 00	Colored to Constitution of Colored to Colore
AC DC			Selects ac Current Meter as DMM function. Selects dc Current Meter as DMM function.
RESistance			Selects Ohmmeter as DMM function.
VOLTage:			4
AC		4-82	Selects ac Voltmeter as DMM function.
DC			Selects dc Voltmeter as DMM function.
FUNCtion? INPut:IMPedance n	150 000 100	4-82	Returns current DMM function. Sets ac Voltmeter Load in ohms.
LL:	150, 600 or 1e6	4-02	Sets ac voltmeter Load in onms.
LEVel n		4-82	Sets Lower Limit for current function.
STATe b	1 or 0	4-82	Enables/Disables Lower Limit for current function.
PH b	1 or 0	4-83	Enables/Disables Peak Hold Feature.
RANGe: AUTO		4 00	Cafasta Automora for Materia Day
UPPer n	0.2, 2, 20, 200 or 2000 (VAC or Vdc); 0.2, 2, 20	4-83 4-83	5
	200, 2000 or 20000 (Ω); 0.02, 0.2, 2 or 20 (A)		
RCL n	1 to 9	4-83	Recalls stored Digital Multimeter environment.
STORe n UL:	1 to 9	4-83	Stores current Digital Multimeter environment.
LEVel n		4-83	Sets Upper Limit for current function.
STATe b	1 or 0	4-83	• •
M_DMM?		4-84	Returns DMM reading in amps, volts or ohms.
DISPLAY COMMANDS			
BCOLOR b	0 to 15 or name	3-25	Sets background color.
BOX f, x1, y1, x2, y2, c	1 or 0, 0 to 639,		Creates box on CRT display.
	0 to 349, 0 to 639,		• •
01.0	0 to 349, 0 to 15		
CLS		3-54	Clears display screen or selected window of everything except active readings.
COLOR f,c	0 to 15 or name,	3-25	Sets foreground and character contrast colors.
	0 to 15 or name		
COLOR?		3-25	
DRAW x1, y1, x2, y2, c	0 to 639, 0 to 349, 0 to 639, 0 to 349, 0 to 15	3-58	Creates line on CRT display.
EDIT:	039, 0 10 349, 0 10 13		
COLOR:			
LETTER ¢	0 to 15 or name	3-25	Sets menu letter color.
LETTER?			Sets menu letter color setting.
MENU c MENU?	0 to 15 or name		Sets menu color. Sets menu color setting.
SOFT:		3-23	Sets menu color setting,
BOX c BOX?	0 to 15 or name	3-26 3-26	Sets Soft Function Key background color. Returns Soft Function Key background color setting.
LETTER c LETTER?	0 to 15 or name	3-26 3-26	• • • • • • • • • • • • • • • • • • • •
SELECT ¢	0 to 15 or name	3-26	Sets Soft Function Key selected color.
SELECT? WIDTH n	0 to 639	3-26	Returns Soft Function Key selected color setting.
ELLIPSE b,x,y,r,a,c	0 or 1, 0 to 639, 0 to	3-26 3-30	Sets width of blinking cursor for INPUT command. Creates an ellipse on CRT display.
	349, (r&a vary), 0 to 15	0 00	ordates an empse on our display.
HEIGHT n	1 to 4	3-64	Sets height of text from 0.175 to 0.7 inches.
ICON b,r,name	0 to 639, 0 to 349	3-30	Creates bit pattern graphic on CRT display.
PPRINT %0nl, expression,		3-77 3-78	Displays point at current xy position on CRT.
PRINT %Onl, expression,\ expression,, expression,		3-79	Prints expression out 1600S RS-232 Connector. Prints expression at current xy position on CRT.
PSCREEN		3-80	Prints CRT screen out 1600S RS-232 Connector.
ROTATE n	0,90,180 or 270	3-82	
SCREEN:USER	0.1.000	3-26	Clears display screen or active window of everything.
XY n, m	0 to 639, 0 to 349	3-90	Sets xy position for other display commands.

COMMAND	RANGE	PAGE	DESCRIPTION
DISTORTION METER COMM	ANDS		
M_DIST:			
ALARM b	1 or 0	4-76	Enables/Disables Alarm for Upper or Lower Limit.
AVErage b	1 or 0		Enables/Disables Averaging.
FILTer f	600 to 1400		Sets Notch Filter Frequency in Hz.
INPut:type	DEMOD, SINAD,		Selects Distortion Meter Input.
,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	XAUDIO or FGEN	., , ,	ocioto biotordon motor input.
LL:	ANODIO OI I GEIT		
LEVel n	0.0 to 20.0	4-76	Sets Lower Limit Level in percent.
STATe b	1 or 0		Enables/Disables Lower Limit.
PEAK?	1 01 0		
FEAR!		4-70	Returns Distortion Meter Peak reading in percent.
PH b	1 or 0	4-76	Enables/Disables Peak Hold Feature.
RCL n	1 to 9		Recalls stored Distortion Meter environment.
SELect:	1 10 9	4-70	necans stored distortion water environment.
		4 77	Calasta C Majaht Filton
CWEight	400 : 00000		Selects C-Weight Filter.
LPASs f	100 to 30000	4-77	
STORe n	1 to 9	4-77	Stores current Distortion Meter environment.
UL:			
LEVel n	0.0 to 20.0	4-77	, ,
STATe b	1 or 0	4-77	Enables/Disables Upper Limit.
M_DIST?		4-77	Returns Distortion Meter reading.
DUPLEX COMMANDS			
DOLFEY COMMEMBED			
DUPlex:			b.
INPut:			
AGC:			
AUTO		4-29	Sets AGC to automatic setting.
MANual n	0 to 255		Sets AGC to manual setting.
USER:xxx	MEASure, SPeech,		Sets AGC to User setting.
	DATA, HIGH, TYPE1		
	TYPE2 or TYPE3.		
ANTenna	111 22 0, 111 20.	4-30	Selects ANTENNA IN Connector for Duplex Tx input.
ATTenuation n	0, 20 or 40	4-30	·
CHANnel n	1 to 1023	4-30	Selects Duplex Transmitter channel.
CHANnel:	1 10 1023	4"30	Selects Buplex Hallstillter channel.
FORMat:			
AMPS:			
FORward			Selects AMPS Forward channels for Channel Mode.
REVerse		4-30	Selects AMPS Reverse channels for Channel Mode.
ETACS:			
FORward		4-30	
REVerse		4-30	Selects ETACS Reverse channels for Channel Mode.
NAMPS:			
FORward		4-30	Selects NAMPS Forward channels for Channel Mode.
REVerse		4-30	Selects NAMPS Reverse channels for Channel Mode.
NT400:			
FORward		4-30	Selects NT400 Forward channels for Channel Mode.
REVerse		4-30	Selects NT400 Reverse channels for Channel Mode.
FORMat?		4-31	Returns Duplex Transmitter channel format setting.
FIND:			•
FREQuency?		4-31	Returns first frequency with amplitude > reference.
REFerence n		4-31	Sets Find frequency reference level in dB.
REFerence?		4-31	Returns Find frequency reference level setting in dB.
FREQuency f [units]	250.0 to 999999.9	4-31	Sets Duplex Transmitter Frequency in kHz or selected
FREQuency I familis			optional units.
EDEOugange?	(kHz); HZ, KHZ or MHZ	4-31	Returns Duplex Transmitter frequency setting in kHz.
FREQuency? METER:		4-31	neturns bupies transmitter hequency setting in kmz.
		4.04	Disalasa Daviatina Makaa (DMC)/Dualay Vasta One
DEVRms		4-31	Displays Deviation Meter (RMS)/Duplex Xmtr Opn
DICT		4 04	Screen.
DISTortion		4-31	Displays Distortion Meter/Duplex Xmtr Opn Screen.
MODMeter		4-31	Displays Modulation Meter/Duplex Xmtr Opn Screen.
PMRms		4-31	Displays Phase Meter (RMS)/Duplex Xmtr Opn Screen.
SINAD	m., m	4-31	Displays SINAD Meter/Duplex Xmtr Opn Screen.
MODE xxx	DIRect or CHANnel	4-32	Selects Duplex Transmitter Mode.

OMMAND		RANGE	PAGE	DESCRIPTION
UPlex:				
INPut:				
MODulatio	n:			
AM <i>n</i>	,,,	1 or 2	4-32	Selects an Amplitude Modulation.
BFO				Selects Beat Frequency Oscillator Modulation.
FMn		1, 2, 3 or 4		Selects a Frequency Modulation.
LSB		1, 2, 3 01 4		Selects Lower Side Band Modulation.
				Selects Phase Modulation.
PM				
USB			4-32	Selects Upper Side Band Modulation.
USER	•			
	LTer f	3, 30 or 300		Selects User Defined IF Filter in kHz.
M	ODulation: <i>type</i>	FM, AM, USB, LSB,	4-32	Selects User Defined Modulation.
		BFO, PM or DATA		
P	DST:			
	APASs		4-32	Selects All Pass Post Detection Filter.
		0.5 to 20; 0.1 to 30	4-32	Selects Bandpass Post Detection Filter with low a
	2.7.00 7.,777			high cutoff frequencies in kHz.
	CWEight		4.32	Selects C-Weighted Post Detection Filter.
	HPASs f	0.5 to 20	4 22	Selects High-Pass Post Detection Filter with cutof
	MMASS I	0.5 to 20	4-33	
				frequency in kHz.
	LPASs f	0.1 to 30	4-33	Selects Low-Pass Post Detection Filter with cutoff
				frequency in kHz.
MODulatio	in?		4-33	Returns current Duplex Transmitter Modulation.
TO:				
AUDIO) b	1 or 0	4-33	Sets demodulated routing to AUDIO OUT Connect
DEMO	D b	1 or 0	4-33	Sets demodulated routing to DEMOD OUT Connec
SPEA		1 or 0		Sets demodulated routing to Test Set Speaker.
TR		. 0, 0	4-33	Selects T/R Connector as Duplex Transmitter Inpu
			4.00	Octobes 1711 Confector as Espiex Transmitter Inpu
VOLume:	<i>I</i> -	4 0	4-33	Enables/Disables Automatic Volume Control.
AUTO		1 or 0		
AUTO	?		4-33	Returns Automatic Volume Control status.
METER:				
DISTortion	1		4-29	Displays Distortion Meter/Duplex Operation Scree
MODMeter	r		4-29	Displays Modulation Meter/Duplex Operation Scre
OFF			4-29	Disables Modulation, Distortion and SINAD Meters
SINAD			4-29	Displays SINAD Meter/Duplex Operation Screen.
OUTput:				, ,
AUDio b		1 or 0	4-34	Sets AF Generator Output to AUDIO OUT Connect
CHANnel	-	1 to 1023		Selects Duplex Receiver channel.
	! !	1 10 1023	m - O m	Selects Duplex Hecelver Chamies.
CHANnel:				
FORM				
A	MPS:			TO THE AMERICAN TO SECURE A SECURITION OF THE SE
	FORward			Selects AMPS Forward channels for Channel Mod
	REVerse		4-34	Selects AMPS Reverse channels for Channel Mod
E.	TACS:			
	FORward		4-34	Selects ETACS Forward channels for Channel Mo
	REVerse		4-34	Selects ETACS Reverse channels for Channel Mo
N	AMPS:			
14	FORward		4-34	Selects NAMPS Forward channels for Channel Mo
	REVerse		4-34	Selects NAMPS Reverse channels for Channel Mo
**			4-04	Delects Main o Heverse chambers for Chamber and
N	T400:			
	FORward		4-34	Selects NT400 Forward channels for Channel Mod
	REVerse		4-34	
FORM	lat?			Returns Duplex Receiver channel format setting.
DEMOD b		1 or 0	4-35	Sets AF Generator Output to DEMOD OUT Conne-
DUPlex			4-35	Selects DUPLEX OUT Connector as Duplex Recei
- W110/				Output.
EDECHAS	ov flunitel	250.0 to 999999.9	4-35	Sets Duplex Receiver Frequency in kHz or selecte
i WECKNG!!!	cy f [units]			optional units.
EDE0		(kHz); HZ, KHZ or MHZ		
FREQuen	gy ?		4-35	Returns Duplex Receiver frequency setting in kHz
LEVel:				
DBm .		-137.0 to 0.0	4-35	Sets Duplex RF Level in dBm.
DBm?			4-35	Returns Duplex RF Level setting in dBm.

COMMAND	RANGE	PAGE	DESCRIPTION
DUPlex:			
OUTput:			
METER:			
AF		4-36	Displays AF Meter/Duplex Receiver Operation Screen.
DISTortion		4-36	Displays Distortion Meter/Duplex Rovr Opn Screen.
DMM		4-36	Displays Digital Multimeter/Duplex Rovr Opn Screen.
SINAD		4-36	Displays SINAD Meter/Duplex Rovr Opn Screen.
MODE xxx	DIRect or CHANnel	4-36	Selects Duplex Receiver Mode.
OFFSet f	-999749.9 to 999749.9	4-36	Sets Offset Frequency in kHz.
OFFSet?		4-36	Returns Offset Frequency setting in kHz.
TR		4-36	Selects T/R Connector as Duplex Receiver Output.
RCL n	1 to 9	4-29	Recalls stored Duplex environment.
SPEAKer:			·
SOURce type	OFF, FGEN, SINAD or EXT MOD	4-29	Routes selected connector or source to Speaker.
STORe n	1 to 9	4-29	Stores current Duplex environment.

FETCH COMMANDS (SEE INITIATE AND FETCH COMMANDS.)

FREQUENCY ERROR METER COMMANDS

M_RF:			
ALARM <i>b</i>	1 or 0	4-67	Enables/Disables Alarm for Upper or Lower Limit.
LL:			[·]······
LEVel f	0.0000 to 100,000	4-67	Sets Lower Limit Level in kHz.
STATe b	1 or 0	4-67	Enables/Disables Lower Limit.
PEAK?		4-67	Returns Frequency Error Meter Peak reading in Hz.
PH b	1 or 0	4-67	Enables/Disables Peak Hold Feature.
RANGe:			
AUTO		4-67	Selects Autorange for Meter Range.
UPPer f	0.1, 1, 10 or 100	4-67	Sets Meter Range in kHz.
RCL n	1 to 9	4-67	Recalls stored Frequency Error Meter environment.
RESolution f	1 or 10	4-67	Sets Meter Resolution in Hz.
STORe n	1 to 9	4-67	Stores current Frequency Error Meter environment.
UL:			, ,
LEVel f	0,0000 to 100,000	4-68	Sets Upper Limit Level in kHz.
STATe b	1 or 0	4-68	Enables/Disables Upper Limit.
M_RF?		4-68	

FUNCTION GENERATOR COMMANDS (SEE AF GENERATOR COMMANDS.)

GENERATOR COMMANDS (SEE RF GENERATOR COMMANDS.)

GENERIC MEASURE COMMANDS

MEASure: AUDio? [<i>e,r</i>] CURRent:		4-103	Returns AF Meter reading in Hz.
AC? [e]		4-103	Returns DMM ac Current reading in amps.
DC? [e]			Returns DMM dc Current reading in amps.
FREQuency? [9, <i>r</i>]	4-103	Returns signal frequency in kHz.
MIC?		4-103	Returns state of MIC/ACC Connector Input.
PHASe? [<i>e</i>]		4-103	Returns Phase Meter reading in radians.
POWer? [e]		4-103	Returns Power Meter readings in mW.
RESistance? [;]	4-103	Returns DMM Resistance readings in kW.
SINAD? r		4-103	Returns SINAD Meter reading in dB.
SQUelch?		4-103	Returns Squelch state (1 if broken).
TEMPerature:			,
AMBient?		4-103	Returns Ambient temperature in degrees Celsius.
POWer?			Returns Power Term temperature in degrees Celsius.
: VOLTage:			•
AC? [e]		4-103	Returns DMM ac voltage reading in volts.
DC? [e]			Returns DMM dc voltage reading in volts.
SUPply? [r	-15, 5 or	15 4-104	Returns selected Power Supply voltage in volts.
			.,

	COMMAND	RANGE	PAGE	DESCRIPTION
}	IEEE 488.2 COMPLIANCE CO	VMANDS		
	*CLS			Clears all Status Registers to zero.
	*DDT			Defines Device Trigger.
	≱ DMC "name, command;			Defines a macro.
	★ EMC <i>b</i>	1 or 0		Enables/disables macros.
	*EMC?		3-46	Returns enable/disable macros status.
	★ ESE n	0 to 255	3-46	Sets Standard Event Status enable register.
	*ESE?		3-46	Returns Standard Event Status enable register value.
	*ESR?		3-46	Returns Standard Event Status Register value.
	*IDN?		3-49	Returns FM/AM-1600S identification.
	*LMC?		3-46	Returns list of currently defined macros.
	*OPC			Activates bit 0 of Standard Event Status Register when operation finishes.
	*OPC?		3-46	Activates bit 4 of Status Byte when operation finishes.
	*PMC		3-49	Deletes all macros (except predefined) and declared variables from FM/AM-1600S.
	≉RCL n	1 to 9	3-47	Recalls stored FM/AM-1600S environment.
	*RST		3-47	Returns FM/AM-1600S to default settings.
		1 to 9	3-47	Stores current FM/AM-1600S environment.
		0 to 255	3-47	Sets Service Request enable register.
	*SRE?		3-47	Returns Service Request enable register value.
	*STB?		3-47	Returns Status Byte value.
	*TRG		3-47	Executes trigger command as defined by *DDT.
	*TST?		3-47	Performs Self Test/Returns 0 (passed) or 1 (failed).
	*WAI		3-49	Pauses command execution to complete operations.
	INITIATE and FETCH COMMA	NDS		
	FETCh:			
	AF?		4-104	Returns Audio Frequency Meter reading in kHz.
	DMM?		4-104	Returns Digital Multimeter reading in Å, V or kΩ.
i i	RF?			Returns Frequency Error Meter reading in kHz.
ł.	INITiate:			, ,
	AF		4-104	Prepares AF Meter for FETch reading.
	DMM			Prepares DMM for FETch reading.
	RF		4-104	Prepares Frequency Error Meter for FETch reading.
	KEY COMMANDS			
	KEY		3-32	Returns keycode of next Front Panel Key pressed.
	KEY?		3-32	Returns 1 if any Front Panel Key is pressed or 0.
	KEYPAD COMMANDS			
	KEYPAD:			
	CLAIM		3-32	Sends Front Panel Keyboard input to TMAC Interpreter.
	ERASE n	1 to 6	3-73	Erases current Soft Function Key Fn definition.
	LABel n, "Label"	1 to 6	3-74	Creates Label for Soft Function Key Fn.
	SOFT		3-75	Creates Soft Function Key frame in current screen.
	UNCLAIM		3-32	Releases Front Panel Keyboard for normal use.
	MACRO FUNCTION COMMAN	DS		
	BEGIN		3-50	Allows macro to have multiple lines.
	CASE variable			Provides predetermined decision point.
	OF value1: command			•
	OF value2: command			
	OTHERWISE: command			
	DELAY t		3-56	Provides time delay in ms.
	DO sequence UNTIL condition		3-56	Performs set of commands.
	END		3-59	Ends macro.
	ENDCASE		3-52	Ends Case command.
	EXEC address or EXEC & name		3-59	
}	FLUSH		3-60	
/			- 00	

COMMAND	RANGE	PAGE	DESCRIPTION
FOR variable=initial TO endir	g STEP step	3-61	Performs set of commands repeatedly.
NEXT variable FORGET "name"		2.02	Dalahar mana ali di Kasara Hiliana di Kasara d
IF condition sequence; ENDIF	:		Deletes macro called "name" from memory. Provides decision point.
IF condition sequence; ELIF	condition sequence	3-69	
ELIF condition sequence;	ENDIF	0.70	Provide a destata a set a
IF condition sequence ELSE condition sequence	ENDIE	3-70	Provides decision point.
INPUT variable	,	3-72	Allows data entry through RS-232 Connector during macro execution.
INTERP "string;string;;strin	a"	3-72	Executes commands, unknown when macro is defined.
RETURN	3		Returns value from function or returns macro execution to previous macro.
ROOM		3-82	Used with PPRINT to return memory bytes available.
WHILE condition sequence;W	END		Performs set of commands repeatedly until conditional expression is false.
MATHEMATICAL FUNCTION	ON COMMANDS		
ABS(n)		3-13	Produces absolute value of n.
CALCULATE? expression			Calculates expression functions and returns result.
COS(n)		3-14	Produces cosine of n in radians.
EXP(n)			Produces e to the power of n.
FALSE,OFF			Produces 0.
FLOOR(n) LN(n)			Produces truncated value of n.
LOG(n)			Produces natural logarithm (base e) of n. Produces base 10 logarithm of n.
RAND x			Sets seed (starting point) to x for random generator.
RND(n)			Produces random integer between 0 and n.
SIGN(n)			Produces -1 if n<0, 0 if n=0 or 1 if n>0.
SIN(n)			Produces sine of n in radians.
SQR(n)			Produces positive square root of n.
TRUE, ON		3-12	Produces 1.
MASS MEMORY COMMAN	DS		
MMEMory: CATalog:			
ENTRY? n	0 to 512	4-101	Returns line n from Flash Memory File Directory.
FREE?	0 (0 0 12		Returns available file space in bytes.
USED?			Returns used file space in bytes.
CATalog?			Returns Flash Memory status.
DELete "f"			Deletes file with file name f.
INITialize			Erases all files stored in Flash Memory.
INITialize? LOAD:		4-101	Returns 1 for file system initialized or 0 otherwise.
CALibration "f"			Loads Calibration Data from Flash to 1600S Memory.
DATA v,"f"		4-101	Loads variable stored as file name f, from Flash to 1600S Memory as v.
MACRo "m","f"		4-101	Loads macros and variables stored as file name f from Flash to 1600S memory, executing macro m.
STATe n,"f"	0 to 9	4-101	Loads 1600S State stored as f, into Auxiliary Functions "Store Parameters Menu" as entry n.
TRACe:			·
ANLZ n,"f"	0 to 9	4-101	Loads Spectrum Analyzer trace stored as f, into Spectrum Analyzer "Store Parameters Menu" as
SCOPe n,"f"	0 to 9	4-101	entry n. Loads Oscilloscope trace stored as f, into Oscilloscope "Store Parameters Menu" as entry n.
PACK STORe:		4-101	Frees memory space from deleted files.
CALibration "f"		4-102	Stores current Calibration Data as f in Flash Memory.
DATA v,"f"			Stores variable v in Flash Memory as file name f.
MACRo "m","f"		4-101	Stores currently loaded macros and variables as file name f in Flash Memory with designated macro m to activate from Flash Memory File Directory.

COMMAND	RANGE	PAGE	DESCRIPTION
MMEMory:			
STOŘe:			
STATe n,"f"	0 to 9	4-102	Stores entry n of Auxiliary Functions "Store Parameters Menu" as f in Flash Memory.
TRACe: ANLZ n,"f"	0 to 9	4-102	Stores entry n of Spectrum Analyzer "Store
SCOPe n,"f"	0 to 9	4-102	Parameters Menu" as f in Flash Memory. Stores entry n of Oscilloscope "Store Parameters Menu" as f in Flash Memory.
TYPE? "f"		4-102	Returns file type of file name f.
MODULATION METER (AM) COMMANDS		
M_MOD:			
ALARM b	1 or 0	4-74	Enables/Disables Alarm for Upper or Lower Limit.
LEVel n	0.0 to 100.0	4-74	Sets Lower Limit Level in percent.
STATe b	1 or 0		Enables/Disables Lower Limit.
PEAK?		4-74	Returns Modulation Meter Peak reading in percent.
PH <i>b</i>	1 or 0	4-74	Enables/Disables Peak Hold Feature.
RANGe:			
AUTO		4-74	Selects Autorange for Meter Range.
UPPer n	40 or 100	4-74	Selects Meter Range in percent.
RCL n	1 to 9	4-74	Recalls stored Modulation Meter environment.
STORe n	1 to 9	4-74	Stores current Modulation Meter environment.
UL: LEVel <i>n</i>	0.0 to 100.0	4-75	Sets Upper Limit Level in percent.
	1 or 0		Enables/Disables Upper Limit.
STATe b M_MOD?	1 01 0	4-75	Returns Modulation Meter reading in percent.
MULTITASKING MACR	OS COMMANDS		
ACTIVATE "name"		3-50	Puts specified task in schedule queue.
SLEEP "name"		3-83	Removes specified task from schedule queue.
STOP		3-84	Stops all macros.
		3-85	
TASK "name"			Passes command execution to next task in queue.
TPAUSE		3.05	Stops and removes current task from queue.
TSTOP WAKE "name"		3-85	Puts specified task in queue/executes from last stop.
NON-VOLATILE MEMO	RY COMMANDS		
NVRCL name, location		3-76	Recalls variable or array store in NVRAM.
NVSAV name, location		3-76	Stores variable or array in NVRAM.
OSCILLOSCOPE COM	MANDS		
SCOPe:			
ARM		4-45	Arms Oscilloscope if in One shot Mode.
AVErage n	1 to 100	4-45	Selects Average Mode and number of samples.
COMPare n	1 to 9	4-45	Selects Compare Mode with stored trace n.
COUPling type	AC, DC or GROund	4-45	Selects external coupling.
FULL		4-45	Selects full size Oscilloscope display for other Operation Screens.
HORIZontal <i>n</i> INPut: FILTer:	-12 to 12	4-45	Sets Horizontal Time Offset in major divisions.
CWEight:			
STATe b	1 or 0	4-45	Selects C-Weight Filter as Input Filter.
HPASs:			Onto think Dana autoff fanguranau in tella
FREQuen	•	4-45	
STATe b	1 or 0	4-45	Selects High-Pass Filter as Input Filter.
LPASs:			Onto Law Done autoff for manage to bitio
FREQuen			Sets Low-Pass cutoff frequency in kHz.
STATe b	1 or 0	4-45	Selects Low-Pass Filter as Input Filter.

COMMAND	RANGE	PAGE	DESCRIPTION
SCOPe:			
INPut:			
FILTer:			
NOTch:			
FREQuency	0.5 to 1.5	4-46	Sets Notch Filter width in kHz.
STATE	1 or 0		Selects Notch Filter as Input Filter.
INTernal <i>type</i>	IF, DEMOD, POWer,	4-46	Selects Internal Oscilloscope Input.
	SINAD, FUNCtion or		
	XAUDIO		
LEVel n	0 to 255	4-46	Sets Trigger Level.
LIVe [b]	1 or 0	4-46	Selects Live Trace Mode performing SCREEN:SCOPE
			if b is 1. Default b is 1.
MARKer:			
AOFF		4-46	Disable both markers.
DELTA:			
AMPLitude?		4-46	Returns amplitude difference between Trace Marker
DOMANA			crossings in volts.
POINt?		4-46	Returns Marker position difference in graticules.
TIME?	4 0	4-46	Returns difference in Marker time positions in ms.
TRACK b	1 or 0	4-46	Enables/Disables marker tracking.
MARKer1: AMPLitude?		4 4 ***	
POINt n	1 1- 100	4-47	
POINt?	1 to 100	4-4/	Sets Marker 1 position in graticules.
STATe b	1 or 0	4-4/	Returns Marker 1 position in graticules.
STATe?	1 01 0		Enables/Disables Marker 1.
TIME?		4-47	Returns Marker 1 status.
MARKer2:		4-4/	Returns Marker 1 position in ms.
AMPLitude?		447	Returns Vertical value at Marker 2 in volts.
POINt n	1 to 100		Sets Marker 2 position in graticules.
POINt?		4.47	Returns Marker 2 position in graticules.
STATe b	1 or 0	4-47	Enables/Disables Marker 2.
STATe?		4-47	Returns Marker 2 status.
TIME?		4-47	Returns Marker 2 position in ms.
QTR		4-48	Selects 1/4 size Oscilloscope display for other
			Operation Screens.
RCL n	1 to 9	4-48	Recalls stored Oscilloscope Trace and environment.
SCALe n	1 to 50000 (1-2-5	4-48	Sets Scale in mV/div for AC, DC or GND Input.
	sequence);		
	2, 4, 10 or 20;		Sets Scale in kHz/div for FM Demod Audio Input.
	500, 1000 or 2500		Sets Scale in mV/div for Func Gen or Ext Mod Input.
SCALe?		4-48	Returns Scope Scale.
SOURce type	EXTernal or INTernal	4-48	Selects Input type.
STATe b	1 or 0	4-48	Enables/Disables Scope display in other Operation
0.7.0.0			Screens.
STORe n	1 to 9	4-48	Stores current Oscilloscope Trace and environment.
SWEep t	1 to 100000 (1-2-5	4-49	Sets Oscilloscope Sweep Rate in μs.
\$141E am 2	sequence)		.
SWEep? TRACE:		4-49	Returns Oscilloscope Sweep Rate in µs.
	44.004.000.01.055		
DATA n, offset, data	1 to 9;0 to 399; 0 to 255		Sets points into trace beginning at offset.
DATA? n,offset,points GET name,n	0 to 9;0 to 399;1 to 400	4-49	Sends trace data points directly to host.
GET? n.offset	array name;0 to 9		Assigns values of trace n to named array.
MAX? n,offset,points	0 to 9;0 to 399 0 to 9;0 to 399;1 to 400	4-49	Returns value of trace 0 to 9 at offset.
MIN? n,offset,points	0 to 9;0 to 399;1 to 400	4-50 4-50	Returns maximum vertical value. Returns x,y position.
PUT name,n	array name; 1 to 9	4-50	Returns minimum vertical value. Returns x,y position.
TRIGger:	alvay hame, I to s	₩±0V	Assigns values of an array to a stored trace.
AUTO		4 51	Colonia Ania Compania Trimona Maria
IMMediate		4-51 4-51	Selects Auto Sweep for Trigger Mode.
NORM		4-51 4-51	Triggers Oscilloscope after command interpretation.
ONE		4-51	Selects Normal Sweep for Trigger Mode.
SOURce type	EXTernal, INTernal	4-51	Selects One Shot for Trigger Mode.
	or BUS	7"31	Selects source to trigger on. External or Internal (AC or DC Input only). BUS is *TRG or GET command.
VERTical n	0 to 255	4-51	Sets Vertical Offset in graticules.
	***** * *	. • 1	

COMMAND	RANGE	PAGE	DESCRIPTION
PHASE METER COMM	ANDS		
M_PM:			
ALARM b	1 or 0	4-84	Enables/Disables Alarm for Upper or Lower Limit.
LL:			
LEVel n	0.00 to 10.00	4-84	Sets Lower Limit Level in radians.
STATe b	1 or 0		Enables/Disables Lower Limit.
PH b	1 or 0	4-84	Enables/Disables Peak Hold Feature.
RANGe:		4-84	Colonta Autorongo for Motor Pango
AUTO UPPer n	1, 5 or 10		Selects Autorange for Meter Range. Sets Meter Range in radians.
RCL n	1 to 9		Recalls stored Phase Meter environment.
STORe n	1 to 9		Stores current Phase Meter environment.
UL:	1 10 5	, , ,	C,C,CC COLLCTIC MACO MACO
LEVel n	0.00 to 10.00	4-85	Sets Upper Limit Level in radians.
STATe b	1 or 0	4-85	Enables/Disables Upper Limit.
И_РМ ?			Returns Phase Meter reading in radians.
	~~BBBB & \$1 ~~		
PHASE METER (RMS)	COMMANUS		
M_PMRMS:			
ALARM b	1 or 0	4-88	Enables/Disables Alarm for Upper or Lower Limit
LL:			
LEVel n	0.00 to 10.00		Sets Lower Limit Level in radians.
STATe b	1 or 0		Enables/Disables Lower Limit.
PH b	1 or 0	4-88	Enables/Disables Peak Hold Feature.
RANGe:		4 00	Colonta Autorongo for Motor Pango
AUTO	1 F or 10		Selects Autorange for Meter Range. Sets Meter Range in radians.
UPPer n RCL n	1, 5 or 10 1 to 9	4-88	
STORe n	1 to 9		Stores current Phase Meter (RMS) environment.
UL:	1 10 9	4-00	Otores current i naso motor (iimo) on incimo.
LEVel n	0.00 to 10.00	4-88	Sets Upper Limit Level in radians.
STATe b	1 or 0	4-88	Enables/Disables Upper Limit.
M_PMRMS?	, ,, ,		Returns Phase Meter (RMS) reading in radians.
	IANDO		
POWER METER COMN	IANUS		
M_PWR:			The state of the s
ALARM b	1 or 0	4-69	Enables/Disables Alarm for Upper or Lower Limit
EXT:		4 00	Enables/Disables External Loss/Gain Offset.
STATe b	1 or 0		Returns External Loss/Gain Offset state.
STATe?	00 0 4+ 00 0		Sets External Loss/Gain Offset in dBm.
OFFSet n	-99.9 to 99.9	4-69	Returns External Loss/Gain Offset value in dBm
OFFSet? LL:		4-05	Hetatiis External E033/Cam Ondot Taide in apin
LEVel n	0.0000 to 200.0000	4-69	Sets Lower Limit Level in Watts.
STATe b	1 or 0		Enables/Disables Lower Limit.
PEAK?			Returns Power Meter Peak reading in mW.
PH <i>b</i>	1 or 0	4-69	
RANGe:			
AUTO		4-69	Selects Autorange for Meter Range.
UPPer n	.02, .05, .1, .2, .5, 1, 2,	4-69	Selects Meter Range value in Watts.
	5, 10, 20, 50, 100 or 20	0	
RCL n	1 to 9	4-70	Recalls stored Power Meter environment.
STORe n	1 to 9	4-70	Stores current Power Meter environment.
TYPE:			
CW			Selects Average Power Measurement.
PEAK			Selects Peak Power Measurement.
RMS		4-70	Selects RMS Power Measurement.
UL:			
LEVel n	0.0000 to 200.00		Sets Upper Limit Level in Watts.
STATe b	1 or 0		Enables/Disables Upper Limit.
M_PWR?		4-70	Returns Power Meter reading in mW.

COMMAND	RANGE	PAGE	DESCRIPTION
PROGRAM COMMANDS			
PROGram: STARTup:			
NAME "name"		4-99	Selects macro name to execute at power up.
NAME? DELETE		4-99	Returns name of macro set to execute at power up.
		4-99	Deletes power up macro designation (not macro).
RECEIVER COMMANDS			
NOTE: Queries return -1 if data	is not available or is inva	lid.	
CALibration:FMZ n	1 to 4	4-21	Zeros FM Deviation Meter, displays Rovr Opn Screen, and selects FMn Modulation.
RECeive: AGC:			
AUTO		4-14	Selects Auto Mode for AGC.
MANual n	0 to 255	4-14	Selects Manual Mode and level for AGC.
USER:xxx	DATA, HIGH, MEASure, SPeech, TYPE1, TYPE2 or TYPE3		Selects User Defined Mode and type for AGC.
CHANnel n	1 to 1023	4-14	Sets Receiver to selected cellular channel.
CHANnel: FORMat:			
AMPS: FORward		1 1 4	Selects AMPS Forward channels for Channel Mode.
REVerse		4-14	Selects AMPS Perward channels for Channel Mode. Selects AMPS Reverse channels for Channel Mode.
ETACS:			
FORward		4-14	Selects ETACS Forward channels for Channel Mode.
REVerse NAMPS:		4-14	Selects ETACS Reverse channels for Channel Mode.
FORward		4-14	Selects NAMPS Forward channels for Channel Mode.
REVerse		4-14	Selects NAMPS Reverse channels for Channel Mode.
NT400: FORward		4.45	Colored NT400 F and 4 4 4 4 4
REVerse		4-15 4-15	Selects NT400 Forward channels for Channel Mode. Selects NT400 Reverse channels for Channel Mode.
FORMat?			Returns channel format setting.
DCS:			•
INVert? NORMal?		4-15	
STATe b	1 or 0	4-15 4-15	Returns 3 octal digits from normal DCS. Enables/Disables DCS decoding.
DECode type	DTMF, TONE or DIGital	4-15	Sets Receiver decoding type.
DEVRms		4-15	Displays Deviation Meter (RMS) on Rovr Opn Screen.
Digital type	DCS, DCSINV, DST POCSAG or DSAT	4-15	Sets digital type.
DISTortion DMM		4-15	
DMM DSAT:		4-16	Displays Digital Multimeter on Rcvr Opn Screen.
STATe b	1 or 0	4-16	Enables/Disables DSAT decode.
DSAT?			Returns DSAT reading (NAMPS option installed).
DST: STATe <i>b</i>	1 0 0		,
DST?	1 or 0	4-16 4-16	Enables/Disables DST decode. Returns DST reading (NAMPS option installed).
DTMF:		7 10	receive box reading (waters option installed).
STATe b	1 or 0	4-16	
DTMF? FIND:		4-16	Returns string of decoded digits.
FREQuency?		4-16	Searches for first frequency > Reference Level.
REFerence n	-110 to -5	4-16	Sets Find Reference Level in dBm.
REFerence?	A#A A	4-16	Returns Find Reference Level setting in dBm.
FREQuency f[units]	250.0 to 999999.9 kHz; HZ, KHZ or MHZ	4-17	Sets Receiver Frequency.
FREQuency? INPut:		4-17	Returns Receiver Frequency setting in kHz.
ANTenna		4-17	Selects ANTENNA IN Connector for Receiver Input.
ATTenuation n	0, 20 or 40	4-17	Sets Receiver Input Attenuation Level in dB.
TR		4-17	Selects T/R Connector for Receiver Input.

RECeive: MODE type MODMeter MODMater MODulation: AMn BFO BFO BFO BFN LSB PM USB USER: FILTer f MODulation: AMn MODulation: AMn MODulation: AMn AMn BFO	
MODE type MODMeter MODMater MODulation: AMn BFO BFO FMn LSB PM USER: FILTer f MODulation: MODUlation: AM, PM, PM, DATA, BFO, LSB or USB POST: DIR, CHAN or SCAN 4-17 Selects Receiver Operation Mode. 4-17 Displays Modulation Meter on Rovr Opn Screen 4-17 Selects an Amplitude Modulation Type. 4-17 Selects Beat Frequency Oscillation. 5 Selects Beat Frequency Modulation Type. 4-18 Selects Lower Side Band Modulation. 5 Selects Upper Side Band Modulation. 4-18 Selects Upper Side Band Modulation. 5 Selects User Defined IF Filter cutoff frequency in Selects User Defined Modulation Type.	
MODMeter MODulation: AMn BFO BFO FMn LSB PM USB USER: FILTer f MODulation: AMn AMn AMn AMn AMn AMn AMn A	
MODulation: AMn BFO BFO A-17 Selects an Amplitude Modulation Type. 4-17 Selects Beat Frequency Oscillation. FMn LSB Selects a Frequency Modulation Type. 4-18 Selects Lower Side Band Modulation. PM USB USER: FILTer f MODulation: AM, FM, PM, DATA, BFO, LSB or USB POST: 4-18 Selects User Defined IF Filter cutoff frequency in Selects User Defined Modulation Type.	
AMn 1 or 2 4-17 Selects an Amplitude Modulation Type. BFO 4-17 Selects Beat Frequency Oscillation. FMn 1, 2, 3 or 4 4-17 Selects a Frequency Modulation Type. LSB 4-18 Selects Lower Side Band Modulation. PM 4-18 Selects Upper Side Band Modulation. USB 4-18 Selects Upper Side Band Modulation. USER: FILTer f 3, 30 or 300 4-18 Sets User Defined IF Filter cutoff frequency in MODulation: AM, FM, PM, DATA, BFO, LSB or USB POST:	kHz.
BFO FMn 1, 2, 3 or 4 LSB PM USB USER: FILTer f MODulation: AM, FM, PM, DATA, BFO, LSB or USB POST: 8-17 Selects Beat Frequency Oscillation. 4-17 Selects a Frequency Modulation Type. 4-18 Selects Lower Side Band Modulation. 4-18 Selects Upper Side Band Modulation. 4-18 Selects Upper Side Band Modulation. 4-18 Selects Upper Side Band Modulation. 4-18 Selects User Defined IF Filter cutoff frequency in Selects User Defined Modulation Type.	kHz.
FMn 1, 2, 3 or 4 4-17 Selects a Frequency Modulation Type. LSB 4-18 Selects Lower Side Band Modulation. PM 4-18 Selects Phase Modulation. USB 4-18 Selects Upper Side Band Modulation. USER: FILTer f 3, 30 or 300 4-18 Sets User Defined IF Filter cutoff frequency in MODulation: MODulation: AM, FM, PM, DATA, BFO, LSB or USB POST:	kHz.
LSB PM USB USER: FILTer f MODulation: AM, FM, PM, DATA, BFO, LSB or USB POST: 4-18 Selects Lower Side Band Modulation. 4-18 Selects Upper Side Band Modulation.	kHz.
PM USB USER: FILTer f MODulation: AM, FM, PM, DATA, BFO, LSB or USB POST: 4-18 Selects Phase Modulation. 4-18 Selects Upper Side Band Modulation. 4-18 Sets User Defined IF Filter cutoff frequency in Selects User Defined Modulation Type.	kHz.
USB USER: FILTer f 3, 30 or 300 4-18 Sets User Defined IF Filter cutoff frequency in MODulation: AM, FM, PM, DATA, 4-18 Selects User Defined Modulation Type. BFO, LSB or USB POST:	kHz.
USB USER: FILTer f 3, 30 or 300 4-18 Selects Upper Side Band Modulation. MODulation: AM, FM, PM, DATA, 4-18 Selects User Defined IF Filter cutoff frequency in BFO, LSB or USB POST:	kHz.
USER: FILTer f 3, 30 or 300 4-18 Sets User Defined IF Filter cutoff frequency in MODulation: AM, FM, PM, DATA, 4-18 Selects User Defined Modulation Type. BFO, LSB or USB POST:	kHz.
FILTer f 3, 30 or 300 4-18 Sets User Defined IF Filter cutoff frequency in MODulation: AM, FM, PM, DATA, 4-18 Selects User Defined Modulation Type. BFO, LSB or USB POST:	kHz.
MODulation: AM, FM, PM, DATA, 4-18 Selects User Defined Modulation Type. BFO, LSB or USB POST:	
BFO, LSB or USB POST:	
POST:	
APASs 4-18 Selects All Pass Post Detection Filter.	
BPASs fl,fh .5 to 20; 0.1 to 30 4-18 Selects Bandpass Post Detection Filter and se	ts low-
high cutoff frequencies in kHz.	
CWEight 4-18 Selects C-Weighted Post Detection Filter.	
HPASs f .5 to 20 4-18 Selects High-Pass Post Detection Filter and se	∍ts
cutoff frequency in kHz.	
	• ~
LPASs f .1 to 30 4-18 Selects Low-Pass Post Detection Filter and se	13
cutoff frequency in kHz.	
MODulation? 4-18 Returns Modulation Type.	
OUTput:	
AUDio b 1 or 0 4-19 Enables/Disables AUDIO OUT Connector Outp	ut.
DEMOD b 1 or 0 4-19 Enables/Disables DEMOD OUT Connector Out	
the man the contract of the co	
A CONTRACT OF THE PROPERTY OF	200
	, ,, ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,
POCSAG:	
CAPcode? 4-19 Returns received capcode.	
MESSage? 4-19 Returns message string.	
RATe b 1 or 0 4-19 Selects High (1) or Low (0) POCSAG rate to d	∍code.
RATE? 4-19 Returns selected POCSAG rate.	
STATe b 1 or 0 4-19 Enables/Disables POCSAG decoding.	
110 = 17	
SCAN:	
ABORt 4-20 Stops Receiver Scan Function.	
CONTinue 4-20 Starts or, if paused, continues Scan Function.	
FREQuency? 4-20 Returns frequency being scanned.	
INCrement f 0.0 to 99999.9 4-20 Sets Receiver Scan increment in kHz.	
the second secon	
PAUSe? 4-20 Returns 1 if paused, 0 otherwise.	
RATe t 0.00 to 99.99 4-20 Sets Receiver Scan Rate in seconds.	
STARt f 250.0 to 999999.9 4-20 Sets Receiver Scan start frequency in kHz.	
STOP f 250.0 to 9999999.9 4-20 Sets Receiver Scan stop frequency in kHz.	
SINAD 4-20 Displays SINAD Meter on Receiver Operation	Screen.
SQUelch n 0.0 to 1.0 4-20 Sets squelch level.	
0 1 0 1 0 1	
TONE:	
STATe b 1 or 0 4-21 Enables/Disables Audio Tone decoding.	
TYPE xxx CCIR, EEA, EIA, ZVEI, 4-21 Selects Audio Tone Type to decode.	
DDZVEI, DZVEI, NATEL,	
EURO, TONE56, CCIRH,	
CCIRH4 or USER	
VOCUME II	
VOLume? 4-21 Returns volume level setting.	
VOLume:	
AUTO b 4-21 Enables/Disables Automatic Volume Control.	
AUTO? 4-21 Returns Automatic Volume Control state.	

COMMAND	RANGE	PAGE	DESCRIPTION
RF GENERATOR COMMANDS	3		
GENerator:			
AF		4-4	Displays AF Level Meter on RF Gen Opn Screen.
CHANnel <i>n</i> CHANnel:	1 to 1023	4-4	Selects RF Generator cellular channel.
FORMat:			
AMPS:			
FORward		4-4	Selects AMPS Forward channels for Channel Mode.
REVerse		4-4	Selects AMPS Reverse channels for Channel Mode.
ETACS: FORward		4-4	Selects ETACS Forward channels for Channel Mode.
REVerse		4-4	Selects ETACS Perward channels for Channel Mode.
NAMPS:		• •	Total Lines have be swallhed for blighter mode.
FORward		4-4	Selects NAMPS Forward channels for Channel Mode.
REVerse		4-4	Selects NAMPS Reverse channels for Channel Mode.
NT400: FORward		4 4	Colorta NT400 Farmand about the Observation
REVerse		4-4 4-4	Selects NT400 Forward channels for Channel Mode. Selects NT400 Reverse channels for Channel Mode.
FORMat?		4-4	Returns channel format setting.
DCS:			The state of the s
INVert nnn	000 to 777	4-5	Generates 3 digit octal DCS Code in inverted mode.
NORMal nnn	000 to 777	4-5	Generates 3 digit octal DCS Code in normal mode.
STOP DIAL "sequence"	0 to 0 (oneh digit)	4-5 4-5	Stops generating continuous DCS Code.
DIAL:	0 to 9 (each digit)	4-D	Encodes sequence (≤16 digits) as 2805 Pulse Code.
FREQuency f	0.0 to 40000.0	4-5	Sets 2805 Pulse Tone Frequency.
FREQuency?		4-5	Returns 2805 Pulse Tone Frequency.
DISTortion DMM		4-5	Displays Distortion Meter on RF Gen Opn Screen.
DSAT n	0 to 6	4-5 4-5	Displays DMM on RF Generator Operation Screen. Generates DSAT code (NAMPS option installed).
DSAT:STOP	0.00	4-5	Stops generating continuous DSAT code.
DST n	0 to 6	4-5	Generates DST code.
DST:STOP		4-5	Stops generating continuous DST code.
DTMF "seq",mark,space	0 to 9 (each digit), 25 to 9999 (ms), 25 to 99 (ms)		Generates DTMF coded sequence (≤16 digits).
FREQuency f[units]	250.0 to 999999.99 kHz; HZ,KHZ or MHZ	4-6	Sets RF Generator Frequency.
FREQuency?		4-6	Returns RF Generator Frequency setting in kHz.
IMTS "sequence"	0 to 9 (each digit)	4-6	Generates sequence (≤16 digits) as IMTS Code.
LEVel n[units]	-137.0 to 0.0 (dBm); 0.031 μV to 0.224 V; DB:	4-6 m	Sets RF Generator Output Level.
LEVel:UNIT?	V, MV (mV) or UV (μV)	4-6	Returns current units for RF Generator Output Level.
LEVel?		4-6	Returns RF Generator Output Level in current units.
MODE type	DIRect or CHANnel	4-6	Selects RF Generator Operation Mode.
MTS "sequence"	0 to 9	4-6	Generates sequence (≤16 digits) as MTS Code.
OUTput:	1 0		Destruction AF Associated AUDIO OFF A
AUDio <i>b</i> DEMOD <i>b</i>	1 or 0 1 or 0	4-6 4-7	Routes AF Gen Output to AUDIO OUT Connector. Routes AF Gen Output to DEMOD OUT Connector.
POCSAG:		4-1	Troutes Ar deli output to bemob our conflector.
ALPHA:			
LOWer capcode	0 to 2097151	4-7	Generates lower case alpha message for capcode.
NUMeric capcode	0 to 2097151	4-7	Generates alphanumeric message for capcode.
SPECial capcode	0 to 2097151	4-7	Generates special character message for capcode.
UPPer capcode BEEP n,capcode	0 to 2097151 1 to 4, 0 to 2097151	4-7 4-7	Generates upper case alpha message for capcode. Generates n Tone beep POCSAG message for capcode.
NUMeric capcode	0 to 2097151	4-7	Generates numeric message for capcode.
RATe b	1 or 0	4-7	Selects High (1) or Low (1) POCSAG rate.
RATe?		4-7	Returns current POCSAG rate setting.
RCL n	1 to 9	4-8	Recalls stored RF Generator environment.
SINAD	OFE FORM SINAD	4-8	Displays SINAD Meter on RF Gen Opn Screen.
SPEAKer:SOURce type	OFF, FGEN, SINAD or EXTMOD	4-8	Routes selected connector or source to Test Set Speaker.
STORe n	1 to 9	4-8	Stores current RF Generator environment.
TONE "sequence"		4-8	Generates sequence as an Audio Tone.

COMMAND	RANGE	PAGE	DESCRIPTION
GENerator:			
TONE:			
TYPE code	CCIR, EEA, EIA, ZVEI,	4-8	Selects an Audio Tone Type.
	DDZVEI, DZVEI, NATEL	1	• •
	EURO, TONE56, CCIRH	•	
	CCIRH4 or USER	,	
USER:			
DEFine "id",f,d	0 to 9 or A to T, 0.0 to	4-8	Assigns frequency f in Hz and duration d in ms to
DE: 1110 70 ,1,0	9999.9, 20.0 to 9999.9	4 0	id character for User Defined Audio Tone Type.
TREMote f	1050 to 2050 (by 100)	4-9	Generates Tone Remote sequence for f tone in Hz.
TREMote:STOP	1030 to 2030 (by 100)	4-9	Stops Tone remote Guard Tone.
I REMOTE.S FOR		4-9	Stops rolle remote duald rolle.
SCOPE COMMANDS (SEE C	SCILLOSCOPE COMM	NDS.)	
SCREEN COMMANDS			
SCREEN:			
AF		4-2	Displays AF Meter Operation Screen.
ANLZ		4-2	Displays Spectrum Analyzer Operation Screen.
BER		4-2	Displays BER Meter Operation Screen.
CELL		4-2	Displays Forward Control Channel Screen of AMPS
			Cell Site Monitor (AMPS option installed).
DEViation		4-2	Displays Deviation Meter (Peak) Operation Screen.
DISTortion		4-2	Displays Distortion Meter Operation Screen.
DMM		4-2	
			Displays DMM Meter Operation Screen.
DRMS		4-2	Displays Deviation Meter (RMS) Operation Screen.
DUPlex		4-2	Displays Duplex Operation Screen.
DUPRX		4-2	Displays Duplex Transmitter Operation Screen.
DUPTX		4-2	Displays Duplex Receiver Operation Screen.
FREQuency		4-2	Displays Frequency Error Meter Operation Screen.
FUNC		4-2	Displays AF Generator Operation Screen.
GENCELLular		4-2	Displays Main Menu of AMPS Mobile Simulator (AM option installed).
GENerator		4-2	Displays RF Generator Operation Screen.
GENRECC		4-2	Displays Reverse Control simulation Screen of AMP
			Mobile Simulator (AMPS option installed).
GENRVC		4-3	Displays Reverse Voice Channel Simulation Screen AMPS Mobile Simulator (AMPS option installed).
MODulation		4-3	Displays Modulation Meter Operation Screen.
PM		4-3	Displays Phase Meter Operation Screen.
PMRMS		4-3	Displays Phase Meter (RMS) Operation Screen.
POWer		4-3	Displays Power Meter Operation Screen.
RECeiver		4-3	Displays Receiver Operation Screen.
SCOPe		4-3	Displays Oscilloscope Operation Screen.
SIGnal		4-3	Displays Signal Strength Meter Operation Screen.
SINAD		4-3	Displays SINAD Meter Operation Screen.
USER		4-3	Displays blank User Screen.
SETUP COMMANDS			
SETUP:			
AF.		4-1	Selects AF Meter routing.
ANLZ		4-1	Selects Spectrum Analyzer routing.
DISTortion		4-1	Selects Distortion Meter routing.
DUPlex		4-1	Selects Duplex routing.
DUPRX		4-1	Selects Duplex Receiver routing.
DOLUV			
DUDTY		4-1	Selects Duplex Transmitter routing.
DUPTX		4-1	Selects AF Generator routing.
FUNC			- C - I
FUNC GENerator		4-1	Selects RF Generator routing.
FUNC GENerator MONitor		4-1	Selects Generator/Monitor routing.
FUNC GENerator MONitor RECeiver		4-1 4-1	Selects Generator/Monitor routing. Selects Receiver routing.
FUNC GENerator MONitor		4-1	Selects Generator/Monitor routing.

COMMAND	RANGE	PAGE	DESCRIPTION
SIGNAL STRENGTH METER	COMMANDS		
M_SIG: PEAK? PH b RCL n STORe n M_SIG?	1 or 0 1 to 9 1 to 9 79	4-80 4-80 4-80 4-80 4-80	Enables/Disables Peak Hold Feature. Recalls stored Signal Strength Meter environment. Stores current Signal Strength Meter environment.
SINAD METER COMMANDS			
M_SINAD:			
ALARM b AVErage b FILTer f INPut:type	1 or 0 1 or 0 600 to 1400 DEMOD, SINAD, XAUDIO or FGEN	4-78 4-78	Enables/Disables Alarm for Upper or Lower Limit. Enables/Disables Averaging. Sets Notch Filter Frequency in Hz. Selects SINAD Meter Input.
LEVel n STATe b PEAK? PH b RCL n RESolution n RESolution? SELect:	3.0 to 40.0 1 or 0 1 or 0 1 to 9 0.1 or 0.5	4-78 4-78 4-78 4-78 4-78	Sets Lower Limit Level in dB. Enables/Disables Lower Limit. Returns SINAD Meter Peak reading in dB. Enables/Disables Peak Hold Feature. Recalls stored SINAD Meter environment. Sets SINAD Meter readout resolution in dB. Returns SINAD Meter readout resolution setting in dB.
CWEight LPASs f STORe n UL:	100 to 30000 1 to 9	4-79 4-79 4-79	Selects Low-Pass Filter with cutoff frequency in Hz.
LEVel n STATe b M_SINAD?	3.0 to 40.0 1 or 0	4-79 4-79 4-79	Enables/Disables Upper Limit.
SOUND COMMAND			
SOUND f,t		3-83	Sends f Hz tone for t ms to Test Set Speaker.
SPECTRUM ANALYZER CO	MMANDS		
ANLZ: AVErage n CHANnel n CHANnel: FORMat: AMPS:	1 to 100 1 to 1023	4-55 4-55	
FORward REVerse ETACS:			Selects AMPS Forward for Analyzer Channel Mode. Selects AMPS Reverse for Analyzer Channel Mode.
FORward REVerse NAMPS:		4-55 4-55	Selects ETACS Forward for Analyzer Channel Mode. Selects ETACS Reverse for Analyzer Channel Mode.
FORward REVerse NT400:		4-55 4-55	Selects NAMPS Forward for Analyzer Channel Mode. Selects NAMPS Reverse for Analyzer Channel Mode.
FORward REVerse FORMat? COMPare n	1 to 9	4-55 4-55 4-55 4-56	Selects NT400 Forward for Analyzer Channel Mode. Selects NT400 Reverse for Analyzer Channel Mode. Returns channel format setting. Selects Compare Mode with stored trace n.
FIND: FREQuency? REFerence n REFerence? FREQuency f FREQuency? FULL	(varies) 250.0 to 999999.9	4-56	Sets Find Reference Level in dB. Returns Find Reference Level. Sets Analyzer Frequency in kHz.

COMMAND	RANGE	PAGE	DESCRIPTION
ANLZ:			•
INPut:			
ANTenna		4-56	7
Attenuation n	0, 20 or 40		Selects Input Attenuation in dB.
Attenuation?		4-56	3
TR			Selects T/R Connector for Analyzer Input.
INPut? LIVe			Returns Analyzer Input source.
MARKer:		4-57	Selects Live Mode for Analyzer.
AOFF		4-57	Disables both Markers.
DELTa:		4-57	Disables bottl warkers.
AMPLitude?		4-57	Returns amplitude difference between mkrs in dB.
FREQuency?		4-57	
POINt?		4-57	
TRACK b	1 or 0	4-57	Enables/Disables Marker Tracking feature.
MARKer1:	1 01 0	-4-J1	Chaptes Disables Marker Hacking realtife.
AMPLitude?		4-57	Returns amplitude of Trace at Marker 1 crossing.
FREQuency?		4-57	,
POINt n	1 to 100	4-57	
POINt?	1 10 100	4-57	
STATe b	1 or 0	4-58	Enables/Disables Marker 1.
MARKer2:	. 0. 0	4-50	ENGEROUS MICHAEL I.
AMPLitude?		4-57	Returns amplitude of Trace at Marker 2 crossing.
FREQuency?		4-57	
POINt n	1 to 100	4-57	
POINt?	1 10 100	4-57	
STATe b	1 or 0		Enables/Disables Marker 2.
MODE type	DIRect or CHANnel		Selects Analyzer RF Mode.
NORMalize	Diffect of OffAmiles		Normalizes Analyzer Trace to match RF Gen Output.
PEAK		4-58	
QTR		4-58	Selects 1/4 size Analyzer for other Operation Screens.
RCL n	1 to 9	4-58	
BLEVel?	1 10 3	4-58	
SCALe n	2 or 10	4-59	
UNIT:type	DBM, DBMV, DBUV, DBUW, DBV or DBW	4-59	Sets Analyzer Scale Units.
UNIT?	,	4-59	Returns Analyzer Scale Units setting.
SCALe?		4-59	
SCAN n	0 or 1 to 100000 (1-2-5)	4-59	
SCAN?	` '	4-59	
STATe b	1 or 0	4-59	
STORe n	1 to 9	4-59	Stores current Spectrum Analyzer Trace/environment.
TOP?		4-59	Returns top of screen scale value in current units.
TRACE:			
DATA n, offset, v,, v	1 to 9,0 to 399,0 to 255	4-60	Replaces points in stored Trace starting at offset.
DATA? n,offset,points	0 to 9,0 to 399,1 to 400	4-60	Sends Trace data points directly to Host.
GET name,n	array name 0 to 9	4-60	Assigns values of Trace n to a declared array.
GET? n,offset	0 to 9,0 to 399	4-60	Returns vertical point value of Trace.
MAX? n,offset,points	0 to 9,0 to 399,1 to 400	4-60	Returns x,y point position of maximum vertical value.
MIN? n,offset,points	0 to 9,0 to 399,1 to 400	4-61	Returns x,y point position of minimum vertical value.
PUT name,n	array name,1 to 9	4-61	Assigns values of an array to Trace n.
TRACK:			
BWIDth f	.3, 3, 30, 300 or 3000	4-61	Selects Tracking Generator bandwidth in kHz.
BWIDth?		4-61	Returns Tracking Generator bandwidth setting in kHz.
LEVel n	-127.0 to 0.0	4-61	Sets Tracking Generator Level in dB.
LEVel?		4-61	Returns Tracking Generator Level setting.
OUTput:			
DUPlex		4-62	Selects DUPLEX OUT Connector as Track Gen Output.
TR		4-62	Selects T/R Connector as Tracking Generator Output.
OUTput?		4-62	
RESolution:			
HIGH		4-62	Selects High Tracking Generator Resolution.
LOW		4-62	Selects Low Tracking Generator Resolution.
MED		4-62	Selects Medium Tracking Generator Resolution.
RESolution?		4-62	Returns Tracking Generator Resolution setting.
STATe b	1 or 0	4-62	<u> </u>
STATe?		4-62	Returns Tracking Generator State.

COMMAND	RANGE	PAGE	DESCRIPTION
STATUS COMMANDS			
STATus:			
OPERation:	•		
CONDition?		3-43	
ENABle n	0 to 65535	3-43	,
ENABle?		3-43	,
EVENt?		3-43	Returns Operation Status event register value.
INSTRument:			
CONDition?	n.i. ommor	3-44	Returns Operation Instrument condition register value.
ENABle n ENABle?	0 to 65535	3-44	(
EVENt?		3-44 3-44	
QUEStionable:		3-44	Returns Operation Instrument event register value.
CONDition?		3-44	Returns Questionable Status condition register value.
ENABle n	0 to 65535	3-44	
ENABle?	0 10 03333	3-44	
EVENt?		3-44	
INSTRument:		0 4.7	notallis assistinable states event register value.
CONDition?		3-44	Returns Instrument Status condition register value.
ENABle n	0 to 65535	3-44	
ENABle?		3-44	
EVENt?		3-44	•
ISUMmary:			·
CONDition?		3-45	Returns Instrument Summary Status condition
			register value.
ENABle n	0 to 65535	3-45	Sets Instrument Summary Status enable register
			contents.
ENABle?		3-45	Returns Instrument Summary Status enable register
			setting.
EVENt?		3-45	Returns Instrument Summary Status event register
			value.
STRING FUNCTION COMM	ANDS		
ASC(\$)		3-17	Poturno ASCII volvo of first above tox in attimus
CHR(n)		3-17 3-16	· · · · · · · · · · · · · · · · · · ·
LEN(\$)		3-16	
PIXLEN(\$)		3-17	
STR(n)		3-17	
STRPOS(\$1,\$2)		3-18	
TAB(n)		3-16	
VAL(\$)		3-17	
, ,			· · · · · · · · · · · · · · · · · · ·

COMMAND	RANGE	PAGE	DESCRIPTION
SYSTEM COMMANDS			
SYSTem:	•		
COMMunicate: GPIB:			
ADDRess a	0 to 31	3-36	Sets 1600S GPIB address.
CONTroller		3-37	
GMD " <i>string</i> " DCL		3-38	Issues commands to subordinate test sets on GPIB.
GET		3-38 3-38	•
LONIy		3-39	Sets 1600S to Listen Only mode.
SLAVe a	0 to 31	3-37	Sets address destination of pass through commands.
SPOLL? a	0 to 31	3-38	Performs Serial Poll on device with selected address
SRQ?		3-38	1 1
TONIY SERial:		3-39	Sets 1600S to Talk Only mode.
BAUD n	300 to 38400	3-34	Sets baud rate.
BITS n	7 or 8	3-34	
ECHO b	1 or 0	3-34	Enables/Disables RCI echo.
PACE type	XON or NONE	3-34	Sets software handshake mode.
PARity type	NONE, ODD or EVEN MARK or SPACE	3-34	Sets parity check.
SBITs n	1 or 2	3-34	Sets number of stop bits per word.
DATE year, month, day	1992 to 9999, 1 to 12, 1 to 31	3-33	Sets date.
DATE?		3-33	Returns date.
DEFaults		3-33	Restores Test Set to factory default state.
ERRor? FREQuency:		3-33	Returns error number and message.
LOCK b	1 or 0	3-35	Enables/Disables RF lock feature.
LOCK?		3-35	Returns RF lock feature state.
KEY n		3-32	
KEY?		3-32	Returns keycode of last key or simulated key pressed
KEY: DEFine n,sequence		3-32	Assigns command sequence to key with keycode n.
DELete n		3-32	Deletes command assignment from key with keycode
KLOCK b	1 or 0	3-35	Locks/Unlocks Front Panel Keyboard.
PLOT:			
GPIB SERial		3-33	
PTHRough:		3-33	Selects 1600S RS-232 Connector for plotter output.
GPIB [a],"string"	0 to 31	3-38	Sends command string out 1600S GPIB Connector.
GPIB? [a]	0 to 31		Waits to receive string at 1600S GPIB Connector.
SERial "string"			Sends command string out 1600S RS-232 Connector.
SERial?		3-34	Waits to receive string at 1600S RS-232 Connector.
SERial: KEY?		3-34	Waits to receive character at 1600S RS-232 Connecto
QUEue?		3-34	
SECurity:			
STATe n	0 to 255	3-35	
STATe?	01.00 01.50 01.50	3-35	Returns system security setting.
TIME hour, minute, second TIME?	0 to 23, 0 to 59, 0 to 59	3-33 3-33	Sets time. Returns time.
VINDOW COMMANDS			
CLS		3-54	Clears everything except active readings from
		3-26	selected window. Clears everything from active window.
SCREEN:USER			
	1 to 16	3-87	Erases selected generated window(s) from CRT.
VCLOSE n VINDOW?	1 to 16		Returns number of currently selected window.
NCLOSE n NINDOW?	1 to 16 0 to 639,0 to 349	3-87	Returns number of currently selected window. Moves currently selected window to selected new top
SCREEN:USER NCLOSE n NINDOW? NMOVE x,y NOPEN c,x1,y1,x2,y2		3-87 3-88 3-89	
NCLOSE n NINDOW? NMOVE x,y	0 to 639,0 to 349	3-87 3-88 3-89	Returns number of currently selected window. Moves currently selected window to selected new top left xy location.
NCLOSE n NINDOW? NMOVE x,y	0 to 639,0 to 349 0 to 15,0 to 639,	3-87 3-88 3-89	Returns number of currently selected window. Moves currently selected window to selected new top left xy location.

)			

SECTION 6 - CREATING AND LOADING CSA SPECIFIC PROGRAMS

6-1 SETUP

6-1-1 TERMINAL EMULATION PROGRAM SETUP

Any RS-232 Terminal or PC with Terminal Emulation software can be used to create and load CSA macros. For the purpose of clarity and actual operation, the following procedures use Procomm Plus $^{\mathsf{TM}}$ as the Terminal Emulation program.

STEP

PROCEDURE

- 1. Enter Procomm PlusTM from Host System terminal.
- 2. Set Line Settings as follows:

PARAMETER	SETTING
Baud Rate	300 to 38400
Parity	NONE
Data Bits	8
Stop Bits	1
Port	(Comm Connector on PC used for RS-232 to CSA)

3. Set Terminal Options as follows:

PARAMETER	SETTING
Terminal emulation	ANSI
Duplex	FULL
Soft flow ctrl (Xon/Xoff)	ON
Hard Flow ctrl (RTS/CTS)	OFF
Line wrap	ON
Screen scroll	ON
CR translation	CR
BS translation	NON-DESTRUCTIVE
Break length (millisecs)	N/A
Enquiry (ENQ)	N/A
EGA/VGA true underline	N/A
Terminal width	80
ANSI 7 or 8 bit commands	8 Bit

4. Set ASCII Protocol Options as follows:

PARAMETER	SETTING
Echo locally	NO
Expand blank lines	NO
Expand tabs	NO
Character pacing (millisec)	0
Line pacing (1/10 sec)	0
Pace character	0
Strip 8th bit	NO
ASCII download timeout	N/A
CR translation (upload)	NONE
LF translation (upload)	STRIP
CR translation (download)	N/A
LF translation (download)	N/A

6-1-2 CONNECTION AND FM/AM-1600CSA SETUP

STEP

PROCEDURE

- Connect Host System Comm Connector, selected in Line Settings, to RS-232 Connector on FM/AM-1600CSA rear panel, using standard 9-pin to 9-pin RS-232 cable.
- 2. Press DPLX Mode Key to access Duplex Operation Screen.
- 3. Press "Sp Tst" Soft Function Key F5 to access Dual Mode Cellular Main Menu.
- 4. Press "AUX2" Soft Function Key F5 to access Auxiliary Functions Menu (#2).
- 5. Press 5 DATA ENTRY Key to access External I/O Parameters Screen.
- 6. Use FIELD SELECT Keys to select parameter. Use DATA SCROLL Spinner or DATA SCROLL ↑ and ↓ Keys to edit parameter. Set parameters as follows:

PARAMETER	SETTING
RS-232 BAUDRATE	(same as Host System Line Settings Baud rate)
RS-232 PARITY	NONÉ
RS-232 BIT LENGTH	8
RS-232 STOP BITS	1
RS-232 PACE	XON

7. Verify link: press Enter key on Host System terminal keyboard and verify question mark appears on Host System monitor.

6-2 WRITING PROGRAMS

STEP

PROCEDURE

- 1. Write TMAC programs using text editor. Refer to examples in 6-2 and 6-5.
- Save as text file (program file).
- 3. Upload program file according to 6-3-1.

```
MACRO NAME: minit1
      SYNTAX: minit1
    PURPOSE: Perform a Mobile Station originated call.
      MACRO: (The following example uses the predefined constants F1 and F6 [see
               Appendix A].)
*dmc "minit1", begin
var done=0
var key code
ďο
  css:setup
  css:chan 334
  css:rflvl -60
  css:start
  user
  css:call:type 0
  host ":keypad:soft"
  color 1,15
  keypad: label 1, "START"
  keypad: label 6, "Ret"
  color 1,11
  center "Mobile Init Call", 0, 5, 640
    key_code=val(host? "syst:key?")
                                                   // Waits for valid key.
  until (key_code=F6) or (key_code=F1)
  if key_code=6
    done=1
  else
                                                   // Erases F1 label.
    keypad:label 1,""
    keypad: label 1, "STOP"
    keypad:label 6,""
                                                   // Erases F6 label.
    css:call:proc:mobinit
    center "Place Call", 0, 35, 640
      key_code=val(host? "syst:key?")
    until (key_code=F1) or css:recc:status?
    erase:text 0,35,640
    center "Assign Channel", 0, 35, 640
    if(key_code!=F1)
      css:call:proc:assign
        key_code=val(host? "syst:key?)
      until (key_code=F1) or (meas:sat? > 5960) // Waits for somewhat valid SAT.
      if(key_code!=F1)
         erase:text 0,35,640
         center "Call Successfull", 0, 35, 640
      endif
    endif
    while key code!=F1
      key code=val(host? "syst:key?")
    wend
  endif
until done
end
```

6-3 LOADING

6-3-1 UPLOAD

STEP

PROCEDURE

- 1. Enter Procomm PlusTM from Host System terminal.
- 2. Press PgUp key on Host System terminal and select ASCII Upload Protocol.
- 3. Type in program file name (from 6-2) and press Enter key.
- 4. If failure occurs:
 - Utilize Procomm PlusTM Log function to create separate text file (log file) of Upload function (program file with error messages).
 - Repeat Steps 1 through 3.
 - View log file and correct errors in original program file.
 - Repeat Steps 1 through 3.

6-3-2 STORING IN FLASH MEMORY

Use MMEMory:STORe:MACRo "m","f" command to store uploaded program file from 6-3-1 in Flash Memory. (The MMEMory:STORe:MACRo command also stores all currently loaded macros into Flash Memory.) Set m to name of designated macro to run from Front Panel, contained in uploaded program file. Set f to desired JBox Flash File. (f is the name to appear in the JBox Flash File Directory.) Refer to 7-13 for more information on Flash Memory commands.

```
Examples: mmem:store:macro "minit1", "minit1" // Stores file, written in 6-2 and // and uploaded in 6-3-1, in Flash // Memory.


mmem:store:macro "sense_main", "s_test" // Stores file from 6-6 in Flash // Memory.
```

6-4 FRONT PANEL OPERATION

STEP

PROCEDURE

- 1. Press DPLX MODE Key to display Duplex Operation Screen.
- 2. Press "Sp Tst" Soft Function Key F5 to display Dual Mode Cellular Menu.
- 3. Press "AUX2" Soft Function Key F5 to display Auxiliary Functions Menu.
- 4. Press 6 DATA ENTRY Key to display JBox Flash Files directory.



9117129

Figure 6-1 JBox Flash Files Directory

- 5. Use ↑ and ↓ FIELD SELECT Keys to select desired macro file (indicated by arrow).
- 6. Press "EXEC" Soft Function Key F1 to execute macro.

6-6 MACRO EXAMPLES

FILE NAME: stest.mac

```
    FM/AM-1600CSA TMAC Graphics

                   Cell Site Simulation

    Using multiple macros

    Storing macros in Flash Memory

    Running a TMAC program from the Front Panel.

    Using FM/AM-1600S TMAC commands through the HOST command.

             FILE: (The following example uses the predefined constants F1 and F6 [see
                   Appendix A].)
var key_code
                               // Declares a global variable.
          MACRO: delay1
          SYNTAX: delay1 n
                   (n=delay time in ms.)
        PURPOSE: Provide a delay if the F1 Soft Function Key is not pressed. */
*dmc "delay1", begin
if (key code!=F1)
  delay $1
endif
end
          MACRO: focc_setup
         SYNTAX: focc_setup
        PURPOSE: Set up the System Parameter Overhead message sent on the Forward
                   Control Channel. */
*dmc "focc_setup",begin
css:setup
                               // Sets CSA for Cell Site Simulation.
css:chan 333
                               // Sets Forward Control Channel to 333 (879.99 MHz).
css:rflvl -60.0
                               // Sets output RF Level to -60.0 dBm.
css:focc:pci 1
                               // Sets Protocol Capability Indicator.
css:focc:rcf 0
                               // Sets Read Control Filler bit.
css:focc:sid 0
                               // Sets System Identification Number.
css:focc:n 1
                               // Sets Number of Paging Channels.
css:focc:cmax 1
                              // Sets Number of Access Channels.
css:focc:auth 0
                               // Sets authentication bit.
css:start
end
```

PURPOSE: Demonstrate several capabilities of FM/AM-1600CSA TMAC including:

```
PURPOSE: Set up parameters used in making a digital call to the Mobile Station
                  (cellular phone). */
*dmc "call_setup",begin
                                      // Sets call type to digital.
css:call:type 1
                                      // Sets Mobile Digital Traffic Channel
css:call:chan 10
                                      // assignment.
                                      // Sets Digital Mode Attenuation Code.
css:call:dmac 5
                                      // Sets to Timeslot 2.
css:call:slot 2
                                      // Sets Privacy Mode bit.
css:call:pm 0
css:call:mem 0
                                      // Sets Message Encryption Mode to 0.
css:call:ef 0
                                      // Sets Extended Protocol Forware Channel
                                      // Indicator.
                                      // Enables Signal field.
css:fdtc:enable:signal 1
                                      // Sets pitch and pattern of Alert tone.
css:fdtc:signal:pitch 0;cadence 1
                                      // Enables Calling Party Number field.
css:fdtc:enable:calling:num 1
                                      // Sets Calling Party Type.
css:fdtc:calling:type 0
                                      // Sets Calling Party Numbering Plan
css:fdtc:calling:plan 0;pi 0;si 0
                                      // Identification, Presentation Indicator
                                      // and Screening Indicator.
css:fdtc:enable:dmac 0;ta 1;dtx 0;dic 0
                                      // Disables Digital Mobile Attenuation
                                      // Code, Discontinuous Transmission bit
                                      // and Delay Interval. Enables Time
                                      // Alignment field.
                                      // Sets Time Alignment to 2.
css:fdtc:ta 2
end
          MACRO: registration
         SYNTAX: registration
        PURPOSE: Force Mobile Station to register. */
*dmc "registration", begin
center "Registering Mobile", 0, 35, 640
call setup
do
  css:call:proc:reg
  delay1 1000
  key_code=val(host? "syst:key?")
until (key code=F1) or css:recc:status?
                                         // Prints information out CSA RS-232
print "MIN of mobile is ", recc:min?
                                          // Connector.
print "ESN of mobile is "%h, recc:esn?
end
```

MACRO: call_setup SYNTAX: call setup

```
/*
          MACRO: page1
          SYNTAX: page1
        PURPOSE: Page Mobile Station until Page Response is received. */
*dmc "pagel", begin
erase:text 0,35,640
center "Paging Mobile", 0, 35, 640
css:call:proc:page
do
  delay1 1000
  key_code=val(host? "syst:key?")
until (key code=F1) or css:recc:status?
erase:text 0,35,640
center "Page Response Received", 0, 35, 640
end
1*
          MACRO: assign
         SYNTAX: assign
        PURPOSE: Assign Mobile Station to a digital voice channel. */
*dmc "assign", begin
css:call:proc:assign
delayl 1000
                                        // Waits for channel change.
erase:text 0,35,640
center "Digital Voice Channel Assigned", 0, 35, 640
end
/*
          MACRO: plc
         SYNTAX: plc
       PURPOSE: Send Physical Layer Control message to the Mobile Station until a Physical
                   Layer Control Ack message is received. */
*dmc "plc", begin
do
  css:fdtc:facch:plc
  delay1 500
  key code=val(host? "syst:key?")
until((key_code=F1) or (rdtc:facch:msg? = "PLC ACK"))
erase:text 0,35,640
center "Physical Layer Control", 0, 35, 640
end
```

MACRO: alert SYNTAX: alert

PURPOSE: Send Alert message to Mobile Station until Alert with Info Ack is received.

Wait until Connect message is received. */

```
*dmc "alert", begin
do
    css:fdtc:facch:alert
    delay1 500
    key_code=val(host? "syst:key?")
until((key_code=F1) or (rdtc:facch:amt? = "ALERT"))
erase:text 0,35,640
center "Answer Phone",0,35,640
while !(key_code=F1) and (rdtc:facch:msg? != "CONNECT")
    key_code=val(host? "syst:key?")
wend
erase:text 0,35,640
center "Connect",0,35,640
end
```

```
MACRO: sense
          SYNTAX: sense
        PURPOSE: Vary the output RF Level of the FM/AM-1600CSA until the Mobile Station
                   (phone) reports a BER of 2% to 4%. */
*dmc "sense", begin
var timeout, ber
i=0
\dot{\eta} = 0
erase:text 0,35,640
center "Finding Sensitivity of Mobile", 0, 35, 640
  css:fdtc:facch:meas
                                            // Sends Measurement Order until
  delay1 400
                                            // Measurement Order Ack message is
  key_code=val(host? "syst:key?")
                                            // received.
until (key_code=F1) or (rdtc:facch:msg?="MEAS ACK")
css:rflv1 -90
                                            // Starts with RF Level set at -90 dBm.
delay1 3000
do
  timeout=25
  css:rflvl -90 - i
  erase:text 0,140,640
  xyprint 40,140, "RFLVL: ", %d, -90 - i
  while ((rdtc:sacch:msg? != "CHAN QUAL1") and (--timeout))
    delay1 100
  ber=rdtc:sacch:ber?
  erase:text 0,160,640
  xyprint 40,160, "BER: ", %d, ber
  if ber=0
                                            // BER < 0.01%
    i=i+2
  elif ber=1
                                            // 0.01 < BER < 0.1
    i=i+1
  elif ber=2
                                            // 0.1 < BER < 0.5
    i=i+.2
  elif ber=3
                                           // 0.5 < BER < 1.0
    i=i+.1
  elif ber=4
                                            // 1.0 < BER < 2.0
    i=i+.1
  elif ber=5
                                           // 2.0 < BER < 4.0
    j=j+1
  elif ber=6
                                           // 4.0 < BER < 8.0
    i=i-.1
  else
                                           // BER > 8.0
    i=i-.2
  endif
  key_code=val(host? "syst:key?")
until j=6 or !(timeout) or key_code=F1
                                           // Goes on when BER=5 is found 6 times.
(The sense macro continues on the next page.)
```

```
if key_code != F1
                                                 // Checks for STOP.
                                                 // Prints information out CSA
 print "Sensitivity of Mobile is ", %4d, -90-i
                                                 // RS-232 Connector.
 print ""
 erase:text 0,35,640
 center "Test Done, Press End or STOP", 0, 35, 640
 while (key_code != F1) and (rdtc:facch:msg? != "RELEASE")
   key_code=val(host? "syst:key?")
  delay1 100
 wend
 erase:text 0,35,640
 center "Test Completed", 0, 35, 640
endif
css:stop
delay 500
end
```

```
MACRO: sense_main
         SYNTAX: sense_main
       PURPOSE: Provide the main calling routine for the sensitivity test. */
*dmc "sense_main",begin
var done=0
do
 focc_setup
 user
 host ":keypad:soft"
 color 1,15
 keypad:label 1, "START"
 keypad:label 6, "Ret"
 color 1,11
 center "Sensitivity Test", 0, 5, 640
   key_code=val(host? "syst:key?")
  until (key code=F6) or (key_code=F1)
                                           // Waits for valid key.
  if key_code=F6
   done=1
                                           // Goes to end if Ret key is pressed.
  else
   keypad:label 1,""
                                           // Erases F1 label.
   keypad:label 1, "STOP"
   keypad:label 6,""
                                           // Erases F6 label.
    registration
    if(key_code != F1)
      page1
    endif
    if(key_code != F1)
      assign
    endif
    if(key_code != F1)
      plc
    endif
    if(key_code != F1)
      alert
    endif
    if(key_code != F1)
      delay 3000
    if(key_code != F1)
      sense
    endif
  endif
until done
```

end

SECTION 7 - CSA SPECIFIC TMAC COMMANDS

7-1 GENERAL

This Section lists the FM/AM-1600CSA specific commands by Operation Mode. Commands are used remotely (Section 2) through GPIB (if option is installed) or RS-232, or as part of a TMAC program downloaded to the FM/AM-1600CSA. There are nine major modes of operation:

FOCC	Forward Control Channel Monitor
FVC	Forward Voice Channel Monitor
FDTC	Forward Digital Traffic Channel Monitor
RECC	Reverse Control Channel Monitor
RVC	Reverse Voice Channel Monitor
RDTC	Reverse Digital Traffic Channel Monitor
CSS	Cell Site Simulation
BER	Bit Error Rate for RDTC
MODACC	Modulation Accuracy for FDTC

The short forms of commands are shown in uppercase letters and the long forms are finished in lower case. When entering commands, it is not necessary to use a particular letter case. The TMAC compiler/interpreter is not case sensitive. Commands in each subsection are presented in logical operating order. Values are in decimal unless specified otherwise.

For remote operation, activate one of the 1600S operation modes and do not run Sp Tst. Refer to Section 6 for creating and downloading programs. Refer to Section 9 for programming examples.

Monitor commands, used to monitor forward channels from a Cell Site (Base Station) or reverse channels from a Mobile Phone (Station), implement the same functions available in the screens entered under Cell Site Data Monitor. CSS: commands, used to simulate a Cell Site, implement many of the same functions available in the screens entered under Cell Site Simulation. CSS:CALL:PROCess: commands add more flexibility than the front panel when setting up remote call processing. BER: commands implement the same functions available in the Base Station Digital Traffic BER screen. MODacc: commands implement the same functions available in the Modulation Accuracy screen.

7-2 HOST COMMANDS

HOST commands allow execution of 1600S specific commands and general commands limited to 1600S remote operation, when operating as the FM/AM-1600CSA.

```
HOST "string"
Issues commands, as strings, to the host FM/AM-1600S.

Example: HOST "SETUP:DUPL" // Passes the SETUP:DUPL command to the 1600S.

// 1600S configures Test Set routing and displays

// screen for Duplex Operation.

HOST? "string?"
Issues queries, as strings, to the host FM/AM-1600S.

Example: HOST? "MEAS:POW?" // Passes the MEAS:POW? query to the 1600S.

// 1600S returns a power meter reading (if

// configured to take power meter readings).
```

7-3 FORWARD CONTROL CHANNEL (FOCC) MONITOR COMMANDS

7-3-1 FORWARD CONTROL CHANNEL CONTROL

FOCC:

SETUD

Sets up the FM/AM-1600CSA as when entering the Forward Control Channel screen. (Screen is not displayed.) The FM/AM-1600S is forced into Duplex Mode through selection of Duplex screen. The Antenna is selected as the input source.

CHANnel n

Selects Forward Control Channel to monitor. Range of n is 1 to 1023 (800 to 990 not used).

STAR

Starts decoding Forward Control Channel data. (Data returned by query. Refer to 7-3-2.)

STOP

Stops decoding Forward Control Channel data.

REMote:

STAR

Stops decoding and redirects the received Forward Control Channel data (10 kbit) as ASCII characters out the RS-232 Connector. Each character represents one nibble (4 bits) of data. (Set Baud Rate to 38400 prior to command execution to allow RS-232 to keep up with data received.)

STOP

Stops redirection of Forward Control Channel data out the RS-232 Connector.

WORD:

A

Selects Stream A to decode.

В

Selects Stream B to decode.

BOTH

Selects Streams A and B to decode. Responses come randomly from either Stream A or B, unless the FOCC:STREAM command is used.

STREAM:

A

Used prior to a decode data query, to select data from Stream A when both streams are being decoded (FOCC:WORD:BOTH).

8

Used prior to a decode data query, to select data from Stream B when both streams are being decoded (FOCC:WORD:BOTH).

CAPTure?

Used with Capture commands to test if a specific message (ORDER) and/or communication to specific Mobile Station (MIN) has occurred (returns 1). Returns 0 otherwise.

CAPTure:

CLEAR

Restarts Capture Function (same as RECAP from front panel).

SELect:

BOTH

Sets Capture Mode to BOTH (MIN and ORDER) to capture a specific message from communication with specific Mobile Station.

MIN

Sets Capture Mode to MIN to capture communication with specific Mobile Station.

NONE

Sets Capture Mode to NONE.

ORDER

Sets Capture Mode to ORDER to capture a specific message.

MODE?

Returns current Capture Mode setting (0 for NONE, 1 for ORDER, 2 for MIN or 3 for BOTH [MIN and ORDER]).

Messages (Orders) for capture (used when FOCC:CAPTure:SELect: command is set to ORDER or BOTH):

FOCC:

CAPTure:

A ALERT

Selects Abbreviated Alert message as order for Capture.

AUDIT

Selects Audit message as order for Capture.

AUT REG

Selects Autonomous Registration Confirmation message as order for Capture.

BSCHALCON

Selects Base Station Challenge Confirmation Message as order for Capture.

DIR RTRY

Selects Directed-Retry message as order for Capture.

INTRCPT

Selects Intercept message as order for Capture.

LC

Selects Local Control message as order for Capture.

MSG WTG

Selects Message Waiting message as order for Capture.

CAPTure:

N AUT REG

Selects Non-autonomous Registration Confirmation message as order for Capture.

PAGE

Selects Page as order for Capture.

RELease

Selects Release message as order for Capture.

REORDER

Selects Reorder message as order for Capture.

SLOT_1

Selects Slot 1 Handoff message as order for Capture.

SLOT_2

Selects Slot 2 Handoff message as order for Capture.

SLOT 3

Selects Slot 3 Handoff message as order for Capture.

SSD UPdate

Selects Shared Secret Data Update as order for Capture.

UCHAL

Selects Unique Challenge message as order for Capture.

VC DES

Selects Voice Channel Designation message as order for Capture.

ORDer?

Returns name (string) of order currently selected for Capture.

Communication to specific Mobile Station for capture (used when FOCC:CAPTure:SELect: command is set to MIN or BOTH):

FOCC:

CAPTure:

MIN "n"

Selects Mobile Identification Number to Capture. The Mobile Identification Number (n) is entered as a string, with quotation marks. Wild cards are indicated using a tilde (\sim) .

Examples: FOCC: CAPTure: MIN "316/522-4981"
FOCC: CAPTure: MIN "~ ~ ~/522-~9~1"

MIN ?

Returns MIN currently selected for Capture.

7-3-2 FORWARD CONTROL CHANNEL DECODE DATA

The FOCC decode data queries return the specific monitored data items. If the specific data item is not available or has already been read, the query returns -1. Prior to initiating FOCC decode data queries, set FM/AM-1600CSA to FOCC initial setup (FOCC:SET) and start decoding (FOCC:STAR). If the queries are used as part of a TMAC Program, a TPAUSE command in conjunction with the queries may be needed to allow the data processing to take place. Refer to 9-2-1.

FOCC:

ACT?

Returns Global Action field value (four bit value).

AUTH?

Returns Authentication (one bit value).

AUTHBS?

Returns AUTHBS (18 bit value).

Bidle?

Returns Busy-Idle bit. Busy-Idle bit, multiplexed in with FOCC data, is 0 if Reverse Control Channel is busy or 1 if Reverse Control Channel is idle.

BIS?

Returns Busy-Idle Status bit from the Access Type Parameters Global Action message. (Busy-Idle Status bit is 0 if monitoring the Busy-Idle bit is not required by the Mobile Station, otherwise 1.)

CHAN?

Returns Channel Number field indicating designated RF channel (1 to 1023).

CHANPOS1?

Returns Channel Position 1 (seven bit value).

CHANPOS2?

Returns Channel Position 2 (seven bit value).

CHANPOS3?

Returns Channel Position 3 (seven bit value).

CHANPOS4?

Returns Channel Position 4 (seven bit value).

CHANPOS5?

Returns Channel Position 5 (seven bit value).

CHANPOS6?

Returns Channel Position 6 (seven bit value).

CMAC?

Returns Control Mobile Attenuation Code (three bit value).

CMAX 1?

Returns number of Access Channels minus one.

CPA?

Returns Combined Paging/Access (one bit value).

DCC?

Returns Digital Color Code (two bit value).

DMAC?

Returns Digital Mobile Attenuation Code (four bit value).

DTX?

Returns Discontinuous Transmission (one bit value).

DVCC?

Returns Digital Verification Color Code (eight bit value).

E?

Returns Extended Address (one bit value).

EF?

Returns Extended Protocol Forward Channel Indicator (one bit value).

END?

Returns End Indication (one bit value).

EP?

Returns Extended Protocol (one bit value).

LOC CONTRL?

Returns Local Control message (16 bit value).

LOCAID?

Returns Location Area Identity (12 bit value).

LOCAL MT?

Returns Local Control (Local Control message)/Message Type field (five bit value).

LREG?

Returns Location Registration (one bit value).

MBUSY:

OTH?

Returns Maximum Number of Busy Occurrences Allowed for Other Accesses (four bit value).

PGR?

Returns Maximum Number of Busy Occurrences Allowed for Page Responses (four bit value).

MEM?

Returns Message Encryption Mode (one bit value).

MIN?

Returns Mobile Identification Number (string).

MSZTR:

OTH?

Returns Maximum Number of Seizure Attempts Allowed for Other Accesses (four bit value).

PGR?

Returns Maximum Number of Seizure Attempts Allowed for Page Responses (four bit value).

N 1?

Returns number of Paging Channels minus one, to be scanned by the Mobile Station (five bit value).

NAWC?

Returns Number of Additional Words Coming (four bit value).

NEWACC?

Returns New Access Channel Starting Point (11 bit value).

OLC?

Returns Overload Control Class (15 bit value).

ORDER?

Returns name (string) of received order.

ORDERCD?

Returns Order Code (five bit value).

ORDQ?

Returns Order Qualifier (three bit value).

PCI?

Returns Protocol Capability Indicator (one bit value).

PDREG?

Returns Power Down Registration (one bit value).

PM?

Returns Privacy Mode (one bit value).

PUREG?

Returns Power Up Registration (one bit value).

RANDSSD_1?

Returns value of 24 most significant bits of RANDSSD (24 bit value).

RANDSSD 2?

Returns value of bits 8 through 31 of RANDSSD (24 bit value).

RANDSSD 3?

Returns value of eight least significant bits of RANDSSD (eight bit value).

RANDU?

Returns RANDU received in the Unique Challenge message (24 bit value).

RAND1 A?

Returns value of 16 most significant bits of RAND (16 bit value).

RAND1 B?

Returns value of 16 least significant bits of RAND (16 bit value).

RCF?

Returns Read Control-Filler (one bit value).

REGH?

Returns Registration for Home Mobile Stations (one bit value).

REGID?

Returns Registration Identification (20 bit value).

REGINCR?

Returns Registration Increment field (12 bit value).

REGR?

Returns Registration for Roaming Mobile Stations (one bit value).

S?

Returns Serial Number (one bit value).

SCC?

Returns Supervisory Audio Tone Color Code (two bit value).

SDCC1?

Returns Supplementary Digital Color Code 1 (two bit value).

SDCC2?

Returns Supplementary Digital Color Code 2 (two bit value).

SID?

Returns System Identification Number (14 bit value).

VMAC?

Returns Voice Mobile Attenuation Code (three bit value).

WFOM?

Returns Wait For Overhead Message (one bit value).

7-3-3 FORWARD CONTROL CHANNEL RAW DATA

The FM/AM-1600CSA contains a 100 word data buffer to capture raw data (undecoded bit streams) received on the Forward Control Channel. Prior to initiating FOCC raw data queries, set the FM/AM-1600CSA to initial FOCC setup (FOCC:SET) and select the RF Channel (FOCC:CHAN n). Refer to 9-2-2.

FOCC:

RAW:

WORD:

Δ

Selects raw data from Stream A to monitor.

В

Selects raw data from Stream B to monitor.

BOTH

Selects raw data from Streams A and B, randomly, to monitor.

Messages (Orders) for raw data capture:

FOCC:

RAW:

CAPTure:

NONE

Sets Capture Mode to NONE.

A ALERT

Selects Abbreviated Alert Message as order for Capture.

AUDIT

Selects Audit Message as order for Capture.

AUT_REG

Selects Autonomous Registration Confirmation message as order for Capture.

BSCHALCON

Selects Base Station Challenge Confirmation Message as order for Capture.

DIR RTRY

Selects Directed-Retry message as order for Capture.

INTROPT

Selects Intercept message as order for Capture.

LC

Selects Local Control Message as order for Capture.

RAW:

CAPTure:

MSG WTG

Selects Message Waiting message as order for Capture.

N_AUT_REG

Selects Non-autonomous Registration Confirmation message as order for Capture.

PAGE

Selects Page as order for Capture.

RELease

Selects Release message as order for Capture.

REORDER

Selects Reorder message as order for Capture.

SLOT 1

Selects Slot 1 Handoff message as order for Capture.

SLOT 2

Selects Slot 2 Handoff message as order for Capture.

SLOT 3

Selects Slot 3 Handoff message as order for Capture.

SSD UPdate

Selects Shared Secret Data Update as order for Capture.

UCHAL

Selects Unique Challenge message as order for Capture.

VC DES

Selects Voice Channel Designation message as order for Capture.

ORDer?

Returns name (string) of order currently selected for Capture.

INDex?

Returns position (0 to 99) of Captured Order in the 100 word data buffer.

TRIGger n

Selects position of Captured Order in the 100 word data buffer. Range of n is 0 to 4.

STARt

Starts raw data Capture.

STOP

Stops raw data Capture.

RAW:

CAPTure?

Returns 1 if Capture condition has occurred; 0 otherwise.

FULL?

Returns 1 if 100 word data buffer is full; 0 otherwise.

Α:

CHECK? n

Returns CRC Check result for selected data word from Stream A (0 [good], 1 [bad]). Range of n is 0 to 99.

DATA? n

Returns selected raw data word from Stream A. Range of n is 0 to 99.

PARITY? n

Returns Parity for selected data word from Stream A. Range of n is 0 to 99.

В:

CHECK? n

Returns CRC Check result for selected data word from Stream B (0 [good], 1 [bad]). Range of n is 0 to 99.

DATA? n

Returns Raw Data word from Stream B. Range of n is 0 to 99.

PARITY n

Returns Parity for selected data word from Stream B. Range of n is 0 to 99.

B 1? n

Returns Busy-Idle bit for selected data word. Range of n is 0 to 99.

TS? n

Returns Time Stamp in ms of selected data word. Range of n is 0 to 99.

ADDENDUM TO SECTION 7-3

7-3A FOCC

FOCC:

CONFigure:

USER

[FOCC:CONGigure:USER]

This command is identical to the **FOCC:SETup** command except that it selects the USER screen.

NONE

[FOCC:CONGigure:NONE]

This command is also identical to the FOCC:SETup command except that it does not select a screen.

PVI?

[FOCC:PVI?]

Returns current state of Protocol Version Indicator (1 bit value).

ORDER?

[FOCC:ORDER?]

Add the following orders:

G3FAX WTG

SMS WTG

G3 PAGE

ASYNC PAGE

MSG WTG

ANA VC DES



7-4 FORWARD VOICE CHANNEL (FVC) MONITOR COMMANDS

7-4-1 FORWARD VOICE CHANNEL CONTROL

FVC:

SETup

Sets up the FM/AM-1600CSA as when entering the Forward Voice Channel screen. (Screen is not displayed.)

STAR

Starts decoding Forward Voice Channel data. (Data returned by query. Refer to 7-4-2.)

STOP

Stops decoding Forward Voice Channel data.

CHANnel n

Selects Forward Voice Channel to monitor. Range of n is 1 to 1023 (800 to 900 not used).

SCC n

Specifies the SCC by providing the SAT frequency in Hz (n) corresponding to the SAT Color Code (SCC). Range of n is 5955 to 6044. The FVC decode task only decodes messages having a specified SCC. Sending the command as FVC:SCC:MEAS:SAT? insures the SCC matches the SAT frequency on the channel being monitored. The :MEAS:SAT? query returns the SAT frequency in Hz and the FVC:SCC sets up the SCC match as follows:

SAT Frequency	SCC
5955-5984 Hz	0 (00)
5985-6014 Hz	1 (01)
6015-6044 Hz	2 (10)

Using the command in this way insures only messages on the selected channel, and not an adjacent channel, are decoded.

7-4-2 FORWARD VOICE CHANNEL DECODE DATA

The FVC Decode Data queries return the last value decoded or a -1, if value has not been decoded since the last time requested. Prior to initiating FVC decode data queries, set FM/AM-1600CSA to FVC initial setup (FVC:SET) and start decoding data (FVC:STAR). If queries are used as part of a TMAC Program, a TPAUSE command in conjunction with the queries may be needed to allow the background decoding task time to run. Refer to 9-3-1.

FVC:

AUTHRS2

Returns Output Response of Base Station Authentication Algorithm (18 bit value).

CHAN?

Returns Channel Number field indicating designated RF channel (1 to 1023).

CHAR1?

Returns first Characters in Called Party Number message (Flash with Information) or Calling Party Number message (Alert with Information or Flash with Information) (up to 16 digits).

CHAR2?

Returns last Characters in Called Party Number message (Flash with Information) or Calling Party Number message (Alert with Information or Flash with Information) (up to 16 digits).

FVC:

CPN RL?

Returns Calling Party Number Remaining Length (six bit value).

DMAC?

Returns Digital Mobile Attenuation Code (four bit value).

DVCC?

Returns Digital Verification Color Code (eight bit value).

EF?

Returns Extended Protocol Forward Channel Indicator (one bit value).

LOCAL MT?

Returns Local Control (Local Control message)/Message Type field (five bit value).

MEM?

Returns Message Encryption Mode (one bit value).

ORDER?

Returns name (string) of received Order.

ORDERCD?

Returns Order Code (five bit value).

ORDQ?

Returns Order Qualifier (three bit value).

PI?

Returns Calling Party Number Presentation Indicator (two bit value).

PM?

Returns Privacy Mode (one bit value).

PSCC?

Returns Present SAT Color Code (two bit value).

PWRL?

Returns Power Level requested of Mobile Station in Power Level message (same as ORDQ).

RANDSSD1?

Returns value of 24 most significant bits of RANDSSD (24 bit value).

RANDSSD2?

Returns value of bits 8 through 31 of RANDSSD (24 bit value).

RANDSSD3?

Returns eight least significant bits of RANDSSD (eight bit value).

RANDU?

Returns RANDU received in the Unique Challenge message (24 bit value).

RL W?

Returns Remaining Length in Words (five bit value).

FVC:

SBI?

Returns Shortened Burst Indicator (two bit value).

SCC?

Returns Supervisory Audio Tone Color Code (two bit value).

SI?

Returns Calling Party Screening Indicator (two bit value).

SIGnal?

Returns Signal field (eight bit value).

TA?

Returns Time Alignment offset (five bit value).

VMAC?

Returns Voice Mobile Attenuation Code (three bit value).

7-4-3 FORWARD VOICE CHANNEL RAW DATA

The FM/AM-1600CSA contains a variable capacity data buffer to capture raw data (undecoded bit stream) received on the Forward Voice Channel. Prior to initiating FVC raw data commands, set the FOCC Capture Mode to NONE (FOCC:CAPT:SEL:NONE) and set FM/AM-1600CSA to initial FVC setup (FVC:SET). Obtain new data information by setting *n* from 0 to current FVC:RAW:DEPTH setting minus one, when using raw data information queries. Refer to 9-3-2.

FVC:

RAW:

DEPTH n

Selects size of data buffer in data words. Range of n is 1 to 100 data words.

STAR

Starts receiving raw data into data buffer.

STOP

Stops receiving raw data into data buffer.

COUNT?

Returns number of data words received (increments with each new data word). Used to know when to query for new data information.

DATA? n

Returns selected raw data word (28 bits). Range of n is 0 to 99.

PARITY? r

Returns Parity for selected data word (12 bits). Range of n is 0 to 99.

CHECK? n

Returns CRC Check result for selected data word (0 [good], 1 [bad]). Range of n is 0 to 99.

TS? n

Returns Time Stamp of selected data word in seconds from 0 data word. Range of n is 0 to 99.

ADDENDUM TO SECTION 7-4

7-4A FVC

FVC:

CONFigure:

USER

[FVC:CONFigure:USER]

This command is identical to the FVC:SETup command except that it selects the USER screen.

NONE

[FVC:CONFigure:NONE]

This command is also identical to the FVC:SETup command except that it does not select a screen.

PVI?

[FVC:PVI?]

Returns current state of Protocol Version Indicator (1 bit value).

HYPERband?

[FVC:HYPERband?]

Returns current value of Hyperband (2 bit value).

ORDER?

[FVC:ORDER?]

Add the following orders:

G3FAX WTG

SMS WTG

G3 PAGE

ASYNC PAGE

MSG WTG

RELEASE W/INFO

7-5 FORWARD DIGITAL TRAFFIC CHANNEL (FDTC) MONITOR COMMANDS

7-5-1 FORWARD DIGITAL TRAFFIC CHANNEL CONTROL

FDTC:

SETup

Sets up the FM/AM-1600CSA as when entering the Forward Digital Traffic Channel screen. (Screen is not displayed.)

STARt

Starts decoding Forward Digital Traffic Channel data. (Data returned by query. Refer to 7-5-2.)

STOP

Stops decoding Forward Digital Traffic Channel data.

CHANnel n

Selects Forward Digital Traffic Channel to monitor. Range of n is 1 to 1023. (800 to 900 not used.)

SLOT n

Selects Digital Traffic Channel Timeslot. Range of n is 1 to 3.

DVCC?

Returns Digital Verification Color Code.

R0?

Returns VSELP frame energy value (0 to 31).

7-5-2 FORWARD DIGITAL TRAFFIC CHANNEL DECODE DATA

FDTC:FACCH: queries pertain to the blank and burst Fast Associated Control Channel (FACCH). **FDTC:SACCH:** queries pertain to the continuous Slow Associated Control Channel (SACCH).

FDTC:

FACCH:

MSGtype?

Returns Message Type (string):

ALERT HANDOFF
AUDIT LC
BS ACK MAINT
FILL OCT MEAS
FLASH PLC
FLASH ACK PU

AMT?

Returns Acknowledge Message Type (string).

AUTHBS?

Returns AUTHBS (18 bit value).

RELEASE

SBDA

SCDA

SR

S MEAS

FACCH:

CALLING:

NUM?

Returns number of the calling party (string).

PI?

Returns Calling Party Presentation Indicator (two bit value).

PLANId?

Returns Calling Party Numbering Plan Identification (four bit value).

SI?

Returns Calling Party Screening Indicator (two bit value).

SPare?

Returns value of Calling Party Number spare bits (five bit value).

TYpe?

Returns Calling Party Number Type (three bit value).

CNPC?

Returns the Calling Number Presentation Code (four bit value).

DIC?

Returns Delay Interval Compensation (one bit value).

DIGits? n

Returns the 11 digits (string) of the selected digit set. Setting for n is 0 (DIGITS1), 1 (DIGITS2) or 2 (DIGITS3).

DMAC?

Returns Digital Mobile Attenuation Code (four bit value).

DTX?

Returns Discontinuous Transmission (one bit value).

HDVCC?

Returns Handoff Digital Verification Color Code (eight bit value).

LC?

Returns Local Control (five bit value).

LDP?

Returns Last Decoded Parameter (four bit value).

MEM?

Returns Message Encryption Mode (one bit value).

NOMW?

Returns Number of Messages Waiting (six bit value).

FACCH:

NV? n

Returns Number of Values (six bit value) for selected optional information element. Range of n is 0 (1st element) to 5 (6th element).

PD?

Returns Protocol Discriminator (two bit value).

PT? n

Returns Parameter Type (four bit value) for selected optional information element. Range of n is 0 (1st element) to 5 (6th element).

RANDSSD1?

Returns value of 24 most significant bits of RANDSSD (24 bit value).

RANDSSD2?

Returns value of bits 8 through 31 of RANDSSD (24 bit value).

RANDU?

Returns RANDU received in Unique Challenge message (24 bit value).

RATE?

Returns Channel Rate (one bit value).

RFCHAN? n

Returns RF Channel (1 to 1023) for the selected index (1 to 1023). Range of n is 0 to 11.

RL? n

Returns Remaining Length as number of octets (six bit value) remaining in selected message segment. Range of n is 0 to 2. (Segments pertain to the 0 to 2 instances the Calling Party Number may be sent in the Alert with Information or Flash with Information messages.)

RN?

Returns Request Number (four bit value).

SBI?

Returns Shortened Burst Indicator (two bit value).

SIGnal?

Returns Signal field (eight bit value).

TA?

Returns Time Alignment (five bit value).

TI?

Returns Timeslot Indicator (0 to 6). (0 is analog.)

VPM?

Returns Voice Privacy Mode (one bit value).

SACCH:

MSGtype?

Returns Message Type (string):

ALERT **HANDOFF** RELEASE AUDIT LC SBDA BS ACK SCDA MAINT FILL OCT MEAS S MEAS FLASH PLC SR FLASH ACK PU

AMT?

Returns Acknowledge Message Type (string).

AUTHBS?

Returns AUTHBS (18 bit value).

CALLING:

NUM?

Returns number of the calling party (string).

P12

Returns Calling Party Presentation Indicator (two bit value).

PLANId?

Returns Calling Party Numbering Plan Identification (four bit value).

SI?

Returns Calling Party Screening Indicator (two bit value).

SPare?

Returns value of Calling Party Number spare bits (five bit value).

TYpe?

Returns Calling Party Number Type (three bit value).

CNPC?

Returns Calling Number Presentation Code (four bit value).

DIC?

Returns Delay Interval Compensation (one bit value).

DIGits? n

Returns the 11 digits (string) of the selected digit set. Setting for n is 0 (DIGITS1), 1 (DIGITS2) or 2 (DIGITS3).

DMAC?

Returns Digital Mobile Attenuation Code (four bit value).

DTX?

Returns Discontinuous Transmission (one bit value).

SACCH:

HDVCC?

Returns Handoff Digital Verification Color Code value (eight bit value).

LC?

Returns Local Control (five bit value).

LDP?

Returns Last Decoded Parameter (14 bit value).

MEM?

Returns Message Encryption Mode (one bit value).

NOMW?

Returns Number of Messages Waiting (six bit value).

NV? r

Returns Number of Values (six bit value) for selected optional information element. Range of n is 0 (1st element) to 5 (6th element).

PD?

Returns Protocol Discriminator (two bit value).

PT? r

Returns Parameter Type (two bit value) for selected optional information element. Range of n is 0 (1st element) to 5 (6th element).

RANDSSD1?

Returns value of 24 most significant bits of RANDSSD (24 bit value).

RANDSSD2?

Returns value of bits 8 through 31 of RANDSSD (24 bit value).

RANDU?

Returns RANDU received in Unique Challenge message (24 bit value).

RATE?

Returns Channel Rate (one bit value).

RFCHAN? n

Returns RF Channel (1 to 1023) for the selected index. Range of n is 0 to 11.

RL? n

Returns Remaining Length as number of octets (six bit value) remaining in selected message segment. Range of n is 0 to 2. (Segments pertain to the 0 to 2 instances the Calling Party Number may be sent in the Alert with Information or Flash with Information messages.)

RN?

Returns Request Number (four bit value).

SACCH:

SBI?

Returns Shortened Burst Indicator (two bit value).

SIGnal?

Returns Signal Field (eight bit value).

TA?

Returns Time Alignment (five bit value).

TI?

Returns Timeslot Indicator (0 to 6). (0 is analog.)

VPM?

Returns Voice Privacy Mode (one bit value).

7-5-3 FORWARD DIGITAL TRAFFIC CHANNEL RAW DATA

The FM/AM-1600CSA contains a variable capacity data buffer to capture raw data (undecoded bit stream) received on the Forward Digital Traffic Channel. Prior to initiating FDTC raw data commands, set FM/AM-1600CSA to initial FDTC setup (FDTC:SET). Obtain new data information by setting *n* from 0 to current FDTC:RAW:DEPTH setting minus one, when using raw data information queries. Refer to 9-4-2.

FDTC:

RAW:

START

Starts raw data Capture.

STOP

Stops raw data Capture.

SELect:

FACCH

Selects Fast Associated Control Channel for raw data.

SACCH

Selects Slow Associated Control Channel for raw data.

DEPTH n

Selects size (number of data words) of data buffer. Range of n is 1 to 100.

COUNt?

Returns number of data words received (increments with each new data word). Used to know when to query for new data information.

CF? n

Returns Continuation Flag bit from selected data word. Range of n is 0 to 99.

RAW:

RSVD? n

Returns Reserved for Future Use bits from selected data word. Range of n is 0 to 99.

MESSage? n,x

Returns selected message byte from selected data word. Range of n is 0 to 99. Range of x (byte) is 0 to 5.

DVCC? n

Returns Digital Verification Color Code from selected data word. Range of n is 0 to 99.

TIME? n

Returns Time Stamp in ms of selected data word. Range of n is 0 to 99.

7-5-4 IS-54 RAW DATA

The FM/AM-1600CSA contains a fixed capacity data buffer (100 data words) to capture raw timeslot data (undecoded bit streams) received on the Forward Digital Traffic Channel. Prior to initiating FDTC raw data commands, set FM/AM-1600CSA to initial FDTC setup (FDTC:SET). Refer to 9-4-3.

FDTC:

IS54:

START

Starts IS-54 timeslot raw data Capture

STOP

Stops IS-54 timeslot raw data Capture.

COUNt?

Returns number of data words received (increments with each new data word). Used to know when to query for new data information.

SACCH? n

Returns 12 bits of the SACCH message in selected data word. Range of n is 0 to 99.

SYNC? n

Returns the 28 Synchronization bits from selected data word. Range of n is 0 to 99.

DATA? n,x

Returns SACCH character data from selected data word. Range of n is 0 to 99. Range of x (character) is 1 to 65.

CDVCC? n

Returns the 12 bit Coded Digital Color Code from selected data word. Range of n is 0 to 99.

TIME? n

Returns Time Stamp in ms of selected data word. Range of n is 0 to 99.

ADDENDUM TO SECTION 7-5

7-5A FDTC

FDTC:

CONFigure:

USER

[FDTC:CONFigure:USER]

This command is identical to the **FDTC:SETup** command except that it selects the USER screen.

NONE

[FDTC:CONFigure:NONE]

This command is also identical to the **FDTC:SETup** command except that it does not select a screen.

FACCH: or SACCH:

MSGtype?

[FDTC:FACCH: or SACCH:MSGtype?]

Add the following orders:

DEDICATED HANDOFF

CAPABILITY REQ

R-DATA ACCEPT

HYPERBAND MEAS

CAPABILITY RESP

R-DATA REJECT

BSMC

R-DATA

SOC

RFCHAN? n

[FDTC:FACCH: or SACCH:RFCHAN?]

Returns current value of RFCHAN (11 bit value) indexed by n. Range of n is (0-23).

PVI?

[FDTC:FACCH: or SACCH:PVI?]

Returns current state of Protocol Version Indicator (1 bit value)

DTXControl?

[FDTC:FACCH: or SACCH:DTXControl?]

Returns current state of DTX Control (1 bit value).

DCCHinfo:

HYPERband? n

[FDTC:FACCH: or SACCH:DCCHinfo:HYPERband?]

Returns current value of DCCH Info Hyperband (2 bit value) indexed by n. Range of n is 0 to 2.

CHANnel? n

[FDTC:FACCH: or SACCH:DCCHinfo:CHANnel?]

Returns current value of DCCH info Channel (8 bit value) indexed by n. Range of n is 0 to 2.

FACCH: or SACCH:

DCCHinfo:

DVCC? n

[FDTC:FACCH: or SACCH:DCCHinfo:DVCC?]

Returns current value of DCCH info DVCC (8 bit value) indexed by n. Range of n is 0 to 2.

MSGWTG:

TYPE? n

[FDTC:FACCH: or SACCH:MSGWTG:TYPE?]

Returns current value of Other Messages Waiting Info Type (4 bit value) indexed by n. Range of n is 0 to 14.

NUMBer? n

[FDTC:FACCH: or SACCH:MSGWTG:NUMBer?]

Returns current value of Number of Other Messages Waiting (6 bit value) indexed by n. Range of n is 0 to 14.

TASK?

[FDTC:FACCH: or SACCH:TASK?]

Returns current value of Task Status (3 bit value).

ATCO

[FDTC:FACCH: or SACCH:ATS?]

Returns current value of ATS (4 bit value).

PV?

[FDTC:FACCH: or SACCH:PV?]

Returns current value of Protocol Version (4 bit value).

CHANGE:

SOC?

[FDTC:FACCH: or SACCH:CHANGE:SOC?]

Returns current state of SOC Change Indicator (1 bit value).

BSMC?

[FDTC:FACCH: or SACCH:CHANGE:BSMC?]

Returns current state of BSMC Change Indicator (1 bit value).

DELTA:

TIME?

[FDTC:FACCH: or SACCH:DELTA:TIME?]

Returns current value of Delta Time (11 bit value).

FACCH: or SACCH:

VMI:

VC?

[FDTC:FACCH: or SACCH:VMI:VC?]

Returns current value of Voice Mode Voice coder (3 bit value).

PM V?

[FDTC:FACCH: or SACCH:VMI:PM_V?]

Returns current value of Voice Privacy Mode (3 bit value).

DPM?

[FDTC:FACCH: or SACCH:DPM?]

Returns current state of Data Privacy Mode (1 bit value).

MEMC:

MEA?

[FDTC:FACCH: or SACCH:MEMC:MEA?]

Returns current value of Message Encryption Mode C Algorithm (2 bit value).

MED?

[FDTC:FACCH: or SACCH:MEMC:MED?]

Returns current value of Message Encryption Mode C Domain (2 bit value).

MEK?

[FDTC:FACCH: or SACCH:MEMC:MEK?]

Returns current value of Message Encryption Mode C Key (2 bit value).

MAP:

VPM?

[FDTC:FACCH: or SACCH:MAP:VPM?]

Returns current value of Voice Privacy Mode Map (4 bit value).

CODER?

[FDTC:FACCH: or SACCH:MAP:CODER?]

Returns current value of Voice Coder Map (6 bit value).

MEA:

DOMAIN?

[FDTC:FACCH: or SACCH:MAP:MEA:DOMAIN?]

Returns current value of Message Encryption Algorithm Map Domain (8 bit value).

Algorithms? n

[FDTC:FACCH: or SACCH:MAP:MEA:ALGORithms?]

Returns current value of Message Encryption Algorithm Map (4 bit value) indexed by n. Range of n is 0 to 7.

FACCH: or SACCH:

MAP:

MEK?

[FDTC:FACCH: or SACCH:MAP:MEK?]

Returns current value of Message Encryption Key Map (4 bit value).

ARQ?

[FDTC:FACCH: or SACCH:MAP:ARQ?]

Returns current state of FACCH/SACCH ARQ Map (1 bit value).

SMS?

[FDTC:FACCH: or SACCH:MAP:SMS?]

Returns current value of SMS Map (2 bit value).

SUPPort:

IRA?

[FDTC:FACCH: or SACCH:SUPPort:IRA?]

Returns current state of RA Support (1 bit value).

SOC?

[FDTC:FACCH: or SACCH:SOC?]

Returns current value of SOC (12 bit value).

BSMC?

[FDTC:FACCH: or SACCH:BSMC?]

Returns current value of BSMC (8 bit value).

RTRANSaction?

[FDTC:FACCH: or SACCH:RTRANSaction?]

Returns current value of R-Transaction Identifier (8 bit value).

RDATA_UNIT:

LENGth?

[FDTC:FACCH: or SACCH:RDATA_UNIT:LENGth?]

Returns current value of R-Data Unit Extended Remaining Length (8 bit value).

HLP:

IDentifier?

[FDTC:FACCH: or SACCH:RDATA_UNIT:HLP:IDentifier?]

Returns current value of R-Data Unit Higher Layer Protocol Identifier (8 bit value).

DATA? n

[FDTC:FACCH: or SACCH:RDATA_UNIT:HLP:DATA?]

Returns current value of R-Data Unit Higher Layer Data Unit (8 bit value) indexed by n. Range of n is 0 to 255.

FACCH: or SACCH:

MESSage:

CENTer:

LENGth?

[FDTC:FACCH: or SACCH:MESSage:CENTer:LENGth?]

Returns current value of Message Center Address Extended Remaining Length (8 bit value).

TYPE?

[FDTC:FACCH: or SACCH:MESSage:CENTer:TYPE?]

Returns current value of Message Center Address Type of Number (3 bit value).

PLANId?

[FDTC:FACCH: or SACCH:MESSage:CENTer:PLANid?]

Returns current value of Message Center Address Number Plan Identification (4 bit value).

ENCodina?

[FDTC:FACCH: or SACCH:MESSage:CENTer:ENCoding?]

Returns current state of Message Center Address Encoding (1 bit value).

ADDRess?

[FDTC:FACCH: or SACCH:MESSage:CENTer:ADDRess?]

Returns current string value of Message Center Address (ASCII string).

USER:

DEST:

LENGth?

[FDTC:FACCH: or SACCH:USER:DEST:LENGth?]

Returns current value of User Destination Address Extended Remaining Length (8 bit value).

TYPE?

[FDTC:FACCH: or SACCH:USER:DEST:TYPE?]

Returns current value of User Destination Address Type of Number (3 bit value).

PLANId?

[FDTC:FACCH: or SACCH:USER:DEST:PLANId?]

Returns current value of User Destination Address Number Plan Identification (4 bit value).

ENCoding?

[FDTC:FACCH: or SACCH:USER:DEST:ENCoding?]

Returns current state of User Destination Address Encoding (1 bit value).

FACCH: or SACCH:

USER:

DEST:

ADDRess?

[FDTC:FACCH: or SACCH:USER:DEST:ADDRess?]

Returns current string value of User Destination Address (ASCII string).

SUBaddress:

LENGth?

[FDTC:FACCH: or SACCH:USER:DEST;SUBaddress:LENGth?]

Returns current value of User Destination Subaddress Extended Remaining length (8 bit value).

ODD EVEN?

[FDTC:FACCH: or SACCH:USER:DEST:SUBaddress:ODD_EVEN?]

Returns current state of User Destination Subaddress Odd/Even Indicator (1 bit value).

TYPE?

[FDTC:FACCH: or SACCH:USER:DEST:SUBaddress:TYPE?]

Returns current value of User Destination Type of Subaddress (3 bit value).

REServed?

[FDTC:FACCH: or SACCH:USER:DEST:SUBaddress:REServed?]

Returns current value of User Destination Subaddress Reserved bits (4 bit value).

ADDRess? n

[FDTC:FACCH: or SACCH:USER:DEST:SUBaddress:ADDRess?]

Returns current value of User Destination Subaddress (8 bit value) indexed by n. Range of n is 0 to 19.

ORIG:

LENGth?

[FDTC:FACCH: or SACCH:USER:ORIG:LENGth?]

Returns current value of User Originating Address Extended Remaining Length (8 bit value).

TYPE?

[FDTC:FACCH: or SACCH:USER:ORIG:TYPE?]

Returns current value of User Originating Address Type of Number (3 bit value).

PLANId?

[FDTC:FACCH: or SACCH:USER:ORIG:PLANId?]

Returns current value of User Originating Address Number Plan Identification (4 bit value).

FACCH: or SACCH:

USER:

ORIG:

ENCoding?

[FDTC:FACCH: or SACCH:USER:ORIG:ENCoding?]

Returns current state of User Originating Address Encoding (1 bit value).

ADDRess?

[FDTC:FACCH: or SACCH:USER:ORIG:ADDRess?]

Returns current value of User Originating Address (ASCII string).

SUBaddress:

LENGth?

[FDTC:FACCH: or SACCH:USER:ORIG:SUBaddress:LENGth?]

Returns current value of User Originating Subaddress Extended Remaining length (8 bit value).

ODD EVEN?

[FDTC:FACCH: or SACCH:USER:ORIG:SUBaddress:ODD_EVEN?]

Returns current state of User Originating Subaddress Odd/Even Indicator (1 bit value).

TYPE?

[FDTC:FACCH: or SACCH:USER:ORIG:SUBaddress:TYPE?]

Returns current value of User Originating Type of Subaddress (3 bit value).

REServed?

[FDTC:FACCH: or SACCH:USER:ORIG:SUBaddress:REServed?]

Returns current value of User Originating Subaddress Reserved bits (4 bit value).

ADDRess? n

[FDTC:FACCH: or SACCH:USER:ORIG:SUBaddress:ADDRess?]

Returns current value of User Originating Subaddress (8 bit value) indexed by n. Range of n is 0 to 19.

PRESentation:

LENGth?

[FDTC:FACCH: or SACCH:USER:ORIG:LENGth?]

Returns current value of User Originating Address Presentation Indicator Extended Remaining Length (8 bit value).

PI?

[FDTC:FACCH: or SACCH:USER:ORIG:PI?]

Returns current value of User Originating Address Presentation Indicator (2 bit value).

FACCH: or SACCH:

USER:

ORIG:

SI?

[FDTC:FACCH: or SACCH:USER:ORIG:SI?]

Returns current value of User Originating Address Screening Indicator (2 bit value).

REServed?

[FDTC:FACCH: or SACCH:USER:ORIG:REServed?]

Returns current value of User Originating Address Presentation Indicator reserved bits (4 bit value).

RCAUSE?

[FDTC:FACCH: or SACCH:RCAUSE?]

Returns current value of R-Cause (8 bit value).

CUSTOM:

LENGth?

[FDTC:FACCH: or SACCH:CUSTOM:LENGth?]

Returns current value of Length of Custom Control in Octets (8 bit value).

CONTrol? n

[FDTC:FACCH: or SACCH:CUSTOM:CONTrol?]

Returns current value of Custom Control (8 bit value) indexed by n. Range of n is 0 to 255.

HYPERband:

NUMBer?

[FDTC:FACCH: or SACCH:HYPERband:NUMBer?]

Returns current value of RF Channel and Hyperband, Number of Hyperband channels (5 bit value).

BAND? n

[FDTC:FACCH: or SACCH:HYPERband:BAND?]

Returns current value of RF Channel and Hyperband, Hyperband (2 bit value) indexed by n. Range of n is 0 to 23.

CHANnel? n

[FDTC:FACCH: or SACCH:HYPERband:CHANnel?]

Returns current value of RF Channel and Hyperband, Channel (11 bit value) indexed by n. Range of n is 0 to 23.

TARGet?

[FDTC:FACCH: or SACCH:HYPERband:TARGet?]

Returns current value of Target Hyperband (2 bit value).

7-6 REVERSE CONTROL CHANNEL (RECC) MONITOR COMMANDS

7-6-1 REVERSE CONTROL CHANNEL CONTROL

RECC:

SETup

Sets up the FM/AM-1600CSA as when entering the Reverse Control Channel Screen. (Screen is not displayed.)

STAR

Starts monitoring Reverse Control Channel data. (Data returned by query. Refer to 7-6-2.)

STOP

Stops monitoring Reverse Control Channel data.

CHANnel n

Selects Reverse Control Channel to monitor. Range of n is 1 to 1023 (800 to 900 not used).

7-6-2 REVERSE CONTROL CHANNEL DECODE DATA

RECC:

AUTHR?

Returns AUTHR from Mobile Station Authentication Algorithms (18 bit value).

AUTHU?

Returns AUTHU used in Unique Challenge Order Confirmation (18 bit value).

COUNT?

Returns modulo-64 count sent from Mobile Station.

DCC?

Returns Digital Color Code (seven bit value).

DIGITS1?

Returns up to 16 digits (string).

DIGITS2?

Returns up to 16 digits (string).

E?

Returns Extended Address (one bit value).

EP?

Returns Extended Protocol (one bit value).

ER?

Returns Extended Protocol Reverse Channel Indicator (one bit value).

ESN?

Returns Electronic Serial Number (32 bit value).

ADDENDUM TO SECTION 7-6

7-6A RECC

RECC:

CONFigure:

USER

[RECC:CONFigure:USER]

This command is identical to the **RECC:SETup** command except that it selects the USER screen.

NONE

[RECC:CONFigure:NONE]

This command is also identical to the **RECC:SETup** command except that it does not select a screen.

SERVice?

[RECC:SERVice?]

Returns current value of Service code (4 bit value).

PM D?

[RECC:PM_D?]

Returns current value of Selected Privacy Mode (3 bit value).

SAP?

[RECC:SAP?]

Returns current state of Service Access Point for data/fax call (1 bit value).

CRC?

[RECC:CRC?]

Returns 16 or 24 bit CRC setting on data/fax call (1 bit value).

DATA:

PART?

[RECC:DATA:PART?]

Returns current value of Data Part (3 bit value).

ACKED?

[RECC:DATA:ACKED?]

Returns current state of Acked Data (1 bit value).

RLP?

[RECC:RLP?]

Returns current value of Layer 2 Radio Link Protocol used for a data/fax call (2 bits value).

TORDER?

[RECC:TORDER?]

The new orders for RECC are:

ORIGIN W/SERVICE

PAGE RESP W/SERVICE

% <u>.</u> 			
	·		
			. •
÷			***************************************

RECC:

LOCAL_MT?

Returns Local Control (Local Control message)/Message Type (five bit value).

LT?

Returns Last Try (one bit value).

MIN?

Returns Mobile Identification Number (string) of Mobile Station.

MPCI?

Returns Mobile Protocol Capability Indicator (one bit value).

ORDERCD?

Returns Order Code (five bit value).

ORDQ?

Returns Order Qualifier (three bit value).

RANDBS?

Returns RANDBS used in Base Station Challenge Order (32 bit value).

RANDC?

Returns RANDC (eight bit value).

S?

Returns Serial Number (one bit value).

SCM?

Returns Station Class Mark (four bit value).

SDCC1?

Returns Supplementary Digital Color Code 1 (two bit value).

SDCC27

Returns Supplementary Digital Color Code 2 (two bit value).

TORDer?

Returns combination of the T and Order Fields (string):

A ALERT CNF AUDIT CNF ORIGIN PAGE RESP REG

7-7 REVERSE VOICE CHANNEL (RVC) MONITOR COMMANDS

7-7-1 REVERSE VOICE CHANNEL CONTROL

RVC:

SETup

Sets up the FM/AM-1600CSA as when entering the Reverse Voice Channel Screen. (Screen is not displayed.)

STARt

Starts decoding Reverse Voice Channel data. (Data returned by query. Refer to 7-7-2.)

STOP

Stops decoding Reverse Voice Channel data.

CHANnel n

Selects Reverse Voice Channel to monitor. Range of n is 1 to 1023 (800 to 900 not used).

7-7-2 REVERSE VOICE CHANNEL DECODE DATA

RVC:

AUTHu?

Returns AUTHU used in Unique Challenge Order Confirmation (18 bit value).

DIGITS?

Returns up to 32 digits (string).

ESN?

Returns Electronic Serial Number (32 bit value).

LOCAL_MT?

Returns Local Control (Local Control message)/Message Type (five bit value).

ORDERCD?

Returns Order Code (five bit value).

ORDQ?

Returns Order Qualifier (three bit value).

RANDbs?

Returns RANDBS used in Base Station Challenge Order (32 bit value).

TORDer?

Returns combination of the T and Order Fields (string):

CALLED ADDR ORDER CNF PAGE RESP SNR RES

ADDENDUM TO SECTION 7-7

7-7A RVC

RVC:

CONFigure:

USER

[RVC:CONFigure:USER]

This command is identical to the **RVC:SETup** command except that it selects the USER screen.

NONE

[RVC:CONFigure:NONE]

This command is also identical to the RVC:SETup command except that it does not select a screen.

TORDER?

[RVC:TORDER?]

New order for RVC is:

RELEASE

7-8 REVERSE DIGITAL TRAFFIC CHANNEL (RDTC) MONITOR COMMANDS

7-8-1 REVERSE DIGITAL TRAFFIC CHANNEL CONTROL

RDTC:

SETup

Sets up the FM/AM-1600CSA as when entering the Reverse Digital Traffic Channel Screen. (Screen is not displayed.)

STARt

Starts decoding Reverse Digital Traffic Channel data. (Data returned by query. Refer to 7-8-2.)

STOP

Stops decoding Reverse Digital Traffic Channel data.

CHANnel n

Selects Reverse Digital Traffic Channel to monitor. Range of n is 1 to 1023 (800 to 900 not used).

SLOT n

Selects Timeslot. Range of n is 1 to 3.

REMote:

STARt

Monitoring stops and VSELP data is redirected as ASCII characters out RS-232 Connector. (Baud Rate should be set to 38400 prior to command execution to allow RS-232 to keep up with data received.) Each line contains 54 ASCII Characters representing 27 bytes, followed by a carriage return. Refer to Table 7-1.

STOP

Stops redirection of VSELP data out RS-232 Connector.

R0?

Returns the VSELP frame energy value (0 to 31).

Byte	Description	Byte	Description	Byte	Description
RO	Frame Energy	LPC9	9th Reflection Coefficient	CODE1_4	1st Code,I,4th Subframe
LPC1	1st Reflection Coefficient	LPC10	10th Reflection Coefficient	CODE2_1	2nd Code,H,1st Subframe
LPC2	2nd Reflection Coefficient	LAG_1	Lag,1st Subframe	CODE2_2	2nd Code,H,2nd Subframe
LPC3	3rd Reflection Coefficient	LAG_2	Lag,2nd Subframe	CODE2_3	2nd Code,H,3rd Subframe
LPC4	4th Reflection Coefficient	LAG_3	Lag,3rd Subframe	CODE2_4	2nd Code,H,4th Subframe
LPC5	5th Reflection Coefficient	LAG_4	Lag,4th Subframe	GSP0_1	GSP0P1 Code,1st Subframe
LPC6	6th Reflection Coefficient	CODE1_1	1st Code,I,1st Subframe	GSP0_2	GSP0P1 Code,2nd Subframe
LPC7	7th Reflection Coefficient	CODE1_2	1st Code,I,2nd Subframe	GSP0_3	GSP0P1 Code,3rd Subframe
LPC8	8th Reflection Coefficient	CODE1_3	1st Code,I,3rd Subframe	GSP0_4	GSP0P1 Code,4th Subframe

Table 7-1 Speech Parameter (27 bytes)

7-8-2 REVERSE DIGITAL TRAFFIC CHANNEL DECODE DATA

RDTC:FACCH: queries pertain to the blank and burst Fast Associated Control Channel (FACCH). RDTC:SACCH: queries pertain to the continuous Slow Associated Control Channel (SACCH).

RDTC:

FACCH:

AMT?

Returns Acknowledge Message Type (string):

ALERT AUDIT HANDOFF

LC MAINTNC RELEASE STOP MEAS

AUTHU?

Returns AUTHU used in Unique Challenge Order Confirmation (18 bit value).

BER?

Returns Bit Error Rate (three bit value). Refer to Table 7-2.

Bit Value	BER Interval (%)	Bit Value	BER Interval (%)
0	0.00 to 0.01	4	1.0 to 2.0
†	0.01 to 0.1	5	2.0 to 4.0
2	0.1 to 0.5	6	4.0 to 8.0
3	0.5 to 1.0	7	≥8.0

Table 7-2 BER Bit Definition

CALLED:

NUM?

Returns number of Called Party (string).

PLANId?

Returns Called Party Numbering Plan Identification (four bit value).

SPare?

Returns value of Called Party Number spare bit (one bit value).

TYpe?

Returns Called Party Number Type (three bit value).

CALLING:

NUM?

Returns number of Calling Party (string).

PLANIA?

Returns Calling Party Numbering Plan Identification (four bit value).

SPare?

Returns value of Calling Party Number spare bits (five bit value).

TYpe?

Returns Calling Party Number Type (three bit value).

FACCH:

CM?

Returns Call Mode (five bit value).

DIC?

Returns the Delay Interval Compensation (one bit value).

DIGits?

Returns up to 32 digits (string).

DMAC?

Returns Digital Mobile Attenuation Code (four bit value).

DTX?

Returns Discontinuous Transmission (one bit value).

ESN?

Returns Electronic Serial Number (32 bit value).

FI2

Returns Feature Indicator (four bit value).

KF?

Returns Keypad Facility (32 digits).

LDP?

Returns Last Decoded Parameter (four bit value).

MEM?

Returns Memory Encryption Mode (one bit value).

MSGtype?

Returns Message Type received from Mobile Station (string):

CHAN QUAL1	MEAS ACK	RELEASE
CHAN QUAL2	MOBILE ACK	SBDTMF
CONNECT	PLC ACK	SCDTMF
FLASH	PU ACK	STATUS
FLASH ACK		

NV?

Returns Numbers of Values (string of numbers, one for each optional information element in the message, with each number derived from the corresponding six bit value).

PD?

Returns the Protocol Discriminator (two bit value).

PT?

Returns Parameter Types (string of numbers, one for each optional information element in the message, with each number derived from the corresponding six bit value).

RANDBS?

Returns RANDBS used in the Base Station Challenge Order (32 bit value).

FACCH:

RFCHAN? n

Returns RF Channel (1 to 1023) for the selected index. Range of n is 0 to 11.

RL?

Returns Remaining Length (six bit value).

RN?

Returns Request Number (four bit value).

RR?

Returns Release Reason (four bit value).

RSSI?

Returns Received Signal Strength Indicator (five bit value) for the selected index. (0 indicates -113 dBm and 31 indicates -51 dBm.) Range of n (index) is 0 to 11.

RSSIC?

Returns Received Signal Strength Indicator (five bit value) of Current RF Channel. (0 indicates -113 dBm and 31 indicates -51 dBm.)

SSDUP?

Returns Shared Secret Data Update (one bit value).

TA?

Returns Time Alignment offset (five bit value).

TERMINT?

Returns Terminal Information of Mobile Station (32 bit value).

VPM2

Returns Voice Privacy Mode (one bit value).

SACCH:

AMT?

Returns Acknowledge Message Type (string):

ALERT AUDIT HANDOFF

LC MAINTNC RELEASE STOP MEAS

Returns AUTHU used in Unique Challenge Order Confirmation (18 bit value).

BER?

Returns Bit Error Rate (three bit value). Refer to Table 7-2.

CALLED:

NIIM?

Returns number of Called Party (string).

PLANId?

Returns Called Party Numbering Plan Identification (four bit value).

SACCH:

CALLED:

SPare?

Returns value of Called Party Number spare bit (one bit value).

TYpe?

Returns Called Party Number Type (three bit value).

CALLING:

NUM?

Returns number of Calling Party (string).

PLANId?

Returns Calling Party Numbering Plan Identification (four bit value).

SPare?

Returns value of Calling Party Number spare bits (five bit value).

TYpe?

Returns Calling Party Number Type (three bit value).

CM₂

Returns Call Mode (five bit value).

DIC?

Returns Delay Interval Compensation (one bit value).

DIGITS?

Returns up to 32 digits (string).

DMAC?

Returns Digital Mobile Attenuation Code (four bit value).

DTX?

Returns Discontinuous Transmission (one bit value).

ESN?

Returns Electronic Serial Number (32 bit value).

FI?

Returns Feature Indicator (four bit value).

transported that we consider a great months of the constant of the state of the state of the state of the constant of the KF?

Returns Keypad Facility (32 digits).

LDP?

Returns Last Decoded Parameter (four bit value).

MEM?

Returns Memory Encryption Mode (one bit value).

SACCH:

MSGtvpe?

Returns Message Type received from Mobile Station (string):

CHAN QUAL1 CHAN QUAL2 CONNECT FLASH FLASH ACK MEAS ACK MOBILE ACK PLC ACK PU ACK RELEASE SBDTMF SCDTMF STATUS

NV?

Returns Numbers of Values (string of numbers, one for each optional information element in the message, with each number derived from the corresponding six bit value).

PD?

Returns the Protocol Discriminator (two bit value).

PT?

Returns Parameter Types (string of numbers, one for each optional information element in the message, with each number derived from the corresponding six bit value).

RANDBS?

Returns RANDBS used in the Base Station Challenge Order (32 bit value).

RFCHAN? n

Returns RF Channel (1 to 1023) for the selected index. Range of n is 0 to 11.

RL?

Returns Remaining Length (six bit value).

RN?

Returns Request Number (four bit value).

RR?

Returns Release Reason (four bit value).

RSSI? r

Returns Received Signal Strength Indicator (five bit value) for selected index. (0 indicates -113 dBm and 31 indicates -51 dBm.) Range of n (index) is 0 to 11.

RSSIC2

Returns Received Signal Strength Indicator (five bit value) of Current RF Channel. (0 indicates -113 dBm and 31 indicates -51 dBm.)

SSDUP?

Returns Shared Secret Data Update (one bit value).

TA?

Returns Time Alignment offset (five bit value).

TERMinf?

Returns Terminal Information of Mobile Station (32 bit value).

VPM?

Returns Voice Privacy Mode (one bit value).

ADDENDUM TO SECTION 7-8

7-8A RDTC

RDTC:

CONFigure:

USER

[RDTC:CONFigure:USER]

This command is identical to the RDTC:SETup command except that it selects the USER screen.

NONE

[RDTC:CONFigure:NONE]

This command is also identical to the RDTC:SETup command except that it does not select a screen.

FACCH: or SACCH:

MSGtype?

[FACCH: or SACCH:MSGtype?]

Add the following message types.

CHAN QUAL3

SOC

CHAN QUAL4

BSMC

HYPER MEAS ACK

R-DATA

CAPABILITY RESP

R-DATA REJECT

CAPABILITY REQ

R-DATA ACCEPT

RFCHAN? n

[FACCH: or SACCH:RFCHAN?]

Returns current value of RFCHAN (8 bit value) indexed by n. Range of n is 0 to 23.

RSSI? n

[FACCH: or SACCH:RSSI?]

Returns current value of RSSI (8 bit value) indexed by n. Range of n is 0 to 23.

AMT?

[FACCH: or SACCH:AMT?]

Add the following message types.

DTC HANDOFF

TASK?

[FACCH: or SACCH:TASK?]

Returns current value of Task Status (3 bit value).

FACCH: or SACCH:

RTRANSaction?

[RDTC:FACCH: or SACCH:RTRANSaction?]

Returns current value of R-Transaction Identifier (8 bit value).

RDATA_UNIT:

LENGth?

[RDTC:FACCH: or SACCH:RDATA_UNIT:LENGth?]

Returns current value of R-Data Unit Extended Remaining Length (8 bit value).

HLP:

IDentifier?

[RDTC:FACCH: or SACCH:RDATA_UNIT:HLP:IDentifier?]

Returns current value of R-Data Unit Higher Layer Protocol Identifier (8 bit value).

DATA? n

[RDTC:FACCH: or SACCH:RDATA_UNIT:HLP:DATA?]

Returns current value of R-Data Unit Higher Layer Protocol Data Unit (8 bit value) indexed by n. Range of n is 0 to 254.

MESSage:

CENTer:

LENGth?

[RDTC:FACCH: or SACCH:MESSage:CENTer:LENGth?]

Returns current value of Message Center Address Extended Remaining Length (8 bit value).

TYPE?

[RDTC:FACCH: or SACCH:MESSage:CENTer:TYPE?]

Returns current value of Message Center Address Type of Number (3 bit value).

PLANId?

[RDTC:FACCH: or SACCH:MESSage:CENTer:PLANid?]

Returns current value of Message Center Address Number Plan Identification (4 bit value).

ENCoding?

[RDTC:FACCH: or SACCH:MESSage:CENTer:ENCoding?]

Returns current state of Message Center Address Encoding (1 bit value).

ADDRess?

[RDTC:FACCH: or SACCH:MESSage:CENTer:ADDRess?]

Returns current string value of Message Center Address (ASCII string).

FACCH: or SACCH:

USER:

DEST:

LENGth?

[RDTC:FACCH: or SACCH:USER:DEST:LENGth?]

Returns current value of User Destination Address Extended Remaining Length (8 bit value).

TYPE?

[RDTC:FACCH: or SACCH:USER:DEST:TYPE?]

Returns current value of User Destination Address Type of Number (3 bit value).

PLANId?

[RDTC:FACCH: or SACCH:USER:DEST:PLANId?]

Returns current value of User Destination Address Number Plan Identification (4 bit value).

ENCoding?

[RDTC:FACCH: or SACCH:USER:DEST:ENCoding?]

Returns current state of User Destination Address Encoding (1 bit value).

ADDRess?

[RDTC:FACCH: or SACCH:USER:DEST:ADDRess?]

Returns current string value of User Destination Address (ASCII string).

SUBaddress:

LENGth?

[RDTC:FACCH: or SACCH:USER:DEST:SUBaddress:LENGth?]

Returns current value of User Destination Subaddress Extended Remaining length (8 bit value).

ODD EVEN?

[RDTC:FACCH: or SACCH:USER:DEST:SUBaddress:ODD_EVEN?]

Returns current state of User Destination Subaddress Odd/Even Indicator (1 bit value).

TYPE?

[RDTC:FACCH: or SACCH:USER:DEST:SUBaddress:TYPE?]

Returns current value of User Destination Type of Subaddress (3 bit value).

REServed?

[RDTC:FACCH: or SACCH:USER:DEST:SUBaddress:REServed?]

Returns current value of User Destination Subaddress Reserved bits (4 bit value).

FACCH: or SACCH:

USER:

DEST:

SUBaddress:

ADDRess? n

[RDTC:FACCH: or SACCH:USER:DEST:SUBaddress:ADDRess?]

Returns current value of User Destination Subaddress (8 bit value) indexed by n. Range of n is 0 to 19.

ORIG:

LENGth?

[RDTC:FACCH: or SACCH:USER:ORIG:LENGth?]

Returns current value of User Originating Address Extended Remaining Length (8 bit value).

TYPE?

[RDTC:FACCH: or SACCH:USER:ORIG:TYPE?]

Returns current value of User Originating Address Type of Number (3 bit value).

PLANId?

[RDTC:FACCH: or SACCH:USER:ORIG:PLANId?]

Returns current value of User Originating Address Number Plan Identification (4 bit value).

ENCoding?

[RDTC:FACCH: or SACCH:USER:ORIG:ENCoding?]

Returns current state of User Originating Address Encoding (1 bit value).

ADDRess?

[RDTC:FACCH: or SACCH:USER:ORIG:ADDRess?]

Returns current string value of User Originating Address (ASCII string).

SUBaddress:

LENGth?

[RDTC:FACCH: or SACCH:USER:ORIG:SUBaddress:LENGth?]

Returns current value of User Originating Subaddress Extended Remaining length (8 bit value).

ODD EVEN?

[RDTC:FACCH: or SACCH:USER:ORIG:SUBaddress:ODD_EVEN?]

Returns current state of User Originating Subaddress Odd/Even Indicator (1 bit value).

FACCH: or SACCH:

USER:

ORIG:

SUBaddress:

TYPE?

[RDTC:FACCH: or SACCH:USER:ORIG:SUBaddress:TYPE?]

Returns current value of User Originating Type of Subaddress (3 bit value).

REServed?

[RDTC:FACCH: or SACCH:USER:ORIG:SUBaddress:REServed?]

Returns current value of User Originating Subaddress Reserved bits (4 bit value).

ADDRess? n

[RDTC:FACCH: or SACCH:USER:ORIG:SUBaddress:ADDRess?]

Returns current value of User Originating Subaddress (8 bit value) indexed by n. Range of n is 0 to 19.

PRESentation:

LENGth?

[RDTC:FACCH: or SACCH:USER:ORIG:PRESentation:LENGth?]

Returns current value of User Originating Address Presentation Indicator Extended Remaining Length (8 bit value).

017

[RDTC:FACCH: or SACCH:USER:ORIG:PRESentation:PI?]

Returns current value of User Originating Address Presentation Indicator (2 bit value).

SI?

[RDTC:FACCH: or SACCH:USER:ORIG:PRESentation:SI?]

Returns current value of User Originating Address Screening Indicator (2 bit value).

REServed?

[RDTC:FACCH: or SACCH:USER:ORIG:PRESentation:REServed?]

Returns current value of User Originating Address Presentation Indicator reserved bits (4 bit value).

RCAUSE?

[RDTC:FACCH: or SACCH:RCAUSE?]

Returns current value of R-Cause (8 bit value).

PV?

[RDTC:FACCH: or SACCH:PV?]

Returns current value of Protocol Version (8 bit value).

FACCH: or SACCH:

MAP:

VPM?

[RDTC:FACCH: or SACCH:MAP:VPM?]

Returns current value of Voice Privacy Mode Map (4 bit value).

CODER?

[RDTC:FACCH: or SACCH:MAP:CODER?]

Returns current value of Voice Coder Map (6 bit value).

MEA:

DOMAIN?

[RDTC:FACCH: or SACCH:MAP:MEA:DOMAIN?]

Returns current value of Message Encryption Algorithm map domain (8 bit value).

ALGORIthms? n

[RDTC:FACCH: or SACCH:MAP:MEA:ALGORithms?]

Returns current value of Message Encryption Algorithms (4 bit value) indexed by n. Range of n is 0 to 7.

MEK?

[RDTC:FACCH: or SACCH:MAP:MEK?]

Returns current value of Message Encryption Key Map (4 bit value).

ARQ?

[RDTC:FACCH: or SACCH:MAP:ARQ?]

Returns current state of FACCH/SACCH ARQ Map (1 bit value).

SMS?

[RDTC:FACCH: or SACCH:MAP:SMS?]

Returns current value of SMS Map (2 bit value).

SOC?

[RDTC:FACCH: or SACCH:SOC?]

Returns current value of SOC (12 bit value).

BSMC?

[RDTC:FACCH: or SACCH:BSMC?]

Returns current value of BSMC (8 bit value).

FACCH: or SACCH:

SUPPort:

IRA?

[RDTC:FACCH: or SACCH:SUPPort:IRA?]

Returns current state of IRA Support (1 bit value).

FREQuency:

BANDS?

[RDTC:FACCH: or SACCH:SUPPort:FREQuency:BANDS?]

Returns current value of Supported Frequency Bands (8 bit value).

ANAlog?

[RDTC:FACCH: or SACCH:SUPPort:ANAlog?]

Returns current state of 800 MHz Analog Speech Support (1 bit value).

CUSTOM:

LENGth?

[RDTC:FACCH: or SACCH:CUSTOM:LENGth?]

Returns current value of Length of custom control in octets (8 bit value).

CONTrol? n

[RDTC:FACCH: or SACCH:CUSTOM:CONTrol?]

Returns current value of Custom Control (8 bit value) indexed by n. Range of n is 0 to 255.

HYPERband:

NUMBer?

[RDTC:FACCH: or SACCH:HYPERband:NUMBer?]

Returns current value of Number of Hyperband Channels (5 bit value).

BAND? n

[RDTC:FACCH: or SACCH:HYPERband:BAND?]

Returns current value of Hyperband band (2 bit value) indexed by n. Range of n is 0 to 23.

CHANnel? n

[RDTC:FACCH: or SACCH:HYPERband:CHANnel?]

Returns current value of Hyperband Channel (11 bit value) indexed by n. Range of n is 0 to 23.

•			
			·

7-9 CELL SITE SIMULATION COMMANDS

Refer to 9-8 for command guidelines and programming examples.

7-9-1 GENERAL

CSS:

SETup

Sets up the FM/AM-1600CSA as when entering the first Cell Site Simulation screen. (Screen is not displayed and the FM/AM-1600S is not transmitting at this point.)

STARt

Starts Cell Site Simulation transmission (Overhead Message on FOCC).

STOP

Stops Cell Site Simulation transmission.

CHANnel n

Selects Forward Control Channel for sending Overhead Messages. Range of n is 1 to 1023.

RFLvI n

Sets RF Output Level, in dBm, of Overhead Message. Range of n is -30.0 to -127.0.

7-9-2 FOCC OVERHEAD MESSAGE PARAMETERS

CSS:

FOCC:

AUTH n

Sets Authentication bit (1 or 0).

AUTH?

Returns Authentication bit setting.

BIn

Sets Busy-Idle bit (1 or 0).

B 1?

Returns Busy-Idle bit setting.

CMAC r

Sets Control Mobile Attenuation Code. Range of n is 0 to 7.

CMAC?

Returns Control Mobile Attenuation Code setting.

CMAX n

Sets maximum Number of Channels to be scanned by Mobile Station when accessing a system. Range of n is 1 to 32.

CMAX?

Returns maximum Number of Channels to be scanned by Mobile Station setting.

CSS:

FOCC:

DCC n

Sets Digital Color Code. Range of n is 0 to 3.

DCC?

Returns Digital Color Code setting.

En

Sets Extended Address bit (1 or 0).

E?

Returns Extended Address bit setting.

EP n

Sets Extended Protocol bit (1 or 0).

EP?

Returns Extended Protocol bit setting.

Nn

Sets Number of Paging Channels to be scanned by Mobile Station. Range of n is 1 to 32.

N?

Returns Number of Paging Channels to be scanned by Mobile Station setting.

PCI n

Sets Protocol Capability Indicator (1 or 0).

PCI?

Returns Protocol Capability Indicator setting.

RCF n

Sets Read Control Filler bit (1 or 0).

RCF?

Returns Read Control Filler bit setting.

REGH n

Sets Home Registration bit (1 or 0).

REGH?

Returns Home Registration bit setting.

REGR /

Sets Roaming Registration bit (1 or 0).

REGR?

Returns Roaming Registration bit setting.

CSS:

FOCC:

Sn

Sets Serial Number bit (1 or 0).

S?

Returns Serial Number bit setting.

SDCC1 n

Sets Supplementary Digital Color Code 1. Range of n is 0 to 3.

SDCC1?

Returns Supplementary Digital Color Code 1 setting.

SDCC2 n

Sets Supplementary Digital Color Code 2. Range of n is 0 to 3.

SDCC2?

Returns Supplementary Digital Color Code 2 setting.

SID n

Sets System Identification Number (14 most significant digits). Range of n is 0 to 32767.

SID?

Returns System Identification Number setting.

WFOM /

Sets Wait For Overhead Message bit (1 or 0).

WFOM?

Returns Wait For Overhead Message bit setting.

7-9-3 CALLING SETUP

CSS:

CALL:

CHANnel n

Selects Digital Traffic Channel or Voice Channel the call to the Mobile Station is assigned to. Range of n is 1 to 1023.

CHANnel?

Returns Digital Traffic Channel or Voice Channel the call to the Mobile Station is assigned to (1 to 1023).

DEViation n

Sets SAT Deviation in kHz. Range of n is 0.0 to 4.0.

DEViation?

Returns SAT Deviation in kHz setting.

DMAC n

Selects Digital Mobile Attenuation Code. Range of n is 0 to 7.

DMAC?

Returns Digital Mobile Attenuation Code setting.

DVCC n

Selects Digital Verification Color Code. Range of n is 0 to 255.

DVCC2

Returns Digital Verification Color Code setting.

EF n

Sets Extended Protocol Forward Channel Indicator (1 or 0).

EF?

Returns Extended Protocol Forward Channel Indicator setting.

MEM r

Sets Message Encryption Mode (1 or 0).

MEM?

Returns Message Encryption Mode setting.

MIN "n"

Selects Mobile Identification Number to call. The Mobile Identification Number (n) is entered as a string, with quotation marks.

Example: CSS:CALL:MIN "316/522-4981"

MIN?

Returns MIN currently selected.

PMn

Sets Privacy Mode bit (1 or 0).

CSS:

CALL:

PM?

Returns Privacy Mode bit setting.

SAT n

Sets Supervisory Audio Tone in Hz. Range of n is 5965 to 6035.

SAT?

Returns Supervisory Audio Tone setting.

SLOT r

Selects Timeslot. Range of n is 1 to 3.

SLOT?

Returns Timeslot setting.

TYPE n

Selects channel type (1 [Digital] or 0 [Analog]).

TYPE?

Returns channel type.

VMAC n

Selects Voice Mobile Attenuation Code. Range of n is 0 to 7.

VMAC?

Returns Voice Mobile Attenuation Code setting.

7-9-4 PROCESS AND HANDOFF

CSS:

CALL:

PROCess:

ASSIGNment

Sends an initial channel designation command to the Mobile Station. After sending the channel designation, the FM/AM-1600CSA changes the channel and mode to transmit and receive on the assigned channel.

MOBINIT

Sets up the FM/AM-1600CSA for a call initiated by the Mobile Station. The Busy-Idle bit changes from a 1 to a 0 at the correct time to enable the access to occur. An access sends an SRQ=1 on the GPIB (if GPIB:MASK 1 had been initiated before the CSS:CALL:PROCess:MOBINIT) and sets the status bit returned by the CSS:RECC:STATus? query.

PAGE

Simulates a Base Station (Cellsite) initiated call.

REGistration

Causes the Mobile Station to send a Registration message. An access by the Mobile Station sends an SRQ=1 on the GPIB (if GPIB:MASK 1 had been initiated before the CSS:CALL:PROCess:REGistration) and sets the status bit returned by the CSS:RECC:STATus? query. The RECC:TORDer? query verifies the registration order was or was not received.

FVC:

HANDoff

Sends an analog to analog handoff order to the Mobile Station. The CSS:FVC:HAND:CHAN n command specifies the new analog Voice Channel. After the handoff order, the FM/AM-1600CSA changes to the specified Voice Channel.

SLOT1

Sends an analog to digital handoff order (to Timeslot 1) to the Mobile Station. The CSS:FVC:HAND:CHAN n command specifies the new Digital Traffic Channel. After the handoff order, the FM/AM-1600CSA changes to the specified Digital Traffic Channel.

SLOT2

Sends an analog to digital handoff order (to Timeslot 2) to the Mobile Station. The CSS:FVC:HAND:CHAN n command specifies the new Digital Traffic Channel. After the handoff order, the FM/AM-1600CSA changes to the specified Digital Traffic Channel.

SLOT3

Sends an analog to digital handoff order (to Timeslot 3) to the Mobile Station. The **CSS:FVC:HAND:CHAN** *n* command specifies the new Digital Traffic Channel. After the handoff order, the FM/AM-1600CSA changes to the specified Digital Traffic Channel.

CSS:

CALL:

PROCess:

FDTC:

HANDoff?

Performs a digital to digital (CSS:FDTC:TI? \neq 0), or digital to analog (CSS:FDTC:TI? = 0) handoff and returns a 1 if successful or a 0 if not successful. If successful, the FM/AM-1600CSA changes to the channel specified by the CSS:FDTC:HAND:CHAN n command.

RECC:

STATus?

Returns access with the Mobile Station status (0 indicates no access has occurred; 1 indicates an access has occurred).

7-9-5 FORWARD VOICE CHANNEL (FVC)

Data commands set the data in the messages and order commands send the orders (messages).

A. FVC ORDERS

CSS:

FVC:

ORDER:

ALERT

Sends the Alert message.

ALERTWInfo

Sends the Alert with Information message.

AUDIT

Sends the Audit order.

BSCHALCON

Sends the Base Station Challenge Confirmation message.

CALLMODEACK

Sends the Call Mode Acknowledgment message.

DISDTMF

Sends the Disable DTMF message.

DISMEM

Sends the Message Encryption Mode order with disable indication.

ENAMEN

Sends the Message Encryption Mode order with enable indication.

FLASHWinfo

Sends the Flash with Information message.

HANDoff

Sends the Handoff message. (For complete handoff testing, use the CSS:CALL:PROCess commands.)

LC

Sends the Local Control message.

MAINTenance

Sends the Maintenance message.

MSGWTG

Sends the Message Waiting message.

PAGE

Sends the Page order.

CSS:

FVC:

ORDER:

PU

Sends the Parameter Update message.

PWRLVL

Sends the Power Level message.

RELease

Sends the Release message.

SALERT

Sends the Stop Alert message.

SLOT1

Sends the Handoff to Digital Traffic Channel on Timeslot 1 message. (For complete handoff testing, use the CSS:CALL:PROCess commands.)

SLOT2

Sends the Handoff to Digital Traffic Channel on Timeslot 2 message. (For complete handoff testing, use the CSS:CALL:PROCess commands.)

SLOTS

Sends the Handoff to Digital Traffic Channel on Timeslot 3 message. (For complete handoff testing, use the CSS:CALL:PROCess commands.)

SNDAddi

Sends the Send Called Address message.

SNRrea

Sends the Serial Number Request message.

SSDUP

Sends the Shared Secret Data Update message.

UCHAL

Sends the Unique Challenge message.

B. FVC DATA FIELDS

CSS:

FVC:

AUTHBS n

Sets the AUTHBS value. Range of n is 0 to 262143.

AUTHBS?

Returns AUTHBS value setting.

CSS:

FVC:

CALLING:

NUM "n"

Sets Calling Party Number. The number n is entered as a string, with quotation marks (i.e., "316/522-4981").

NUM?

Returns Calling Party Number setting (string).

PIn

Sets Calling Party Number Presentation Indicator. Range of n is 0 to 3.

PI?

Returns Calling Party Number Presentation Indicator setting.

SIn

Sets Calling Party Screening Indicator. Range of n is 0 to 3.

SI?

Returns Calling Party Screening Indicator setting.

DMAC n

Sets Digital Mobile Attenuation Code. Range of n is 0 to 10.

DMAC2

Returns Digital Mobile Attenuation Code setting.

DVCC n

Sets Digital Verification Color Code. Range of n is 1 to 255.

DVCC?

Returns Digital Verification Color Code setting.

FF /

Sets Extended Protocol Forward Channel Indicator (0 or 1).

EF?

Returns Extended Protocol Forward Channel Indicator setting.

ENABLE:

VOICEPrivacy n

Sets the Voice Privacy in the Call Mode Acknowledgment message (0 or 1).

VOICEPrivacy?

Returns the Voice Privacy setting.

FVC:

HANDoff:

CHANnel n

Sets analog Voice or Digital Traffic Channel for Handoff. Range of n is 1 to 1023. (Use the CSS:CALL:PROCess commands to initiate Handoff.)

CHANnel?

Returns Channel for Handoff setting.

LOCAL

Sets the Local Control field used in the Local Control message. Range of n is 0 to 31.

LOCAL?

Returns the Local Control field setting.

MEM n

Sets Message Encryption Mode bit (0 or 1).

MEM?

Returns Message Encryption Mode bit setting.

MT /

Sets the Message Type field. Range of n is 0 to 31.

AAT?

Returns the Message Type field setting.

PMn

Sets Privacy Mode bit (0 or 1).

PM?

Returns Privacy Mode bit setting.

PSCC n

Sets Present SAT Color Code. Range of n is 0 to 2.

PSCC?

Returns Present SAT Color Code setting.

PWRLVL A

Sets Power Level requested of Mobile Station in the Power Level message. Range of n is 0 to 7.

PWRLVL?

Returns requested Power Level setting.

RANDSSD "n"

Sets the 56 bit Random Number sent in the Shared Secret Data Update message. The number n is entered in hexadecimal as a string, with quotation marks (i.e., "4A59BE232F9C26").

FVC:

RANDSSD?

Returns the Shared Secret Data 56 bit Random Number setting (string).

RANDU n

Sets the 24 bit Random Number sent in the Unique Challenge message. Range of n is 0 to 16777215.

RANDU?

Returns the Unique Challenge 24 bit Random Number setting.

SBI

Sets Shortened Burst Indicator. Range of n is 0 to 3.

SBI?

Returns Shortened Burst Indicator setting.

SCC n

Sets Supervisory Audio Tone Color Code. Range of n is 0 to 2.

SCC?

Returns Supervisory Audio Tone Color Code setting.

SIGNAL:

CADENCE n

Sets the on, off pattern of the Alert tone. Range of n is 0 to 63.

CADENCE?

Returns the Alert tone on, off pattern setting.

PITCH n

Sets the pitch of the Alert tone. Range of n is 0 to 3.

DITCHO

Returns Alert tone pitch setting.

TAn

Sets Time Alignment. Range of n is 0 to 31.

TA?

Returns Time Alignment setting.

VMAC n

Sets Voice Mobile Attenuation Code. Range of n is 0 to 7.

VMAC?

Returns Voice Mobile Attenuation Code setting.

ADDENDUM TO SECTION 7-9-5

7-9-5A FVC

CSS:

FVC:

STARt

[CSS:FVC:STARt]

Starts the 1600CSA transmitting on the Forward Voice Channel.

STOP

[CSS:FVC:STOP]

Stops the Forward Voice Channel.

SAT n

[CSS:FVC:SAT]

Specifies the SAT frequency on the FVC. Range of n is 0 or 5965 to 6035.

SAT?

Returns current value of SAT.

PVI n

[CSS:FVC:PVI]

Enables (n = 1) or disables (n = 0) Protocol Version Indicator.

PVI?

Returns current state of PVI.

HYPERband n

[CSS:FVC:HYPERband]

Specifies Hyperband. Range of n is 0 to 3.

HYPERband?

Returns current value of Hyperband.

ORDER:

RELEASE Winfo

[CSS:FVC:ORDER:RELEASE_Winfo]

Sends the Release with DCCH Information message.

VOICE MSG WTG

[CSS:FVC:ORDER:VOICE_MSG_WTG]

Sends the Voice Message Waiting message.

SMS MSG WTG

[CSS:FVC:ORDER:SMS_MSG_WTG]

Sends the SMS Message Waiting message.

G3_MSG_WTG

[CSS:FVC:ORDER:G3_MSG_WTG]

Sends the G3-Fax Message Waiting message.

FVC:

ORDER:

G3_PAGE[CSS:FVC:ORDER:G3_PAGE]
Sends the Page message (Group 3 Fax).

ASYNC_PAGE
[CSS:FVC:ORDER:ASYNC_PAGE]
Sends the Page message (Async Data).

7-9-6 FORWARD DIGITAL TRAFFIC CHANNEL (FDTC)

Data commands set the data in the messages and order commands send the orders (messages). CSS:FDTC:ENABLE commands enable or disable optional fields. CSS:FDTC:FACCH: commands pertain to the blank and burst Fast Associated Control Channel (FACCH). CSS:FDTC:SACCH: commands pertain to the continuous Slow Associated Control Channel (SACCH).

A. FDTC ORDERS

CSS:

FDTC:

FACCH:

ALERT

Sends the Alert with Information message.

AUDIT

Sends the Audit message.

BSACK

Sends the Base Station Acknowledgment message. The ${\it CSS:FDTC:AMT}\ n$ command sets acknowledgment type.

BSCHALCON

Sends the Base Station Challenge Confirmation message.

FLASH

Sends the Flash with Information message.

FLASHACK

Sends the Flash Acknowledgment message.

HANDoff

Sends the Handoff message. (For complete handoff testing, use the CSS:CALL:PROCess commands.)

LC

Sends the Local Control message.

MAINTenance

Sends the Maintenance message.

MEASure

Sends the Measurement message.

PLC

Sends the Physical Layer Control.

PU

Sends the Parameter Update message.

FDTC:

FACCH:

RELease

Sends the Release message.

SBDA

Sends the Send Burst DTMF Acknowledge message.

SCDA

Sends the Send Continuous DTMF Acknowledge message.

SMEASure

Sends the Stop Measurement message.

SR

Sends the Status Request message.

SSDUP

Sends the Shared Secret Data Update message.

UCHAL

Sends the Unique Challenge message.

SACCH:

ALERT

Sends the Alert with Information message.

AUDIT

Sends the Audit message.

BSACK

Sends the Base Station Acknowledgment message. The ${\it CSS:FDTC:AMT}\ n$ command sets acknowledgment type.

BSCHALCON

Sends the Base Station Challenge Confirmation message.

FLASH

Sends the Flash with Information message.

FLASHACK

Sends the Flash Acknowledgment message.

HANDoff

Sends the Handoff message. (For complete handoff testing, use the CSS:CALL:PROCess commands.)

LC

Sends the Local Control message.

FDTC:

SACCH:

MAINTenance

Sends the Maintenance message.

MEASure

Sends the Measurement message.

PLC

Sends the Physical Layer Control.

PU

Sends the Parameter Update message.

RELease

Sends the Release message.

SBDA

Sends the Send Burst DTMF Acknowledge message.

SCDA

Sends the Send Continuous DTMF Acknowledge message.

SMEASure

Sends the Stop Measurement message.

SR

Sends the Status Request message.

SSDUP

Sends the Shared Secret Data Update message.

UCHAL

Sends the Unique Challenge message.

B. FDTC DATA FIELDS

CSS:

FDTC:

AMT:

CONNect

Acknowledges a Connect message from the Mobile Station.

RELease

Acknowledges a Release message from the Mobile Station.

STATus

Acknowledges a Status message from the Mobile Station.

FDTC:

AMT?

Returns Acknowledge Message Type setting (string).

AUTHBS n

Sets the AUTHBS value. Range of n is 0 to 262143.

AUTHBS?

Returns AUTHBS value setting.

CALLING:

NUM "n"

Sets Calling Party Number. The number n is entered as a string, with quotation marks (i.e., "316/522-4981").

NUM?

Returns Calling Party Number setting (string).

PI

Sets Calling Party Number Presentation Indicator. Range of n is 0 to 3.

PI?

Returns Calling Party Number Presentation Indicator setting.

PLANId n

Sets Calling Party Numbering Plan Identification. Range of n is 0 to 15.

PLANId?

Returns Calling Party Numbering Plan Identification setting.

SIn

Sets Calling Party Screening Indicator. Range of n is 0 to 3.

SIZ

Returns Calling Party Screening Indicator setting.

TYpe n

Sets Calling Party Type. Range of n is 0 to 7.

TYpe?

Returns Calling Party Type setting.

CONTROL n

Sets the Local Control field used in the Local Control message. Range of n is 0 to 31.

CONTROL?

Returns the Local Control field setting.

DIC n

Sets Delay Interval Compensation bit (0 or 1).

FDTC:

DIC?

Returns Delay Interval Compensation bit setting.

DMAC n

Sets Digital Mobile Attenuation Code. Range of n is 0 to 10.

DMAC?

Returns Digital Mobile Attenuation Code setting.

DTX n

Sets Discontinuous Transmission bit (0 or 1).

DTX?

Returns Discontinuous Transmission bit setting.

DVCC r

Sets Digital Verification Color Code. Range of n is 0 to 255.

DVCC?

Returns Digital Verification Color Code setting.

ENABLE:

CALLING:

NUM n

Enables or disables Calling Party Number field (1 or 0).

NUM?

Returns the Calling Party Number Enable setting.

DIC n

Enables or disables Delay Interval Compensation bit (1 or 0).

DIC?

Returns Delay Interval Compensation bit Enable setting.

DMAC n

Enables or disables Digital Mobile Attenuation Code (1 or 0).

DMAC?

Returns Digital Mobile Attenuation Code Enable setting.

DTX n

Enables or disables Discontinuous Transmission bit (1 or 0).

DTX?

Returns Discontinuous Transmission bit Enable setting.

FDTC:

ENABLE:

LDP:

BSACK n

Enables or disables Last Decoded Parameter in Base Station Acknowledgment message (1 or 0).

BSACK?

Returns Last Decoded Parameter Enable setting for BSACK message.

FLASHACK n

Enables or disables Last Decoded Parameter in Flash Acknowledgment message (1 or 0).

FLASHACK?

Returns Last Decoded Parameter Enable setting for FLASHACK message.

SBDA n

Enables or disables Last Decoded Parameter in Send Burst DTMF Acknowledge message (1 or 0).

SBDA?

Returns Last Decoded Parameter Enable setting for SBDA message.

NOMW n

Enables or disables Number of Messages Waiting field (1 or 0).

NOMW?

Returns Number of Messages Waiting field Enable setting.

RFCHAN n,x

Enables or disables selected RF Channel index. Range of n is 0 to 11 (index). Range of x is 1 or 0 (enable or disable).

RFCHAN? n

Returns selected RF Channel index Enable setting. Range of n is 0 to 11.

SIGNAL

Enables or disables Signal field (1 or 0).

SIGNAL?

Returns Signal field Enable setting.

STATUS:

CMODE n

Enables or disables Call Mode field in Status Request message (1 or 0).

CMODE?

Returns Call Mode field Enable setting.

FDTC:

ENABLE:

STATUS:

ESN n

Enables or disables Electronic Serial Number field in Status Request message (1 or 0).

ESN?

Returns Electronic Serial Number field Enable setting.

MEM n

Enables or disables Message Encryption Mode field (1 or 0).

MEM?

Returns Message Encryption Mode field Enable setting.

TIn

Enables or disables Terminal Information field (1 or 0).

TIZ

Returns Terminal Information field Enable setting.

VPM n

Enables or disables Voice Privacy Mode bit (1 or 0).

VPM?

Returns Voice Privacy Mode bit Enable setting.

TA n

Enables or Disables Time Alignment field (1 or 0)

TA?

Returns Time Alignment field Enable setting.

HANDoff:

CHANnel n

Sets analog Voice or Digital Traffic Channel for Handoff. Range of n is 1 to 1023. (Use the **CSS:CALL:PROCess** commands to initiate Handoff.)

CHANnel?

Returns channel for Handoff setting.

LDP n

Sets Last Decoded Parameter. Range of n is 0 to 15.

LDP?

Returns Last Decoded Parameter setting.

FDTC:

MEM n

Sets Message Encryption Mode (0 or 1).

MEM?

Returns Message Encryption Mode setting.

NOMW n

Sets Number of Messages Waiting field. Range of n is 0 to 63.

NOMW?

Returns Number of Messages Waiting field setting.

RANDSSD "n"

Sets the 56 bit Random Number sent in the Shared Secret Data Update message. The number n is entered in hexadecimal as a string, with quotation marks (i.e., "4A59BE232F9C26").

RANDSSD?

Returns the Shared Secret Data 56 bit Random Number setting (string).

RANDU n

Sets the 24 bit Random Number sent in the Unique Challenge message. Range of n is 0 to 16777215.

RANDU?

Returns the Unique Challenge 24 bit Random Number setting.

RATe /

Sets Channel Rate (0 [Full-Rate] or 1 [Half-Rate]).

RATe?

Returns Channel Rate setting.

RFCHAN n.x

Sets selected RF Channel index. Range of n is 0 to 11 (index). Range of x is 1 to 1023 (RF Channel setting).

RFCHAN? n

Returns selected RF Channel index setting. Range of n is 0 to 11.

RNn

Sets Request Number. Range of n is 0 to 15.

RN?

Returns Request Number setting.

SBIn

Sets Shortened Burst Indicator. Range of n is 0 to 3.

SBI?

Returns Shortened Burst Indicator setting.

FDTC:

SIGNAL:

CADENCE n

Sets the on, off pattern of the Alert tone. Range of n is 0 to 63.

CADENCE?

Returns the Alert tone on, off pattern setting.

PITCH n

Sets the pitch of the Alert tone. Range of n is 0 to 3.

PITCHT

Returns Alert tone pitch setting.

SLOT n

Sets Timeslot. Range of n is 1 to 3.

SLOT?

Returns Timeslot setting.

TA

Sets Time Alignment. Range of n is 0 to 31.

TA?

Returns Time Alignment setting.

TI

Sets Timeslot Indicator. Range of n is 0 to 6. (0 is analog.)

T1?

Returns Timeslot Indicator setting.

VPM n

Sets Voice Privacy Mode bit (0 or 1).

VPM?

Returns Voice Privacy Mode bit setting.

ADDENDUM TO SECTION 7-9-6

7-9-6A FDTC

CSS:

FDTC:

STARt

[CSS:FDTC:STARr]
Starts the 1600CSA transmitting on the Forward Digital Traffic Channel.

STOP

[CSS:FDTC:STOP]

Stops the Forward Digital Traffic Channel.

FACCH: or SACCH:

New Message types for the FDTC.

DEDicated:

HANDoff

[CSS:FDTC:FACCH: or SACCH:DEDicated:HANDoff] Sends Dedicated DTC Handoff message.

HYPERband:

MEASure

[CSS:FDTC:FACCH: or SACCH:HYPERband:MEASure] Sends Hyperband Measurement message.

CAPability:

REQuest

[CSS:FDTC:FACCH: or SACCH:CAPability:REQuest] Sends Capability Update Request message.

RESPonse

[CSS:FDTC:FACCH: or SACCH:CAPability:RESPonse] Sends Capability Update Response message.

RDATA:

MESSage

[CSS:FDTC:FACCH: or SACCH:RDATA:MESSage] Sends R-DATA message.

ACCept

[CSS:FDTC:FACCH: or SACCH:RDATA:ACCept]
Sends R-DATA ACCEPT message.

REJect

[CSS:FDTC:FACCH: or SACCH:RDATA:REJect]
Sends R-DATA REJECT message.

FDTC:

FACCH: or SACCH:

SOC

[CSS:FDTC:FACCH: or SACCH:SOC]

Sends SOC Message Delivery message.

BSMC

[CSS:FDTC:FACCH: or SACCH:BSMC]

Sends BSMC Message Delivery message.

RAW x(1), x(2), x(3), x(4), x(5), x(6), ..., x(n)

[CSS:FDTC:FACCH: or SACCH:RAW]

This command is used to generate a user defined message. The parameters used with this command each setup 8 bits of the message. Since each word of a FACCH or SACCH message consists of 48 bits, it takes 6 parameters to make 1 word, 12 to make 2 words,.. etc. Therefore the number of parameters used with this message is variable, but it must be a multiple of 6.

RFCHAN n.m

[CSS:FDTC:RFCHAN]

Specifies RF Channel Number (m) indexed by n. Range of n is 0 to 23; range of m is 1 to 1023.

RFCHAN? n

Returns current value of RFCHAN indexed by n. Range of n is 0 to 23.

PVI n

[CSS:FDTC:PVI]

Enables (n = 1) or disables (n = 0) Protocol Version Indicator.

PVI?

Returns current state of PVI.

DTXControl n

[CSS:FDTC:DTXControl]

Enables (n = 1) or disables (n = 0) DTX Control.

Indicates the DTX mode supported on the channel to which a handoff is occurring.

DTXControl?

Returns current state of DTXControl.

css:

FDTC:

DCCHinfo:

Digital Control Channel Information.

NUMBer n

[CSS:FDTC:DCCHinfo:NUMBer]

Specifies Length of DCCH info content. Range of n is 0 to 2.

NUMBer?

Returns current value of NUMBer.

HYPERband n.m

[CSS:FDTC:DCCHinfo:HYPERband]

Specifies Hyperband (m) indexed by n. Range of n is 0 to 2; range of m is 0 to 3.

HYPERband? n

Returns current value of HYPERband indexed by n. Range of n is 0 to 2.

CHANnel n.m

[CSS:FDTC:DCCHinfo:CHANnel]

Specifies Digital Control Channel Information (m) indexed by n. Range of n is 0 to 2; range of m is 0 to 2047.

CHANnel? n

Returns current value of CHANnel indexed by n. Range of n is 0 to 2.

DVCC n.m

[CSS:FDTC:DCCHinfo:DVCC]

Specifies Digital Verification Color Code (m) indexed by n. Range of n is 0 to 2; range of m is 0 to 255.

DVCC? n

Returns current value of DVCC indexed by n. Range of n is 0 to 2.

MSGWTG:

NUMBer n

[CSS:FDTC:MSGWTG:NUMBer]

Specifies Length of Message Waiting info content. Range of n is 1 to 15.

NUMBer?

Returns current value of NUMBer.

FDTC:

MSGWTG:

MESSage:

TYPE n,m

[CSS:FDTC:MSGWTG:MESSage:TYPE]

Specifies Messages Waiting Type (m) indexed by n. Range of n is 0 to 14; range of m is 0 to 15.

Indicates the type of messages that are waiting..

TYPE? n

Returns current value of TYPE indexed by n. Range of n is 0 to 14.

NUMBer n,m

[CSS:FDTC:MSGWTG:MESSage:NUMBer]

Specifies Number of Messages Waiting (m) indexed by n. Range of n is 0 to 14; range of m is 0 to 63.

Indicates the number of messages associated to the Message Waiting Type.

NUMBer? n

Returns current value of NUMBer indexed by n. Range of n is 0 to 14.

TASK n

[CSS:FDTC:TASK]

Specifies Task Status. Range of n is 0 to 7.

TASK?

Returns current value of TASK.

ATS n

[CSS:FDTC:ATS]

Specifies Assigned Time Slot. Range of n is 0 to 15.

ATS?

Returns current value of ATS.

PV n

[CSS:FDTC:PV]

Specifies Protocol Version. Range of n is 0 to 15.

PV?

Returns current value of PV.

FDTC:

CHANGE:

SOC n

[CSS:FDTC:CHANGE:SOC]

Enables (n = 1) or disables (n = 0) System Operator Code Change Indicator.

Indicates whether or not the SOC associated with the current digital traffic channel is different from that associated with the digital traffic channel being assigned.

SOC?

Returns the value of SOC.

BSMC n

[CSS:FDTC:CHANGE:BSMC]

Enables (n = 1) or disables (n = 0) Base Station Manufacturer Code Change Indicator.

Indicates whether or not the BSMC associated with the current digital traffic channel is different from that associated with the digital traffic channel being assigned (0-1).

BSMC?

Returns current state of BSMC.

DELTA:

TIME n

[CSS:FDTC:DELTA:TIME]

Specifies Delta Time. Range of n is 0 to 2047.

Indicates timing advance in half symbols that shall be applied, relative to the current mobile station transmit time, on the assigned digital traffic channel.

TIME?

Returns current value of TIME.

VMI:

Used to provide voice mode operation information for the assigned digital traffic channel.

VC n

[CSS:FDTC:VMI:VC]

Specifies Voice Code. Range of n is 0 to 7.

VC?

Returns current value of VC.

FDTC:

VMI:

PM_V n

[CSS:FDTC:VMI:PM_V]

Specifies Voice Privacy Mode. Range of n is 0 to 7.

PM V?

Returns current value of PM_V.

DPM n

[CSS:FDTC:DPM]

Enables (n = 1) or disables (n = 0) Data Privacy Mode.

DPM?

Returns current state of DPM.

MEMC:

Identifies the message encryption mode of a mobile station.

MEA n

[CSS:FDTC:MEMC:MEA]

Specifies Message Encryption Mode C Algorithm. Range of n is 0 to 3.

MEA?

Returns current value of MEA.

MED n

[CSS:FDTC:MEMC:MED]

Specifies Message Encryption Mode C Domain. Range of n is 0 to 3.

MED?

Returns current value of MED.

MEK n

[CSS:FDTC:MEMC:MEK]

Specifies Message Encryption Mode C Key. Range of n is 0 to 3.

MEK?

Returns current value of MEK.

FDTC:

MAP:

Identifies the forms of voice privacy supported by the BMI.

VPM n

[CSS:FDTC:MAP:VPM]

Specifies Voice Privacy Mode Map. Range of n is 0 to 15.

VPM2

Returns current value of VPM.

CODER n

[CSS:FDTC:MAP:CODER]

Specifies Voice Coder Map. Range of n is 0 to 63.

CODER?

Returns current value of CODER.

MEA:

DOMAIN n

[CSS:FDTC:MAP:MEA:DOMAIN]

Specifies Message Encryption Algorithm Map Domain. Range of n is 0 to 255.

DOMAIN?

Returns current value of DOMAIN.

ALGORIthms n,m

[CSS:FDTC:MAP:MEA:ALGORithms]

Specifies Message Encryption Algorithm Map (m) indexed by n. Range of n is 0 to 7; range of m is 0 to 15.

ALGORithms? n

Returns current value of ALGORithms.

MEK n

[CSS:FDTC:MAP:MEK]

Specifies Message Encryption Key Map. Range of n is 0 to 15.

MEK?

Returns current value of MEK.

ARQ n

[CSS:FDTC:MAP:ARQ]

Enables (n = 1) or disables (n = 0) FACCH/SACCH ARQ Map.

ARQ?

Returns current state of ARQ.

FDTC:

MAP:

SMS n

[CSS:FDTC:MAP:SMS]
Specifies SMS Map. Range of n is 0 to 3.

SMS?

Returns current value of SMS.

SUPPort:

IRA n

[CSS:FDTC:SUPPort:IRA]

Enables (n = 1) or disables (n = 0) IRA Support.

Indicates whether or not a mobile station or BMI supports IRA address encoding in the address field in the Message Center Address.

IRA?

Returns current state of IRA.

SOC n

[CSS:FDTC:SOC]

Enables (n = 1) or disables (n = 0) System Operator Code.

SOC?

Returns current state of SOC.

BSMC n

[CSS:FDTC:BSMC]

Enables (n = 1) or disables (n = 0) Base Station Manufacturer Code.

BSMC?

Returns current state of BSMC.

RTRANSaction n

[CSS:FDTC:RTRANSaction]

Specifies R-Transaction Identifier. Range of n is 0 to 255.

Used to uniquely associate a R-DATA ACCEPT or a R-DATA REJECT message with a specific R-DATA message.

RTRANSaction?

Returns current value of RTRANSaction.

FDTC:

RDATA_UNIT:

Used to carry the higher layer SMS protocol data unit.

LENGth n

[CSS:FDTC:RDATA_UNIT:LENGth]

Specifies Length of the R-Data Unit info content. Range of n is 1 to 256.

LENGth?

Returns current value of LENGth.

HLP:

IDentifier n

[CSS:FDTC:RDATA_UNIT:HLP:IDentifier]

Specifies Higher Layer Protocol Identifier. Range of n is 0 to 255.

IDentifier?

Returns current value of IDentifier.

DATA n,m

[CSS:FDTC:RDATA_UNIT:HLP:DATA]

Specifies Higher Layer Protocol Data Unit (m) indexed by n. Range of n is 0 to 255; range of m is 0 to 255.

DATA? n

Returns current value of DATA. Range of n is 0 to 255.

MESSage:

CENTer:

TYPE n

[CSS:FDTC:MESSage:CENTer:TYPE]

Specifies Type of Number. Range of n is 0 to 7.

TYPE?

Returns current value of TYPE.

PLANId n

[CSS:FDTC:MESSage:CENTer:PLANid]

Specifies Numbering Plan Identification. Range of n is 0 to 15.

PLANId?

Returns current value of PLANid.

FDTC:

MESSage:

CENTer:

ENCoding n

[CSS:FDTC:MESSage:CENTer:ENCoding] Enables (n = 1) or disables (n = 0) Address Encoding.

ENCoding?

Returns current state of ENCoding.

ADDRess "n"

[CSS:FDTC:MESSage:CENTer:ADDRess]
Specifies Address (ASCII string).

Up to 60 characters in this field.

ADDRess?

Returns current string value of ADDRess.

USER:

DEST:

Used to identify the user destination address of a MS originated short message.

TYPE n

[CSS:FDTC:USER:DEST:TYPE]

Specifies Type of Number. Range of n is 0 to 7.

TYPE?

Returns current value of TYPE.

PLANId n

[CSS:FDTC:USER:DEST:PLANId]

Specifies Numbering Plan Identification. Range of n is 0 to 15.

PLANId?

Returns current value of PLANid.

ENCoding n

[CSS:FDTC:USER:DEST:ENCoding]

Enables (n = 1) or disables (n = 0) Address Encoding.

ENCoding?

Returns current state of ENCoding.

FDTC:

USER:

DEST:

ADDRess "n"

[CSS:FDTC:USER:DEST:ADDRess]
Specifies Address (ASCII string).

Up to 60 characters may be sent.

ADDRess?

Returns current string value of ADDRess.

SUBaddress:

Used to identify the subaddress of the destination user of a short message.

LENGth n

[CSS:FDTC:USER:DEST:SUBaddress:LENGth]

Specifies Length of subaddress info content. Range of n is 0 to 21.

LENGth?

Returns current value of LENGth.

ODD_EVEN n

[CSS:FDTC:USER:DEST:SUBaddress:ODD_EVEN]

Enables (n = 1) or disables (n = 0) Odd/Even indicator.

ODD EVEN?

Returns current state of ODD_EVEN.

TVDE A

[CSS:FDTC:USER:DEST:SUBaddress:TYPE]

Specifies Type of subaddress. Range of n is 0 to 7.

TYPE?

Returns current value of TYPE.

REServed n

[CSS:FDTC:USER:DEST:SUBaddress:REServed]

Enables (n = 1) or disables (n = 0) Reserved.

REServed?

Returns current state of REServed.

FDTC:

USER:

DEST:

SUBaddress:

ADDRess n.m

[CSS:FDTC:USER:DEST:SUBaddress:ADDRess]

Specifies User Destination Subaddress (m) indexed by n. Range of n is 0 to 19; range of m is 0 to 255.

ADDRess? n

Returns current value of User Destination Subaddress indexed by n. Range of n is 0 to 19.

ORIG:

Used to identify the originating address of a short message.

TYPE n

[CSS:FDTC:USER:ORIG:TYPE]

Specifies Type of Number. Range of n is 0 to 7.

TYPE?

Returns current value of TYPE.

PLANId n

[CSS:FDTC:USER:ORIG:PLANId]

Specifies Numbering Plan Identification. Range of n is 0 to 15.

PLANId?

Returns current value of PLANid.

ENCoding n

[CSS:FDTC:USER:ORIG:ENCoding]

Enables (n = 1) or disables (n = 0) Address Encoding.

ENCoding?

Returns current state of ENCoding.

ADDRess "n"

[CSS:FDTC:USER:ORIG:ADDRess]

Specifies Address (ASCII string).

Up to 60 characters may be sent.

ADDRess?

Returns current string value of ADDRess.

FDTC:

USER:

ORIG:

SUBaddress:

Used to identify the subaddress of the originating user of a short message.

LENGth n

[CSS:FDTC:USER:ORIG:SUBaddress:LENGth]

Specifies Length of User Originating subaddress info content. Range of n is 0 to 21.

LENGth?

Returns current value of LENGth.

ODD EVEN n

[CSS:FDTC:USER:ORIG:SUBaddress:ODD_EVEN]

Enables (n = 1) or disables (n = 0) Odd/Even Indicator.

ODD_EVEN?

Returns current state of ODD_EVEN.

TYPE n

[CSS:FDTC:USER:ORIG:SUBaddress:TYPE]

Specifies Type of subaddress. Range of n is 0 to 7.

TYPE?

Returns the value of TYPE.

REServed n

[CSS:FDTC:USER:ORIG:SUBaddress:REServed]

Enables (n = 1) or disables (n = 0) Reserved.

REServed?

Returns current state of REServed.

ADDRess n,m

[CSS:FDTC:USER:ORIG:SUBaddress:ADDRess]

Specifies User Originating Subaddress (m) indexed by n. Range of n is 0 to 19; range of m is 0 to 255.

ADDRess? n

Returns current value of User Originating Subaddress indexed by n. Range of n is 0 to 19.

FDTC:

USER:

ORIG:

PRESentation:

PIn

[CSS:FDTC:USER:ORIG:PRESentation:PI] Specifies Presentation Indicator. Range of n is 0 to 3.

PI?

Returns current value of PI.

SI

[CSS:FDTC:USER:ORIG:PRESentation:SI]
Specifies Screening Indicator. Range of n is 0 to 3.

SI?

Returns current value of SI.

REServed n

[CSS:FDTC:USER:ORIG:PRESentation:REServed]
Specifies Reserved. Range of n is 0 to 15.

REServed?

Returns current value of REServed.

RCAUSE n

[CSS:FDTC:RCAUSE]

Specifies R-Cause. Range of n is 0 to 255.

Used to qualify an R-DATA REJECT message.

RCAUSE?

Returns current value of RCAUSE.

CUSTOM:

LENGth n

[CSS:FDTC:CUSTOM:LENGth]

Specifies Length of Custom Control in octets. Range of n is 1 to 255.

LENGth?

Returns current value of LENGth.

FDTC:

CUSTOM:

CONTrol n.m

[CSS:FDTC:CUSTOM:CONTrol]

Specifies Custom Control (m) indexed by n. Range of n is 0 to 255; range of m is 0 to 255.

CONTrol? n

Returns current value of CONTrol indexed by n. Range of n is 0 to 255.

HYPERband:

NUMBer n

[CSS:FDTC:HYPERband:NUMBer]

Specifies Number of Hyperband channels. Range of n is 0 to 24.

NUMBer?

Returns current value of NUMBer.

BAND n.m

[CSS:FDTC:HYPERband:BAND]

Specifies the Hyperband (m) indexed by n. Range of n is 0 to 23; range of m is 0 to 3.

BAND? n

Returns current value of BAND.

CHANnel n.m

[CSS:FDTC:HYPERband:CHANnel]

Specifies Hyperband channels (m) indexed by n. Range of n is 0 to 23; range of m is 0 to 2047.

CHANnel? n

Returns current value of CHANnel indexed by n. Range of n is 0 to 23

TARGet n

[CSS:FDTC:HYPERband:TARGet]

Specifies Target Hyperband. Range of n is 0 to 3.

Specifies the hyperband to which handoff is occurring.

TARGet?

Returns current value of TARGet.

FDTC:

ENABLE:

The following commands enable or disable the optional Information Elements.

DCCHinfo n

[CSS:FDTC:ENABLE:DCCHinfo]
Specifies Digital Control Channel Information.

DCCHinfo?

Returns current value of DCCHinfo.

MSGWTG n

[CSS:FDTC:ENABLE:MSGWTG]
Specifies Other Messages Waiting Info.

MSGWTG?

Returns current value of MSGWTG.

TASK n

[CSS:FDTC:ENABLE:TASK]
Specifies Task Status.

TASK?

Returns current value of TASK.

DELTA:

TIME n

[CSS:FDTC:ENABLE:DELTA:TIME] Specifies Delta Time.

TIME?

Returns current value of TIME.

VMI n

[CSS:FDTC:ENABLE:VMI]
Specifies Voice Mode.

VMI?

Returns current value of VMI.

DPM n

[CSS:FDTC:ENABLE:DPM]
Specifies Data Privacy Mode.

DPM?

Returns current value of DPM.

FDTC:

ENABLE:

MEMC n

[CSS:FDTC:ENABLE:MEMC]
Specifies Message Encryption Mode C.

MEMC?

HYPERband:

TARGet n

[CSS:FDTC:ENABLE:HYPERband:TARGet] Specifies Target Hyperband.

TARGet?

Returns current value of TARGet.

MESSage:

CENTer:

ADDRess n

[CSS:FDTC:ENABLE:MESSage:CENTer:ADDRess]
Specifies Message Center Address.

ADDRess?

Returns current value of ADDRess.

USER:

DEST:

ADDRess n

[CSS:FDTC:ENABLE:USER:DEST:ADDRess]
Specifies User Destination Address.

ADDRess?

Returns current value of ADDRess.

SUBaddress n

[CSS:FDTC:ENABLE:USER:DEST:SUBaddress]
Specifies User Destination Subaddress.

SUBaddress?

Returns current value of SUBaddress.

FDTC:

ENABLE:

USER:

ORIG:

ADDRess n

[CSS:FDTC:ENABLE:USER:ORIG:ADDRess]
Specifies User Originating Address.

ADDRess?

Returns current value of ADDRess.

SUBaddress n

[CSS:FDTC:ENABLE:USER:ORIG:SUBaddress]
Specifies User Originating Subaddress.

SUBaddress?

Returns current value of SUBaddress.

PRESentation n

[CSS:FDTC:ENABLE:USER:ORIG:PREsentation]
Specifies User Originating Address Presentation Indicator.

PRESentation?

Returns current value of PRESentation.

7-9-7 TALKBACK

Talkback commands put data received on the RDTC into data fields of the FDTC. Data including VSELP loops back to the Mobile Station. The FM/AM-1600CSA performs no decoding or error correction with this operation.

CSS:

FDTC:

TALK:

DELAY n

Adds delay between receiving and transmitting in 20 ms intervals. Range of n is 0 to 250.

START

Starts Talkback operation.

STOP

Stops Talkback operation.

7-9-8 GLOBAL ACTION OVERHEAD MESSAGES

Global Action Overhead Messages are appended to the System Parameter Overhead message increasing the length of the overhead message train. Action (CSS:GLACT:ACTion) commands enable specific Global Action messages. Other commands define data and control operation.

CSS:

GLACT:

SEND

Starts Sending the Global Action as part of the Overhead message train.

STOP

Stops sending the Global Action as part of the Overhead message train.

REPEAT:

OFF

Sends the Global Action Overhead message once after starting (CSS:GLACT:SEND).

ON

Sends the Global Action Overhead message continuously after starting (CSS:GLACT:SEND) and stops when the CSS:GLACT:STOP command is initiated.

ACTion:

ACCess n

Enables or disables Access Attempt Parameters message (1 or 0).

ACCess?

Returns Access Attempt Parameters message Enable setting.

BIS r

Enables or disables Access Type Parameters message (1 or 0). The Access Type Parameters message contains the BIS bit.

BIS?

Returns Access Type Parameters message Enable setting.

LOCAID n

Enables or disables Location Area message (1 or 0).

LOCAID?

Returns Location Area message Enable setting.

LOCAL1 n

Enables or disables Local Control 1 message (1 or 0).

LOCAL1?

Returns Local Control 1 message Enable setting.

LOCAL2 n

Enables or disables Local Control 2 message (1 or 0).

GLACT:

ACTion:

LOCAL2?

Returns Local Control 2 message Enable setting.

NEWACC n

Enables or disables New Access Channel Set message (1 or 0).

NEWACC?

Returns New Access Channel Set message Enable setting.

OLC n

Enables or disables Overload Control message (1 or 0).

OLC?

Returns Overload Control message Enable setting.

RANDA n

Enables or disables Random Challenge A message (1 or 0).

RANDA?

Returns Random Challenge A message Enable setting.

RANDB n

Enables or disables Random Challenge B message (1 or 0).

RANDB?

Returns Random Challenge B message Enable setting.

REGINCR /

Enables or disables Registration Increment message (1 or 0).

REGINCR?

Returns Registration Increment message Enable setting.

RESCAN n

Enables or disables Rescan message (1 or 0).

RESCAN?

Returns Rescan message Enable setting.

BIS n

Sets Busy-Idle Status bit (0 or 1).

BIS?

Returns Busy-Idle Status bit setting.

LOCAID n

Sets Cell Site Location Area Identification. Range of n is 0 to 4095.

GLACT:

LOCAID?

Returns Cell Site Location Area Identification setting.

LOCALentl n

Sets Local Control bits. Range of n is 0 to 65535.

LOCALentl?

Returns value set for the Local Control bits.

LREG n

Sets Local Area Identification Registration bit (0 or 1).

LREG?

Returns Local Area Identification Registration bit setting.

MAXBusy:

OTHer n

Sets field indicating Maximum number of Busy occurrences allowed for Other than Page responses. Range of n is 0 to 15.

OTHer?

Returns Maximum number of Busy occurrences allowed for Other than Page responses setting.

PGR n

Sets field indicating Maximum number of Busy occurrences allowed for Page responses. Range of n is 0 to 15.

PGR?

Returns Maximum number of Busy occurrences allowed for Page responses field setting.

MAXSztr:

OTHer n

Sets field indicating Maximum number of Seizure Tries allowed for Other than Page responses. Range of n is 0 to 15.

OTHer?

Returns Maximum number of Seizure Tries allowed for Other than Page responses field setting.

PGR n

Sets field indicating Maximum number of Seizure Tries for Page responses. Range of n is 0 to 15.

PGR?

Returns Maximum number of Busy occurrences allowed for Page responses field setting.

GLACT:

NEWACC n

Sets New Access Channel starting point field. Range of n is 0 to 2047.

NEWACC?

Returns New Access Channel starting point field setting.

OLC n

Sets Overhead Class field. Range of n is 0 to 32767.

OLC?

Returns Overhead Class field setting.

PDREG n

Sets Power Down Registration bit (0 or 1).

PDREG?

Returns Power Down Registration bit setting.

PUREG n

Sets Power Up Registration bit (0 or 1).

PUREG?

Returns Power Up Registration bit setting.

RAND1 An

Sets 16 most significant bits of RAND. Range of n is 0 to 32767.

RAND1 A?

Returns value set for the 16 most significant bits of RAND.

RAND1_B n

Sets 16 least significant bits of RAND. Range of n is 0 to 32767.

RAND1_B?

Returns value set for the 16 least significant bits of RAND.

REGINCR n

Sets Registration Increment field. Range of n is 0 to 4095.

REGINCR?

Returns Registration Increment field setting.

7-9-9 MOBILE STATION CONTROL MESSAGES

Mobile Station Control messages, sent on the Forward Control Channel, replace the Overhead message train. CSS:MSCM:ORDER: commands select the Mobile Station Control Message.

CSS:

MSCM:

SEND

Starts sending the Mobile Station Control message.

STOP

Stops sending the Mobile Station Control message.

REPEAT:

OFF

Sends the Mobile Station Control message once after starting (CSS:MSCM:SEND).

ON

Sends the Mobile Station Control message continuously after starting (CSS:MSCM:SEND) and stops when the CSS:MSCM:STOP command is initiated.

ORDER:

A_ALERT

Selects Abbreviated Alert message.

AUDIT

Selects Audit message.

BSCHALCON

Selects Base Station Challenge Confirmation message.

DIR RTRY

Selects Directed-Retry message.

INTRCPT

Selects Intercept message.

LC

Selects Local Control message.

MSG WTG

Selects Message Waiting message.

REG CNF

Selects Registration Confirmation message.

RELease

Selects Release message.

REORDER

Selects Reorder message.

CSS:

MSCM:

ORDER:

SLOT1

Selects Digital Channel Assignment to Timeslot 1 message.

SLOT2

Selects Digital Channel Assignment to Timeslot 2 message.

SLOT3

Selects Digital Channel Assignment to Timeslot 3 message.

SSD UP

Selects Shared Secret Data Update message.

UCHAL

Selects Unique Challenge message.

VC DES

Selects Voice Channel Designation message.

AUTHBS n

Sets AUTHBS value. Range of n is 0 to 262143.

AUTHBS?

Returns AUTHBS value setting.

CHAN /

Selects RF Channel. Range of n is 1 to 1023.

CHAN?

Returns RF Channel setting.

CHANPos n,x

Sets selected Channel Position field sent in Directed-Retry message. Range of n is 0 to 5 (indicating Channel Positions 1 to 6). Range of x is 0 to 127.

CHANPos? n

Returns selected Channel Position field setting. Range of n is 0 to 5.

DMAC n

Sets Digital Mobile Attenuation Code. Range of n is 0 to 10.

DMAC?

Returns Digital Mobile Attenuation Code setting.

DVCC n

Sets Digital Verification Color Code. Range of n is 0 to 255.

DVCC?

Returns Digital Verification Color Code setting.

CSS:

MSCM:

EF n

Sets Extended Protocol Forward Channel Indicator (0 or 1).

EF?

Returns Extended Protocol Forward Channel Indicator setting.

LOCAL n

Sets the Local Control (Local Control message)/Message Type field. Range of n is 0 to 31.

LOCAL?

Returns the Local Control/Message Type field setting.

MEM r

Sets Message Encryption Mode (0 or 1).

MEM?

Returns Message Encryption Mode setting.

MIN "n"

Selects Mobile Identification Number. The Mobile Identification Number (n) is entered as a string, with quotation marks (i.e., "316/522-4981").

-MIN?

Returns Mobile Identification Number string setting.

ORDQ n

Sets Order Qualifier field. Range of n is 0 to 7.

ORDQ?

Returns Order Qualifier field setting.

PMn

Sets Privacy Mode Indicator bit (0 or 1).

PM2

Returns Privacy Mode Indicator bit setting.

RANDSSD1 n

Sets the 24 most significant bits of the Random Number sent in the SSD Update message (first order word). Range of n is 0 to 16777215.

RANDSSD1?

Returns the value set for the 24 most significant bits of the Random Number sent in the SSD Update message.

RANDSSD2 n

Sets the 24 intermediate bits of the Random Number sent in the SSD Update message (second order word). Range of n is 0 to 16777215.

CSS:

MSCM:

RANDSSD2?

Returns the value set for the 24 intermediate bits of the Random Number sent in the SSD Update message.

RANDSSD3 n

Sets the eight least significant bits of the Random Number sent in the SSD Update message (third order word). Range of n is 0 to 255.

RANDSSD3?

Returns the value set for the eight least significant bits of the Random Number sent in the SSD Update message.

RANDU n

Sets the 24 bit Random Number sent in the Unique Challenge message. Range of n is 0 to 16777215.

RANDU?

Returns the Unique Challenge 24 bit Random Number setting.

SBIn

Sets Shortened Burst Indicator. Range of n is 0 to 3.

SBI?

Returns Shortened Burst Indicator setting.

SCC n

Sets Supervisory Audio Tone Color Code. Range of n is 0 to 2.

SCC?

Returns Supervisory Audio Tone Color Code setting.

VMAC /

Sets Voice Mobile Attenuation Code. Range of n is 0 to 7.

VMAC?

Returns Voice Mobile Attenuation Code setting.

ADDENDUM TO SECTION 7-9-9

7-9-9A FOCC

CSS:

MSCM:

PVI n

[CSS:MSCM:PVI]

Enables (n = 1) or disables (n = 0) Protocol Version Indicator.

PVI?

Returns current state of PVI.

ORDER:

VOICE_MSG_WTG

[CSS:MSCM:ORDER:VOICE_MSG_WTG]
Selects Voice Message Waiting message.

SMS_MSG_WTG

[CSS:MSCM:ORDER:SMS_MSG_WTG]

Selects SMS Message Waiting message.

G3_MSG_WTG

[CSS:MSCM:ORDER:G3_MSG_WTG]
Selects G3-Fax Message Waiting message.

G3 PAGE

[CSS:MSCM:ORDER:G3_PAGE]

Selects Page (Group 3 Fax) message.

ASYNC PAGE

[CSS:MSCM:ORDER:ASYNC_PAGE]

Selects Page (Async Data) message.

ANA_VC_DES

[CSS:MSCM:ORDER:ANA_VC_DES]

Selects Analog Voice Channel Assignment message.

7-9-10 OVERHEAD ENABLE COMMANDS

CSS:

ENABLE:

DCCH n

[CSS:ENABLE:DCCH]

Enables (n = 1) or disables (n = 0) DCCH information word.

REGID n

[CSS:ENABLE:REGID]

Enables (n = 1) or disables (n = 0) Registration ID word.

7-10 BER COMMANDS

BER commands measure the receive Bit Error Rate (BER) of a Base Station. BER is calculated for BER:RDTC:DATA and BER:RDTC:PSUEDO. BER:DATA:LOOPBACK and BER:DATA:45MHZ_OFFset enable the Base Station to measure own BER.

BER:

RDTC:

SETup

Sets up the FM/AM-1600CSA as when entering the Base Station Digital Traffic BER screen. (Screen is not displayed.)

CHANnel n

Sets RF Channel. Range of n is 1 to 1023.

SLOT n

Selects Digital Traffic Timeslot. Range of n is 1 to 3.

RFLVL n

Sets RF Level in dBm. Range of n is -30.0 to -127.0.

DATA:

USER

Sends user selected data (Reverse Digital Traffic Channel data set in the User Defined Data Field Setup screen). Pressing the SETUP Key in the Base Station Digital Traffic BER screen accesses the User Defined Data Field Setup screen. Data must be set prior to initiating this command.

PSUEDO

Sends pseudo-random data.

LOOPBACK

Sends data received from Base Station in the FDTC Slot format, back to the Base Station in the RDTC Slot format (for Base Stations with self BER test capabilities).

45MHZ OFFset

Downconverts frequency 45 MHz and retransmits data.

GO

Starts Base Station Digital Traffic BER test.

STOP

Stops Base Station Digital Traffic BER test.

BITS?

Returns number of bits.

ERRORS?

Returns number of bit errors.

BER?

Returns Bit Error Rate (percentage).

BER:

RDTC:

CLEAR

Clears current results.

STATUS?

Returns synchronous data status (1 if Base Station cannot sync up to the data or 0).

7-11 MODULATION ACCURACY COMMANDS

Modulation Accuracy commands measure the $\pi/4DQPSK$ modulation of Base Station signals.

MODacc:

FDTC:

SETup

Sets up the FM/AM-1600CSA as when entering the Modulation Accuracy screen. (Screen is not displayed.)

CHANnel n

Sets RF Channel. Range of n is 1 to 1023.

RUN?

Starts Modulation Accuracy measurements and returns adjusted AGC value.

COMPlete?

Returns test status (1 if complete or 0 if not complete). (Test takes ≈25 seconds.)

EVM?

Returns RMS Error Vector Magnitude in percent.

FREQ ERRor?

Returns Frequency Error in hertz.

IQ_OFFset?

Returns I/Q Offset in dB.

MAG_ERRor?

Returns RMS Magnitude Error in percent.

PHASE_ERRor?

Returns RMS Phase Error in degrees.

7-12 GENERIC MEASURE COMMANDS

MEASure:

SAT?

Returns Supervisory Audio Tone frequency reading in Hz.

ST?

Returns Signal Tone frequency reading in Hz.

7-13 FLASH MEMORY COMMANDS

The mass memory (MMEMory) subsystem provides the Flash Memory storage capability of the FM/AM-1600CSA. Memory files are displayed in the JBox Flash Files Directory. 512 directory entries are available to store Test Set states, Macro programs, or Calibration data. File names are strings, limited to eight characters. The system promotes all lower case file name characters to upper case. Access and operate JBox Flash Files Directory as follows:

STEP

PROCEDURE

- 1. Press DPLX MODE Key to display Duplex Operation Screen.
- 2. Press "Sp Tst" Soft Function Key F5 to display Dual Mode Cellular Menu.
- 3. Press "AUX2" Soft Function Key F5 to display Auxiliary Functions Menu.
- 4. Press 6 DATA ENTRY Key to display JBox Flash Files directory.




Figure 7-1 JBox Flash Files Directory

9117126

- 5. Use ↑ and ↓ FIELD SELECT Keys to select desired file (indicated by arrow).
- 6. To execute macro, press "EXEC" Soft Function Key F1.
- 7. To delete a file, press "Delete" Soft Function Key F2. Use ↑ and ↓ FIELD SELECT Keys to verify and press ENTER. After deletion, perform Step 8 to release Flash Memory space.
- To perform Pack operation, press "Pack" Soft Function Key F4. Use ↑ and ↓ FIELD SELECT Keys to verify and press ENTER.

NOTE: Do not power off Test Set during Pack operation as files may be lost.

- 9. To Initialize Flash Memory, press "Init" Soft Function Key F3. (Initializing clears Flash Memory and all files are lost.)
- 10. To return to Auxiliary Functions Menu (#2), press "RET" Soft Function Key F6.

Files are stored in Flash Memory using remote commands only. Calibration Data Sets and Test Set States are recalled using remote commands or as part of executable macros. Table 7-3 contains the remote commands used to operate the JBox Flash Files Directory. Error messages are returned to Host when errors occur. Refer to Table 4-3 for description of error messages.

COMMAND	RANGE/VALUE	DESCRIPTION	
MMEMory:CATalog?		Returns Flash Memory status. First number returned is memory space used in bytes. Second number returned is memory space available in bytes. Remainder data is returned in sets of 3 consisting of file name, file type and file size for each file stored in Flash Memory.	
MMEMory:CATalog:ENTRY? n	n is line number (index) in JBox Flash Files Directory. Set n from 0 to 512.	Returns file entry (file name, file type, file size) for given index. Returns \$\$\$ if past end of directory or for deleted file.	
MMEMory:CATalog:USED?		Returns file space used, in bytes.	
MMEMory:CATalog:FREE?		Returns available file space, in bytes.	
MMEMory:DELete "f"	f is file name.	Deletes file but does not release memory space until Pack operation is done.	
MMEMory:INITialize		Erases all files stored in Flash Memory.	
MMEMory:INITialize?		Returns 1 if file system has been initialized, 0 otherwise.	
MMEMory:LOAD:MACRo "m","f"	m is name of designated macro. f is file name.	Loads macros and variables stored as the file name from Flash Memory into Test Set memory. If m is *, designated macro is executed. If m is macro name, that macro is executed. If m is omitted (*"), no macro is executed.	
MMEMory:LOAD:STATe "f"	f is file name.	Loads Test Set State stored as f from Flash Memory (sets CSA according to parameters stored in Flash Memory).	
MMEMory:LOAD:CALibration "f"	f is file name.	Loads Calibration Data from Flash Memory into Test Set memory.	
MMEMory:PACK		Packs Flash Memory and frees memory space from deleted files. Do not power off Test Set during Pack function (may lose files). Do not Pack with a WINDOW open.	
MMEMory:STORe:MACRo "m","f"	m is name of designated macro. f is file name.	Stores all Test Set macros and variables (except free variables) in Flash Memory as f with macro specified as designated macro in JBox Flash Files Directory.	
MMEMory:STORe:STATe "f"	f is file name.	Stores current CSA settings as f in Flash Memory (JBox Flash Files Directory).	
MMEMory:STORe:CALibration *f*	f is file name.	Stores Test Set Calibration Data into Flash Memory (shown as BINary files in JBox Flash Files Directory.	
MMEMory:TYPE? "f"	f is file name.	Returns file type (MACRo, STATe, BINary). Returns null string if file does not exist.	


Table 7-3 CSA Flash Memory Remote Commands

7-14 DCCH MOBILE STATION SIMULATION COMMANDS

This section contains the TMAC commands necessary to simulate the transmit portion of a mobile station operating on the Digital Control Channel (DCCH). These commands are to be used, primarily, as "tools" in applications.

The FM/AM-1600CSA must be receiving data that contains valid sync words on the Forward Digital Control Channel (FDCCH) before it can transmit on the Reverse Digital Control Channel (RDCCH). The RDCCH transmitter waits for a sync word, in the slot to which it is assigned, before transmitting.

In order that the Test Set can understand the transmissions being received, the user must observe the following guidelines illustrated below:



^{*} RF I/O is the only connector that is also an output.

9157045

Figure 7-3 Connector Input Power Ranges

The user is to verify cable connections as depicted in Figure 7-3. There are three possible configurations for interfacing the Test Set to a mobile unit or cell site. See Table 7-4 for interface configurations:

CONFIGURATION	1600S ANT	1600S T/R	1600CSA RF I/0		
1	l	*	0		
2	*	***	0		
3	. Ajc	*	1/0		
I - Input O - Output * - High Impedance					

Table 7-4 Input/Output Connector Configurations

7-14-1 TDMA TRANSMISSION OVERVIEW

The type of TDMA Transmission (as discussed in each subsection of Section 7-14) is determined by three different factors figured in the setup:

- Length
- Mode
- Selection of type of data for data field

The Length can be Normal or Abbreviated. In a Normal length message, the User Data block is 101 bits long, while in an Abbreviated length message, the User Data block is only 79 bits long. In both cases the TDMA slot length is the same (324 bits); however, in the Abbreviated Length Message, extra Ramp Time bits and Guard Time bits are added that make up the difference. See Figure 7-4 for an illustration of a Normal Length Message. See Figure 7-5 for an illustration of an Abbreviated Length Message.

The Mode can be Contiguous or Sub Channel. In a Contiguous transmission mode, the FM/AM-1600CSA transmits at a Full-Rate TDMA in the slot determined by the MSS:SLOT *n* command discussed in 7-14-2. In a Sub Channel transmission mode, the FM/AM-1600CSA transmits in a Sub Channel slot. See Figure 7-6 for an illustration of a Contiguous transmission and a Sub Channel transmission.

The data field can consist of either random data or user-defined data.




Figure 7-4 Normal Length Message in the RDCCH




Figure 7-5 Abbreviated Length Message in the RDCCH




Figure 7-6 Contiguous and Sub Channel Transmissions

7-14-2 SETUP COMMANDS

To set up the FM/AM-1600CSA for Mobile Station Simulation (MSS), use the following TMAC commands:

MSS:SETup

MSS:CHANnel n

These two are to be used first in setting up an application

● MSS:RFLVL n

● MSS:SLOT n

MSS:

SETup

[MSS:SETup]

Configures the FM/AM-1600CSA to simulate a Mobile Station.

MSS:SETup performs the following functions to set up the Test Set:

- Places the 1600S into the Duplex Mode of operation.
- Selects the 1600S Modulation as "User Defined." The parameters defined are as follows:
 - Modulation as FM DATA
 - IF Filters as 30 kHz
 - Post Detection as 15 kHz Low-Pass Filter.
- Sets the output level of the 1600S Duplex Out Connector to +7 dBm.
- Selects the 1600S AGC Type as User Defined High Speed.
- Turns off all 1600S Function Generators
- Sets the 1600S input connector to Antenna.
- Halts all tasks currently executing (i.e. if 1600CSA is decoding FOCC data, then that function is stopped).

CHANnel n

[MSS:CHANnel]

Selects Reverse Channel on which to transmit. Range of n is 1 to 1023.

The 1600S Duplex Operation is set up to receive on the selected forward channel and to transmit out the 1600S Duplex Out Connector at 130 MHz below the selected reverse channel. This output is used as a local oscillator and is mixed with 130 MHz in the 1600CSA and transmitted out the RF I/O Connector on the selected reverse channel.

Example:

RDCCH Channel 1 is selected.

Then, 1600S (in the Duplex mode of operation) receives on a frequency of 870.03 MHz and transmits, via the Duplex Out Connector, on a frequency of 695.03 MHz.

And, the 1600CSA accepts the 695.03 MHz transmission, via the Duplex In Connector, and mixes with 130 MHz and the resultant frequency is 825.03 MHz.

When setting up the channel, the Duplex Operation screen frequencies do not change. In addition, if the Duplex Operation is in Channel Mode <u>and</u> the screen is reselected (using the Front Panel of the 1600S), then, the 1600S Channel Mode overrides these channel settings.

CHANnel?

Returns current mobile simulation channel.

RATE n

[MSS:RATE]

Selects TDMA transmission rate: full (n = 0) or half (n = 1).

RATE?

Returns current state of TDMA transmission RATE.

RFLVL n

[MSS:RFLVL]

Specifies RF output level at which to transmit. Range of n is -127.9 to -30.0 dBm.

SLOT n

[MSS:SLOT]

Specifies DCCH Full Rate Slot in which to transmit. Range of n is 1 to 3.

SLOT?

Returns current value of DCCH slot selection.

7-14-3 RDCCH RAW GENERATOR

The following commands direct the RDCCH Raw Generator to transmit data on the RDCCH synchronous to the FDCCH. The RDCCH Raw Generator transmits user data in the following methods as specified by the MSS:RDCCH:DVCC, MSS:RDCCH:LENGth, MSS:RDCCH:MODE and MSS:RDCCH:SELect commands:

- 1. Full-Rate TDMA Channel as Normal or Abbreviated transmission bursts
 - Random Data
 - User-Defined Data
- 2. Within a Random Access Channel (RACH) Sub-Channel as Normal or Abbreviated transmission bursts
 - Random Data
 - User-Defined Data

The setup commands specified in section 7-14-2 are critical and must be taken into consideration when using this function.

The preamble, sync words, and sync+ as specified in IS-136 as well as the Cyclic Redundancy Check (CRC), convolutional encoding and interleaving are performed by the FM/AM-1600CSA.

The data in the DATA field is setup by the user as wither a user-defined pattern or random data.

Use the following commands to specify the Length and Mode of the Reverse Digital Control Channel:

MSS:

RDCCH:

LENGth:

ABBREViated

[MSS:RDCCH:LENGth:ABBREViated]
Selects Abbreviated length transmission bursts on RDCCH.

NORMal

[MSS:RDCCH:LENGth:NORMal]
Selects Normal length transmission bursts on RDCCH.

MODE:

CONTiguous

[MSS:RDCCH:MODE:CONTiguous]
Selects transmission in Full-Rate TDMA Channel.

SUBCHANnel

[MSS:RDCCH:MODE:SUBCHANnel]
Selects transmission in RACH Sub Channel.

RDCCH:

SELect:

RANDom

[MSS:RDCCH:SELect:RANDom]

Selects Random Data for DATA Field in transmission bursts on RDCCH.

USER

[MSS:RDCCH:SELect:USER]

Selects a user-defined data pattern for DATA Field (See MSS:RDCCH:USER) in transmission bursts on RDCCH.

DVCC n

[MSS:RDCCH:DVCC]

Specifies Digital Verification Color Code. Range of n is 1 to 255.

DVCC is required to calculate the correct CRC.

DVCC?

Returns current value of Digital Verification Color Code.

If the data selected is USER, then the data is specified by the following command:

MSS:

RDCCH:

USER n, word

[MSS:RDCCH:USER]

Specifies each 16 bit word indexed by n. Range of n is 0 to 6; range of word is 0 to #hFFFF.

USER data consists of 7 words (Normal Length) or 5 words (Abbreviated Length). Each word (n) consists of 16 bits. n = 0 selects the most significant word; n = 6 selects the least significant word. The first bit of word is the most significant bit, the last bit of word is the least significant bit (left justified).




Figure 7-7 User Data Message Diagram

9110020

Data left justified is defined as bits aligned such that the most significant bit occurs first, followed by successively less significant bits.

Use the following commands to Start and Stop the data:

STAR

[MSS:RDCCH:STARt]
Starts transmission in RDCCH.

STOP

[MSS:RDCCH:STOP]

Stops transmission in RDCCH.

7-14-4 RANDOM ACCESS CONTROL CHANNEL (RACH) MESSAGE GENERATOR

To simulate a mobile access on the DCCH, the following commands direct the RACH Message Generator to transmit a fixed length, user-defined message as Normal or Abbreviated transmission bursts in a Full-Rate TDMA Channel or within a RACH Sub-channel on the RDCCH synchronous to the FDCCH (See Figure 7-9 and Figure 7-10).

The MSS:RDCCH:MODE, MSS:RDCCH:DVCC, MSS:RDCCH:LENGth and MSS:RDCCH:MESSage:LENGth commands are used to specify the type of transmission.

The setup commands specified in Section 7-14-2 are critical and must be taken into consideration when using this function.

MSS:

RDCCH:

MESSage:

LENGth n

[MSS:RDCCH:MESSage:LENGth]

Specifies the length (number of transmission bursts) of RDCCH message. Range of n is 1 to 320.

LENGth?

Returns current RDCCH message length.

RDCCH:

MESSage:

DATA m,n,word

[MSS:RDCCH:MESSage:DATA]

Specifies a 16 bit data word (indexed by n) in selected transmission burst (m). The range of m is 0 to 319; range of n is 0 to 6; range of m is 0 to #hFFFF.

USER data consists of 1 to 320 transmission bursts. Each burst consists of 7 words (Normal Length) or 5 words (Abbreviated Length). n = 0 selects the most significant word; n = 6 selects the least significant word. The first bit of word is the most significant bit, the last bit of word is the least significant bit.

The MSS:RDCCH:MESSage:DATA and the MSS:RDCCH:MESSage:LENGth commands need to be used to fully define a RACH message.




Figure 7-8 RDCCH Message Diagram




Figure 7-9 RACH Message Transmission (Contiguous)




Figure 7-10 RACH Message Transmission (Sub Channel)

RDCCH:

MESSage:

ACCESS:

SFP n

[MSS:RDCCH:MESSage:ACCESS:SFP]

Selects the Superframe Phase reference for transmission of user-defined message (See MSS:RDCCH:MESSage:DATA). Range of n is 0 to 31.

The first transmission burst of the RACH message is transmitted synchronous to the slot of the Superframe contained in the Superframe Phase selected by this command.

SFP?

Returns current Superframe Phase reference.

TYPE:

RANDom

[MSS:RDCCH:MESSage:ACCESS:TYPE:RANDom] Selects Random access.

REServed

[MSS:RDCCH:MESSage:ACCESS:TYPE:REServed] Selects Reserved access.

SFP

[MSS:RDCCH:MESSage:ACCESS:TYPE:SFP]
Selects Superframe Phase synchronization.

NONE

[MSS:RDCCH:MESSage:ACCESS:TYPE:NONE] Selects no synchronization.

TYPE?

[MSS:RDCCH:MESSage:ACCESS:TYPE?]
Returns current value of Type of Access.

DELay n

[MSS:RDCCH:MESSage:ACCESS:DELay]

Specifies the delay in number of frames before retrying an access after an access failure. Range of n is 0 to 20.

DELay?

Returns current number of frames of the re-access delay.

RDCCH:

MESSage:

REPeat:

ON

[MSS:RDCCH:MESSage:REPeat:ON]

Sends RACH message at Repeat Rate after initial transmission.

Each repeat of the RACH message is synchronized to the selected Superframe Phase (SFP). See MSS:RDCCH:MESSage:SFP command.

OFF

[MSS:RDCCH:MESSage:REPeat:OFF]

Sends RACH message once after initial transmission.

SYNC n

[MSS:RDCCH:MESSage:REPeat:SYNC]

Enables (n = 1) or disables (n = 0) Repeat Synchronizing.

If repeat synchronizing is enabled, then each repeat of the RACH message is synchronized to the designated superframe phase (SFP).

SYNC?

Returns current state of Repeat Synchronizing.

SEND

[MSS:RDCCH:MESSage:SEND]

Sends RACH message once (Repeat is disabled) or repeatedly (Repeat is enabled).

See MSS:RDCCH:MESSage:REPeat.

STOP

[MSS:RDCCH:MESSage:STOP]

Stops sending RACH message.

Applicable only when Repeat is turned on (See MSS:RDCCH:MESSage:REPeat:ON).

CORRUPT n

[MSS:RDCCH:MESSage:CORRUPT]

Selects the frame of the RACH message to corrupt. Range of n is 0 to 320.

If 0 is selected, then none of the frames of the message are corrupted.

CORRUPT?

Returns current corrupted frame.

7-14-5 RACH LAYER 3 MESSAGE BUILDER

The messages that are sent by the RACH Message Generator can be created with the RACH Layer 3 message builder. The process of building a RACH message can be broken down into five steps.

- Setup the Layer 2 data fields that cannot be determined from the layer 3 messages being sent.
- Select the Message Types that are to be included in the Layer 3 message (1 to 8).
- Set up the Elements that make up the specified messages.
- Enable or disable the optional fields.
- Build the RACH message.

A. Layer 2 Data Fields

Some of the Layer 2 data fields are determined by the Layer 3 message being sent. The ones that cannot be determined are set up by the following commands.

MSS:

RDCCH:

LAYER2:

IDT n

[MSS:RDCCH:LAYER2:IDT]

Specifies Identity Type. Range of n is 0 to 3.

IDT?

Returns current value of Identity Type.

EHI n

[MSS:RDCCH:LAYER2:EHI]

Enables (n = 1) or disables (n = 0) Extended Header Information.

EHI?

Returns current state of Extended Header Information.

MEAn

[MSS:RDCCH:LAYER2:MEA]

Specifies Message Encryption Algorithm. Range of n is 0 to 3.

MEA?

Returns current value of Message Encryption Algorithm..

MEK n

[MSS:RDCCH:LAYER2:MEK]

Specifies Message Encryption Key. Range of n is 0 to 3.

MEK?

Returns current value of Message Encryption Key.

NL3M n

[MSS:RDCCH:LAYER2:NL3M]

Specifies Number Layer 3 Messages Range of n is 0 to 7.

Besides being part of the Layer 2 frame, this command specifies the number of Layer 3 messages that are built into the RACH message by the MSS:RDCCH: BUILD command.

NL3M?

Returns current value of Number Layer 3 Messages.

RDCCH:

LAYER2:

MSID:

MS n

[MSS:RDCCH:LAYER2:MSID:MS]

Specifies the 18 Most Significant Bits of Mobile Station Identification. Range of n is 0 to #h3FFFF.

MS?

Returns the 18 Most Significant Bits of Mobile Station Identification.

LS n

[MSS:RDCCH:LAYER2:MSID:LS]

Sets the 32 Least Significant Bits of Mobile Station Identification. Range of n is 0 to #hFFFFFFF.

LS?

Returns the 32 Least Significant Bits of Mobile Station Identification.

MIN "n"

[MSS:RDCCH:LAYER2:MIN]

Specifies Mobile Identification Number. *n* is an ASCII string e.g. "316/522-4981".

This MIN is used to set up the MSID field when the Identity Type (IDT) is equal to 2.

This is for the convenience of the user since the MIN of the phone, and not the MSID, is usually known.

MIN?

Returns current Mobile Identification Number (ASCII string).

ARQ n

[MSS:RDCCH:LAYER2:ARQ]

Enables (n = 1) or disables (n = 0) ARQ status frame.

If ARQ is enabled, then the message built is a Layer 2 ARQ status frame.

ARQ?

Returns current state of ARQ status frame.

PEA n

[MSS:RDCCH:LAYER2:PEA]

Specifies Partial Echo Assigned. Range of n is 0 to 63.

PEA?

Returns current value of Partial Echo Assigned.

RDCCH:

LAYER2:

FRNO n

[MSS:RDCCH:LAYER2:FRNO]

Specifies Frame Number Map. Range of n is 0 to #hFFFFFFF.

FRN07

Returns current value of Frame Number Map.

RSVD:

ARQ n

[RDCCH:RSVD:ARQ]

Specifies Automatic Retransmission Request RSVD. Range of n is 0 to 3.

ARQ

Returns current value of ARQ. Returns -1 if not available.

EHI n

[RDCCH:RSVD:EHI]

Enables (n = 1) or disables (n = 0) Extended Header Indicator RSVD.

EHI2

Returns current state of Extended Header Indicator RSVD. Returns -1 if not available.

END n

[RDCCH:RSVD:END]

Enables (n = 1) or disables (n = 0) END frame RSVD.

END?

Returns current state of END frame RSVD. Returns -1 if not available.

The other Layer 2 data fields are setup as determined by the messages being sent in the Layer 3 data field.

- BT If the messages can be sent in one frame then BT = 3 for a BEGIN and END frame. For a multi-frame message, BT = 0 for the BEGIN frame, BT = 1 for the CONTINUE frame, and BT = 2 for the END frame. If the message is an ARQ status frame then BT = 4.
- The first CONTINUE frame sent has its CI field set to 0 and toggles for each additional CONTINUE frame. If the SCF information received on the FDCCH determines that a CONTINUE frame needs to be resent, then the CI field remains the same for that frame.
- L3L1 This is determined by the length of the specified layer 3 message in octets.
- RSVD All reserved fields are set to zero.

B. RACH Message Types.

A RACH may include from 1 to 8 Layer 3 messages. The NL3M field determines the number of Layer 3 messages included in the RACH. The following commands select the message types sent as Layer 3 messages. The parameter n in each case determines the order and the selected messages types. As an example, if three messages are to be sent (NL3M = 2), then the message types selected with n = 0, n = 1 and n = 2 would be the messages built into the RACH message. These selected messages would be positioned in the RACH message, starting with the message type selected with n = 0.

MSS:

RDCCH:

MSGtype:

The user may specify from 1 to 8 Message Types.

AUDITcon n

[MSS:RDCCH:MSGtype:AUDITcon]

Selects Audit Confirmation to be transmitted as a Message Type. The position of the message is determined by n. Range of n is 0 to 7.

AUTHentication n

[MSS:RDCCH:MSGtype:AUTHentication]

Selects Authentication to be transmitted as a Message Type. The position of the message is determined by n. Range of n is 0 to 7.

BSCHAL n

[MSS:RDCCH:MSGtype:BSCHAL]

Selects Base Station Challenge Order to be transmitted as a Message Type. The position of the message is determined by n. Range of n is 0 to 7.

BSMC n

[MSS:RDCCH:MSGtype:BSMC]

Selects BSMC Message Delivery to be transmitted as a Message Type. The position of the message is determined by n. Range of n is 0 to 7.

CAPability n

[MSS:RDCCH:MSGtype:CAPability]

Selects Capability Report to be transmitted as a Message Type. The position of the message is determined by n. Range of n is 0 to 7.

MACA n

[MSS:RDCCH:MSGtype:MACA]

Selects MACA Report to be transmitted as a Message Type. The position of the message is determined by n. Range of n is 0 to 7.

ORIGination n

[MSS:RDCCH:MSGtype:ORIGination]

Selects Origination to be transmitted as a Message Type. The position of the message is determined by n. Range of n is 0 to 7.

RDCCH:

MSGtype:

The user may specify from 1 to 8 Message Types.

PAGE RESPonse n

[MSS:RDCCH:MSGtype:PAGE_RESPonse]

Selects Page Response to be transmitted as a Message Type. The position of the message is determined by n. Range of n is 0 to 7.

RDATA n

[MSS:RDCCH:MSGtype:RDATA]

Selects R-DATA to be transmitted as a Message Type. The position of the message is determined by n. Range of n is 0 to 7.

RDATA:

ACCept n

[MSS:RDCCH:MSGtype:RDATA:ACCept]

Selects R-DATA ACCEPT to be transmitted as a Message Type. The position of the message is determined by n. Range of n is 0 to 7.

REJect n

[MSS:RDCCH:MSGtype:RDATA:REJect]

Selects R-DATA REJECT to be transmitted as a Message Type. The position of the message is determined by n. Range of n is 0 to 7.

REGistration n

[MSS:RDCCH:MSGtype:REGistration]

Selects Registration to be transmitted as a Message Type. The position of the message is determined by n. Range of n is 0 to 7.

SERial n

[MSS:RDCCH:MSGtype:SERial]

Selects Serial Number to be transmitted as a Message Type. The position of the message is determined by n. Range of n is 0 to 7.

SOC n

[MSS:RDCCH:MSGtype:SOC]

Selects SOC Message Delivery to be transmitted as a Message Type. The position of the message is determined by n. Range of n is 0 to 7.

SPACHcon n

[MSS:RDCCH:MSGtype:SPACHcon]

Selects SPACH Confirmation to be transmitted as a Message Type. The position of the message is determined by n. Range of n is 0 to 7.

RDCCH:

MSGtype:

The user may specify from 1 to 8 Message Types.

SSDUPcon n

[MSS:RDCCH:MSGtype:SSDUPcon]

Selects SSD Update Order Confirmation to be transmitted as a Message Type. The position of the message is determined by n. Range of n is 0 to 7.

TEST n

[MSS:RDCCH:MSGtype:TEST]

Selects Test Registration to be transmitted as a Message Type. The position of the message is determined by n. Range of n is 0 to 7.

UCHALcon n

[MSS:RDCCH:MSGtype:UCHALcon]

Selects Unique Challenge Order Confirmation to be transmitted as a Message Type. The position of the message is determined by n. Range of n is 0 to 7.

C. RACH Layer 3 Data Fields

The values of the elements that make up the Layer 3 messages are determined by the commands in this section. Generally, the name of each command closely matches or is an abbreviation or acronym of the associated data element specified in IS-136.

MSS:

RDCCH:

PD n

[MSS:RDCCH:PD]

Specifies Protocol Discriminator. Range of n is 0 to 3.

PD?

Returns current value of Protocol Discriminator.

PFC 1 n

[MSS:RDCCH:PFC]

Specifies Paging Frame Class Minus One. Range of n is 0 to 7.

PFC_1?

Returns current value of Paging Frame Class.

PSID_RSID:

SELect n

[MSS:RDCCH:PSID_RSID:SELect]

Specifies Selected PSID/RSID (Private System Identification/Residential System Identification). Range of n is 0 to 15.

SELect?

Returns current value of Selected PSID/RSID.

MAP n

[MSS:RDCCH:PSID_RSID:MAP]

Specifies PSID/RSID Map. Range of n is 0 to #hFFFF.

MAP?

Returns current value of PSID/RSID Map.

DISPlay:

LENGth n

[MSS:RDCCH:DISPlay:LENGth]

Specifies Length of Display Information. Range of n is 0 to 81.

LENGth?

Returns current value of Length of Display Information.

RDCCH:

DISPlay:

CHARacter m.n

[MSS:RDCCH:DISPlay:CHARacter]

Specifies Display Character (n) selected by Index (m). Range of m is 0 to 81; range of n is 0 to 255.

The characters are setup one at a time.

CHARacter? n

Returns current value of Display Character selected by n. Range of n is 0 to 81.

COUNt n

[MSS:RDCCH:COUNt]

Specifies COUNT used for the Authentication process. Range of n is 0 to 63.

COUNt?

Returns current value of COUNt.

RANDC n

[MSS:RDCCH:RANDC]

Specifies RANDC used in the Authentication process. Range of n is 0 to 255.

RANDC?

Returns current value of RANDC.

AUTHR n

[MSS:RDCCH:AUTHR]

Specifies AUTHR used in the Authentication process. Range of n is 0 to #h3FFFF.

AUTHR?

Returns current value of AUTHR.

RANDBS n

[MSS:RDCCH:RANDBS]

Specifies RANDBS used in the Authentication process. Range of n is 0 to #hFFFFFFF.

RANDBS?

Returns current value of RANDBS.

BSMC n

[MSS:RDCCH:BSMC]

Specifies Base Station Manufacture Code. Range of n is 0 to 255.

BSMC?

Returns current value of Base Station Manufacture Code.

RDCCH:

PROTocol:

VERsion n

[MSS:RDCCH:PROTocol:VERsion]
Specifies Protocol Version. Range of n is 0 to 15.

VERsion?

Returns current value of Protocol Version.

SCM n

[MSS:RDCCH:SCM]

Specifies Station Class Mark. Range of n is 0 to 31.

SCM?

Returns current value of Station Class Mark.

VINtage:

SOFTware n

[MSS:RDCCH:VINtage:SOFTware]

Specifies Software Vintage. Range of n is 0 to 63.

SOFTware?

Returns current value of Software Vintage.

FIRMware n

[MSS:RDCCH:VINtage:FIRMware]

Specifies Firmware Vintage. Range of n is 0 to 63.

FIRMware?

Returns current value of Firmware Vintage.

MODEL n

[MSS:RDCCH:MODEL]

Specifies Model Number. Range of n is 0 to 15.

MODEL?

Returns current value of Model Number.

MANufacture n

[MSS:RDCCH:MANufacture]

Specifies Manufacture Code. Range of n is 0 to 255.

MANufacture?

Returns current value of Manufacture Code.

RDCCH:

SUPPort:

MAX:

PFC n

[MSS:RDCCH:SUPPort:MAX:PFC]

Specifies MAX_SUPPORTED_PFC. Range of n is 0 to 7.

PFC?

Returns current value of MAX_SUPPORTED_PFC.

SOC n

[MSS:RDCCH:SUPPort:SOC]

Enables (n = 1) or disables (n = 0) SOC Support.

SOC?

Returns current state of SOC Support.

BSMC n

[MSS:RDCCH:SUPPort:BSMC]

Enables (n = 1) or disables (n = 0) BSMC Support.

BSMC?

Returns current state of BSCM Support.

ASYNC n

[MSS:RDCCH:SUPPort:ASYNC]

Enables (n = 1) or disables (n = 0) Async Data Support.

ASYNC?

Returns current state of Async Data Support.

G3fax n

[MSS:RDCCH:SUPPort:G3fax]

Enables (n = 1) or disables (n = 0) G3-Fax Support.

G3fax?

Returns current state of G3-Fax Support.

SMS n

[MSS:RDCCH:SUPPort:SMS]

Enables (n = 1) or disables (n = 0) SMS Broadcast Support.

SMS?

Returns current state of SMS Broadcast Support.

RDCCH:

SUPPort:

SUBaddress n

[MSS:RDCCH:SUPPort:SUBaddress] Enables (n = 1) or disables (n = 0) Subaddressing Support.

SUBaddress?

Returns current state of Subaddressing Support.

FREQuency:

BANDS n

[MSS:RDCCH:SUPPort:FREQuency:BANDS]

Specifies Supported Frequency Bands. Range of n is 0 to 255.

BANDS?

Returns current value of Supported Frequency Bands.

IA5 n

[MSS:RDCCH:SUPPort:IA5]

Enables (n = 1) or disables (n = 0) IA5 Support.

1857

Returns current state of IA5 Support.

USER n

[MSS:RDCCH:SUPPort:USER]

Enables (n = 1) or disables (n = 0) User Group Support.

USER?

Returns current state of User Group Support.

ANA800 n

[MSS:RDCCH:SUPPort:ANA800]

Enables (n = 1) or disables (n = 0) 800 MHz Analog Speech Support.

Indicates whether or not the mobile station supports analog speech in the 800 MHz Hyperband.

ANA800?

Returns current state of ANA800.

RDCCH:

SUPPort:

HALF n

[MSS:RDCCH:SUPPort:HALF]

Enables (n = 1) or disables (n = 0) Half-Rate DTC Support.

Indicates whether or not the mobile station supports half-rate Digital Traffic Channels

HALF?

Returns current state of HALF.

DOUBle n

[MSS:RDCCH:SUPPort:DOUBIe]

Enables (n = 1) or disables (n = 0) Double Rate DTC Support.

Indicates whether or not the mobile station supports double rate Digital Traffic Channels.

DOUBle?

Returns current state of DOUBle.

TRIPle n

[MSS:RDCCH:SUPPort:TRIPle]

Enables (n = 1) or disables (n = 0) Triple Rate DTC Support.

Indicates whether or not the mobile station supports triple rate Digital Traffic Channels.

TRIPle?

Returns current state of TRIPle.

MEASurement:

LTM:

WER n

[MSS:RDCCH:MEASurement:LTM:WER]

Specifies LTM Measurement Word Error Rate. Range of n is 0 to 7.

WER?

Returns current value of LTM Measurement Word Error Rate.

RDCCH:

MEASurement:

LTM:

BER n

[MSS:RDCCH:MEASurement:LTM:BER]

Specifies Word Error Rate LTM Measurement Bit Error Rate. Range of n is 0 to 7.

BER?

Returns current value of LTM Measurement Bit Error Rate.

RSS n

[MSS:RDCCH:MEASurement:LTM:RSS]

Specifies LTM Measurement Receive Signal Strength. Range of n is 0 to 7.

RSS?

Returns current value of LTM Measurement Receive Signal Strength.

FULL n

[MSS:RDCCH:MEASurement:LTM:FULL]

Enables (n = 1) or disables (n = 0) LTM Measurement Full Measurement Indicator.

FULL?

Returns current state of LTM Measurement Full Measurement Indicator.

STM:

NV n

[MSS:RDCCH:MEASurement:STM:NV]

Specifies STM Measurement Number of Values. Range of n is 0 to 15.

NV?

Returns current value of STM Measurement Number of Values.

RSS m,n

[MSS:RDCCH:MEASurement:STM:RSS]

Specifies value of ST_RSS (n) selected by m. Range of m is 0 to 15; Range of n is 0 to 31.

Specifies 1 of 16 STM Measurement Receive Signal Strengths.

RSS? n

Returns current value of STM Measurement Receive Signal Strength selected by n. Range of n is 0 to 15.

RDCCH:

EMERgency n

[MSS:RDCCH:EMERgency]

Enables (n = 1) or disables (n = 0) Emergency Call.

EMERgency?

Returns current state of Emergency Call.

LT n

[MSS:RDCCH:LT]

Enables (n = 1) or disables (n = 0) Last Try flag.

If a mobile station receives a Directed Retry and attempts a new access on another DCCH, it shall set the Last Try flag in the Origination or the Page Response message to the value of the Last Try flag received in the Directed Retry message. Otherwise the mobile station shall reset the Last Try flag at system access.

LT?

Returns current state of Last Try flag.

SERVice n

[MSS:RDCCH:SERVice]

Specifies Service Code. Range of n is 0 to 15.

SERVice?

Returns current value of Service Code.

MODE:

VOICe:

VC n

[MSS:RDCCH:MODE:VOICe:VC]

Specifies Voice Mode VC. Range of n is 0 to 7.

VC?

Returns current value of Voice Mode VC.

PM n

[MSS:RDCCH:MODE:VOICe:PM]

Specifies Voice Mode PM_V. Range of n is 0 to 7.

PM2

Returns current value of Voice Mode PM_V.

RDCCH:

MODE:

DATA:

PM n

[MSS:RDCCH:MODE:DATA:PM]

Specifies Data Mode PM_D. Range of n is 0 to 7.

PM?

Returns current value of Data Mode PM_D.

SAP n

[MSS:RDCCH:MODE:DATA:SAP]

Enables (n = 1) or disables (n = 0) Data Mode SAP.

SAP2

Returns current state of Data Mode SAP.

ACKED n

[MSS:RDCCH:MODE:DATA:ACKED]

Enables (n = 1) or disables (n = 0) Data Mode Acked Data.

ACKED?

Returns current state of Data Mode Acked Data.

CRC n

[MSS:RDCCH:MODE:DATA:CRC]

Enables (n = 1) or disables (n = 0) Data Mode CRC.

CRC?

Returns current state of Data Mode CRC.

PART n

[MSS:RDCCH:MODE:DATA:PART]

Enables (n = 1) or disables (n = 0) Data Mode Data Part.

PART?

Returns current value of Data Mode Data Part.

RLP n

[MSS:RDCCH:MODE:DATA:RLP]

Specifies Data Mode RLP. Range of n is 0 to 3.

RLP?

Returns current value of Data Mode RLP.

RDCCH:

MEM:

Message Encryption Mode - Identifies the selected message encryption algorithm, key and domain.

MEA n

[MSS:RDCCH:MEM:MEA]

Specifies Message Encryption Algorithm. Range of n is 0 to 7.

MEA?

Returns current value of Message Encryption Algorithm.

MED n

[MSS:RDCCH:MEM:MED]

Specifies Message Encryption Domain. Range of n is 0 to 7.

MED?

Returns current value of Message Encryption Domain.

MEK n

[MSS:RDCCH:MEM:MEK]

Specifies Message Encryption Key. Range of n is 0 to 7.

MEK?

Returns current value of Message Encryption Key.

BANDWidth n

[MSS:RDCCH:BANDWidth]

Specifies Bandwidth. Range of n is 0 to 7.

BANDWidth?

Returns current value of Bandwidth.

CALLED:

ADDRess "n"

[MSS:RDCCH:CALLED:ADDRess]

Specifies Called Address (ASCII String).

ADDRess?

Returns current ASCII string value of Called Address.

RDCCH:

CALLED:

ADDRess:

ENCoding n

[MSS:RDCCH:CALLED:ADDRess:ENCoding]

Enables (n = 1) or disables (n = 0) Called Address Encoding.

ENCoding?

Returns current state of Called Address Encoding.

PLANId n

[MSS:RDCCH:CALLED:PLANId]

Specifies Called Address Numbering Plan Identification. Range of n is 0 to 15.

PLANId?

Returns current value of Called Address Numbering Plan Identification.

TYPE n

[MSS:RDCCH:CALLED:TYPE]

Specifies Called Address Type of Number. Range of n is 0 to 7.

TVPE

Returns current value of Called Address Type of Number.

SUBaddress:

ODD EVEN n

[MSS:RDCCH:CALLED:SUBaddress:ODD_EVEN]

Enables (n = 1) or disables (n = 0) Called Party Subaddress Odd/Even indicator.

ODD_EVEN?

Returns current state of Called Party Subaddress Odd/Even indicator.

TYPE n

[MSS:RDCCH:CALLED:SUBaddress:TYPE]

Specifies Called Party Subaddress Type of Subaddress. Range of n is 0 to 3.

TYPE?

Returns current value of Called Party Subaddress Type of Subaddress.

RDCCH:

CALLED:

SUBaddress:

ADDRess m.n

[MSS:RDCCH:CALLED:SUBaddress:ADDRess]

Specifies Called Party Subaddress (n) selected by m. Range of n is 0 to 19; range of m is 0 to 255.

ADDRess? n

Returns current value of Called Party Subaddress selected by n. Range of n is 0 to 255.

CALLING:

ADDRess "n"

[MSS:RDCCH:CALLING:ADDRess]

Specifies Calling Address (ASCII String).

ADDRess?

Returns current ASCII string value of Calling Address.

ADDRess:

ENCoding n

[MSS:RDCCH:CALLING:ADDRess:ENCoding]

Enables (n = 1) or disables (n = 0) Calling Address Encoding.

ENCoding?

Returns current state of Calling Address Encoding.

PRESentation:

Pln

[MSS:RDCCH:CALLING:PRESentation:PI]

Specifies Calling Address Presentation Indicator. Range of n is 0 to 3.

PI?

Returns current value of Calling Address Presentation Indicator.

RDCCH:

CALLING:

PRESentation:

SIn

[MSS:RDCCH:CALLING:PRESentation:SI]

Specifies Calling Address Screening Indicator. Range of n is 0 to 3.

SIZ

Returns current value of Calling Address Screening Indicator.

PLANId n

[MSS:RDCCH:CALLING:PLANId]

Specifies Calling Address Numbering Plan Identification. Range of n is 0 to 15.

PLANId?

Returns current value of Calling Address Numbering Plan Identification.

TYPE n

[MSS:RDCCH:CALLING:TYPE]

Specifies Calling Address Type of Number. Range of n is 0 to 7.

TVPF?

Returns current value of Calling Address Type of Number.

SUBaddress:

LENGth n

[MSS:RDCCH:CALLING:SUBaddress:LENGth]

Specifies Calling Address Subaddress Length. Range of n is 1 to 21.

LENGth?

Returns current value of Calling Address Subaddress Length.

ODD EVEN n

[MSS:RDCCH:CALLING:SUBaddress:ODD_EVEN]

Enables (n = 1) or disables (n = 0) Calling Address Subaddress Odd/Even indicator.

ODD EVEN?

Returns current state of Calling Address Subaddress Odd/Even indicator.

TYPE n

[MSS:RDCCH:CALLING:SUBaddress:TYPE]

Specifies Calling Address Subaddress Type of Number. Range of n is 0 to 3.

TYPE?

Returns current value of Calling Address Subaddress Type of Number.

RDCCH:

CALLING:

SUBaddress:

ADDRess n.m

[MSS:RDCCH:CALLING:SUBaddress:ADDRess]

Specifies Calling Address Subaddress (m) selected by n. Range of n is 0 to 19; range of m is 0 to 255.

ADDRess? n

Returns current value of Calling Address Subaddress selected by n. Range of n is 0 to 19.

SUBaddress:

LENGth n

[MSS:RDCCH:SUBaddress:LENGth]

Specifies Subaddress Length. Range of n is 1 to 21.

LENGth?

Returns current value of Subaddress Length.

ODD EVEN n

[MSS:RDCCH:SUBaddress:ODD_EVEN]

Enables (n = 1) or disables (n = 0) Subaddress Odd/Even indicator.

ODD_EVEN?

Returns current state of Subaddress Odd/Even indicator.

TYPE n

[MSS:RDCCH:SUBaddress:TYPE]

Specifies Type of subaddress. Range of n is 0 to 3.

TYPE?

Returns current value of Type of subaddress.

ADDRess n.m

[MSS:RDCCH:SUBaddress:ADDRess]

Specifies Subaddress (m) selected by n. Range of n is 0 to 19; range of m is 0 to 255.

ADDRess? n

Returns current value of Subaddress selected by n. Range of n is 0 to 19.

RDCCH:

RTRANSaction n

[MSS:RDCCH:RTRANSaction]

Specifies R-Transaction Identifier. Range of n is 0 to 255.

RTRANSaction?

Returns current value of R-Transaction Identifier.

RDATA UNIT:

LENGth n

[MSS:RDCCH:RDATA_UNIT:LENGth]

Specifies R-Data Unit Length Indicator. Range of n is 0 to 255.

LENGth?

Returns current value of R-Data Unit Length Indicator.

HLP:

IDentifier n

[MSS:RDCCH:RDATA_UNIT:HLP:IDentifier]

Specifies R-Data Unit Higher Protocol Identifier. Range of n is 0 to 255.

IDentifier?

Returns current value of R-Data Unit Higher Protocol Identifier.

DATA m,n

[MSS:RDCCH:RDATA_UNIT:HLP:DATA]

Specifies R-Data Higher Layer Protocol Data Unit (n) selected by m. Range of m is 0 to 255; range of n is 0 to 255.

DATA? n

Returns current value of Higher Layer Protocol Data Unit selected by n. Range of n is 0 to 255.

RCAUSE n

[MSS:RDCCH:RCAUSE]

Specifies R-CAUSE. Range of n is 0 to 127.

RCAUSE?

Returns current value of R-CAUSE.

RDCCH:

MESSage:

CENTer:

ADDRess "n"

[MSS:RDCCH:MESSage:CENTer:ADDRess]
Specifies Message Center Address (ASCII String).

ADDRess?

Returns current ASCII string value of Message Center Address.

ADDRess:

ENCoding n

[MSS:RDCCH:MESSage:CENTer:ADDRess:ENCoding]

Enables (n = 1) or disables (n = 0) Message Center Address Encoding.

ENCoding?

Returns current state of Message Center Address Encoding.

PLANID n

[MSS:RDCCH:MESSage:CENTer:PLANid]

Specifies Message Center Identification Plan. Range of n is 0 to 15.

PLANId?

Returns current value of Message Center Identification Plan.

TYPE /

[MSS:RDCCH:MESSage:CENTer:TYPE]

Specifies Message Center Type of Number. Range of n is 0 to 7.

TYPE?

Returns current value of Message Center Type of Number.

USER:

GROUP:

STATus n

[MSS:RDCCH:USER:GROUP:STATus]

Specifies User Group Status. Range of n is 0 to 3.

STATus?

Returns current value of User Group Status.

RDCCH:

USER:

GROUP:

TYPE n

[MSS:RDCCH:USER:GROUP:TYPE]
Specifies User Group Type. Range of n is 0 to 3.

TYPE?

Returns current value of User Group Type.

UGID:

MS n

[MSS:RDCCH:USER:GROUP:UGID:MS]

Specifies the 18 most significant bits of User Group ID. Range of n is 0 to #h3FFFF.

MS?

Returns the 18 most significant bits of User Group ID.

LS n

[MSS:RDCCH:USER:GROUP:UGID:LS]

Specifies the 32 least significant bits of User Group ID. Range of n is 0 to #hffffff.

LS?

Returns the 32 least significant bits of User Group ID.

MIN "n"

[MSS:RDCCH:USER:MIN]

If the User Group type is 2, signifying a 34-bit UGID, then this command sets up the User Group ID with a Mobile Identification Number.

Specifies MIN (ASCII String).

MIN?

Returns current string value of MIN.

DEST:

ADDRess "n"

[MSS:RDCCH:DEST:ADDRess]

Specifies User Destination Address (ASCII String).

ADDRess?

Returns current string value of User Destination Address.

RDCCH:

DEST:

ADDRess:

ENCoding n

[MSS:RDCCH:DEST:ADDRess:ENCoding]

Enables (n = 1) or disables (n = 0) User Destination Address Encoding.

ENCoding?

Returns current state of User Destination Address Encoding.

PLANId n

[MSS:RDCCH:DEST:PLANId]

Specifies User Destination Identification Plan. Range of n is 0 to 15.

PLANId?

Returns current value of the User Destination Identification Plan.

TYPE n

[MSS:RDCCH:DEST:TYPE]

Specifies User Destination Type of Number. Range of n is 0 to 7.

TYPE?

Returns current value of User Destination Type of Number.

SUBaddress:

LENGth n

[MSS:RDCCH:DEST:SUBaddress:LENGth]

Specifies User Destination Subaddress Length. Range of n is 1 to 21.

LENGth?

Returns current value of User Destination Subaddress Length.

ODD_EVEN n

[MSS:RDCCH:DEST:SUBaddress:ODD_EVEN]

Enables (n = 1) or disables (n = 0) User Destination Subaddress Odd/Even indicator.

ODD EVEN?

Returns current state of User Destination Subaddress Odd/Even indicator.

TYPE n

[MSS:RDCCH:DEST:SUBaddress:TYPE]

Specifies User Destination Subaddress Type of Number. Range of n is 0 to 3.

TYPE?

Returns current value of User Destination Type of Number.

RDCCH:

DEST:

SUBaddress:

ADDRess n,m

[MSS:RDCCH:DEST:SUBaddress:ADDRess]

Specifies User Destination Subaddress (m) selected by n. Range of n is 0 to 19; range of m is 0 to 255.

ADDRess? n

Returns current value of User Destination Subaddress selected by n. Range of n is 0 to 19.

ORIG:

ADDRess "n"

[MSS:RDCCH:ORIG:ADDRess]

Specifies User Originating Address (ASCII String).

ADDRess?

Returns current string value of User Originating Address.

ADDRess:

ENCoding n

[MSS:RDCCH:ORIG:ADDRess:ENCoding]

Enables (n = 1) or disables (n = 0) User Originating Address Encoding.

ENCoding?

Returns current state of User Originating Address Encoding.

PLANId n

[MSS:RDCCH:ORIG:PLANId]

Specifies User Originating Identification Plan. Range of n is 0 to 15.

PLANId?

Returns current value of User Originating Identification Plan.

TYPE n

[MSS:RDCCH:ORIG:TYPE]

Specifies User Originating Type of Number. Range of n is 0 to 7.

TYPE?

Returns current value of User Originating Type of Number.

RDCCH:

ORIG:

SUBaddress:

LENGth n

[MSS:RDCCH:ORIG:SUBaddress:LENGth]

Specifies User Originating Subaddress Length. Range of n is 1 to 21.

LENGth?

Returns current value of User Originating Subaddress Length.

ODD EVEN n

[MSS:RDCCH:ORIG:SUBaddress:ODD_EVEN]

Enables (n = 1) or disables (n = 0) User Originating Subaddress Odd/Even indicator.

ODD EVEN?

Returns current state of User Originating Subaddress Odd/Even indicator.

TYPE n

[MSS:RDCCH:ORIG:SUBaddress:TYPE]

Specifies User Originating Subaddress Type of Number. Range of n is 0 to 3.

TYPE?

Returns current value of User Originating Subaddress Type of Number.

ADDRess n.m

[MSS:RDCCH:ORIG:SUBaddress:ADDRess]

Specifies User Originating Subaddress (m) selected by n. Range of n is 0 to 19; range of m is 0 to 255.

ADDRess? n

Returns current value of User Originating Subaddress selected by n. Range of n is 0 to 19.

REG:

TYPE n

[MSS:RDCCH:REG:TYPE]

Specifies Registration Type. Range of n is 0 to 15.

TYPE?

Returns current value of Registration Type.

RDCCH:

CNUMber:

ADDRess "n"

[MSS:RDCCH:CNUMber:ADDRess]
Specifies C-Number Address (ASCII String).

ADDRess?

Returns current string value of C-Number Address.

ADDRess:

ENCoding n

[MSS:RDCCH:CNUMber:ADDRess:ENCoding] Enables (n = 1) or disables (n = 0) C-Number Address Encoding.

ENCoding?

Returns current state of the C-Number Address Encoding.

PLANId n

[MSS:RDCCH:CNUMber:PLANId]

Specifies C-Number Identification Plan. Range of n is 0 to 15.

PLANId?

Returns current value of the C-Number Identification Plan.

TYPE a

[MSS:RDCCH:CNUMber:TYPE]

Specifies C-Number Type of Number. Range of n is 0 to 7.

TYPE?

Returns current value of the C-Number Type of Number.

PFC:

REQuest n

[MSS:RDCCH:PFC:REQuest]

Specifies Paging Frame Class Request. Range of n is 0 to 7.

REQuest?

Returns current value of Paging Frame Class Request.

DCCH_MEM:

ALGORIthm n

[MSS:RDCCH:DCCH_MEM:ALGORithm]

Specifies DCCH Message Encryption Algorithm. Range of n is 0 to 7.

ALGORithm?

Returns current value of the DCCH Message Encryption Algorithm

RDCCH:

DCCH_MEM:

DOMAIN n

[MSS:RDCCH:DCCH_MEM:DOMAIN]

Specifies DCCH Message Encryption Domain. Range of n is 0 to 7.

DOMAIN?

Returns current value of DCCH Message Encryption Domain.

KEY n

[MSS:RDCCH:DCCH_MEM:KEY]

Specifies DCCH Message Encryption Key. Range of *n* is 0 to 7.

KEY?

Returns current value of DCCH Message Encryption Key.

ESN n

[MSS:RDCCH:ESN]

Specifies Electronic Serial Number. Range of n is 0 to #hFFFFFFF.

FSN2

Returns current value of Electronic Serial Number.

SOC n

[MSS:RDCCH:SOC]

Specifies SOC. Range of n is 0 to 4095.

SOC?

Returns current value of SOC.

CUSTom:

LENGth n

[MSS:RDCCH:DCCH:CUSTom:LENGth]

Specifies Custom Control Length. Range of n is 1 to 253.

LENGth?

Returns current value of Custom Control Length.

CONTrol n.x

[MSS:RDCCH:DCCH:CUSTom:CONTrol]

Specifies Custom Control byte (x) selected by n. Range of n is 0 to 252; range of x is 0 to 255.

CONTrol? n

Returns current byte value of Custom Control selected by n. Range of n is 0 to 252.

RDCCH:

CONFirmed:

MSGtype n
[MSS:RDCCH:CONFirmed:MSGtype]
Specifies Confirmed Message Type. Range of n is 0 to 63.

MSGtype?

Returns current value of Confirmed Message Type.

SSDUP:

STATus n

[MSS:RDCCH:SSDUP:STATus] Specifies SSD Update Status. Range of n is 0 to 3.

STATus?

Returns current value of SSD Update Status.

AUTHU n

[MSS:RDCCH:AUTHU]
Specifies AUTHU. Range of n is 0 to #h3FFFF.

AUTHU?

Returns current value of AUTHU.

D. Optional Data Fields

Some of the elements of RACH messages are optional. Optional elements can be enabled or disabled by the following commands.

MSS:

RDCCH:

ENABle:

PSID_RSID:

SELect n

[MSS:RDCCH:ENABLe:PSID_RSID:SELect]

Enables (n = 1) or disables (n = 0) Selected PSID/RSID.

SELect?

Returns current state of Selected PSID/RSID.

DISPlay n

[MSS:RDCCH:ENABLe:DISPlay]

Enables (n = 1) or disables (n = 0) Display.

DISPlay?

Returns current state of Display.

MEASurement:

LTM n

[MSS:RDCCH:ENABLe:MEASurement:LTM]

Enables (n = 1) or disables (n = 0) LTM Measurement.

LTM?

Returns current state of LTM Measurement.

STM n

[MSS:RDCCH:ENABLe:MEASurement:STM]

Enables (n = 1) or disables (n = 0) STM Measurement.

STM?

Returns current state of STM Measurement.

RDCCH:

ENABle:

MODE:

VOICe n

[MSS:RDCCH:ENABLe:MODE:VOICe] Enables (n = 1) or disables (n = 0) Voice Mode.

VOICe?

Returns current state of Voice Mode.

DATA n

[MSS:RDCCH:ENABLe:MODE:DATA] Enables (n = 1) or disables (n = 0) Data Mode.

DATA?

Returns current state of Data Mode.

MEM n

[MSS:RDCCH:ENABLe:MEM]

Enables (n = 1) or disables (n = 0) Message Encryption Mode.

MEM?

Returns current state of Message Encryption Mode.

BANDWidth n

[MSS:RDCCH:ENABLe:BANDWidth]

Enables (n = 1) or disables (n = 0) Bandwidth.

BANDWidth?

Returns current state of Bandwidth.

CALLING:

PRESentation n

[MSS:RDCCH:ENABLe:CALLING:PRESentation]

Enables (n = 1) or disables (n = 0) Calling Party Number Presentation Indicator.

PRESentation?

Returns current state of Calling Party Number Presentation Indicator.

ADDRess n

[MSS:RDCCH:ENABLe:CALLING:ADDRess]

Enables (n = 1) or disables (n = 0) Calling Party Number.

ADDRess?

Returns current state of Calling Party Number.

RDCCH:

ENABle:

CALLING:

SUBaddress n

[MSS:RDCCH:ENABLe:CALLING:SUBaddress]

Enables (n = 1) or disables (n = 0) Calling Party Subaddress.

SUBaddress?

Returns current state of Calling Party Subaddress.

CALLED:

SUBaddress n

[MSS:RDCCH:ENABLe:CALLED:SUBaddress]

Enables (n = 1) or disables (n = 0) Called Party Subaddress.

SUBaddress?

Returns current state of Called Party Subaddress.

SUBaddress n

[MSS:RDCCH:ENABLe:SUBaddress]

Enables (n = 1) or disables (n = 0) Subaddress.

SUBaddress?

Returns current state of Subaddress.

MESSage:

CENTer:

ADDRess n

[MSS:RDCCH:ENABLe:MESSage:CENTer:ADDRess]

Enables (n = 1) or disables (n = 0) Message Center Address.

ADDRess?

Returns current state of Message Center Address.

USER:

GROUP n

[MSS:RDCCH:ENABLe:USER:GROUP]

Enables (n = 1) or disables (n = 0) User Group.

GROUP?

Returns current state of User Group.

RDCCH:

ENABle:

USER:

DEST:

ADDRess n

[MSS:RDCCH:ENABLe:USER:DEST:ADDRess] Enables (n = 1) or disables (n = 0) User Destination Address.

ADDRess?

Returns current state of User Destination Address.

SUBaddress n

[MSS:RDCCH:ENABLe:USER:DEST:SUBaddress]

Enables (n = 1) or disables (n = 0) User Destination Subaddress.

SUBaddress?

Returns current state of User Destination Subaddress.

ORIG:

ADDRess n

[MSS:RDCCH:ENABLe:USER:ORIG:ADDRess] Enables (n = 1) or disables (n = 0) User Originating Address.

ADDRess?

Returns current state of User Originating Address.

SUBADDRess n

[MSS:RDCCH:ENABLe:USER:ORIG:SUBaddress]

Enables (n = 1) or disables (n = 0) User Originating Subaddress.

SUBADDRess?

Returns current state of User Originating Subaddress.

CNUMber n

[MSS:RDCCH:ENABLe:CNUMber]

Enables (n = 1) or disables (n = 0) C-Number.

CNUMber?

Returns current state of C-Number field.

RDCCH:

ENABle:

PFC:

REQuest n

[MSS:RDCCH:ENABLe:PFC:REQuest] Enables (n = 1) or disables (n = 0) PFC Request.

REQuest?

Returns current state of PFC Request.

DCCH:

MEM n

[MSS:RDCCH:ENABLe:DCCH:MEM] Enables (n = 1) or disables (n = 0) DCCH MEM.

MEM?

Returns current state of DCCH MEM.

E. Building a RACH message

MSS:

RDCCH:

BUILD

[MSS:RDCCH:BUILD]

Builds the data that makes up a RACH message.

Before executing this command, the message types and data fields that make up the RACH should be programmed. This command then takes the message types and data fields and generates all the data that makes up the data field in each slot of the RACH message.

After executing this command, the data can returned by the MSS:RDCCH:DATA? command defined below. The RACH message generator can then be programmed with the MSS:RDCCH:PROGRAM command defined below.

LENGth?

[MSS:RDCCH:LENGth]

Returns Length of the RDCCH in number of slots.

Use this command after the build command (MSS:RDCCH:BUILD) has been executed.

DATA? n.m

[MSS:RDCCH:DATA]

Returns RDCCH data that has been built.

Returns current 16 bit value of selected word (m) in selected slot (n). Range of n is 0 to 319; range of m is 0 to 6.

The length of each slot is 101 bits (normal) or 79 bits (abbreviated) long. The data in each slot may returned, 16 bits at a time. The data bits in each word are left justified. The 16 most significant bits of the data are returned when m=0. If the message is normal length, the 5 least significant bits of data are returned when m=6. If the message is abbreviated length, then the 15 least significant bits of data are returned when m=4.

This data format correlates with the data format used in the MSS:RDCCH:MESSAGE:DATA command. Therefore, the data in the message can be programmed by transferring the data, one word at a time, to the message generator. This enables the user to modify the data (i.e. scramble data, repeat a frame, change the CI bit) before programming the message generator. If a straight transfer of data is desired, then use the MSS:RDCCH:PROGRAM command. If that command is not used, then set the length of the message with the MSS:RDCCH: LENGTH? command.

RDCCH:

PROGram

[MSS:RDCCH:PROGram]

Programs the RACH Message Generator with the data constructed by the MSS:RDCCH:BUILD command.

This command automatically determines the length of the RACH message built and overwrites the any length that may have been established by the MSS:RDCCH:MESSAGE:LENGTH command.

The RACH message is not sent with this command, but is sent with the MSS:RDCCH:MESSAGE:SEND command.

7-14-6 BASE STATION PERFORMANCE

The following are miscellaneous commands that are useful for testing the performance of a base station.

Share Channel Feedback

The Share Channel Feedback field is used to control access on the RACH. The following commands returns the state of the SCF flags when an access occurs.

MSS:

SCF?

[MSS:SCF]

Returns current value of the Shared Channel Feedback from the RACH subchannel (22 bit value).

SCF:

RN?

[MSS:SCF:RN]

Returns current value of Receive/Not Received in the Shared Channel Feedback from the RACH subchannel (5 bit value).

CPE?

[MSS:SCF:CPE]

Returns current value of Coded Partial Echo in the Shared Channel Feedback from the RACH subchannel (11 bit value).

BRI?

[MSS:SCF:BRI]

Returns current value of Busy/Reserved/Idle in the Shared Channel Feedback from the RACH subchannel (6 bit value).

Coded Superframe Phase

The Coded Superframe Phase is used to indicate which phase of the superframe is currently being transmitted. It may be useful to know the phase of the superframe associated with the RACH subchannel.

MSS:

CSFP?

[MSS:CSFP]

Returns current value of Coded Superframe Phase associated with the RACH subchannel (12 bit value).

Response

The Base station is required to respond to some of the RACHs. This command provides the time of the response.

MSS:

RESPONSE?

[MSS:RESPONSE]

Returns the Base station response time (in milliseconds) to a RACH requiring a response.

7-15 FDCCH DATA MONITOR

This section contains the TMAC commands to monitor the FDCCH. The FDCCH Data Monitor consists of the TMAC commands necessary to monitor the Forward Digital Control Channel.

7-15-1 SETUP COMMANDS

The FDCCH Setup commands configure the FM/AM-1600CSA to receive and decode data on the FDCCH.

FDCCH:

SETup

[FDCCH:SETup]

Configures the FM/AM-1600CSA to receive on the FDCCH.

This command also sets the FM/AM-1600S to receive through the Antenna Connector.

CHANnel n

[FDCCH:CHANnel]

Selects the Forward channel to monitor. Range of n is 1 to 1023.

SLOT n

[FDCCH:SLOT]

Selects the full or half rate SLOT on which to receive. Range of n is 1 to 3.

SLOT?

Returns current value of Slot.

CHANnel n

[FDCCH:CHANnel]

Selects the Forward channel to monitor. Range of n is 1 to 1023.

CHANnel?

Returns current value of Channel.

RATE n

[FDCCH:RATE]

Selects TDMA transmission rate: Full (n = 0) or Half (n = 1).

RATE?

Return current setting of Rate.

DVCC n

[FDCCH:DVCC]

Specifies Digital Verification Color Code. Range of n is 0 to 255.

DVCC?

Returns current value of DVCC.

7-15-2 CONTINUOUS REMOTE RAW TIMESLOT DATA

The following commands Start or Stop the transmission of data received in an IS-136 DCCH timeslot out the RS-232 Connector and specify whether or not a Sync word is included. The data is retransmitted exactly as received without being de-interleaved, corrected for errors or formatted.

Before entering this mode of operation, the baud rate should be set 57600 (for the FM/AM-1600CSA and remote terminal). Each Timeslot consists of 324 bits, which corresponds to 81 ASCII characters when displayed in hexadecimal. The 81 characters representing each. Timeslot is separated by a newline character. If less than 80 characters/line is desirable, the sync portion of the data may be omitted (sync portion of data is redundant), reducing the bit count to 296 and the character count to 74. An extra character preceding the data indicates the Timeslot (75 total characters).

FDCCH:

REMote:

TIMEslot:

STAR

[FDCCH:REMote:TIMEslot:STARt]

Starts sending the received Timeslot data out the RS-232 Connector.

STOP

[FDCCH:REMote:TIMEslot:STOP]

Stops sending the received Timeslot data out the RS-232 Connector.

SYNC n

[FDCCH:REMote:TIMEslot:SYNC]

Enables (n = 1) or disables (n = 0) sync word.

Directs that Sync word be transmitted with the data out the RS-232 Connector.

7-15-3 CONTINUOUS REMOTE RAW DATA

This mode differs from Section 7-15-2. This mode de-interleaves the data and performs forward error correction before presenting the data. Only slots that contain a valid CRC are displayed. The Timeslot is broken up into the various data fields and continuously transmitted out the RS-232 Connector. Following the data is a millisecond time stamp which provides relative time between slots of data.

The data is presented in hexadecimal out the RS-232 Connector with each frame of data being separated by a newline character. The data is formatted as follows:

- The first 7 characters represent the 28 bits of the SYNC word.
- The next 3 characters are the hexadecimal value of the 12 bits of the Coded Superframe Phase (CSFP).
- The next 6 characters are the hexadecimal value (left justified) of the 22 bits of the Shared Channel Feedback (SCF).
- The next 32 characters are the hexadecimal value (left justified) of the 125 bits of data.
- The data is followed by a CRC check flag, 1 = good, 0 = bad.
- The flag is followed by a millisecond time stamp.

The following TMAC commands are used to start and stop this operation.

FDCCH:

REMote:

RAW:

STAR

[FDCCH:REMote:RAW:STARt]

Starts sending the received, de-interleaved and decoded data out RS-232 Connector.

STOP

[FDCCH:REMote:RAW:STOP]

Stops sending the received data out RS-232 Connector.

DVCC n

[FDCCH:REMote:RAW:DVCC]

Specifies Digital Verification Color Code. Range of n is 1 to 255.

A DVCC, which is used when calculating the CRC, must be specified to decode the message.

An embedded macro named FRAW initiates the START when executed and sends a STOP when any key on the RS-232 terminal is pressed. To use this macro, type in the command FRAW at the RS-232 terminal.

7-15-4 BUFFERED RAW DATA

The FDCCH Raw Data commands consist of the TMAC commands used for Layer 1 raw data buffering. Up to 100 frames of raw data can be captured. (Similar to FOCC raw data TMAC commands.) The following commands are used for this operation.

FDCCH:

RAW:

STARE

[FDCCH:RAW:STARt]

Starts capturing raw data on FDCCH.

STOP

[FDCCH:RAW:STOP]

Stops capturing raw data on FDCCH.

STOP occurs automatically when the buffer is full.

FULL?

[FDCCH:RAW:FULL?]

Returns current state of raw buffer: 1 = full, 0 = not full.

SYNC? n

[FDCCH:RAW:SYNC?]

Returns current value of Sync word (22 bit value) in selected raw data frame (n). Range of n is 0 to 99.

SCF? n

[FDCCH:RAW:SCF?]

Returns current value of Shared Channel Feedback (22 bit value) in selected raw data frame. Range of n is 0 to 99.

CSFP? n

[FDCCH:RAW:CSFP?]

Returns the Coded Super Frame Phase (12 bit value) in the selected raw data frame (n). Range of n is 0 to 99.

DATA? n,x

[FDCCH:RAW:DATA?]

Returns the 16 bit value of the selected raw data byte (x) in the selected raw data frame (n). Range of n is 0 to 99; range of x is 0 to 15.

TS? n

[FDCCH:RAW:TS?]

Returns the Time Stamp (in milliseconds) (32 bit value) of selected raw data frame (n). Range of n is 0 to 99.

7-15-5 LAYER 2 DATA MONITOR

The FDCCH Layer 2 Data Monitor consists of the TMAC commands necessary to decode a Layer 2 message. Up to 100 frames can be captured into a buffer for non real-time decoding into Layer 2 data fields.

The process of decoding FDCCH data into Layer 2 consists of two steps:

- 1. Use the FDCCH Buffered Raw Data commands defined in Section 7-15-4 to capture 100 words into the raw data buffer.
- 2. Select one frame of raw data from the Raw Buffer and decode the frame into Layer 2 fields.

FDCCH:

LAYER2:

DECode n

[FDCCH:LAYER2:DECode]

Decodes the frame of data in selected raw buffer (n). Range of n is 0 to 99.

TYPE?

[FDCCH:LAYER2:TYPE]

Returns value of the type of data in the frame that had been previously decoded.

VALUE	TYPE
1	F-BCCH
2	E-BCCH
3	SPACH
4	S-BCCH
5	RESERVED

The specific commands used to access the Layer 2 data fields are determined by the TYPE of data.

The following commands are used to access the Layer 2 data fields when TYPE of data is FBCCH.

FDCCH:

LAYER2:

FBCCH:

BC?

[FDCCH:LAYER2:FBCCH:BC]

Returns current state of Begin/Continue (1 bit value). Returns -1 if not available.

B1? n

[FDCCH:LAYER2:FBCCH:BI]

Returns current state of Begin Indicator (1 bit value) selected by n. Returns -1 if not available. The range of n is 0 to 3.

A Begin Indicator may follow any of the four Layer 3 data fields.

CLI?

[FDCCH:LAYER2:FBCCH:CLI]

Returns current value of Continuation Length Indicator (7 bit value). Returns -1 if not available.

CLI indicates length of first block of Layer 3 data in a continuation frame.

CRC?

[FDCCH:LAYER2:FBCCH:CRC]

Returns current value of Cyclic Redundancy Code (16 bit value). Returns -1 if not available.

EC?

[FDCCH:LAYER2:FBCCH:EC]

Returns current state of E-BCCH Change (1 bit value). Returns -1 if not available.

FC?

[FDCCH:LAYER2:FBCCH:FC]

Returns current state of F-BCCH Change (1 bit value). Returns -1 if not available.

L3DATA? n,x

[FDCCH:LAYER2:FBCCH:L3DATA]

Returns the 8 bit value of the selected byte (x) of the selected Layer 3 data message (n). Returns -1 if not available. Range of n is 0 to 3; range of x is 0 to 15.

The number of Layer 3 data messages embedded within a Layer 2 frame can be anywhere from a portion of single data message to 4 full data messages. The maximum number of bytes in a Layer 2 frame is 16 bytes.

The L3LI and CLI may be used to determine the number of 8 bit "words" in a Layer 3 message.

LAYER2:

FBCCH:

L3LI? n

[FDCCH:LAYER2:FBCCH:L3L1]

Returns one of four Layer 3 Length Indicators (8 bit value). Returns -1 if not available. Range of n is 0 to 3.

If returned from a continuation frame, the range of n is 1 to 3 because the length of the first block of Layer 3 data is specified by CLI.

The following commands are used to access the Layer 2 data fields when TYPE of data is E-BCCH.

FDCCH:

LAYER2:

EBCCH:

BC?

[FDCCH:LAYER2:EBCCH:BC]

Returns current state of Begin/Continue (1 bit value). Returns -1 if not available.

BI? n

[FDCCH:LAYER2:EBCCH:BI]

Returns current state of Begin Indicator (1 bit value) selected by n. Returns -1 if not available. The range of n is 0 to 3.

A Begin Indicator may follow any of the four Layer 3 data fields.

CLI?

[FDCCH:LAYER2:EBCCH:CLI]

Returns current value of Continuation Length Indicator (7 bit value). Returns -1 if not available.

CLI specifies length of first block of Layer 3 data in a continuation frame.

CRC?

[FDCCH:LAYER2:EBCCH:CRC]

Returns current value of Cyclic Redundancy Code (16 bit value). Returns -1 if not available.

ECL?

[FDCCH:LAYER2:EBCCH:ECL]

Returns current value of E-BCCH Cycle Length (8 bit value). Returns -1 if not available.

L3DATA? n, x

[FDCCH:LAYER2:EBCCH:L3DATA]

Returns the 8 bit value of the selected byte (x) of the selected Layer 3 data message (n). Returns -1 if not available. Range of n is 0 to 3; range of x is 0 to 15.

The number of Layer 3 data messages embedded within a Layer 2 frame can be anywhere from a portion of single data message to 4 full data messages. The maximum number of bytes in a Layer 2 frame is 16 bytes. The data returned is left justified.

The L3LI and CLI may be used to determine the number of 8 bit "words" in a Layer 3 message.

LAYER2:

EBCCH:

L3LI? n

[FDCCH:LAYER2:EBCCH:L3LI]

Returns one of four Layer 3 Length Indicators (8 bit value). Returns -1 if not available. Range of n is 0 to 3.

If returned from a continuation frame, the range of n is 1 to 3 because the length of the first block of Layer 3 data is specified by CLI.

RSVD?

[FDCCH:LAYER2:EBCCH:RSVD]

Returns current state of E-BCCH Layer 2 Reserved (1 bit value). Returns -1 if not available.

The following commands are used to access the Layer 2 data fields when TYPE of data is SPACH:

FDCCH:

LAYER2:

SPACH:

ARM?

[FDCCH:LAYER2:SPACH:ARM]

Returns current state of ARQ Response Mode (1 bit value). Returns -1 if not available.

ARQ RSVD?

[FDCCH:LAYER2:SPACH:ARQ_RSVD]

Returns current value of ARQ Layer 2 frame RSVD (2 bit value). Returns -1 if not available.

BCN?

[FDCCH:LAYER2:SPACH:BCN]

Returns current state of BCCH Change Notification (1 bit value). Returns -1 if not available.

BT?

[FDCCH:LAYER2:SPACH:BT]

Returns current value of Burst Type (3 bit value). Returns -1 if not available.

B112

[FDCCH:LAYER2:SPACH:BU]

Returns current value of Burst Usage (3 bit value). Returns -1 if not available.

CRC?

[FDCCH:LAYER2:SPACH:CRC]

Returns current value of Cyclic Redundancy Code (16 bit value). Returns -1 if not available.

EH_RSVD?

[FDCCH:LAYER2:SPACH:EH_RSVD]

Returns current state of Extended Header RSVD (1 bit value). Returns -1 if not available.

FRNO?

[FDCCH:LAYER2:SPACH:FRNO]

Returns current value of Frame Number (5 bit value). Returns -1 if not available.

GA?

[FDCCH:LAYER2:SPACH:GA]

Returns current state of Go Away (1 bit value). Returns -1 if not available.

LAYER2:

SPACH:

HA RSVD?

[FDCCH:LAYER2:SPACH:HA_RSVD]

Returns SPACH Header A_RSVD field setting (1 bit value). Returns -1 if not available.

IDT?

[FDCCH:LAYER2:SPACH:IDT]

Returns current value of Identity Type (2 bit value). Returns -1 if not available.

L3DATA? n,x

[FDCCH:LAYER2:SPACH:L3DATA]

Returns the 8 bit value of the selected byte (x) of the selected Layer 3 Data message (n). Returns -1 if not available. Range of n is 0 to 3; range of x is 0 to 15.

The number of Layer 3 data messages embedded within a Layer 2 frame can be just a portion of a single data message on up to 4 full data messages. The maximum number of bytes in a Layer 2 frame is 16 bytes. The data returned is left justified.

The L3LENGTH command may be used to determine how many 8 bit "words" make up the Layer 3 data field in the frame currently being decoded.

L3LENGTH? n

[FDCCH:LAYER2:SPACH:L3LENGTH]

Returns current value of Layer 3 data field length (8 bit value) selected by n. Returns -1 if not available. Range of n is 0 to 3.

This is the length of the Layer 3 data field in the SPACH Layer 2 frame currently being decoded.

This is necessary because the L3LIs are all contained in the first frame of a multiframe SPACH message and subsequent frames do not have the information specifying the length of the Layer 3 data field.

L3LI? n

[FDCCH:LAYER2:SPACH:L3LI]

Returns current value of Layer 3 Length Indicator (8 bit value) selected by n. Returns -1 if not available. Range of n is 0 to 3.

A SPACH Layer 2 frame may contain up to four Layer 3 Length Indicators.

MEA?

[FDCCH:LAYER2:SPACH:MEA]

Returns current value of Message Encryption Mode (2 bit value). Returns -1 if not available.

LAYER2:

SPACH:

MEK?

[FDCCH:LAYER2:SPACH:MEK]

Returns current value of Message Encryption Key (2 bit value). Returns -1 if not available.

MM?

[FDCCH:LAYER2:SPACH:MM]

Returns current state of Message Mapping (1 bit value). Returns -1 if not available.

MSID:

LS? n

[FDCCH:LAYER2:SPACH:MSID:LS]

Returns the 32 Least Significant bits of Mobile Station Identification selected by n. Range of n is 0 to 4.

MS? n

[FDCCH:LAYER2:SPACH:MSID:MS]

Returns the 18 Most Significant bits of Mobile Station Identification selected by n. Range of n is 0 to 4.

MSID? n,x

[FDCCH:LAYER2:SPACH:MSID]

Returns the 8 bit value of selected byte (x) of the selected Mobile Station Identity (n). Returns -1 if not available. Range of n is 0 to 4; range of x is 0 to 2, 4 or 6.

A Layer 2 frame may contain up to 5 mobile station identities. Each MSID is 20, 24, 34 or 50 bits long and is accessed 8 bits at a time with this command. The data returned is left justified.

PCON?

[FDCCH:LAYER2:SPACH:PCON]

Returns current state of PCH Continuation (1 bit value). Returns -1 if not available.

PEA?

[FDCCH:LAYER2:SPACH:PEA]

Returns current value of Partial Echo Assigned (7 bit value). Returns -1 if not available.

PFM?

[FDCCH:LAYER2:SPACH:PFM]

Returns current state of Paging Frame Modifier (1 bit value). Returns -1 if not available.

PI?

[FDCCH:LAYER2:SPACH:PI]

Returns current state of Polling Indicator (1 bit value). Returns -1 if not available.

LAYER2:

SPACH:

SRM?

[FDCCH:LAYER2:SPACH:SRM]

Returns current state of SPACH Response Mode (1 bit value). Returns -1 if not available.

UGID:

LS?

[FDCCH:LAYER2:SPACH:UGID:LS]

Returns the 32 Least Significant bits of User Group Identification.

MS?

[FDCCH:LAYER2:SPACH:UGID:MS]

Returns the 18 Most Significant bits of User Group Identification.

UGID? n.x

[FDCCH:LAYER2:SPACH:UGID]

Returns the 8 bit value of the selected byte (x) of the selected User Group Identity (n). Returns -1 if not available. Range of n is 0 to 4; range of x is 0 to 2, 4 or 6.

Each UGID is 20, 24, 34 or 50 bits long and is accessed 8 bits at a time with this command. The data returned is left justified.

7-15-6 L2 FILTERS

The Layer 2 filters enable the user to only buffer Layer 2 frames from a specific logical channel, logical SPACH channel, PCH subchannel, etc. One or more of the filters are selectable by the user.

7-15-7 FDCCH REAL TIME DATA MONITOR

In this mode of operation, the data return is the last data decoded for that data field. Once a data field item is returned, -1 is returned until a new value for that data field is decoded.

A. Layer 1 Data

With the exception of the first two, the following TMAC commands return the data fields defined on the physical layer.

FDCCH:

STAR

[FDCCH:STARt]

Starts decoding the FDCCH.

STOP

[FDCCH:STOP]

Stops decoding the FDCCH.

SYNC?

[FDCCH:SYNC]

Returns the value of the last decoded sync word (28 bit value). Returns -1 if already returned or not available.

CSFP?

[FDCCH:CSFP]

Returns the value of the last decoded Coded Super Frame Phase (12 bit value). Returns -1 if already returned or not available.

SCF?

[FDCCH:SCF]

Returns the value of the last decoded Share Channel Feedback (22 bit value). Returns -1 if already returned or not available.

BRI?

[FDCCH:BRI]

Returns the value of the last decoded Busy/Reserved/Idle (6 bit value). Returns -1 if already returned or not available.

R N?

[FDCCH:R_N]

Returns the value of the last decoded Received/Not received (5 bit value). Returns -1 if already returned or not available.

CPE?

[FDCCH:CPE]

Returns the value of the last decoded Coded Partial Echo (11 bit value). Returns -1 if already returned or not available.

TYPE?

[FDCCH:TYPE]

Returns value of the type of data of the last decoded frame. Returns -1 if already returned or not available. This command returns the following:

VALUE	TYPE
1	F-BCCH
2	E-BCCH
3	SPACH
4	S-BCCH
5	RESERVED

CRC?

[FDCCH:CRC]

Returns the value of the last decoded CRC (16 bit value). Returns -1 if already returned or not available.

B. F-BCCH Frames

The next set of commands return data from the F-BCCH frames.

FDCCH:

FBCCH:

BC?

[FDCCH:FBCCH:BC?]

Returns the last decoded value of Begin/Continue (1 bit value). Returns -1 if already returned or not available.

FC?

[FDGCH:FBGCH:FC?]

Returns the last decoded value of F-BCCH Change (1 bit value). Returns -1 if already returned or not available.

EC?

[FDCCH:FBCCH:EC?]

Returns the last decoded value of E-BCCH Change (1 bit value). Returns-1 if already returned or not available.

CLI?

[FDCCH:FBCCH:CLI?]

Returns the last decoded value of Continuation Length Indicator (7 bit value). Returns -1 if already returned or not available.

L3LI7

[FDCCH:FBCCH:L3L1?]

Returns the last decoded value of Layer 3 Length Indicator (8 bit value). Returns -1 if already returned or not available.

BI?

[FDCCH:FBCCH:BI?]

Returns the last decoded value of Begin Indicator (1 bit value). Returns -1 if already returned or not available.

PD?

[FDCCH:FBCCH:PD?]

Returns the last decoded value of Protocol Discriminator (1 bit value). Returns -1 if already returned or not available.

MSGtype?

[FDCCH:FBCCH:MSGtype?]

Returns the last decoded Message Type. Returns -1 if already returned or not available. This command returns the following valid message types:

DCCH STRUCT	ACCESS PARAM	SELECT PARAM	REG PARAM
SYSID.	OLC	MACA	NEIGHBOR CELL
RCI	BSMC	EMERG INFO	NEIGHBOR INFO
SERVICE MENU	SOC BSMC ID	soc	TIME DATE

FBCCH:

NUMber:

FBCCH?

[FDCCH:FBCCH:NUMber:FBCCH?]

Returns the last decoded value of Number of F-BCCH (3 bit value). Returns -1 if already returned or not available.

This command returns the decoded value plus two in accordance with IS-136.

EBCCH?

[FDCCH:FBCCH:NUMber:EBCCH?]

Returns the last decoded value of Number of E-BCCH (3 bit value). Returns -1 if already returned or not available.

This command returns the decoded value plus one in accordance with IS-136.

SBCCH?

[FDCCH:FBCCH:NUMber:SBCCH?]

Returns the last decoded value of Number of S-BCCH (4 bit value). Returns -1 if already returned or not available.

REServed?

[FDCCH:FBCCH:NUMber:REServed?]

Returns the last decoded value of Number of Reserved Slots (3 bit value). Returns -1 if already returned or not available.

NON PCH?

[FDCCH:FBCCH:NUMber:NON_PCH?]

Returns the last decoded value of Number of Non-PCH Subchannel Slots (2 bit value). Returns -1 if already returned or not available.

HYPERframe?

[FDCCH:FBCCH:HYPERframe?]

Returns the last decoded value of Hyperframe Counter (4 bit value). Returns -1 if already returned or not available.

EXTended:

PT?

[FDCCH:FBCCH:EXTended:PT?]

Returns the last decoded value of SMS Frame Counter Parameter Type or -1 if already returned or not available.

COUNt?

[FDCCH:FBCCH:EXTended:COUNt?]

Returns the last decoded value of SMS Frame Counter (4 bit value). Returns -1 if already returned or not available (3 bit value).

FBCCH:

SUPERframe?

[FDCCH:FBCCH:SUPERframe?]

Returns the last decoded value of Primary Superframe indicator (1 bit value). Returns -1 if already returned or not available.

CONfiguration?

[FDCCH:FBCCH:CONfiguration?]

Returns the last decoded value of Slot Configuration (2 bit value). Returns -1 if already returned or not available.

DVCC?

[FDCCH:FBCCH:DVCC?]

Returns the last decoded value of Digital Verification Color Code (8 bit value). Returns -1 if already returned or not available.

PFC?

[FDCCH:FBCCH:PFC?]

Returns the last decoded value of Maximum Supported PFC (Paging Frame Class) (3 bit value). Returns -1 if already returned or not available.

PCH?

[FDCCH:FBCCH:PCH?]

Returns the last decoded value of PCH (Paging Channel) Displacement (3 bit value). Returns -1 if already returned or not available.

PFM?

[FDCCH:FBCCH:PFM?]

Returns the last decoded value of PFM (Paging Frame Modifier) Direction (1 bit value). Returns -1 if already returned or not available.

CBN:

PT?

[FDCCH:FBCCH:CBN:PT?]

Returns the last decoded value of CBN_High Parameter Type (4 bit value). Returns -1 if already returned or not available.

HIGH?

[FDCCH:FBCCH:CBN:HIGH?]

Returns the last decoded value of CBN_High (16 bit value). Returns -1 if already returned or not available.

FBCCH:

NONPublic:

PROBability:

PT?

[FDCCH:FBCCH:NONPublic:PROBability:PT?]

Returns the last decoded value of Non-Public Probability Block Parameter Type (4 bit value). Returns -1 if already returned or not available.

LENGth?

[FDCCH:FBCCH:NONPublic:PROBability:LENGth?]

Returns the last decoded value of Non-Public Map Length (4 bit value). Returns -1 if already returned or not available.

BLOCk?

[FDCCH:FBCCH:NONPublic:PROBability:BLOCk?]

Returns the last decoded value of Non-Public Block Map (1 to 16 bit value). Returns -1 if already returned or not available.

REGistration:

PT?

[FDCCH:FBCCH:NONPublic:REGistration:PT?]

Returns the last decoded value of Non-Public Registration Control Parameter Type (4 bit value). Returns -1 if already returned or not available.

CONTrol?

[FDCCH:FBCCH:NONPublic:PROBability:CONTrol?]

Returns the last decoded value of Non-Public Registration Control (2 bit value). Returns -1 if already returned or not available.

AUTH?

[FDCCH:FBCCH:AUTH?]

Returns the last decoded value of AUTH (1 bit value). Returns -1 if already returned or not available.

S?

[FDCCH:FBCCH:S?]

Returns the last decoded value of S (1 bit value). Returns -1 if already returned or not available.

RAND?

[FDCCH:FBCCH:RAND?]

Returns the last decoded value of RAND (32 bit value). Returns -1 if already returned or not available.

FBCCH:

ACCess:

MS PWR?

[FDCCH:FBCCH:ACCess:MS_PWR?]

Returns the last decoded value of MS_ACC_PWR (Mobile Station Access Power) (4 bit value). Returns -1 if already returned or not available.

RSS MIN?

[FDCCH:FBCCH:CBN:RSS_MIN?]

Returns the last decoded value of RSS_ACC_MIN (Minimum Access Received Signal Strength) (5 bit value). Returns -1 if already returned or not available.

BURSTsize?

[FDCCH:FBCCH:CBN:BURSTsize?]

Returns the last decoded value of Access Burst Size (1 bit value). Returns -1 if already returned or not available.

MAX:

RETries?

[FDCCH:FBCCH:MAX:RETries?]

Returns the last decoded value of Max Retries (3 bit value). Returns -1 if already returned or not available.

BUSY?

[FDCCH:FBCCH:MAX:BUSY?]

Returns the last decoded value of Max Busy/Reserved (1 bit value). Returns -1 if already returned or not available.

REPetitions?

[FDCCH:FBCCH:MAX:REPetitions?]

Returns the last decoded value of Max Repetitions (2 bit value). Returns -1 if already returned or not available.

STOP?

[FDCCH:FBCCH:MAX:STOP?]

Returns the last decoded value of Max Stop Counter (1 bit value). Returns -1 if already returned or not available.

RDATA:

LENGth?

[FDCCH:FBCCH:RDATA:LENGth?]

Returns the last decoded value of R-DATA Message Length (3 bit value). Returns -1 if already returned or not available.

FBCCH:

BARred?

[FDCCH:FBCCH:BARred?]

Returns the last decoded value of Cell Barred (5 bit value). Returns -1 if already returned or not available.

SUBaddressing?

[FDCCH:FBCCH:SUBaddressing?]

Returns the last decoded value of Subaddressing Support (1 bit value). Returns -1 if already returned or not available.

DIC?

[FDCCH:FBCCH:DIC?]

Returns the last decoded value of Delay Interval Compensation Mode (1 bit value). Returns -1 if already returned or not available.

SS SUFF?

[FDCCH:FBCCH:SS_SUFF?]

Returns the last decoded value of SS_SUFF (Signal Strength Sufficient) (5 bit value). Returns -1 if already returned or not available.

SCAN:

INTerval?

[FDCCH:FBCCH:SCAN:INTerval?]

Returns the last decoded value of SCANINTERVAL (4 bit value). Returns -1 if already returned or not available.

OPTion?

[FDCCH:FBCCH:RDATA:OPTion?]

Returns the last decoded value of Scanning Option Indicator (1 bit value). Returns -1 if already returned or not available.

INITial?

[FDCCH:FBCCH:INITial?]

Returns the last decoded value of Initial Selection Control (1 bit value). Returns -1 if already returned or not available.

DELav?

[FDCCH:FBCCH:DELay?]

Returns the last decoded value of DELAY (4 bit value). Returns -1 if already returned or not available.

FBCCH:

ADDitional:

PT?

[FDCCH:FBCCH:ADDitional:PT?]

Returns the last decoded value of Additional DCCH Information Parameter Type (4 bit value). Returns -1 if already returned or not available.

NUMber?

[FDCCH:FBCCH:ADDitional:NUMber?]

Returns the last decoded value of Number of Additional DCCH Channels (3 bit value). Returns -1 if already returned or not available.

CHANnel? n

[FDCCH:FBCCH:ADDitional:CHANnel]

Returns the last decoded value of Additional DCCH Channel Information (11 bit value) selected by n. Up to 8 instances can be returned. Range of n is 0 to 7 Returns -1 if already returned or not available.

SLOT? n

[FDCCH:FBCCH:ADDitional:SLOT]

Returns the last decoded value of Additional Slot Information (2 bit value) selected by n. Up to 8 instances can be returned. Range of n is 0 to 7. Returns -1 if already returned or not available.

REGH?

[FDCCH:FBCCH:REGH?]

Returns the last decoded value of REGH (1 bit value). Returns -1 if already returned or not available.

REGR?

[FDCCH:FBCCH:REGR?]

Returns the last decoded value of REGR (1 bit value). Returns -1 if already returned or not available.

PUREG?

[FDCCH:FBCCH:PUREG?]

Returns the last decoded value of PUREG (1 bit value). Returns -1 if already returned or not available.

PDREG?

[FDCCH:FBCCH:PDREG?]

Returns the last decoded value of PDREG (1 bit value). Returns -1 if already returned or not available.

FBCCH:

SYREG?

[FDCCH:FBCCH:SYREG?]

Returns the last decoded value of SYREG (1 bit value). Returns -1 if already returned or not available.

LAREG?

[FDCCH:FBCCH:LAREG?]

Returns the last decoded value of LAREG (1 bit value). Returns -1 if already returned or not available.

DEREG?

[FDCCH:FBCCH:DEREG?]

Returns the last decoded value of DEREG (1 bit value). Returns -1 if already returned or not available.

FOREG?

[FDCCH:FBCCH:FOREG?]

Returns the last decoded value of FOREG (1 bit value). Returns -1 if already returned or not available.

CAPability?

[FDCCH:FBCCH:CAPability?]

Returns the last decoded value of Capability Request (1 bit value). Returns -1 if already returned or not available.

RNUM:

PT?

[FDCCH:FBCCH:RNUM:PT?]

Returns the last decoded value of Present RNUM Parameter Type (4 bit value). Returns -1 if already returned or not available.

NUMber?

[FDCCH:FBCCH:RNUM:NUMber?]

Returns the last decoded value of Present RNUM (10 bit value). Returns -1 if already returned or not available.

REGistration:

PT?

[FDCCH:FBCCH:REGistration:PT?]

Returns the last decoded value of Registration Period Parameter Type (4 bit value). Returns -1 if already returned or not available.

PERiod?

[FDCCH:FBCCH:REGistration:PERiod?]

Returns the last decoded value of REGPER (Registration Period) (9 bit value). Returns -1 if already returned or not available.

FBCCH:

REGID:

PT?

[FDCCH:FBCCH:REGid:PT?]

Returns the last decoded value of REGID Parameter Type (4 bit value). Returns -1 if already returned or not available.

ID?

[FDCCH:FBCCH:REGistration:ID?]

Returns the last decoded value of REGID (20 bit value). Returns -1 if already returned or not available.

PER?

[FDCCH:FBCCH:REGistration:PER?]

Returns the last decoded value of REGID_PER (Registration ID Period) (4 bit value). Returns -1 if already returned or not available.

SID?

[FDCCH:FBCCH:SID?]

Returns the last decoded value of SID (System Identification) (15 bit value). Returns -1 if already returned or not available.

NETwork?

[FDCCH:FBCCH:NETwork?]

Returns the last decoded value of Network Type (3 bit value). Returns -1 if already returned or not available.

PROTocol?

[FDCCH:FBCCH:PROTocol?]

Returns the last decoded value of Protocol Version (4 bit value). Returns -1 if already returned or not available.

FBCCH:

PSID RSID:

PT?

[FDCCH:FBCCH:PSID_RSID:PT?]

Returns the last decoded value of PSID/RSID Set Parameter Type (4 bit value). Returns -1 if already returned or not available.

SOC?

[FDCCH:FBCCH:PSID_RSID:SOC?]

Returns the last decoded value of PSID/RSID SOC (12 bit value). Returns -1 if already returned or not available.

NUMber?

[FDCCH:FBCCH:PSID_RSID:NUMber?]

Returns the last decoded value of Number of PSID/RSID (4 bit value). Returns -1 if already returned or not available.

TYPE? n

[FDCCH:FBCCH:PSID_RSID:TYPE?]

Returns the last decoded state of TYPE (1 bit value) of PSID/RSID. Range of n is 0 to 1.

VALUE? n

[FDCCH:FBCCH:PSID_RSID:VALUE?]

Returns the last decoded value of VALUE (16 bit value) of PSID/RSID. Range of n is 0 to 65535.

COUNTRY:

PT?

[FDCCH:FBCCH:COUNTRY:PT?]

Returns the last decoded value of Country Code Parameter Type (4 bit value). Returns -1 if already returned or not available.

CODE?

[FDCCH:FBCCH:COUNTRY:CODE?]

Returns the last decoded value of Country Code (10 bit value). Returns -1 if already returned or not available.

FBCCH:

ALPHA:

SID:

PT?

[FDCCH:FBCCH:ALPHA:SID:PT?]

Returns the last decoded value of Alphanumeric SID Parameter Type (4 bit value). Returns -1 if already returned or not available.

LENGth?

[FDCCH:FBCCH:ALPHA:SID:LENGth?]

Returns the last decoded value of Length of Alphanumeric System ID (8 bit value). Returns -1 if already returned or not available.

CHARacters?

[FDCCH:FBCCH:ALPHA:SID:CHARacters?]

Returns the selected last decoded value of Alphanumeric SID (ASCII String). Returns -1 if already returned or not available.

BSMC?

[FDCCH:FBCCH:BSMC?]

Returns the last decoded value of BSMC (Base Station Manufacture Code) (8 bit value). Returns -1 if already returned or not available.

CUSTOM:

LENGth?

[FDCCH:FBCCH:CUSTOM:LENGth?]

Returns the last decoded value of the Length of the Custom Control (8 bit value) in octets. Returns or -1 if already returned or not available.

CONTrol? n

[FDCCH:FBCCH:CUSTOM:CONTrol]

Returns the last decoded value of Custom Control (8 bit value) selected by n. Up to 256 instances can be returned. Range of n is 0 to 255,

Validity is determined by FDCCH:FBCCH:CUSTOM:LENGth?.

MACA:

STATus?

[FDCCH:FBCCH:MACA:STATus?]

Returns the last decoded value of MACA_STATUS (2 bit value). Returns -1 if already returned or not available.

TYPE?

[FDCCH:FBCCH:MACA:TYPE?]

Returns the last decoded value of MACA_TYPE (4 bit value). Returns -1 if already returned or not available.

FBCCH:

MACA:

EIGHT:

PT?

[FDCCH:FBCCH:MACA:EIGHT:PT?]

Returns the last decoded value of MACA_8_CONTROL Parameter Type (4 bit value). Returns -1 if already returned or not available.

CONTrol?

[FDCCH:FBCCH:MACA:EIGHT:CONTrol?]

Returns the last decoded value of MACA_8_CONTROL (1 bit value). Returns -1 if already returned or not available.

LIST:

PT?

[FDCCH:FBCCH:MACA:LIST:PT?]

Returns the last decoded value of MACA_LIST Parameter Type (4 bit value). Returns -1 if already returned or not available.

NUMber?

[FDCCH:FBCCH:MACA:LIST:NUMber?]

Returns the last decoded value of Number of MACA Channels (4 bit value). Returns -1 if already returned or not available.

CHAN? n

[FDCCH:FBCCH:MACA:LIST:CHAN]

Returns the last decoded value of MACA_LIST CHAN (11 bit value) selected by n. Up to 16 instances can be returned. Range of n is 0 to 15.

Validity is determined by FDCCH:FBCCH:MACA:LIST:NUMber?.

FBCCH:

MACA:

LIST:

OTHER:

PT?

[FDCCH:FBCCH:MACA:LIST:OTHER:PT?]

Returns the last decoded value of MACA_LIST (Other Hyperband) Parameter Type (4 bit value). Returns -1 if already returned or not available.

HYPERband?

[FDCCH:FBCCH:MACA:LIST:OTHER:HYPERband?]

Returns the last decoded value of Hyperband (Other Hyperband) (2 bit value). Returns -1 if already returned or not available.

NUMber?

[FDCCH:FBCCH:MACA:LIST:OTHER:NUMber?]

Returns the last decoded value of Number of MACA Channels (Other Hyperband) (4 bit value). Returns -1 if already returned or not available.

CHAN? n

[FDCCH:FBCCH:MACA:LIST:OTHER:CHAN]

Returns the selected last decoded value of MACA_LIST (Other Hyperband) CHAN (11 bit value) selected by n. Up to 16 instances can be returned. Range of n is 0 to 15.

Validity is determined by FDCCH:FBCCH:MACA:LIST:OTHER:NUMber?.

OLC?

[FDCCH:FBCCH:OLC?]

Returns the last decoded value of Overload Control (16 bit value). Returns -1 if already returned or not available.

MAP:

VPM?

[FDCCH:FBCCH:MAP:VPM?]

Returns the last decoded value of Voice Privacy Mode Map (4 bit value). Returns -1 if already returned or not available.

DPM?

[FDCCH:FBCCH:MAP:DPM?]

Returns the last decoded value of Data Privacy Mode Map (4 bit value). Returns -1 if already returned or not available.

FBCCH:

MAP:

CODER?

[FDCCH:FBCCH:MAP:CODER?]

Returns the last decoded value of Voice Coder Map (6 bit value). Returns -1 if already returned or not available.

MEA:

DOMAIN?

[FDCCH:FBCCH:MAP:MEA:DOMAIN?]

Returns the last decoded value of Message Encryption Algorithm Domain Map (8 bit value). Returns -1 if already returned or not available.

ALGORIthms? n

[FDCCH:FBCCH:MAP:MEA:ALGORithms]

Returns the selected last decoded value of Message Encryption Algorithm (4 bit value) selected by n. Up to 8 instances can be returned. Range of n is 0 to 7.

Validity is determined by FDCCH:FBCCH:MAP:MEA:DOMAIN?.

MEK?

[FDCCH:FBCCH:MAP:MEK?]

Returns the last decoded value of Message Encryption Key Map (4 bit value). Returns -1 if already returned or not available.

MENU?

[FDCCH:FBCCH:MAP:MENU?]

Returns the last decoded value of Menu Map (10 bit value). Returns -1 if already returned or not available.

ARQ?

[FDCCH:FBCCH:MAP:ARQ?]

Returns the last decoded value of FACCH/SACCH ARQ Map (1 bit value). Returns -1 if already returned or not available.

USER?

[FDCCH:FBCCH:MAP:USER?]

Returns the last decoded value of User Group Map (1 bit value). Returns -1 if already returned or not available.

SMS?

[FDCCH:FBCCH:MAP:SMS?]

Returns the last decoded value of SMS Map (2 bit value). Returns -1 if already returned or not available.

FBCCH:

IRA? n

[FDCCH:FBCCH:IRA?]

Returns the last decoded state of IRA Support (1 bit value) selected by n. Range of n is 0 to 1.

SOC?

[FDCCH:FBCCH:SOC?]

Returns the last decoded value of SOC (System Operator Code) (12 bit value). Returns -1 if already returned or not available.

C. E-BCCH Frames

The following set of commands return the data fields in E-BCCH Messages.

FDCCH:

EBCCH:

BC?

[FDCCH:EBCCH:BC?]

Returns the last decoded value of Begin/Continue (1 bit value). Returns -1 if already returned or not available.

CLI?

[FDCCH:EBCCH:CLI?]

Returns the last decoded value of Continuation Length Indicator (7 bit value). Returns -1 if already returned or not available.

L3LI?

[FDCCH:EBCCH:L3L1?]

Returns the last decoded value of Layer 3 Length Indicator (8 bit value). Returns -1 if already returned or not available.

[FDCCH:EBCCH:BI?]

Returns the last decoded value of Begin Indicator (1 bit value). Returns -1 if already returned or not available.

ECL?

[FDCCH:EBCCH:ECL?]

Returns the last decoded value of E-BCCH Cycle Length (8 bit value). Returns -1 if already returned or not available.

PD?

[FDCCH:EBCCH:PD?]

Returns the last decoded value of Protocol Discriminator (2 bit value). Returns -1 if already returned or not available.

MSGtype?

[FDCCH:EBCCH:MSGtype?]

Returns the last decoded value of Message Type. Returns -1 if already returned or not available. This command returns the following valid message types:

DCCH STRUCT	ACCESS PARAM	SELECT PARAM	REG PARAM
SYSID	OLC	MACA	NEIGHBOR CELL
RCI	BSMC	EMERG INFO	NEIGHBOR INFO
SERVICE MENU	SOC BSMC ID	soc	TIME DATE
ALT RCI			

EBCCH:

SERV SS?

[FDCCH:EBCCH:SERV_SS?]

Returns the last decoded value of SERV_SS (4 bit value). Returns -1 if already returned or not available.

NONPublic:

PT?

[FDCCH:EBCCH:NONPublic:PT?]

Returns the last decoded value of Non-Public Probability Blocks Parameter Type (4 bit value). Returns -1 if already returned or not available.

LENGth?

[FDCCH:EBCCH:NONPublic:LENGth?]

Returns the last decoded value of Non-Public Map Length (4 bit value). Returns -1 if already returned or not available.

BLOCk?

[FDCCH:EBCCH:NONPublic:BLOCK?]

Returns the last decoded value of Non-Public Block Map (16 bit value). Returns -1 if already returned or not available.

NEIGHbor:

TDMA:

PT?

[FDCCH:EBCCH:NEIGHbor:TDMA:PT?]

Returns the last decoded value of Neighbor Cell List (TDMA) Parameter Type (4 bit value). Returns -1 if already returned or not available.

NUMber?

[FDCCH:EBCCH:NEIGHbor:TDMA:NUMber?]

Returns the last decoded value of Number of TDMA Neighbor Cells (5 bit value). Returns -1 if already returned or not available.

CELL:

CHAN? n

[FDCCH:EBCCH:NEIGHbor:TDMA:CELL:CHAN?]

Returns the last decoded value of TDMA Neighbor Cell CHAN (11 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

PROTocol? n

[FDCCH:EBCCH:NEIGHbor:TDMA:CELL:PROTocol?]

Returns the last decoded value of TDMA Neighbor Cell Protocol Version (4 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

EBCCH:

NEIGHbor:

TDMA:

CELL:

DVCC? n

[FDCCH:EBCCH:NEIGHbor:TDMA:CELL:DVCC?]

Returns the last decoded value of TDMA Neighbor Cell DVCC (8 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

OFFset? n

[FDCCH:EBCCH:NEIGHbor:TDMA:CELL:OFFset?]

Returns the last decoded value of TDMA Neighbor Cell RESEL_OFFSET (7 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

SS SUFF? n

[FDCCH:EBCCH:NEIGHbor:TDMA:CELL:SS_SUFF?]

Returns the last decoded value of TDMA Neighbor Cell SS_SUFF (5 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

DELay? n

[FDCCH:EBCCH:NEIGHbor:TDMA:CELL:DELay?]

Returns the last decoded value of TDMA Neighbor Cell DELAY (4 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

HL FREQ? n

[FDCCH:EBCCH:NEIGHbor:TDMA:CELL:HL_FREQ?]

Returns the last decoded value of TDMA Neighbor Cell HL_FREQ (1 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

SYNC? n

[FDCCH:EBCCH:NEIGHbor:TDMA:CELL:SYNC?]

Returns the last decoded value of TDMA Neighbor Cell SYNC (1 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

EBCCH:

NEIGHbor:

TDMA:

CELL:

TYPE:

CELL? n

[FDCCH:EBCCH:NEIGHbor:TDMA:CELL:TYPE:CELL?]

Returns the last decoded value of TDMA Neighbor Cell CELLTYPE (2 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

NETwork? n

[FDCCH:EBCCH:NEIGHbor:TDMA:CELL:TYPE:NETwork?]

Returns the last decoded value of TDMA Neighbor Cell Network Type (3 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

RETRY? n

[FDCCH:EBCCH:NEIGHbor:TDMA:CELL:RETRY?]

Returns the last decoded value of TDMA Neighbor Cell Directed Retry Channel (1 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

ACCess:

MS PWR? n

[FDCCH:EBCCH:NEIGHbor:TDMA:CELL:ACCess:MS_PWR?]

Returns the last decoded value of TDMA Neighbor Cell MS_ACC_PWR (4 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

RSS MIN? n

[FDCCH:EBCCH:NEIGHbor:TDMA:CELL:ACCess:RSS_MIN?]

Returns the last decoded value of TDMA Neighbor Cell RSS_ACC_MIN (5 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

EBCCH:

NEIGHbor:

TDMA:

CELL:

PSID_RSID:

INDicator? n

[FDCCH:EBCCH:NEIGHbor:TDMA:CELL:PSID_RSID:INDicator?]

Returns the last decoded value of TDMA Neighbor Cell PSID/RSID Indicator (1 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

LENGth? n

[FDCCH:EBCCH:NEIGHbor:TDMA:CELL:PSID_RSID:LENGth?]

Returns the last decoded value of TDMA Neighbor Cell PSID/RSID Support Length (4 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

SUPport? n

[FDCCH:EBCCH:NEIGHbor:TDMA:CELL:PSID_RSID:SUPport?]

Returns the last decoded value of TDMA Neighbor Cell PSID/RSID Support (16 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

INFO:

PT?

[FDCCH:EBCCH:NEIGHbor:TDMA:INFO:PT?]

Returns the last decoded value of TDMA Service Info Parameter Type (4 bit value). Returns -1 if already returned or not available.

COUNt?

[FDCCH:EBCCH:NEIGHbor:TDMA:INFO:COUNt?]

Returns the last decoded value of TDMA Neighbor Count (5 bit value). Returns -1 if already returned or not available.

EBCCH:

NEIGHbor:

TDMA:

INFO:

SERVice:

INDicator? n

[FDCCH:EBCCH:NEIGHbor:TDMA:INFO:SERVice:INDicator?]

Returns the last decoded value of TDMA Service Map Indicator (1 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

MAP? n

[FDCCH:EBCCH:NEIGHbor:TDMA:INFO:SERVice:MAP?]

Returns the last decoded value of TDMA Service Map (10 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

ANAlog:

PT?

[FDCCH:EBCCH:NEIGHbor:ANAlog:PT?]

Returns the last decoded value of Neighbor Cell List (Analog) Parameter Type (4 bit value). Returns -1 if already returned or not available.

NUMber?

[FDCCH:EBCCH:NEIGHbor:ANAlog:NUMber?]

Returns the last decoded value of Number of Analog Neighbor Cells (5 bit value). Returns -1 if already returned or not available.

CELL:

CHAN? n

[FDCCH:EBCCH:NEIGHbor:ANAlog:CELL:CHAN?]

Returns the last decoded value of Neighbor Cell List (Analog) CHAN (11 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

PROTocol? n

[FDCCH:EBCCH:NEIGHbor:ANAlog:CELL:PROTocol?]

Returns the last decoded value of Neighbor Cell List (Analog) Protocol Version (4 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

EBCCH:

NEIGHbor:

ANAlog:

CELL:

DCC? n

[FDCCH:EBCCH:NEIGHbor:ANAlog:CELL:DCC?]

Returns the last decoded value of Neighbor Cell List (Analog) DCC (2 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

OFFset? n

[FDCCH:EBCCH:NEIGHbor:ANAlog:CELL:OFFset?]

Returns the last decoded value of Neighbor Cell List (Analog) RESEL_OFFSET (7 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

SS SUFF? n

[FDCCH:EBCCH:NEIGHbor:ANAlog:CELL:SS_SUFF?]

Returns the last decoded value of Neighbor Cell List (Analog) SS_SUFF (5 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

DELav? n

[FDCCH:EBCCH:NEIGHbor:ANAlog:CELL:DELay?]

Returns the last decoded value of Neighbor Cell List (Analog) DELAY (4 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

HL FREQ? n

[FDCCH:EBCCH:NEIGHbor:ANAlog:CELL:HL_FREQ?]

Returns the last decoded value of Neighbor Cell List (Analog) HL_FREQ (1 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

TYPE:

CELL? n

[FDCCH:EBCCH:NEIGHbor:ANAlog:CELL:TYPE:CELL?]

Returns the last decoded value of Neighbor Cell List (Analog) CELLTYPE (2 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

EBCCH:

NEIGHbor:

ANAlog:

CELL:

TYPE:

NETwork? n

[FDCCH:EBCCH:NEIGHbor:ANAlog:CELL:TYPE:NETwork?]

Returns the last decoded value of Neighbor Cell List (Analog) Network Type (3 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

RETRY? n

[FDCCH:EBCCH:NEIGHbor:ANAlog:CELL:RETRY?]

Returns the last decoded value of Neighbor Cell List (Analog) Directed Retry Channel (1 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

ACCess:

MS PWR? n

[FDCCH:EBCCH:NEIGHbor:ANAlog:CELL:ACCess:MS_PWR?]

Returns the last decoded value of Neighbor Cell List (Analog) MS_ACC_PWR (4 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

RSS MIN? n

[FDCCH:EBCCH:NEIGHbor:ANAlog:CELL:ACCess:RSS_MIN?]

Returns the last decoded value of Neighbor Cell List (Analog) RS_ACC_MIN (5 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

OTHER:

PT?

[FDCCH:EBCCH:NEIGHbor:OTHER:PT?]

Returns the last decoded value of Neighbor Cell List (Other Hyperband) Parameter Type (4 bit value). Returns -1 if already returned or not available.

NUMber?

[FDCCH:EBCCH:NEIGHbor:OTHER:NUMber?]

Returns the last decoded value of Number of Neighbor Cells (Other Hyperband) (5 bit value). Returns -1 if already returned or not available.

EBCCH:

NEIGHbor:

OTHER:

CELL:

HYPERband?

[FDCCH:EBCCH:NEIGHbor:OTHER:CELL:HYPERband?]

Returns the last decoded value of Neighbor Cell List (Other Hyperband) (2 bit value). Returns -1 if already returned or not available.

CHAN? n

[FDCCH:EBCCH:NEIGHbor:OTHER:CELL:CHAN?]

Returns the last decoded value of Neighbor Cell List (Other Hyperband) CHAN (11 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

PROTocol? n

[FDCCH:EBCCH:NEIGHbor:OTHER:CELL:PROTocol?]

Returns the last decoded value of Neighbor Cell List (Other Hyperband) Protocol Version (4 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

DVCC? n

[FDCCH:EBCCH:NEIGHbor:OTHER:CELL:DVCC?]

Returns the last decoded value of Neighbor Cell List (Other Hyperband) DVCC (8 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

OFFset? n

[FDCCH:EBCCH:NEIGHbor:OTHER:CELL:OFFset?]

Returns the last decoded value of Neighbor Cell List (Other Hyperband) RESEL_OFFSET (7 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

SS_SUFF? n

[FDCCH:EBCCH:NEIGHbor:OTHER:CELL:SS_SUFF?]

Returns the last decoded value of Neighbor Cell List (Other Hyperband) SS_SUFF (5 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

DELay? n

[FDCCH:EBCCH:NEIGHbor:OTHER:CELL:DELay?]

Returns the last decoded value of Neighbor Cell List (Other Hyperband) DELAY (4 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

EBCCH:

NEIGHbor:

OTHER:

CELL:

HL FREQ? n

[FDCCH:EBCCH:NEIGHbor:OTHER:CELL:HL_FREQ?]

Returns the last decoded value of Neighbor Cell List (Other Hyperband) HL_FREQ (1 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

SYNC? n

[FDCCH:EBCCH:NEIGHbor:OTHER:CELL:SYNC?]

Returns the last decoded value of Neighbor Cell List (Other Hyperband) SYNC (1 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

TYPE:

CELL? n

[FDCCH:EBCCH:NEIGHbor:OTHER:CELL:TYPE:CELL?]

Returns the last decoded value of Neighbor Cell List (Other Hyperband) CELLTYPE (2 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

NETwork? n

[FDCCH:EBCCH:NEIGHbor:OTHER:CELL:TYPE:NETwork?]

Returns the last decoded value of Neighbor Cell List (Other Hyperband) Network Type (3 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

RETRY? n

[FDCCH:EBCCH:NEIGHbor:OTHER:CELL:RETRY?]

Returns the last decoded value of Neighbor Cell List (Other Hyperband) Directed Retry Channel (1 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

EBCCH:

NEIGHbor:

OTHER:

CELL:

ACCess:

MS PWR? n

[FDCCH:EBCCH:NEIGHbor:OTHER:CELL:ACCess:MS_PWR?]
Returns the last decoded value of Neighbor Cell List (Other Hyperband) MS_ACC_PWR (4 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

RSS_MIN? n

[FDCCH:EBCCH:NEIGHbor:OTHER:CELL:ACCess:RSS_MIN?]
Returns the last decoded value of Neighbor Cell List (Other Hyperband) RSS_ACC_MIN (5 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

PSID_RSID:

INDicator? n

[FDCCH:EBCCH:NEIGHbor:OTHER:CELL:PSID_RSID:INDicator?]
Returns the last decoded value of Neighbor Cell List (Other Hyperband) PSID/RSID Indicator (1 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

LENGth? n

[FDCCH:EBCCH:NEIGHbor:OTHER:CELL:PSID_RSID:LENGth?]
Returns the last decoded value of Neighbor Cell List (Other Hyperband) PSID/RSID Support Length (4 bit value) selected by n.
Up to 32 instances can be returned. Range of n is 0 to 31. Returns - 1 if already returned or not available.

SUPport?

[FDCCH:EBCCH:NEIGHbor:OTHER:CELL:PSID_RSID:SUPport?]
Returns the last decoded value of Neighbor Cell List (Other Hyperband) PSID/RSID Support (16 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

Validity is determined by FDCCH: EBCCH: NEIGHbor: OTHER: CELL: PSID_RSID: LENGth?.

EBCCH:

NEIGHbor:

OTHER:

INFO:

PT?

[FDCCH:EBCCH:NEIGHbor:OTHER:INFO:PT?]

Returns the last decoded value of TDMA Service Info (Other Hyperband) Parameter Type (4 bit value). Returns -1 if already returned or not available.

HYPERband?

[FDCCH:EBCCH:NEIGHbor:OTHER:INFO:HYPERband?]

Returns the last decoded value of TDMA Service Info (Other Hyperband) (2 bit value). Returns -1 if already returned or not available.

COUNt?

[FDCCH:EBCCH:NEIGHbor:OTHER:INFO:COUNt?]

Returns the last decoded value of TDMA Service Info (Other Hyperband) Neighbor Count (5 bit value). Returns -1 if already returned or not available.

SERVice:

INDicator? n

[FDCCH:EBCCH:NEIGHbor:OTHER:INFO:SERVice:INDicator?]

Returns the last decoded value of TDMA Service Info (Other Hyperband) Service Map Indicator (1 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

MAP? n

[FDCCH:EBCCH:NEIGHbor:OTHER:INFO:SERVice:MAP?]

Returns the last decoded value of TDMA Service Info (Other Hyperband) Service Map (10 bit value) selected by n. Up to 32 instances can be returned. Range of n is 0 to 31. Returns -1 if already returned or not available.

RCI2

[FDCCH:EBCCH:RCI?]

Returns the last decoded value of RCI (2 bit value). Returns -1 if already returned or not available.

EBCCH:

CHANnel:

PT?

[FDCCH:EBCCH:CHANnel:PT?]

Returns the last decoded value of RF Channel Allocation Parameter Type (4 bit value). Returns -1 if already returned or not available.

NUMber?

[FDCCH:EBCCH:CHANnel:NUMber?]

Returns the last decoded value of RF Channel Allocation Number of Channel Groups (6 bit value). Returns -1 if already returned or not available.

GROUP:

FIRST? n

[FDCCH:EBCCH:CHANnel:GROUP:FIRST?]

Returns the last decoded value of RF Channel Allocation Channel Group First Channel (11 bit value) selected by n. Up to 64 instances can be returned. Range of n is 0 to 63. Returns -1 if already returned or not available.

LAST? n

[FDCCH:EBCCH:CHANnel:GROUP:LAST?]

Returns the last decoded value of RF Channel Allocation Channel Group Last Channel (11 bit value) selected by n. Up to 64 instances can be returned. Range of n is 0 to 63. Returns -1 if already returned or not available.

BSMC?

[FDCCH:EBCCH:BSMC?]

Returns the last decoded value of BSMC (Base Station Manufacture Code) (8 bit value). Returns -1 if already returned or not available.

CUSTOM:

LENGth?

[FDCCH:EBCCH:CUSTOM:LENGth?]

Returns the last decoded value of Length of Custom Control in octets (8 bit value). Returns -1 if already returned or not available.

CONTrol? n

[FDCCH:EBCCH:CUSTOM:CONTrol?]

Returns the last decoded value of Custom Control (8 bit value) selected by n. Up to 256 instances can be returned. Range of n is 0 to 255. Returns -1 if already returned or not available.

Validity is determined by FDCCH:EBCCH:CUSTOM:LENGth?.

EBCCH:

TEXT:

LENGth?

[FDCCH:EBCCH:TEXT:LENGth?]

Returns the last decoded value of Length of Text Message Data Unit in octets (8 bit value). Returns -1 if already returned or not available.

ENCoding?

[FDCCH:EBCCH:TEXT:ENCoding?]

Returns the last decoded value of Text Message Data Unit Encoding Identifier (5 bit value). Returns -1 if already returned or not available.

REServed?

[FDCCH:EBCCH:TEXT:REServed?]

Returns the last decoded value of Text Message Data Unit Reserved (3 bit value). Returns -1 if already returned or not available.

CHARacter? n

[FDCCH:EBCCH:TEXT:CHARacter?]

Returns the last decoded value of Text Message Data Unit Short Message Character (8 bit value) selected by n. Up to 245 instances can be returned. Range of n is 0 to 244. Returns -1 if already returned or not available.

Validity is determined by FDCCH:EBCCH:TEXT:LENGth?.

SIGnal:

PT?

[FDCCH:EBCCH:SIGnal:PT?]

Returns the last decoded value of Signal Parameter Type (4 bit value). Returns -1 if already returned or not available.

PITCH?

[FDCCH:EBCCH:SIGnal:PITCH?]

Returns the last decoded value of Signal Pitch (2 bit value). Returns -1 if already returned or not available.

CADence?

[FDCCH:EBCCH:SIGnal:CADence?]

Returns the last decoded value of Signal Cadence (6 bit value). Returns -1 if already returned or not available.

DURation?

[FDCCH:EBCCH:SIGnal:DURation?]

Returns the last decoded value of Signal Duration (4 bit value). Returns -1 if already returned or not available.

EBCCH:

MACA:

STATus?

[FDCCH:EBCCH:MACA:STATus?]

Returns the last decoded value of MACA_STATUS (2 bit value). Returns -1 if already returned or not available.

TYPE?

[FDCCH:EBCCH:MACA:TYPE?]

Returns the last decoded value of MACA_TYPE (4 bit value). Returns -1 if already returned or not available.

EIGHT:

PT?

[FDCCH:EBCCH:MACA:EIGHT:PT?]

Returns the last decoded value of MACA_8_CONTROL Parameter Type (4 bit value). Returns -1 if already returned or not available.

CONTrol?

[FDCCH:EBCCH:MACA:EIGHT:CONTrol?]

Returns the last decoded value of MACA_8_CONTROL (1 bit value). Returns -1 if already returned or not available.

LIST:

PT?

[FDCCH:EBCCH:MACA:LIST:PT?]

Returns the last decoded value of MACA_LIST Parameter Type (4 bit value). Returns -1 if already returned or not available.

NUMber?

[FDCCH:EBCCH:MACA:LIST:NUMber?]

Returns the last decoded value of Number of MACA Channels (4 bit value). Returns -1 if already returned or not available.

CHAN? n.

[FDCCH:EBCCH:MACA:LIST:CHAN?]

Returns the last decoded value of MACA_LIST CHAN (11 bit value) selected by n. Up to 16 instances can be returned. Range of n is 0 to 15. Returns -1 if already returned or not available.

Validity is determined by FDCCH: EBCCH: MACA: LIST: NUMber?.

EBCCH:

MACA:

OTHER:

PT?

[FDCCH:EBCCH:MACA:OTHER:PT?]

Returns the last decoded value of MACA_LIST (Other Hyperband) Parameter Type (4 bit value). Returns -1 if already returned or not available.

HYPERband?

[FDCCH:EBCCH:MACA:OTHER:HYPERband?]

Returns the last decoded value of Hyperband (2 bit value). Returns -1 if already returned or not available.

NUMber?

[FDCCH:EBCCH:MACA:OTHER:NUMber?]

Returns the last decoded value of Number of MACA Channels (4 bit value). Returns -1 if already returned or not available.

CHAN? n

[FDCCH:EBCCH:MACA:OTHER:CHAN?]

Returns the last decoded value of MACA_LIST (Other Hyperband) CHAN (11 bit value) selected by n. Up to 16 instances can be returned. Range of n is 0 to 15. Returns -1 if already returned or not available.

Validity is determined by FDCCH:EBCCH:MACA: OTHER:NUMber?.

MAP:

VPM?

[FDCCH:EBCCH:MAP:VPM?]

Returns the last decoded value of Voice Privacy Mode Map (4 bit value). Returns -1 if already returned or not available.

DPM2

[FDCCH:EBCCH:MAP:DPM?]

Returns the last decoded value of Data Privacy Mode Map (4 bit value). Returns -1 if already returned or not available.

CODER?

[FDCCH:EBCCH:MAP:CODER?]

Returns the last decoded value of Voice Coder Map (6 bit value). Returns -1 if already returned or not available.

EBCCH:

MAP:

MEA:

DOMAIN?

[FDCCH:EBCCH:MAP:MEA:DOMAIN?]

Returns the last decoded value of Message Encryption Algorithm Domain Map (8 bit value). Returns -1 if already returned or not available.

ALGORithms? n

[FDCCH:EBCCH:MAP:MEA:ALGORithms?]

Returns the last decoded value of Message Encryption Algorithm (4 bit value) selected by n. Up to 8 instances can be returned. Range of n is 0 to 7. Returns -1 if already returned or not available.

Validity is determined by FDCCH:EBCCH:MAP:MEA:DOMAIN?.

MEK?

[FDCCH:EBCCH:MAP:MEK?]

Returns the last decoded value of Message Encryption Key Map (4 bit value). Returns -1 if already returned or not available.

MENU?

[FDCCH:EBCCH:MAP:MENU?]

Returns the last decoded value of Menu Map (10 bit value). Returns -1 if already returned or not available.

ARQ?

[FDCCH:EBCCH:MAP:ARQ?]

Returns the last decoded value of FACCH/SACCH ARQ Map (1 bit value). Returns -1 if already returned or not available.

USER?

[FDCCH:EBCCH:MAP:USER?]

Returns the last decoded value of User Group Map (1 bit value). Returns -1 if already returned or not available.

SMS?

[FDCCH:EBCCH:MAP:SMS?]

Returns the last decoded value of SMS Map (2 bit value). Returns -1 if already returned or not available.

SOC?

[FDCCH:EBCCH:SOC?]

Returns the last decoded value of SOC (System Operator Code) (12 bit value). Returns -1 if already returned or not available.

EBCCH:

TIME?

[FDCCH:EBCCH:TIME?]

Returns the last decoded value of Time from Jan 1, 1980 (32 bit value). Returns -1 if already returned or not available.

SID?

[FDCCH:EBCCH:SID?]

Returns the last decoded value of System Identification (14 bit value). Returns -1 if already returned or not available.

CHAN?

[FDCCH:EBCCH:CHAN?]

Returns the last decoded value of CHAN (10 bit value). Returns -1 if already returned or not available.

MCC:

CODE?

IFDCCH:EBCCH:MCC:CODE?1

Returns the last decoded value of Mobile Country Code (9 bit value). Returns -1 if already returned or not available.

PT?

[FDCCH:EBCCH:MCC:PT?]

Returns the last decoded value of Mobile Country Code Parameter Type (4 bit value). Returns -1 if already returned or not available.

HYPERband:

INFO?

[FDCCH:EBCCH:HYPERband:INFO?]

Returns the last decoded value of Hyperband Info (2 bit value). Returns -1 if already returned or not available.

PT?

[FDCCH:EBCCH:HYPERband:PT?]

Returns the last decoded value of Hyperband Info Parameter Type (4 bit value). Returns -1 if already returned or not available.

EBCCH:

ZONE:

DIRection?

[FDCCH:EBCCH:ZONE:DIRection?]

Returns the last decoded value of Time Zone Offset Direction (1 bit value). Returns -1 if already returned or not available.

MINutes?

[FDCCH:EBCCH:ZONE:MINutes?]

Returns the last decoded value of Time Zone Offset Minutes (10 bit value). Returns -1 if already returned or not available.

DST?

[FDGCH:EBGCH:ZONE:DST?]

Returns the last decoded value of Time Zone Offset Daylight Savings Indicator (1 bit value). Returns -1 if already returned or not available.

D. SPACH Frames

The next set of commands return data from SPACH frames.

FDCCH:

SPACH:

BU?

[FDCCH:SPACH:BU?]

Returns the last decoded value of Burst Usage (3 bit value). Returns -1 if already returned or not available.

PCON?

[FDCCH:SPACH:PCON?]

Returns the last decoded value of PCH Continuation (1 bit value). Returns -1 if already returned or not available.

BCN?

[FDCCH:SPACH:BCN?]

Returns the last decoded value of BCCH Change Notification (1 bit value). Returns -1 if already returned or not available.

PFM?

[FDCCH:SPACH:PFM?]

Returns the last decoded value of Paging Frame Modifier (1 bit value). Returns -1 if already returned or not available.

BT?

[FDCCH:SPACH:BT?]

Returns the last decoded value of Burst Type (3 bit value). Returns -1 if already returned or not available.

IDT?

[FDCCH:SPACH:IDT?]

Returns the last decoded value of Identity Type (2 bit value). Returns -1 if already returned or not available.

SPACH:

MSID:

MS? n

[FDCCH:SPACH:MSID:MS?]

Returns the 18 Most Significant bits of MSID (Mobile Station Identification) selected by n. Range of n is 0 to 4.

LS? n

[FDCCH:SPACH:MSID:LS?]

Returns the 32 Least Significant bits of MSID (Mobile Station Identification) selected by n. Range of n is 0 to 4.

MIN? n

[FDCCH:SPACH:MSID:MIN?]

Returns the last decoded value of MIN (ASCII String) selected by n. Up to four instances can be returned. Range of n is 0 to 3. Returns -1 if already returned or not available.

If IDT indicates a 34 bit MSID then the value is also stored as a Mobile Identification Number.

MM?

[FDCCH:SPACH:MM?]

Returns the last decoded value of Message Mapping (1 bit value). Returns -1 if already returned or not available.

PEA?

[FDCCH:SPACH:PEA?]

Returns the last decoded value of Partial Echo Assigned (7 bit value). Returns -1 if already returned or not available.

PI?

[FDCCH:SPACH:PI?]

Returns the last decoded value of Polling Indicator (1 bit value). Returns -1 if already returned or not available.

SRM?

[FDCCH:SPACH:SRM?]

Returns the last decoded value of SPACH Response Mode (1 bit value). Returns -1 if already returned or not available.

SPACH:

UGID:

MS? n

[FDCCH:SPACH:UGID:MS?]

Returns the 18 Most Significant bits of UGID (Mobile Station Identification) selected by n. Range of n is 0 to 4.

LS? n

[FDCCH:SPACH:UGID:LS?]

Returns 32 Least Significant bits of UGID (Mobile Station Identification) selected by n. Range of n is 0 to 4.

MIN? n

[FDCCH:SPACH:UGID:MIN?]

Returns the last decoded value of MIN (ASCII String) selected by n. Up to four instances can be returned. Range of n is 0 to 3. Returns -1 if already returned or not available.

If IDT indicates a 34 bit MSID then the value is also stored as a Mobile Identification Number.

EHI?

[FDCCH:SPACH:EHI?]

Returns the last decoded value of Extended Header Information (1 bit value). Returns -1 if already returned or not available.

MEA?

[FDCCH:SPACH:MEA?]

Returns the last decoded value of Message Encryption Algorithm (2 bit value). Returns -1 if already returned or not available.

MEK?

[FDCCH:SPACH:MEK?]

Returns the last decoded value of Message Encryption Key (2 bit value). Returns -1 if already returned or not available.

ARM?

[FDCCH:SPACH:ARM?]

Returns the last decoded value of ARQ Response Mode (1 bit value). Returns -1 if already returned or not available.

FRNO?

[FDCCH:SPACH:FRNO?]

Returns the last decoded value of Frame Number (5 bit value). Returns -1 if already returned or not available.

SPACH:

GA?

[FDCCH:SPACH:GA?]

Returns the last decoded value of Go Away (1 bit value). Returns -1 if already returned or not available.

L3DATA:

SELect n

[FDCCH:SPACH:L3DATA:SELect]

Returns the last decoded value of MIN (ASCII String) selected by n. (There may be up to four L3DATA messages in a SPACH message.) Range of n is 0 to 3. Returns -1 if already returned or not available.

SELect?

Returns the number of the selected L3DATA Message (2 bit value).

MSGtype?

[FDCCH:SPACH:MSGtype?]

Returns the last decoded value of Message Type from the selected L3DATA Message. Returns -1 if already returned or not available. This command returns the following valid message types:

ANALOG	AUDIT	BSCHALCON
BSMC	CAPABILITY	DIGITAL
DRETRY	MSGWTG	PAGE
PU	R-DATA	R-DATA ACCEPT
R-DATA REJECT	REG ACCEPT	REG REJECT
RELEASE	REORDER/INTER	soc
SPACH NOTIF	SSDUP	TEST REG
UCHAL	USER ALERT	INVALID

INVALID is returned if an illegal message code was decoded.

PD?

[FDCCH:SPACH:PD?]

Returns the last decoded value of Protocol Discriminator (2 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

MEM?

[FDCCH:SPACH:MEM?]

Returns the last decoded value of Message Encryption Mode (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPACH:

SCC?

[FDCCH:SPACH:SCC?]

Returns the last decoded value of SAT Color Code (2 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

VMAC?

[FDCCH:SPACH:VMAC?]

Returns the last decoded value of Voice Mobile Attenuation Code (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

CHAN?

[FDCCH:SPACH:CHAN?]

Returns the last decoded value of CHAN (11 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

PROTocol?

[FDCCH:SPACH:PROTocol?]

Returns the last decoded value of Protocol Version (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SUBaddress:

PT7

[FDCCH:SPACH:SUBaddress:PT?]

Returns the last decoded value of Subaddress Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

LENGth?

[FDCCH:SPACH:SUBaddress:LENGth?]

Returns the last decoded value of Length of Subaddress Info content (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ODD EVEN?

[FDCCH:SPACH:SUBaddress:ODD_EVEN?]

Returns the last decoded value of Subaddress Odd/Even indicator (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

TYPE?

[FDCCH:SPACH:SUBaddress:TYPE?]

Returns the last decoded value of Type of Subaddress (3 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPACH:

SUBaddress:

REServed?

[FDCCH:SPACH:SUBaddress:REServed?]

Returns the last decoded value of the combination of the two Subaddress Reserved fields (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ADDRess?

[FDCCH:SPACH:SUBaddress:ADDress?]

Returns the last decoded value of Subaddressing (ASCII String) from the selected L3DATA Message. Returns -1 if already returned or not available.

DTX:

PT?

[FDCCH:SPACH:DTX:PT?]

Returns the last decoded value of DTX Support Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SUPport?

[FDCCH:SPACH:DTX:SUPport?]

Returns the last decoded value of DTX Support (2 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

DISPlay:

PT?

[FDCCH:SPACH:DISPlay:PT?]

Returns the last decoded value of Display Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

LENGth?

[FDCCH:SPACH:DISPlay:LENGth?]

Returns the last decoded value of Length of Display Info (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

CHARacter? n

[FDCCH:SPACH:DISPlay:CHARacter?]

Returns the last decoded value Display Character (8 bit value) selected by n from the selected L3DATA Message. Up to 82 instances can be returned. Range of n is 0 to 81. Returns -1 if already returned or not available.

Validity is determined by FDCCH:SPACH:DISPlay:LENGth?

SPACH:

REREG?

[FDCCH:SPACH:REREG?]

Returns the last decoded value of Forced Re-registration (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

DEBUG?

[FDCCH:SPACH:DEBUG?]

Returns the last decoded value of Debug Display Allowed (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

AUTHBS?

[FDCCH:SPACH:AUTHBS?]

Returns the last decoded value of AUTHBS (18 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

BSMC?

[FDCCH:SPACH:BSMC?]

Returns the last decoded value of BSMC (Base Station Manufacture Code) (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

CUSTOM:

LENGth?

[FDCCH:SPACH:CUSTOM:LENGth?]

Returns the last decoded value of Length of Custom Control in octets (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

CONTrol? n

[FDCCH:SPACH:CUSTOM:CONTrol?]

Returns the last decoded value of Custom Control (8 bit value) selected by n from the selected L3DATA Message. Up to 256 instances can be returned. Range of n is 0 to 255. Returns -1 if already returned or not available.

Validity is determined by FDCCH:SPACH:CUSTOM:LENGth?.

DVCC?

[FDCCH:SPACH:DVCC?]

Returns the last decoded value of DVCC (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

DMAC?

[FDCCH:SPACH:DMAC?]

Returns the last decoded value of DMAC (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPACH:

ATS?

[FDCCH:SPACH:ATS?]

Returns the last decoded value of ATS (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SB?

[FDCCH:SPACH:SB?]

Returns the last decoded value of SB (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

TA?

[FDCCH:SPACH:TA?]

Returns the last decoded value of Time Alignment (5 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

MODE:

DIC?

[FDCCH:SPACH:MODE:DIC?]

Returns the last decoded value of Delay Interval Compensation Mode (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

VOICE:

PT?

[FDCCH:SPACH:MODE:VOICE:PT?]

Returns the last decoded value of Voice Mode Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

VC?

[FDCCH:SPACH:MODE:VOICE:VC?]

Returns the last decoded value of Voice Coder (3 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

PM V?

[FDCCH:SPACH:MODE:VOICE:PM_V?]

Returns the last decoded value of Voice Privacy Mode (3 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

MEM:

PT?

[FDCCH:SPACH:MODE:MEM:PT?]

Returns the last decoded value of Message Encryption Mode Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPACH:

MODE:

MEM:

MEA?

[FDCCH:SPACH:MODE:MEM:MEA?]

Returns the last decoded value of Message Encryption Algorithm (3 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

MED?

[FDCCH:SPACH:MODE:MEM:MED?]

Returns the last decoded value of Message Encryption Domain (3 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

MEK?

[FDCCH:SPACH:MODE:MEM:MEK?]

Returns the last decoded value of Message Encryption Key (3 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

HYPERband:

PT?

[FDCCH:SPACH:HYPERband:PT?]

Returns the last decoded value of Hyperband Info Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

INFO?

[FDCCH:SPACH:HYPERband:INFO?]

Returns the last decoded value of Hyperband Info (2 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

LT?

[FDCCH:SPACH:LT?]

Returns the last decoded value of Last Try (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPACH:

FLAG:

PT?

[FDCCH:SPACH:FLAG:PT?]

Returns the last decoded value of the RCF and AUTH flags Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

RCF?

[FDCCH:SPACH:FLAG:RCF?]

Returns the last decoded value of RCF flag (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

AUTH?

[FDCCH:SPACH:FLAG:AUTH?]

Returns the last decoded value of AUTH flag (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

MSGWTG:

NV?

[FDCCH:SPACH:MSGWTG:NV?]

Returns the last decoded value of Message Waiting Info Number of Values (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

TYPE? n

[FDCCH:SPACH:MSGWTG:TYPE?]

Returns the last decoded value of Type of Message Waiting (4 bit value) selected by n from the selected L3DATA Message. Up to 16 instances can be returned. Range of n is 0 to 15. Returns -1 if already returned or not available.

NUMber? n

[FDCCH:SPACH:MSGWTG:NUMber?]

Returns the last decoded value of Number of Messages Waiting (6 bit value) selected by n from the selected L3DATA Message. Up to 16 instances can be returned. Range of n is 0 to 15. Returns -1 if already returned or not available.

SERVice?

[[FDCCH:SPACH:SERVice?]]

Returns the last decoded value of Service Code (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPACH:

SIGnal:

PT?

[FDCCH:SPACH:SIGnal:PT?]

Returns the last decoded value of Signal Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

PITCH?

[FDCCH:SPACH:SIGnal:PITCH?]

Returns the last decoded value of Signal Pitch (2 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

CADence?

[FDCCH:SPACH:SIGnal:CADence]

Returns the last decoded value of Signal Cadence (6 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

DURation?

[FDCCH:SPACH:SIGnal:DURation?]

Returns the last decoded value of Signal Duration (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

CALLED:

PT?

[FDCCH:SPACH:CALLED:PT?]

Returns the last decoded value of Called Party Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

LENGth?

[FDCCH:SPACH:CALLED:LENGth?]

Returns the last decoded value of Called Party Length of Address Info (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

TYPE?

[FDCCH:SPACH:CALLED:TYPE?]

Returns the last decoded value of Called Party Type of Number (3 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

PLANId?

[FDCCH:SPACH:CALLED:PLANid?]

Returns the last decoded value of Called Party Numbering Plan Identification (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPACH:

CALLED:

ENCoding?

[FDCCH:SPACH:CALLED:ENCoding?]

Returns the last decoded value of Called Party Address Encoding (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ADDRess?

[FDCCH:SPACH:CALLED:ADDRess?]

Returns the last decoded value of Called Party Address (ASCII String) from the selected L3DATA Message. Returns -1 if already returned or not available.

SUBaddress:

PT?

[FDCCH:SPACH:CALLED:SUBaddress:PT?]

Returns the last decoded value of Called Party Subaddress Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

LENGth?

[FDCCH:SPACH:CALLED:SUBaddress:LENGth?]

Returns the last decoded value of Length of Called Party Subaddress Info (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ODD EVEN?

[FDCCH:SPACH:CALLED:SUBaddress:ODD_EVEN?]

Returns the last decoded value of Called Party Subaddress Odd/Even Indicator (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

TYPE?

[FDCCH:SPACH:CALLED:SUBaddress:TYPE?]

Returns the last decoded value of Type of Called Party Subaddress (3 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

REServed?

[FDCCH:SPACH:CALLED:SUBaddress:REServed?]

Returns the last decoded value of the combination of the two Called Party Subaddress Reserved fields (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPACH:

CALLED:

SUBaddress:

ADDRess?

[FDCCH:SPACH:CALLED:SUBaddress:ADDRess?]

Returns the last decoded value of Called Party Subaddress (ASCII String) from the selected L3DATA Message. Returns -1 if already returned or not available.

CALLING:

PT?

[FDCCH:SPACH:CALLING:PT?]

Returns the last decoded value of Calling Party Number Parameter Type available (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not.

LENGth?

[FDCCH:SPACH:CALLING:LENGth?]

Returns the last decoded value of Calling Party Length of Address Info (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

TYPE?

[FDCCH:SPACH:CALLING:TYPE?]

Returns the last decoded value of Type of Calling Party Number (3 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

PLANId?

[FDCCH:SPACH:CALLING:PLANId?]

Returns the last decoded value of Calling Party Number Plan Identification (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ENCoding?

[FDCCH:SPACH:CALLING:ENCoding?]

Returns the last decoded value of Calling Party Address Encoding (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ADDRess?

[FDCCH:SPACH:CALLING:ADDRess?]

Returns the last decoded value of Calling Party Number Address (ASCII String) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPACH:

CALLING:

SUBaddress:

PT?

[FDCCH:SPACH:CALLING:SUBaddress:PT?]

Returns the last decoded value of Calling Party Subaddress Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

LENGth?

[FDCCH:SPACH:CALLING:SUBaddress:LENGth?]

Returns the last decoded value of Calling Party Length of Subaddress Info (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ODD EVEN?

[FDCCH:SPACH:CALLING:SUBaddress:ODD_EVEN?]

Returns the last decoded value of Calling Party Subaddress Odd/Even Indicator (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

TYPE?

[FDCCH:SPACH:CALLING:SUBaddress:TYPE?]

Returns the last decoded value of Calling Party Type of Subaddress (3 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

REServed?

[FDCCH:SPACH:CALLING:SUBaddress:REServed?]

Returns the last decoded value of the combination of the two Calling Party Subaddress Reserved fields (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ADDRess? n

[FDCCH:SPACH:CALLING:SUBaddress:ADDRess?]

Returns the last decoded value of Calling Party Subaddress (8 bit value) selected by n from the selected L3DATA Message. Up to 20 instances can be returned. Range of n is 0 to 19. Returns -1 if already returned or not available.

SPACH:

CALLING:

PRESentation:

PT?

[FDCCH:SPACH:CALLING:PRESentation:PT?]

Returns the last decoded value of Calling Party Presentation Indicator Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

PI?

[FDCCH:SPACH:CALLING:PRESentation:PI?]

Returns the last decoded value of Presentation Indicator (2 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SI?

[FDCCH:SPACH:CALLING:PRESentation:SI?]

Returns the last decoded value of Screening Indicator (2 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

RN?

[FDCCH:SPACH:RN?]

Returns the last decoded value of Request Number (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

RTRANSaction?

[FDCCH:SPACH:RTRANSaction?]

Returns the last decoded value of R-Transaction Identifier (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

RDATA_UNIT:

LENGth?

[FDCCH:SPACH:RDATA_UNIT:LENGth?]

Returns the last decoded value of R-Data Unit Length (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPACH:

RDATA UNIT:

HLP:

IDentifier?

[FDCCH:SPACH:RDATA_UNIT:HLP:IDentifier?]

Returns the last decoded value of R-Data Unit Higher Layer Protocol Identifier (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

DATA? n

[FDCCH:SPACH:RDATA_UNIT:HLP:DATA?]

Returns the last decoded value of Higher Layer Protocol Data Unit (8 bit value) selected by n from the selected L3DATA Message. Up to 255 instances can be returned. Range of n is 0 to 254.

Validity is determined by FDCCH:SPACH:RDATA_UNIT:LENGth?.

MESSage:

CENTer:

PT?

[FDCCH:SPACH:MESSage:CENTer:PT?]

Returns the last decoded value of Message Center Address Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

LENGth?

[FDCCH:SPACH:MESSage:CENTer:LENGth?]

Returns the last decoded value of Message Center Length of Address Info (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

TYPE?

[FDCCH:SPACH:MESSage:CENTer:TYPE?]

Returns the last decoded value of Message Center Address Type of Number (3 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

PLANId?

[FDCCH:SPACH:MESSage:CENTer:PLANid?]

Returns the last decoded value of Message Center Numbering Plan Identification (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPACH:

MESSage:

CENTer:

ENCoding?

[FDCCH:SPACH:MESSage:CENTer:ENCoding?]

Returns the last decoded value of Message Center Address Encoding (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ADDRess?

[FDCCH:SPACH:MESSage:CENTer:ADDRess?]

Returns the last decoded value of Message Center Address (ASCII String) from the selected L3DATA Message. Returns -1 if already returned or not available.

USER:

DEST:

PT7

[FDCCH:SPACH:USER:DEST:PT?]

Returns the last decoded value of User Destination Address Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

LENGth?

[FDCCH:SPACH:USER:DEST:LENGth?]

Returns the last decoded value of User Destination Length of Address Info (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

TYPE?

[FDCCH:SPACH:USER:DEST:TYPE?]

Returns the last decoded value of User Destination Type of Number (3 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

PLANId?

[FDCCH:SPACH:USER:DEST:PLANId?]

Returns the last decoded value of User Destination Address Identification Plan (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPACH:

USER:

DEST:

ENCoding?

[FDCCH:SPACH:USER:DEST:ENCoding?]

Returns the last decoded value of User Destination Address Encoding (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ADDRess?

[FDCCH:SPACH:USER:DEST:ADDRess?]

Returns the last decoded value of User Destination Address (ASCII String) from the selected L3DATA Message. Returns -1 if already returned or not available.

SUBaddress:

PT?

[FDCCH:SPACH:USER:DEST:SUBaddress:PT?]

Returns the last decoded value of User Destination Subaddress Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

LENGth?

[FDCCH:SPACH:USER:DEST:SUBaddress:LENGth?]

Returns the last decoded value of User Destination Length of Subaddress Info (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ODD EVEN?

[FDCCH:SPACH:USER:DEST:SUBaddress:ODD_EVEN?]

Returns the last decoded value of User Destination Subaddress Odd/Even Indicator (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

TYPE?

[FDCCH:SPACH:USER:DEST:SUBaddress:TYPE?]

Returns the last decoded value of User Destination Type of Subaddress (3 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

REServed?

[FDCCH:SPACH:USER:DEST:SUBaddress:REServed?]

Returns the last decoded value of the combination of the two User Destination Subaddress Reserved fields (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPACH:

USER:

DEST:

SUBaddress:

ADDRess?

[FDCCH:SPACH:USER:DEST:SUBaddress:ADDRess?]

Returns the last decoded value of User Destination Subaddressing (ASCII String) from the selected L3DATA Message. Returns -1 if already returned or not available.

GROUP:

PT?

[[FDCCH:SPACH:USER:GROUP:PT?]]

Returns the last decoded value of User Group Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

STATus?

[FDCCH:SPACH:USER:GROUP:STATus?]

Returns the last decoded value of User Group Status (2 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

TYPE?

[FDCCH:SPACH:USER:GROUP:TYPE?]

Returns the last decoded value of User Group Type (2 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ID:

MS?

[FDCCH:SPACH:USER:GROUP:ID:MS?]

Returns the 18 Most Significant bits of User Group Identification. Returns -1 if already returned or not available.

LS?

[FDCCH:SPACH:USER:GROUP:ID:LS?]

Returns the 32 Least Significant bits of User Group Identification. Returns -1 if already returned or not available.

SPACH:

USER:

ORIG:

PT?

[FDCCH:SPACH:USER:ORIG:PT?]

Returns the last decoded value of User Originating Address Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

LENGth?

[FDCCH:SPACH:USER:ORIG:LENGth?]

Returns the last decoded value of User Originating Length of Address Info (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

TYPE?

[FDCCH:SPACH:USER:ORIG:TYPE?]

Returns the last decoded value of User Originating Type of Address (3 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

PLANId?

[FDCCH:SPACH:USER:ORIG:PLANId?]

Returns the last decoded value of User Originating Address Identification Plan (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ENCodina?

[FDCCH:SPACH:USER:ORIG:ENCoding?]

Returns the last decoded value of User Originating Address Encoding (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ADDRess?

[FDCCH:SPACH:USER:ORIG:ADDRess?]

Returns the last decoded value of User Originating Address (ASCII String) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPACH:

USER:

ORIG:

SUBaddress:

PT?

[FDCCH:SPACH:USER:ORIG:SUBaddress:PT?]

Returns the last decoded value of User Originating Subaddress Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

LENGth?

[FDCCH:SPACH:USER:ORIG:SUBaddress:LENGth?]

Returns the last decoded value of User Originating Length of Subaddress Info (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ODD EVEN?

[FDCCH:SPACH:USER:ORIG:SUBaddress:ODD_EVEN?]

Returns the last decoded value of User Originating Subaddress Odd/Even Indicator (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

TYPE?

[FDCCH:SPACH:USER:ORIG:SUBaddress:TYPE?]

Returns the last decoded value of User Originating Type of Subaddress (3 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

REServed?

[FDCCH:SPACH:USER:ORIG:SUBaddress:REServed?]

Returns the last decoded value of the combination of the two User Originating Subaddress Reserved fields (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ADDRess? n

[FDCCH:SPACH:USER:ORIG:SUBaddress:ADDRess?]

Returns the last decoded value of User Originating Subaddress (8 bit value) selected by n from the selected L3DATA Message. Up to 20 instances can be returned. Range of n is 0 to 19. Returns -1 if already returned or not available.

SPACH:

PFC:

PT?

[FDCCH:SPACH:PFC:PT?]

Returns the last decoded value of PFC Assignment Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ASSIGNment?

[FDCCH:SPACH:PFC:ASSIGNment?]

Returns the last decoded value of PFC Assignment (3 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

RNUM:

PT?

[FDCCH:SPACH:RNUM:PT?]

Returns the last decoded value of RNUM List Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

NUMber?

[FDCCH:SPACH:RNUM:NUMber?]

Returns the last decoded value of Number of RNUMs (6 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

LIST? n

[FDCCH:SPACH:RNUM:LIST?]

Returns the last decoded value of RNUM (10 bit value) selected by n from the selected L3DATA Message. Up to 50 instances can be returned. Range of n is 0 to 49. Returns -1 if already returned or not available.

Validity is determined by FDCCH:SPACH:RNUM:NUMber?

MSID:

PT?

[FDCCH:SPACH:MSID:PT?]

Returns the last decoded value of MSID Assignment Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

IDT?

[FDCCH:SPACH:MSID:IDT?]

Returns the last decoded value of MSID Assignment IDT (2 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPACH:

MSID:

ASSIGNment?

[FDCCH:SPACH:MSID:ASSIGNment?]

Returns the last decoded value of MSID Assignment (24 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

PSID_RSID:

AVAILable:

PT?

[FDCCH:SPACH:PSID_RSID:AVAILable:PT?]

Returns the last decoded value of PSID/RSID Available Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

NUMber?

[FDCCH:SPACH:PSID_RSID:AVAILable:NUMber?]

Returns the last decoded value of Number of PSID/RSID (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

TYPE? n

[FDCCH:SPACH:PSID RSID:AVAILable:TYPE?]

Returns the last decoded value of PSID/RSID Type Indicator (1 bit value) selected by n from the selected L3DATA Message. Up to 16 instances can be returned. Range of n is 0 to 15. Returns -1 if already returned or not available.

Validity is determined by FDCCH:SPACH:PSID_RSID:AVAILable:NUMber?.

VALUE? n

[FDCCH:SPACH:PSID RSID:AVAILable:VALUE?]

Returns the last decoded value of PSID/RSID Value (1 bit value) selected by n from the selected L3DATA Message. Up to 16 instances can be returned. Range of n is 0 to 15. Returns -1 if already returned or not available.

Validity is determined by FDCCH:SPACH:PSID RSID:AVAILable:NUMber?

MAP?

[FDCCH:SPACH:PSID_RSID:MAP?]

Returns the last decoded value of PSID/RSID Map (16 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPACH:

DIRectory:

PT?

[FDCCH:SPACH:DIRectory:PT?]

Returns the last decoded value of Directory Address Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

LENGth?

[FDCCH:SPACH:DIRectory:LENGth?]

Returns the last decoded value of Director Length of Address Info (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

TYPE?

[FDCCH:SPACH:DIRectory:TYPE?]

Returns the last decoded value of Directory Address Type of Number (3 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

PLANId?

[FDCCH:SPACH:DIRectory:PLANid?]

Returns the last decoded value of Directory Address Identification Plan (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ENCoding?

[FDCCH:SPACH:DIRectory:ENCoding?]

Returns the last decoded value of Directory Address Encoding (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ADDRess?

[FDCCH:SPACH:DIRectory:ADDRess?]

Returns the last decoded value of Directory Address (ASCII String) from the selected L3DATA Message. Returns -1 if already returned or not available.

SUBaddress:

PT?

[FDCCH:SPACH:DIRectory:SUBaddress:PT?]

Returns the last decoded value of Directory Subaddress Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPACH:

DIRectory:

SUBaddress:

LENGth?

[FDCCH:SPACH:DIRectory:SUBaddress:LENGth?]

Returns the last decoded value of Directory Length of Subaddress Info (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ODD_EVEN?

[FDCCH:SPACH:DIRectory:SUBaddress:ODD_EVEN?]

Returns the last decoded value of Directory Subaddress Odd/Even Indicator (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

TYPE?

[FDCCH:SPACH:DIRectory:SUBaddress:TYPE?]

Returns the last decoded value of Directory Type of Subaddress (3 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

REServed?

[FDCCH:SPACH:DIRectory:SUBaddress:REServed?]

Returns the last decoded value of the combination of the two Directory Subaddress Reserved fields (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

ADDRess? n

[FDCCH:SPACH:DIRectory:SUBaddress:ADDRess?]

Returns the last decoded value of Directory Subaddress (8 bit value) selected by n from the selected L3DATA Message. Up to 20 instances can be returned. Range of n is 0 to 19. Returns -1 if already returned or not available.

REJect:

REGistration:

CAUSE?

[FDCCH:SPACH:REJect:REGistration:CAUSE?]

Returns the last decoded value of Registration Reject Cause (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPACH:

REJect:

REGistration:

TIME:

PT?

[FDCCH:SPACH:REJect:REGistration:TIME:PT?]

Returns the last decoded value of Reject Time Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

LOWer?

[FDCCH:SPACH:REJect:REGistration:TIME:LOWer?]

Returns the last decoded value of Reject Lower Time Boundary in 100 SF (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

UPPer?

[FDCCH:SPACH:REJect:REGistration:TIME:UPPer?]

Returns the last decoded value of Reject Upper Time Boundary in 100 SF (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

RDATA:

CAUSE?

[FDCCH:SPACH:REJect:RDATA:CAUSE?]

Returns the last decoded value of R-CAUSE (7 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPARE?

[FDCCH:SPACH:REJect:RDATA:SPARE?]

Returns the last decoded value of R-CAUSE Spare (1 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

RELease:

CAUSE?

[FDCCH:SPACH:RELease:CAUSE?]

Returns the last decoded value of Release Cause (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPACH:

REorder:

CAUSE?

[FDCCH:SPACH:REorder:CAUSE?]

Returns the last decoded value of Reorder/Intercept Cause (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

TONE?

[FDCCH:SPACH:REorder:TONE?]

Returns the last decoded value of Tone Indicator (2 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SOC?

[FDCCH:SPACH:SOC?]

Returns the last decoded value of SOC (System Operator Code) (12 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

NOTification?

[FDCCH:SPACH:NOTification?]

Returns the last decoded value of SPACH Notification (6 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

RANDSSD1?

[FDCCH:SPACH:RANDSSD1?]

Returns the last decoded value of the 24 most significant bits of RANDSSD from the selected L3DATA Message. Returns -1 if already returned or not available.

RANDSSD2?

[FDCCH:SPACH:RANDSSD2?]

Returns the last decoded value of the 32 least significant bits of RANDSSD from the selected L3DATA Message. Returns -1 if already returned or not available.

ALPHA:

SID:

PT?

[FDCCH:SPACH:ALPHA:SID:PT?]

Returns the last decoded value of Alphanumeric System ID Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

LENGth?

[FDCCH:SPACH:ALPHA:SID:LENGth?]

Returns the last decoded value of Length of Alphanumeric System ID (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

SPACH:

ALPHA:

SID:

CHARacters?

[FDCCH:SPACH:ALPHA:SID:CHARacters?]

Returns the last decoded value of Alphanumeric System ID (ASCII String) from the selected L3DATA Message. Returns -1 if already returned or not available.

PSID RSID:

PT?

[FDCCH:SPACH:ALPHA:PSID_RSID:PT?]

Returns the last decoded value of Alphanumeric PSID/RSID List Parameter Type (4 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

LENGth?

[FDCCH:SPACH:ALPHA:PSID_RSID:LENGth?]

Returns the last decoded value of Length of Alphanumeric PSID/RSID List (8 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

NAME:

LENGth? n

[FDCCH:SPACH:ALPHA:PSID_RSID:NAME:LENGth?]

Returns the last decoded value of Length of PSID/RSID Alphanumeric Name (4 bit value) selected by n from the selected L3DATA Message. Up to 16 instances can be returned. Range of n is 0 to 15. Returns -1 if already returned or not available.

CHARacters? n

[FDCCH:SPACH:ALPHA:PSID_RSID:NAME:CHARacters?]

Returns the last decoded value of Alphanumeric PSID/RSID Display Characters (ASCII String) selected by n from the selected L3DATA Message. Up to 16 instances can be returned. Range of n is 0 to 15. Returns -1 if already returned or not available.

RANDU?

[FDCCH:SPACH:RANDU?]

Returns the last decoded value of RANDU (24 bit value) from the selected L3DATA Message. Returns -1 if already returned or not available.

			· (**

7-16 DCCH CELL SITE SIMULATION

This section contains the TMAC commands necessary to simulate the transmit portion of a Base Station operating on the DCCH. The RDCCH monitor commands, also considered a part of Cell Site Simulation, are described in Section 7-17.

7-16-1 SETUP COMMANDS

To configure the FM/AM-1600CSA for Cell Site Simulation, use the following TMAC commands:

- **CSS:SETup** (See 7-9-1)
- CSS:CHANnel (See 7-9-1)
- CSS:RFLVL (See 7-9-1)
- CSS:SLOT (See 7-9-1)
- CSS:RATE (See 7-9-1)

7-16-2 SUPERFRAME SETUP

The FDCCH Generator has all the TMAC commands and operations needed to build and maintain a Superframe. Each phase of the Superframe can be changed as the Superframe is being transmitted. A TMAC command returns the Superframe phase currently being transmitted. This enables a TMAC program, that changes the data, to become synchronized with the Superframe cycle.

CSS:

FDCCH:

SUPERframe:

SFP n.m

[CSS:FDCCH:SUPERframe:SFP]

Selects a Super Frame Phase (m) within a Superframe slot (n) being programmed. Range of n is 0 to 31; range of m is 0 to 255.

The CRC is performed by the FM/AM-1600CSA.

SFP? n

Returns current value of SFP indexed by n. Range of n is 0 to 31.

BRI n.m

[CSS:FDCCH:SUPERframe:BRI]

Specifies Busy/Idle/Reserved (m) within a selected Superframe slot (n) being programmed. Range of n is 0 to 31; range of m is 0 to 63.

BRI? n

Returns current value of BRI indexed by n. Range of n is 0 to 31.

PE n, m

[CSS:FDCCH:SUPERframe:PE]

Specifies Partial Echo (m) within a Superframe slot (n) being programmed. Range of n is 0 to 31; range of m is 0 to 127.

The CRC is performed by the FM/AM-1600CSA.

PE? n

Returns current value of PE indexed by n. Range of n is 0 to 31.

RN n,m

[CSS:FDCCH:SUPERframe:RN]

Specifies Received/Not Received (m) within a Superframe slot (n) being programmed. Range of n is 0 to 31; range of m is 0 to 31.

RN? n

Returns current value of RN indexed by n. Range of n is 0 to 31.

FDCCH:

SUPERframe:

DATA n,x,word

[CSS:FDCCH:SUPERframe:DATA]

Specifies one of the 7 words (indexed by x) that comprise the data transmitted per selected Superframe slot (n). Range of n is 0 to 31; range of x is 0 to 6; range of word is 0 to #hFFFF.

The data transmitted in a Superframe slot consists of 109 bits. The data is divided into seven 16 bit words. x = 0 selects the most significant word. x = 6 selects the least significant word.

The CRC, convolutional encoding and interleaving processes are performed by the FM/AM-1600CSA.




Figure 7-11 Superframe Data Message

DATA? n,m

Returns current value of DATA indexed by n. Range of n is 0 to 31; range of m is 0 to 6.

FDCCH:

SUPERframe:

TYPE n,m

[CSS:FDCCH:SUPERframe:TYPE]

Specifies Type (m) of data in Superframe slot (n). Range of n is 0 to 31, range of m is 0 to 4.

m	TYPE		
0	F-BCCH		
1	E-BCCH		
2	S-BCCH		
3	SPACH		
4	RESERVED		

TYPE? n

Returns current value of TYPE indexed by n. Range of n is 0 to 31.

DVCC n

[CSS:FDCCH:SUPERframe:DVCC]

Specifies Digital Verification Color Code. Range of n is 0 to 255.

DVCC must be specified in order to calculate the CRC for each type except F-BCCH.

DVCC?

Returns current value of DVCC. Range of n is 0 to 31.

STAR

[CSS:FDCCH:SUPERframe:STARt]

Starts the superframe generating task.

STOP

[CSS:FDCCH:SUPERframe:STOP]

Stops the superframe generating task.

FDCCH:

SUPERframe:

ACCess:

TYPE:

RANDom

[CSS:FDCCH:SUPERframe:ACCess:TYPE:RANDom]

Programs the FM/AM-1600CSA to allow a mobile station to make a Random access.

The values that make up the SCF (Shared Channel Feedback) are overwritten when an access occurs.

REServed

[CSS:FDCCH:SUPERframe:ACCess:TYPE:REServed]

Programs the FM/AM-1600CSA to allow a mobile station to make a Random access.

The values that make up the SCF (Shared Channel Feedback) are overwritten when an access occurs.

PROGram

[CSS:FDCCH:SUPERframe:ACCess:TYPE:PROGram]

The values of SCF will be setup as pre-programmed by the following command.

NONE

[CSS:FDCCH:SUPERframe:ACCess:TYPE:NONE]

The values that make up the SCF do not change when an access occurs.

TYPE?

[CSS:FDCCH:SUPERframe:ACCess:TYPE?]

Returns current value of TYPE.

PE n

[CSS:FDCCH:SUPERframe:ACCess:PE]

Programs the Partial Echo used during a Random or Reserved access. Range of n is 0 to 127.

The CRC is performed by the FM/AM-1600CSA.

PE?

Returns current value of PE.

FDCCH:

SUPERframe:

ACCess:

SCF n,m

[CSS:FDCCH:SUPERframe:ACCess:SCF]

Pre-program the Shared Channel Feedback response (m) in the selected frame (n) of a RACH. Range of n is 0 to 79; range of m is 0 to 11.

m	PE MATCH	R/N	BRI	LEGEND
0	Match	R	В	R Received
1	Mismatch	R	В	N Not Received
2	Match	R	R	B Busy
3	Mismatch	R	R	R Reserved
4	Match	R	I	l Idle
5	Mismatch	R	1	
6	Match	N	В	
7	Mismatch	N	В	
æ	Match	N	R	
9	Mismatch	N	R	
10	Match	N	-	
11	Mismatch	N		

Table 7-1 Shared Channel Feedback Response

SCF? n

Returns current value of SCF indexed by n. Range of n is 0 to 31.

NUMber?

[CSS:FDCCH:SUPERframe:NUMber?]

Returns the current number of the selected slot in the superframe being transmitted.

The returned value of this command indicates which slot of the superframe is currently being transmitted. Using this information, a program or macro can change the data in the superframe without disturbing the slot currently being transmitted.

7-16-3 F-BCCH COMMANDS

The F-BCCH commands are used to build data into the F-BCCH slots of the superframe. These commands enable the user to construct the F-BCCH by specifying the Layer 3 BCCH message types and data fields. The F-BCCH slots can be built and then, with the aid of the CSS:FDCCH: SUPERframe:NUMber? command, be placed at the start of the superframe while the E-BCCH slots or SPACH slots are being transmitted. This enables the F-BCCH to be constantly updated, even as the superframe is being transmitted. In addition, any slot of the F-BCCH can be manually modified or distorted by the CSS:FDCCH:SUPERframe:DATA command.

CSS:

FBCCH:

BUILD

[CSS:FBCCH:BUILD]

This command builds the data that makes up the F-BCCH. This data can then be returned by the CSS:FBCCH:DATA? command defined below. Before executing this command, the message types and data fields that make up the F-BCCH should be programmed. This command then, takes that information and generates all the data that makes up the data field in each slot of the F-BCCH section of the superframe. The superframe can then be programmed with the CSS:FBCCH:PROGram command defined below. Perform the following steps to build an F-BCCH:

- 1. Enable the desired Message Types.
- 2. Enable the desired optional fields associated with the selected message types.
- 3. Program the data fields associated with the enabled message types.
- 4. Build the F-BCCH.
- 5. Program the superframe.

LENGth?

[CSS:FBCCH:LENGth?]

After the CSS:FBCCH:BUILD command has been executed, the Length of the F-BCCH in slots, can be returned. Knowing the length of the F-BCCH aids the user in setting up the number of F-BCCH data fields in the DCCH Structure.

DATA? n,m

[CSS:FBCCH:DATA?]

This command returns the F-BCCH data that has been built. Returns the 16 bit word indexed by m from slot (n). Range of n is 0 to 10; range of m is 0 to 6.

Each slots consist of 109 bits. The 16 most significant bits of the data are returned when m = 0; the 13 least significant bits of data are returned when m = 6. The data returned is left justified.

The above data format correlates with the data format used in the CSS:FDCCH:SUPER: DATA n,x,word command.

FBCCH:

PROGram

[CSS:FBCCH:PROGram]

Programs the F-BCCH slots in the superframe with the data constructed by the CSS:FBCCH:BUILD command.

FC n

[CSS:FBCCH:FC]

Enables (n = 1) or disables (n = 0) Fast Broadcast Control Channel Change Flag.

FC?

Returns current state of FC.

EC n

[CSS:FBCCH:EC]

Enables (n = 1) or disables (n = 0) Extended Broadcast Control Channel Change Flag.

EC?

Returns current state of EC.

MSGtype:

STRUCTure n

[CSS:FBCCH:MSGtype:STRUCTure]

Enables (n = 1) or disables (n = 0) DCCH Structure.

This message shall always be sent first.

ACCess n

[CSS:FBCCH:MSGtype:ACCess]

Enables (n = 1) or disables (n = 0) Access Parameters.

SELection n

[CSS:FBCCH:MSGtype:SELection]

Enables (n = 1) or disables (n = 0) Control Channel Selection Parameters.

REGistration n

[CSS:FBCCH:MSGtype:REGistration]

Enables (n = 1) or disables (n = 0) Registration parameters.

SYSID n

[CSS:FBCCH:MSGtype:SYSID]

Enables (n = 1) or disables (n = 0) System Identification.

OLC n

[CSS:FBCCH:MSGtype:OLC]

Enables (n = 1) or disables (n = 0) Overload Class.

Used to regulate originations and registrations on the RACH.

FBCCH:

MSGtype:

MACA n

[CSS:FBCCH:MSGtype:MACA]

Enables (n = 1) or disables (n = 0) Mobile Assisted Channel Allocation.

When enabled, orders the mobile station to report radio measurements on certain channels. Order consists of instructions regarding the channels the mobile station shall measure and when to report the measurements for the Mobile Assisted Channel Allocation.

BSMC n

[CSS:FBCCH:MSGtype:BSMC]

Enables (n = 1) or disables (n = 0) Base Station Manufacture Code.

SERVice n

[CSS:FBCCH:MSGtype:SERVice]

Enables (n = 1) or disables (n = 0) Service Menu.

Provides a list of services supported by the BMI.

SOC_BSMC n

[CSS:FBCCH:MSGtype:SOC_BSMC]

Enables (n = 1) or disables (n = 0) System Operator Code/Base Station Manufacture Code.

SOC and BSMC value associated with the BMI.

SOC n

[CSS:FBCCH:MSGtype:SOC]

Enables (n = 1) or disables (n = 0) Message Delivery.

NUMber:

FBCCH n

[CSS:FBCCH:NUMber:FBCCH]

Specifies Number of FBCCH. Range of n is 0 to 7.

FBCCH?

Returns current value of FBCCH.

EBCCH n

[CSS:FBCCH:NUMber:EBCCH]

Specifies Number of EBCCH. Range of n is 0 to 7.

EBCCH?

Returns current value of FBCCH.

FBCCH:

NUMber:

SBCCH n

[CSS:FBCCH:NUMber:SBCCH]

Specifies Number of SBCCH. Range of n is 0 to 15.

SBCCH?

Returns current value of SBCCH.

REServed n

[CSS:FBCCH:NUMber:REServed]

Specifies Number of Reserved Slots. Range of n is 0 to 7.

REServed?

Returns current value of REServed.

NON PCH n

[CSS:FBCCH:NUMber:NON_PCH]

Specifies Number of Non-Paging Channel Subchannel Slots. Range of n is 0 to 3.

NON PCH?

Returns current value of NON_PCH.

HYPERframe n

[CSS:FBCCH:HYPERframe]

Specifies Hyperframe Counter. Range of n is 0 to 15.

HYPERframe?

Returns current value of HYPERframe.

EXTended n

[CSS:FBCCH:EXTended]

Specifies Extended Hyperframe Counter. Range of n is 0 to 7.

EXTended?

Returns current value of EXTended.

SUPERframe n

[CSS:FBCCH:SUPERframe]

Enables (n = 1) or disables (n = 0) Primary Superframe Indicator.

SUPERframe?

Returns current state of SUPERframe.

FBCCH:

CONfiguration n

[CSS:FBCCH:CONfiguration]

Specifies Slot Configuration. Range of n is 0 to 3.

CONfiguration?

Returns current value of CONFiguration.

DVCC n

[CSS:FBCCH:DVCC]

Specifies Digital Verification Color Code. Range of n is 0 to 255.

DVCC?

Returns current value of DVCC.

PFC n

[CSS:FBCCH:PFC]

Specifies MAX_SUPPORTED_PFC. Range of n is 0 to 7.

Maximum paging frame class supported by a DCCH or a mobile station

PFC?

Returns current value of PFC.

PCH n

[CSS:FBCCH:PCH]

Specifies PCH_DISPLACEMENT (Paging Channel Displacement). Range of n is 0 to 7.

Number of additional SPACH Slots the mobile station reads when PCON (page continuation) is enabled.

PCH?

Returns the value of PCH.

PFM n

[CSS:FBCCH:PFM]

Enables (n = 1) or disables (n = 0) PFM_DIRECTION.

Paging Frame Modifier defines whether the Layer 2 PFM flag is a pull-in (reduce the Paging Frame Class by one) or a push-out (increment by one) flag.

PFM?

Returns current state of PFM.

FBCCH:

CBN:

HIGH n

[CSS:FBCCH:CBN:HIGH]

Specifies CBN High. Range of n is 0 to #hFFFF.

Contains information to support message encryption on the forward and reverse DCCH and DTC.

HIGH?

Returns the value of HIGH.

NONPublic:

PROBability:

Can be used to determine if each channel probability block for a given system configuration contains a DCCH for a non-public system in the current service area.

LENGth n

[CSS:FBCCH:NONPublic:PROBability:LENGth]

Specifies Non-Public Map Length. Range of n is 0 to 15.

LENGth?

Returns current value of LENGth.

BLOCK n

[CSS:FBCCH:NONPublic:PROBability:BLOCK]

Specifies Non-Public Block Map. Range of n is 0 to #hFFFF.

BLOCk?

Returns current value of BLOCk.

REGistration:

CONTrol n

[CSS:FBCCH:NONPublic:REGistration:CONTrol]

Specifies Non-Public Registration Control. Range of n is 0 to 3.

CONTrol?

Returns current value of CONTrol.

FBCCH:

AUTH n

[CSS:FBCCH:AUTH]

Enables (n = 1) or disables (n = 0) AUTH.

When enabled, mobile station sends the Authentication message along with a Registration, Origination, Page Response or SPACH Confirmation message due to SPACH Notification indicating R-DATA.

AUTH?

Returns current state of AUTH.

S n

[CSS:FBCCH:S]

Enables (n = 1) or disables (n = 0) Serial number.

When enabled, the mobile station sends the Serial Number message along with a Registration, Origination, Page Response or SPACH Confirmation message due to SPACH Notification indicating R-DATA, Base Station Challenge Order or Unique Challenge Order Confirmation.

S?

Returns current state of S.

RAND n

[CSS:FBCCH:RAND]

Specifies RAND. Range of n is 0 to #hFFFFFFF.

Random number stored by a mobile station is used for selected authentication processes.

RAND?

Returns current value of RAND.

ACCess:

MS PWR n

[CSS:FBCCH:ACCess:MS_PWR]

Specifies MS_ACC_PWR (Mobile Station Analog Control Channel Power). Range of *n* is 0 to 15.

Maximum nominal output power that the mobile station shall use when accessing the BMI (Base Station, MSC and Interworking Function). MS_ACC_PWR is also used when determining criteria for control channel selection and reselection.

MS PWR?

Returns current value of MS PWR.

FBCCH:

ACCess:

RSS MIN n

[CSS:FBCCH:ACCess:RSS_MIN]

RSS_ACC_MIN (Received Signal Strength Analog Control Channel Minimum). Range of n is 0 to 31.

Used for the cell (re)selection process. RSS_ACC_MIN is the minimum received signal strength required to access the cell.

RSS MIN?

Returns current value of RSS_MIN.

BURSTsize n

[CSS:FBCCH:ACCess:BURSTsize]

Enables (n = 1) or disables (n = 0) Access Burst Size.

Informs the mobile station of which burst size to use on the RACH (Random Access Control Channel).

BURSTsize?

Returns current state of BURSTsize.

MAX:

RETries n

[CSS:FBCCH:MAX:RETries]

Specifies Max Retries. Range of n is 0 to 7.

Maximum number of access attempts that Layer 2 can make before declaring the access to have failed.

RETries?

Returns current value of RETries.

BUSY n

[CSS:FBCCH:MAX:BUSY]

Enables (n = 1) or disables (n = 0) Max Busy/Reserved.

Maximum number of times that BRI (Busy Reserved Idle) # Idle can be detected during any given access attempt before Layer 2 declares an access attempt failure.

BUSY?

Returns current state of BUSY.

FBCCH:

MAX:

REPetitions n

[CSS:FBCCH:MAX:REPititions]

Specifies Max Repetitions. Range of n is 0 to 3.

Maximum number of times a specific burst within any given access attempt may be sent to the RACH before Layer 2 declares an access attempt failure.

REPetitions?

Returns current value of REPetitions.

STOP n

[CSS:FBCCH:MAX:STOP]

Enables (n = 1) or disables (n = 0) Max Stop Counter.

Max Stop Counter identifies the maximum number of times either of the following conditions can be detected for any given access attempt before Layer 2 declares an access attempt failure:

- BRI set to Reserved or Idle after sending an intermediate burst of an access attempt.
- R/N set to Not Received along with BRI set to Reserved or Idle after sending the last burst of an access attempt.

STOP?

Returns current value of STOP.

RDATA:

LENGth n

[CSS:FBCCH:RDATA:LENGth]

Specifies R-DATA Message Length. Range of n is 0 to 7.

LENGth?

Returns current value of LENGth.

BARred n

[CSS:FBCCH:BARred]

Specifies Cell Barred. Range of n is (0-31).

BARred?

Returns current value of BARred.

FBCCH:

SUBaddressing n

[CSS:FBCCH:SUBaddressing]

Enables (n = 1) or disables (n = 0) Subaddressing Support.

SUBaddressing?

Returns current state of SUBaddressing.

DIC n

[CSS:FBCCH:DIC]

Enables (n = 1) or disables (n = 0) Delay Interval Compensation Mode.

Controls the DIC mode application in the mobile station. When received in the access parameters message, the domain of DIC application shall be the DCCH. When received in the Digital Traffic Channel Designation message, the domain of DIC application shall be the DTC.

DIC?

Returns current value of DIC.

SS SUFF n

[CSS:FBCCH:SS_SUFF]

Specifies Signal Strength Sufficient. Range of n is 0 to 31.

Minimum Signal Strength Sufficient for a candidate control channel to be considered for control channel reselection. SS_SUFF is used, in some instances, to control cell reselection using an absolute threshold.

SS SUFF?

Returns current value of SS_SUFF.

SCAN:

iNTerval n

[CSS:FBCCH:SCAN:INTerval]

Specifies SCANINTERVAL. Range of n is 0 to 15.

Basic interval, in Hyperframes, between consecutive signal strength measurements. The basic interval is set to 1 plus the value of the field.

INTerval?

Returns current value of INTerval.

FBCCH:

SCAN:

OPTION n

[CSS:FBCCH:SCAN:OPTION]

Enables (n = 1) or disables (n = 0) Scanning Option Indicator.

When enabled, mobile station can apply the optional enhancements to the signal strength measurement interval applicable to NL entries.

OPTION?

Returns current state of OPTION.

INITial n

[CSS:FBCCH:INITial]

Enables (n = 1) or disables (n = 0) Initial Selection Control.

Used to discourage a mobile station executing the Control Channel Selection procedure (initial selection) from selecting a DCCH for camping purposes.

INITial?

Returns current state of INITial.

DELay n

[CSS:FBCCH:DELay]

Specifies Delay. Range of n is 0 to 15.

Used for Control Channel reselection purposes.

DELay?

Returns current value of DELay.

ADDitional:

NUMber n

[CSS:FBCCH:ADDitional:NUMber]

Specifies Number of additional DCCH Channels. Range of n is 0 to 7.

NUMber?

Returns current value of NUMber.

DCCH:

CHANnel n.m

[CSS:FBCCH:ADDitional:DCCH:CHANnel]

Specifies DCCH Channel (m) indexed by n. Range of n is 0 to 7; range of m is 0 to 2047.

CHANnel? n

Returns current value of CHANnel indexed by n. Range of n is 0 to 7.

FBCCH:

ADDitional:

DCCH:

SLOT n.m

[CSS:FBCCH:ADDitional:DCCH:SLOT]

Specifies Slot Configuration (m) indexed by n. Range of n is 0 to 7; range of m is 0 to 3.

Indicates the number of slots assigned to DCCHs on the channel in the DCCH Channel field.

SLOT? n

Returns current value of SLOT indexed by n. Range of n is 0 to 7.

REGH n

[CSS:FBCCH:REGH]

Enables (n = 1) or disables (n = 0) REGH.

When enabled, a home mobile station is allowed to register.

REGH?

Returns current state of REGH.

REGR n

[CSS:FBCCH:REGR]

Enables (n = 1) or disables (n = 0) REGR.

When enabled, a roaming mobile station is allowed to register.

REGR?

Returns current state of REGR.

PUREG n

[CSS:FBCCH:PUREG]

Enables (n = 1) or disables (n = 0) Power Up Registration.

PUREG?

Returns current state of PUREG.

PDREG n

[CSS:FBCCH:PDREG]

Enables (n = 1) or disables (n = 0) Power Down Registration.

PDREG?

Returns current state of PDREG.

FBCCH:

SYREG n

[CSS:FBCCH:SYREG]

Enables (n = 1) or disables (n = 0) SYREG.

When enabled, a mobile station is to register when it enters a new system identification area.

SYREG?

Returns current state of SYREG.

LAREG n

[CSS:FBCCH:LAREG]

Enables (n = 1) or disables (n = 0) LAREG.

When enabled, a mobile station is to register when the registration number of the current DCCH is not a part of its registration number list used to define its location area.

LAREG?

Returns current state of LAREG.

DEREG n

[CSS:FBCCH:DEREG]

Enables (n = 1) or disables (n = 0) De-Registration.

DEREG?

Returns current state of DEREG.

FOREG n

[CSS:FBCCH:FOREG]

Enables (n = 1) or disables (n = 0) forced registration.

FOREG?

Returns current state of FOREG.

CAPability n

[CSS:FBCCH:CAPability]

Enables (n = 1) or disables (n = 0) Capability Request.

When enabled, a mobile station shall include a Capability Report message when sending a New System registration, Forced registration or Power-Up registration.

CAPability?

Returns current state of CAPability.

FBCCH:

RNUM n

[CSS:FBCCH:RNUM]

Specifies Present RNUM. Range of n is 0 to 1023.

Registration number that is used to define a particular mobile station's VMLA (Virtual Mobile Location Area).

RNUM?

Returns current value of RNUM.

REGPER n

[CSS:FBCCH:REGPER]

Specifies REG Period. Range of n is 0 to 511.

Identifies the registration periodically in number of 94 superframes. REGPER values are coded from 0 to 511 indicating 94 to 48128 superframes (approximately 1 minute to 8.5 hours).

REGPER?

Returns current value of REGPER.

REGID:

ID n

[CSS:FBCCH:REGID:ID]

Specifies System clock. Range of n is 0 to #hFFFFF.

ID?

Returns current value of ID.

PER n

[CSS:FBCCH:REGID:PER]

Specifies how often ID is incremented. Range of n is 0 to 15.

PER?

Returns current value of PER.

SID n

[CSS:FBCCH:SID]

Specifies System Identification. Range of n is 0 to 32767.

Digital identification associated with a cellular system where each system is assigned a unique number.

SID?

Returns current value of SID.

FBCCH:

NETwork n

[CSS:FBCCH:NETwork]

Specifies which Network Types are supported on a control channel. Range of n is 0 to 7.

NETwork?

Returns current value of NETwork.

PROTocol n

[CSS:FBCCH:PROTocol]

Specifies Protocol Version supported. Range of n is 0 to 15.

PROTocol?

Returns current value of PROTocol

PSID_RSID:

Private/Residential System Identification.

SOC n

[CSS:FBCCH:PSID_RSID:SOC]

Specifies System Operator Code. Range of n is 0 to 4095.

Identifies which operator is providing service. If the mobile station receives a reserved SOC value, the value shall be considered an unknown system operator code.

SOC?

Returns current value of SOC.

NUMber n

[CSS:FBCCH:PSID_RSID:NUMber]

Specifies Number of PSID/RSID. Range of n is 0 to 15.

NUMber?

Returns current value of NUMber.

TYPE n,m

[CSS:FBCCH:PSID_RSID:TYPE]

Enables (m = 1) or disables (m = 0) PSID/RSID Type Indicator indexed by n. Range of n is 0 to 15.

TYPE? n

Returns current state of TYPE indexed by n. Range of n is 0 to 15.

FBCCH:

PSID_RSID:

VALUE n,m

[CSS:FBCCH:PSID_RSID:VALUE]

Specifies PSID/RSID Value (m) indexed by n. Range of n is 0 to 15; range of m is 0 to #hFFFF

VALUE? n

Returns current value of VALUE indexed by n. Range of n is 0 to 15.

COUNTRY:

CODE n

[CSS:FBCCH:COUNTRY:CODE]

Specifies Mobile Country Code of the current DCCH. Range of n is 0 to 1023.

CODE?

Returns current value of CODE.

ALPHA:

SID "n"

[CSS:FBCCH:ALPHA:SID]

Specifies Alphanumeric System Identification. n is ASCII string.

SID?

Returns current value of SID.

BSMC n

[CSS:FBCCH:BSMC]

Specifies assigned manufacturers code (Base Station Manufacture Code). Range of n is 0 to 255.

The value of 0 is reserved and shall be considered an unknown base station manufacturer code by the receiving mobile station.

BSMC?

Returns current value of BSMC.

CUSTOM:

LENGth n

[CSS:FBCCH:CUSTOM:LENGth]

Specifies Length. Range of n is 1 to 64.

LENGth?

Returns current value of LENGth.

FBCCH:

CUSTOM:

CONTrol n.m

[CSS:FBCCH:CUSTOM:CONTrol]

Specifies Custom Control (m) indexed by n. Range of n is 0 to 63; range of m is 0 to 255.

CONTrol?

Returns current value of CONTrol.

MACA:

Mobile Assisted Channel Allocation.

STATus n

[CSS:FBCCH:MACA:STATus]

Specifies which MACA function combinations are enabled (MACA_STATUS). Range of n is 0-3.

STATus?

Returns current value of STATus.

TYPE n

[CSS:FBCCH:MACA:TYPE]

Specifies when MACA reporting is to take place (MACA_TYPE). Range of n is 0 to 15.

TYPE?

Returns current value of TYPE.

EIGHT:

CONTrol n

[CSS:FBCCH:MACA:EIGHT:CONTrol]

Enables (n = 1) or disables (n = 0) MACA_8_CONTROL.

This information element, together with MACA_TYPE and MACA_STATUS, determines the number of channels reported.

CONTrol?

Returns current value of CONTrol.

FBCCH:

MACA:

LIST:

Contains information regarding the channels, other than the current DCCH, the mobile station shall measure for mobile assisted channel allocation.

NUMber n

[CSS:FBCCH:MACA:LIST:NUMber]

Specifies Number of MACA Channels. Range of n is 0 to 15.

NUMber?

Returns current value of NUMber.

CHAN n.m

[CSS:FBCCH:MACA:LIST:CHAN]

Specifies Channel (m) indexed by n. Range of n is 0 to 15; range of m is 0 to 2047.

CHAN? n

Returns current value of CHAN indexed by n. Range of n is 0 to 15.

OTHER:

Contains information regarding the channels other than the current DCCH. A mobile station that is not capable of performing measurements on a channel specified in this list shall report a RSS value of 00000 for that channel.

HYPERband n

[CSS:FBCCH:MACA:LIST:OTHER:HYPERband]

Specifies Frequency band information. Range of n is 0 to 3.

HYPERband?

Returns current value of HYPERband.

NUMber n

[CSS:FBCCH:MACA:LIST:OTHER:NUMber]

Specifies Number of MACA Channels. Range of n is 0 to 15.

NUMber?

Returns current value of NUMber.

CHAN n,m

[CSS:FBCCH:MACA:LIST:OTHER:CHAN]

Specifies Channel (m) indexed by n. Range of n is 0 to 15; range of m is 0 to 2047.

CHAN? n

Returns current value of CHAN indexed by n. Range of n is 0 to 15.

FBCCH:

OLC n

[CSS:FBCCH:OLC]

Specifies Overload Class. Range of n is 0 to #hFFFF.

Determines whether or not a mobile station can make an Origination, Registration or Originated Point-to-Point Teleservice. The mobile station must examine the value of the OLC bit map corresponding to internally stored access overload class assignment. If the bit in the OLC bit map is enabled, the mobile station shall continue with its access attempt. Otherwise, it shall not make an access attempt.

OLC?

Returns current value of OLC.

MAP:

VPM n

[CSS:FBCCH:MAP:VPM]

Specifies the forms of voice privacy supported by the BMI (Voice Privacy Mode Map). Range of n is 0 to 15.

VPM?

Returns current value of VPM.

DPM n

[CSS:FBCCH:MAP:DPM]

Specifies the forms of data privacy supported by the BMI (Data Privacy Mode Map). Range of n is 0 to 15.

DPM?

Returns current value of DPM.

CODER n

[CSS:FBCCH:MAP:CODER]

Specifies the types of voice coders supported by the BMI (Voice Coder Map). Range of n is 0 to 63.

CODER?

Returns current value of CODER.

FBCCH:

MAP:

MEA:

Message Encryption Algorithm Map - Identifies the message encryption algorithms, domain and keys supported by a DCCH or a DTC.

DOMAIN n

[CSS:FBCCH:MAP:MEA:DOMAIN]

Specifies the number of instances and ordering of the Encryption Algorithms field (Domain Map). Range of n is 0 to 255.

DOMAIN?

Returns current value of DOMAIN.

ALGORIthms n.m

[CSS:FBCCH:MAP:MEA:ALGORithms]

Specifies Encryption Algorithms (m) indexed by n. Range of n is 0 to 7; range of m is 0 to 15.

ALGORIthms? n

Returns current value of ALGORithms indexed by n. Range of n is 0 to 7.

MEK n

[CSS:FBCCH:MAP:MEK]

Specifies the message encryption keys supported by the BMI (Message Encryption Key Map). Range of n is 0 to 15.

MEK?

Returns current value of MEK.

MENU n

[CSS:FBCCH:MAP:MENU]

Specifies the services supported by the BMI (Menu Map). Range of n is 0 to #h3FF.

MENU?

Returns current value of MENU.

ARQ n

[CSS:FBCCH:MAP:ARQ]

Enables (n = 1) or disables (n = 0) FACCH/SACCH ARQ (Automatic Retransmission Request) Map.

When enabled, the BMI supports FACCH/SACCH ARQ mode on the IS-136 digital traffic channels.

ARQ?

Returns current state of ARQ.

FBCCH:

MAP:

USER n

[CSS:FBCCH:MAP:USER]

Enables (n = 1) or disables (n = 0) User Group Map.

When enabled, the BMI supports User Group operation.

USER?

Returns current state of USER.

SMS n

[CSS:FBCCH:MAP:SMS]

Specifies the extent to which the BMI supports the CMT teleservice (Short Message Service Map). Range of n is 0 to 3.

SMS?

Returns current value of SMS.

IRA n

[CSS:FBCCH:IRA]

Enables (n = 1) or disables (n = 0) International Reference Alphabet.

When enabled, mobile station or BMI supports IRA address encoding in the Address Info information element.

IRA?

Returns current state of IRA.

SOC n

[CSS:FBCCH:SOC]

Specifies which operator is providing service (System Operator Code). Range of n is 0 to 4095.

A received reserved SOC value shall be considered an unknown system operator code by the receiving mobile station.

SOC?

Returns current value of SOC.

ENABLE:

EXTENDED n

[CSS:FBCCH:ENABLE:EXTENDED]

Enables (n = 1) or disables (n = 0) Extended Hyperframe Counter.

EXTENDED?

Returns current state of EXTENDED.

FBCCH:

ENABLE:

CBN:

HIGH n

[CSS:FBCCH:ENABLE:CBN:HIGH]

Enables (n = 1) or disables (n = 0) CBN_High.

HIGH?

Returns current state of HIGH.

NONPublic:

PROBability n

[CSS:FBCCH:ENABLE:NONPublic:PROBability]

Enables (n = 1) or disables (n = 0) Non-Public Probability Blocks.

PROBability?

Returns current state of PROBability.

REGistration n

[CSS:FBCCH:ENABLE:NONPublic:REGistration]

Enables (n = 1) or disables (n = 0) Non-Public Registration Control.

REGistration?

Returns current state of REGistration.

ADDitional:

DCCH n

[CSS:FBCCH:ENABLE:ADDitional:DCCH]

Enables (n = 1) or disables (n = 0) Additional DCCH information.

DCCH?

Returns current state of DCCH.

RNUM n

[CSS:FBCCH:ENABLE:RNUM]

Enables (n = 1) or disables (n = 0) Present Registration Number.

RNUM?

Returns current state of RNUM.

REGPER n

[CSS:FBCCH:ENABLE:REGPER]

Enables (n = 1) or disables (n = 0) REG Period.

REGPER?

Returns current state of REGPER.

FBCCH:

ENABLE:

REGID n

[CSS:FBCCH:ENABLE:REGID]

Enables (n = 1) or disables (n = 0) REGID Parameters.

REGID?

Returns current state of REGID.

PSID RSID n

[CSS:FBCCH:ENABLE:PSID_RSID]

Enables (n = 1) or disables (n = 0) Private/Residential System Identification.

PSID_RSID?

Returns current state of PSID_RSID.

COUNTRY:

CODE n

[CSS:FBCCH:ENABLE:COUNTRY:CODE]

Enables (n = 1) or disables (n = 0) Mobile Country Code.

CODE

Returns current state of CODE.

ALPHA:

SID n

[CSS:FBCCH:ENABLE:ALPHA:SID]

Enables (n = 1) or disables (n = 0) Alphanumeric System Identification.

SID?

Returns current state of SID.

MACA:

Mobile Assisted Channel Allocation.

EIGHT:

CONTrol n

[CSS:FBCCH:ENABLE:MACA:EIGHT:CONTrol]

Enables (n = 1) or disables (n = 0) MACA_8_CONTROL.

CONTrol?

Returns current state of CONTrol.

FBCCH:

ENABLE:

MACA:

LIST n

[CSS:FBCCH:ENABLE:MACA:LIST] • Enables (n = 1) or disables (n = 0) MACA_LIST.

IIST?

Returns current state of LIST.

LIST:

OTHER n

[CSS:FBCCH:ENABLE:MACA:LIST:OTHER] Enables (n = 1) or disables (n = 0) MACA_LIST (Other Hyperband).

OTHER?

Returns current state of OTHER.

7-16-4 E-BCCH COMMANDS

CSS:

EBCCH:

BUILD

[CSS:EBCCH:BUILD]

This command builds the data that makes up the E-BCCH.

Before executing this command, the message types and data fields that make up the E-BCCH should be programmed. This command takes that information and generates all of the slots in the E-BCCH cycle. Since an E-BCCH cycle may continue through several superframes, the length of the E-BCCH built may be longer than Number of E-BCCH allocated to a superframe. Therefore, each time after the E-BCCH slots have been sent, the CSS:EBCCH:PROGram n command, defined below, can be used to transfer the appropriate number of slots of data into the superframe. The following, outlines the process involved in building a E-BCCH:

- 1. Enable the desired message types.
- 2. Enable the desired optional fields associated with the selected message types.
- 3. Program the data fields associated with the enabled message types.
- 4. Build the E-BCCH.
- 5. Program the superframe with the next section of the E-BCCH cycle.

The data built to make up the E-BCCH can be returned by the CSS:EBCCH:DATA? n,m command defined below.

LENGth?

[CSS:EBCCH:LENGth?]

Returns current length of the E-BCCH in slots after the CSS:EBCCH:BUILD command has been executed.

This value is useful in programming the ECL Layer 2 field.

DATA? n.m

[CSS:EBCCH:DATA?]

Returns the E-BCCH data that has been built.

Returns current 16 bit word (indexed by m) in slot (n). Range of n is 0 to 255; range of m is 0 to 6.

Each slot consists of 109 bits of data. The 16 most significant bits of the data are returned when m = 0, and the 13 least significant bits of data are returned when m = 6. All returned data is left justified.

This data format correlates with the data format used in the CSS:FDCCH:SUPER:DATA n.x.word command.

EBCCH:

PROGram dest, source, length

[CSS:EBCCH:PROGram]

Programs the slots in the superframe with the data constructed by CSS:EBCCH:BUILD command. dest is the location in the superframe; source is the start location in the EBCCH buffer; length is the number of frames of data moved from the EBCCH buffer to the superframe. Range of dest is 0 to 31; range of source is 0 to 255; range of length is 0 to 8.

ECL n

[CSS:EBCCH:ECL]

Specifies the total number of Layer 2 frames required for the current E-BCCH Cycle (Extended Broadcast Control Channel Cycle Length). Range of n is 0 to 255.

ECL?

Returns current value of ECL.

MSGtype:

MACA n

[CSS:EBCCH:MSGtype:MACA]

Enables (n = 1) or disables (n = 0) Mobile Assisted Channel Allocation.

Used to order the mobile station to report radio measurements on certain channels. It contains information regarding the channels the mobile station shall measure and when to report the measurements for the mobile assisted channel allocation.

NEIGHbor:

CELL n

[CSS:EBCCH:MSGtype:NEIGHbor:CELL]

Enables (n = 1) or disables (n = 0) Neighbor Cell.

SERVice n

[CSS:EBCCH:MSGtype:NEIGHbor:SERVice]

Enables (n = 1) or disables (n = 0) Neighbor Service Info.

Provides information regarding services support by a TDMA Neighbor.

RCI n

CSS:EBCCH:MSGtype:RCI

Enables (n = 1) or disables (n = 0) Regulatory Configuration.

BSMC n

[CSS:EBCCH:MSGtype:BSMC]

Enables (n = 1) or disables (n = 0) Base Station Manufacture Code Message Delivery.

Used to carry BSMC specific signaling information, the content of which is beyond the scope of this specification.

EBCCH:

MSGtype:

EMERGency n

[CSS:EBCCH:MSGtype:EMERGency]

Enables (n = 1) or disables (n = 0) Emergency Information Broadcast.

Provides emergency information to all mobile stations.

SERVice n

[CSS:EBCCH:MSGtype:SERVice]

Enables (n = 1) or disables (n = 0) Service Menu.

Provides a list of services supported by the BMI.

SOC BSMC n

[CSS:EBCCH:MSGtype:SOC_BSMC]

Enables (n = 1) or disables (n = 0) System Operator Code/Base Station Manufacture Code Message Delivery.

Used to identify the SOC and BSMC value associated with the BMI.

SOC n

[CSS:EBCCH:MSGtype:SOC]

Enables (n = 1) or disables (n = 0) System Operator Code Message Delivery.

Used to carry SOC specific signaling information, the content of which is beyond the scope of this specification.

TIME n

[CSS:EBCCH:MSGtype:TIME]

Enables (n = 1) or disables (n = 0) Time and Date.

ALTrci n

[CSS:EBCCH:MSGtype:ALTrci]

Enables (n = 1) or disables (n = 0) Alternate Regulatory Configuration Information.

Provides information regarding a DCCH associated with a regulatory configuration different from that of the current DCCH.

SERV SS n

[CSS:EBCCH:SERV_SS]

Specifies SERV_SS. Range of n is 0 to 15.

Used in the control channel reselection process.

SERV SS?

Returns current value of SERV_SS.

EBCCH:

NONPublic:

LENGth n

[CSS:EBCCH:NONPublic:LENGth]

Specifies Non-Public Map Length. Range of n is 0 to 15.

LENGth?

Returns current value of LENGth.

BLOCK n

[CSS:EBCCH:NONPublic:BLOCK]

Specifies Non-Public Block Map. Range of n is 0 to #hFFFF.

BLOCK?

Returns current value of BLOCK.

NEIGHbor:

TDMA:

Time Division Multiplex Access. This optional information element specifies the digital channels the mobile station shall measure with regard to the Control Channel Selection and Reselection procedures.

NUMber n

[CSS:EBCCH:NEIGHbor:TDMA:NUMber]

Specifies Number of TDMA Neighbor Cells. Range of n is 0 to 31.

NUMber?

Returns current value of NUMber.

CELL:

Provides neighbor DCCH specific information.

CHAN n.m

[CSS:EBCCH:NEIGHbor:TDMA:CELL:CHAN]

Specifies CHAN (m) select by index (n). Range of n is 0 to 31; range of m is 0 to 2047.

CHAN? n

Returns current value of CHAN indexed by n, Range of n is 0 to 31.

EBCCH:

NEIGHbor:

TDMA:

CELL:

PROTocol n.m

[CSS:EBCCH:NEIGHbor:TDMA:CELL:PROTocol]

Specifies Version (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 15

Identifies the protocol version supported.

PROTocol?

Returns current value of PROTocol indexed by n. Range of n is 0 to 31.

DVCC n.m

[CSS:EBCCH:NEIGHbor:TDMA:CELL:DVCC]

Specifies Digital Verification Color Code (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 255.

DVCC?

Returns current value of DVCC indexed by n. Range of n is 0 to 31.

OFFset n.m

[CSS:EBCCH:NEIGHbor:TDMA:CELL:OFFset]

Specifies RESEL_OFFSET (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 127.

Used to increase/decrease the preference of a new candidate cell being considered for control channel reselection.

OFFset? n

Returns current value of RESEL_OFFSET indexed by n. Range of n is 0 to 31.

SS SUFF n.m

[CSS:EBCCH:NEIGHbor:TDMA:CELL:SS_SUFF]

Specifies SS_SUFF (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 31.

Identifies the minimum signal strength sufficient for a candidate control channel to be considered for control channel reselection. SS_SUFF is used, in some instances, to control cell reselection using an absolute threshold.

SS SUFF? n

Returns current value of SS SUFF indexed by n. Range of n is 0 to 31.

EBCCH:

NEIGHbor:

TDMA:

CELL:

DELAY n,m

[CSS:EBCCH:NEIGHbor:TDMA:CELL:DELAY]

Specifies DELAY (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 15.

Used for Control Channel Reselection purposes.

DELAY? n

Returns current value of DELAY indexed by n. Range of n is 0 to 31.

HL FREQ n,m

[CSS:EBCCH:NEIGHbor:TDMA:CELL:HL_FREQ]

Selects HL_FREQ (m) indexed by n. Range of n is 0 to 31; range of m is 0 or 1.

Used to determine the frequency of channel measurements.

HL FREQ? n

Returns current state of HL_FREQ indexed by n. Range of n is 0 to 31.

SYNC n,m

[CS\$:EBCCH:NEIGHbor:TDMA:CELL:SYNC]

Selects SYNC (m) indexed by n. Range of n is 0 to 31; range of m is 0 or 1.

When enabled, a candidate DCCH is superframe-synchronized with the current DCCH. If this flag is enabled, the maximum time offset between superframes sent on the candidate DCCH and current DCCH shall be no more than 7.5 symbols, i.e., a mobile station shall expect to find synchronization on a candidate DCCH within +/- 7.5 symbols relative to its current DCCH superframe.

SYNC?

Returns current state of SYNC indexed by n. Range of n is 0 to 31.

EBCCH:

NEIGHbor:

TDMA:

CELL:

TYPE:

CELL n,m

[CSS:EBCCH:NEIGHbor:TDMA:CELL:TYPE:CELL]

Specifies CELLTYPE (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 3.

Provides a relative distinction by an operator to bias mobile station control channel reselection decisions in order to insure traffic flows according to an operator's desires.

CELL? n

Returns current value of CELL indexed by n. Range of n is 0 to 31.

NETwork n.m

[CSS:EBCCH:NEIGHbor:TDMA:CELL:TYPE:NETwork]

Specifies Network Type (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 7.

Identifies which Network Types are supported on a control channel.

NETwork? n

Returns current value of NETwork indexed by n. Range of n is 0 to 31.

RETRY n,m

[CSS:EBCCH:NEIGHbor:TDMA:CELL:RETRY]

Enables (m = 1) or disables (m = 0) Directed Retry Channel indexed by n. Range of n is 0 to 31.

Used to determine if the neighbor list is to be considered for Directed Retry purposes.

RETRY? n

Returns current state of RETRY indexed by n. Range of n is 0 to 31.

EBCCH:

NEIGHbor:

TDMA:

CELL:

ACCess:

MS PWR n,m

[CSS:EBCCH:NEIGHbor:TDMA:CELL:ACCess:MS_PWR]

Specifies MS_ACC_PWR (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 15.

Mobile Station/Analog Control Channel Power. Identifies the maximum nominal output power that the mobile station shall use when accessing the BMI (Base Station, MSC and Interworking Function). MS_ACC_PWR is also used when determining criteria for control channel selection and reselection.

MS PWR? n

Returns current value of MS PWR indexed by n. Range of n is 0 to 31.

RSS MIN n.m

[CSS:EBCCH:NEIGHbor:TDMA:CELL:ACCess:RSS_MIN]

Specifies RSS_ACC_MIN (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 31.

Received Signal Strength/Analog Control Channel Minimum. Used for the cell (re)selection process. RSS_ACC_MIN is the minimum received signal strength required to access the cell.

RSS MIN? n

Returns current value of RSS_MIN indexed by n. Range of n is 0 to 31.

PSID RSID:

Private/Residential System Identification

INDicator n,m

[CSS:EBCCH:NEIGHbor:TDMA:CELL:PSID_RSID:INDicator]

Enables (m = 1) or disables (m = 0) PSID/RSID Indicator indexed by n. Range of n is 0 to 31.

Indicates whether or not the PSID/RSID related mapping fields are present for the associated DCCH neighbor. Specifically, if the PSID/RSID Indicator value is set to 1, the PSID/RSID Support Length and PSID/RSID Support fields are present, otherwise, not present.

INDicator? n

Returns current state of INDicator indexed by n. Range of n is 0 to 31.

EBCCH:

NEIGHbor:

TDMA:

CELL:

PSID_RSID:

LENGth n,m

[CSS:EBCCH:NEIGHbor:TDMA:CELL:PSID_RSID:LENGth]

Specifies PSID/RSID Support Length (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 15.

The PSID/RSID Support Length field is only present when the PSID/RSID Indicator field is set to 1. When present, this field is always 4 bits long and is used to determine the length of the PSID/RSID Support field. The value of PSID/RSID Support Length is 0 if not present.

LENGth? n

Returns current value of LENGth indexed by n. Range of n is 0 to 31.

EBCCH:

NEIGHbor:

TDMA:

CELL:

PSID_RSID:

SUPport n,m

[CSS:EBCCH:NEIGHbor:TDMA:CELL:PSID_RSID:SUPport]
Specifies PSID/RSID Support (m) indexed by n. Range of n is 0 to 31; range of m is 1 to #hFFFF.

The PSID/RSID Support field is only present when the PSID/RSID Indicator field is set to 1. When present, the length of this is determined by adding 1 to the value of the PSID/RSID Support Length field. The value of PSID/RSID Support is 0 if not present.

The PSID/RSID Support field indicates which PSID/RSID values identified in the PSID/RSID Set information element of the System Identity message of the current DCCH are supported by the DCCH neighbor under consideration. The ordering of the bits in this field reflects the ordering of the PSID/RSID Set sent in the System Identity message in that the least significant bit is corresponds to the first PSID/RSID listed in the PSID/RSID Set. If a bit in this field is set to 1, then the corresponding PSID/RSID entry in the PSID/RSID Set is supported by the neighbor cell under consideration. On the other hand, if a bit in this field is set to 0, then the corresponding PSID/RSID entry in the PSID/RSID Set is *not* supported by the neighbor cell under consideration.

For example, if 16 PSID/RSIDs are listed in the System Identity message and the neighbor cell supports the 1st, 2nd,3rd, and 5th PSID/RSIDs in the PSID/RSID Set, the values of PSID/RSID Support Length and PSID/RSID Support shall be:

PSID/RSID Support length = 0100 PSID/RSID Support = 10111

If 16 PSID/RSIDs are listed in the System Identity message and the neighbor cell supports 3rd and 16th PSID/RSID Set, the values of PSID/RSID Support Length and PSID/RSID Support shall be:

PSID/RSID Support length = 1111
PSID/RSID Support = 100000000000100

SUPport? n

Returns current value of SUPport indexed by n. Range of n is 0 to 31.

EBCCH:

NEIGHbor:

TDMA:

INFO:

Service Info - Provides service attribute information for TDMA neighbors.

COUNt n

[CSS:EBCCH:NEIGHbor:TDMA:INFO:COUNt]

Specifies number of TDMA Service Map instances present in the Neighbor Service Info message (TDMA Neighbor Count). Range of n is 0 to 31.

Set to 1 plus the value in this field.

COUNT?

Returns current value of COUNt.

SERVice:

Provides service information for one or more TDMA neighbors.

INDicator n,m

[CSS:EBCCH:NEIGHbor:TDMA:INFO:SERVice:INDicator]

Enables (m = 1) or disables (m = 0) Service Map Indicator indexed by n. Range of n is 0 to 31.

Indicates, when enabled, that Service Map field is present.

INDicator? n

Returns current state of INDicator indexed by n. Range of n is 0 to 31.

MAP n.m

[CSS:EBCCH:NEIGHbor:TDMA:INFO:SERVice:MAP]

Specifies Service Map (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 1023.

This field, when present, provides service information.

MAP? n

Returns the value of MAP indexed by n. Range of n is 0 to 31.

EBCCH:

NEIGHbor:

ANAlog:

This optional information element contains information regarding the analog channels the mobile station shall measure with regard to the Control Channel Selection and Reselection procedures. This information element always specifies analog neighbors in the 800 MHz hyperband.

NUMber n

[CSS:EBCCH:NEIGHbor:ANAlog:NUMber]

Specifies Number of Analog Neighbor Cells. Range of n is 0 to 31.

NUMber?

Returns current value of NUMber.

CELL:

CHAN n.m

[CSS:EBCCH:NEIGHbor:ANAlog:CELL:CHAN]

Specifies CHAN (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 2047.

CHAN? n

Returns current value of CHAN indexed by n. Range of n is 0 to 31.

PROTocol n.m

[CSS:EBCCH:NEIGHbor:ANAlog:CELL:PROTocol]

Specifies Protocol Version (m) indexed by n. Range of n is 0 to 31; range of m in 0 to 15.

Identifies the protocol version supported.

PROTocol? n

Returns current value of PROTocol indexed by n. Range of n is 0 to 31.

DCC n,m

[CSS:EBCCH:NEIGHbor:ANAlog:CELL:DCC]

Specifies Digital Color Code (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 3.

DCC? n

Returns current value of DCC indexed by n. Range of n is 0 to 31.

EBCCH:

NEIGHbor:

ANAlog:

CELL:

OFFset n.m

[CSS:EBCCH:NEIGHbor:ANAlog:CELL:OFFset]

Specifies RESEL_OFFSET (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 127.

Used to increase or decrease the preference of a new candidate cell being considered for control channel reselection.

OFFset? n

Returns current value of OFFset indexed by n. Range of n is 0 to 31.

SS SUFF n.m

[CSS:EBCCH:NEIGHbor:ANAlog:CELL:SS_SUFF]

Specifies SS_SUFF (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 31.

Identifies the minimum signal strength sufficient for a candidate control channel to be considered for control channel reselection. SS_SUFF is used, in some instances, to control cell reselection using an absolute threshold.

SS SUFF? n

Returns current value of SS_SUFF indexed by n. Range of n is 0 to 31.

DELAY n,m

[CSS:EBCCH:NEIGHbor:ANAlog:CELL:DELAY]

Specifies DELAY (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 15.

Used for Control Channel Reselection purposes.

DELAY? n

Returns current value of DELAY indexed by n. Range of n is 0 to 31.

HL FREQ n.m

[CSS:EBCCH:NEIGHbor:ANAlog:CELL:HL_FREQ]

Enables (m = 1) or disables (m = 0) HL_FREQ indexed by n. Range of n is 0 to 31.

Used to determine the frequency of channel measurements.

HL_FREQ? n

Returns current state of HL FREQ indexed by n. Range of n is 0 to 31.

EBCCH:

NEIGHbor:

ANAlog:

CELL:

TYPE:

CELL n,m

[CSS:EBCCH:NEIGHbor:ANAlog:CELL:TYPE:CELL]

Specifies CELLTYPE (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 3.

Provides a relative distinction by an operator to bias mobile station control channel reselection decisions in order to insure traffic flows according to an operator's desires.

CELL? n

Returns current value of CELL indexed by n (0-31).

NETwork n.m

[CSS:EBCCH:NEIGHbor:ANAlog:CELL:TYPE:NETwork]

Specifies Network Type (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 7.

Identifies which Network Types are supported on a control channel.

NETwork? n

Returns current value of NETwork indexed by n. Range of n is 0 to 31.

RETRY n,m

[CSS:EBCCH:NEIGHbor:ANAlog:CELL:RETRY]

Enables (m = 1) or disables (m = 0) Directed Retry Channel indexed by n. Range of n is 0 to 31.

When enabled, the neighbor list is to be considered for Directed Retry purposes.

RETRY? n

Returns current state of RETRY indexed by n. Range of n is 0 to 31.

EBCCH:

NEIGHbor:

ANAlog:

CELL:

ACCess:

MS PWR n,m

[CSS:EBCCH:NEIGHbor:ANAlog:CELL:ACCess:MS_PWR]

Specifies MS_ACC_PWR (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 15.

Mobile Station/Analog Control Channel Power. Identifies the maximum nominal output power that the mobile station shall use when accessing the BMI (Base Station, MSC and Interworking Function). MS_ACC_PWR is also used when determining criteria for control channel selection and reselection.

MS PWR? n

Returns current value of MS_PWR indexed by n. Range of n is 0 to 31.

RSS MIN n.m

[CSS:EBCCH:NEIGHbor:ANAlog:CELL:ACCess:RSS_MIN]

Specifies RSS_ACC_MIN (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 31.

Received Signal Strength/Analog Control Channel Minimum. Used for the cell (re)selection process. RSS_ACC_MIN is the minimum received signal strength required to access the cell.

RSS_MIN? n

Returns current value of RSS MIN indexed by n. Range of n is 0 to 31.

OTHER:

Other Hyperband - This optional information element contains information specifying the digital channels the mobile station may measure in order to acquire service in an alternate frequency band.

NUMber n

[CSS:EBCCH:NEIGHbor:OTHER:NUMber]

Specifies Number of Neighbor Cells. Range of n is 0 to 31.

NUMber?

Returns current value of NUMber.

EBCCH:

NEIGHbor:

OTHER:

CELL:

Provides neighbor DCCH specific information.

CHAN n,m

[CSS:EBCCH:NEIGHbor:OTHER:CELL:CHAN]

Specifies channel (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 2047.

CHAN? n

Returns current value of CHAN indexed by n. Range of n is 0 to 31.

PROTocol n.m

[CSS:EBCCH:NEIGHbor:OTHER:CELL:PROTocol]

Specifies Protocol Version (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 15.

Identifies the protocol version supported.

PROTocol?

Returns current value of PROTocol indexed by n. Range of n is 0 to 31.

DVCC n.m

[CSS:EBCCH:NEIGHbor:OTHER:CELL:DVCC]

Specifies Digital Verification Color Code (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 255.

DVCC?

Returns current value of DVCC indexed by n. Range of n is 0 to 31.

OFFset n.m

[CSS:EBCCH:NEIGHbor:OTHER:CELL:OFFset]

Specifies RESEL_OFFSET (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 127.

Used to increase or decrease the preference of a new candidate cell being considered for control channel reselection.

OFFset? n

Returns current value of OFFset indexed by n. Range of n is 0 to 31.

EBCCH:

NEIGHbor:

OTHER:

CELL:

SS SUFF n.m

[CSS:EBCCH:NEIGHbor:OTHER:CELL:SS_SUFF]

Specifies SS_SUFF (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 31.

Identifies the minimum signal strength sufficient for a candidate control channel to be considered for control channel reselection. SS_SUFF is used, in some instances, to control cell reselection using an absolute threshold.

SS SUFF? n

Returns current value of SS SUFF indexed by n. Range of n is 0 to 31.

DELAY n,m

[CSS:EBCCH:NEIGHbor:OTHER:CELL:DELAY]

Specifies DELAY (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 15.

Used for Control Channel Reselection purposes.

DELAY? n

Returns current value of DELAY indexed by n. Range of n is 0 to 31.

HL FREQ n,m

[CSS:EBCCH:NEIGHbor:OTHER:CELL:HL_FREQ]

Enables (m = 1) or disables (m = 0) HL_FREQ indexed by n. Range of n is 0 to 31.

Used to determine the frequency of channel measurements.

HL FREQ? n

Returns current state of HL_FREQ indexed by n. Range of n is 0 to 31.

EBCCH:

NEIGHbor:

OTHER:

CELL:

SYNC n.m

[CSS:EBCCH:NEIGHbor:OTHER:CELL:SYNC]

Enables (m = 1) or disables (m = 0) SYNC indexed by n. Range of n is 0 to 31.

Indicates if a candidate DCCH is superframe-synchronized with the current DCCH. If this flag is enabled, the maximum time offset between superframes sent on the candidate DCCH and current DCCH shall be no more than 7.5 symbols, i.e., a mobile station shall expect to find synchronization on a candidate DCCH within +/- 7.5 symbols relative to its current DCCH superframe.

SYNC?

Returns current state of SYNC indexed by n. Range of n is 0 to 31.

TYPE:

CELL n.m

[CSS:EBCCH:NEIGHbor:OTHER:CELL:TYPE:CELL]

Specifies CELLTYPE (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 3.

Provides a relative distinction by an operator to bias mobile station control channel reselection decisions in order to insure traffic flows according to an operator's desires.

CELL? n

Returns current value of CELL indexed by n. Range of n is 0 to 31.

NETwork n,m

[CSS:EBCCH:NEIGHbor:OTHER:CELL:TYPE:NETwork]

Specifies Network Type (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 7.

Identifies which Network Types are supported on a control channel.

NETwork? n

Returns current value of NETwork indexed by n. Range of n is 0 to 31.

EBCCH:

NEIGHbor:

OTHER:

CELL:

RETRY n.m

[CSS:EBCCH:NEIGHbor:OTHER:CELL:RETRY]

Enables (m = 1) or disables (m = 0) Directed Retry Channel indexed by n. Range of n is 0 to 31.

When enabled, the neighbor list is to be considered for Directed Retry purposes.

RETRY? n

Returns current state of RETRY indexed by n. Range of n is 0 to 31.

ACCess:

MS PWR n,m

[CSS:EBCCH:NEIGHbor:OTHER:CELL:ACCess:MS_PWR]

Specifies MS_ACC_PWR (m) indexed by n. Range of n is 0 to 31; range of m 0 to 15.

Mobile Station/Analog Control Channel Power. Identifies the maximum nominal output power that the mobile station shall use when accessing the BMI (Base Station, MSC and Interworking Function). MS_ACC_PWR is also used when determining criteria for control channel selection and reselection.

MS_PWR? n

Returns current value of MS_PWR indexed by n. Range of n is 0 to 31.

RSS_MIN n,m

[CSS:EBCCH:NEIGHbor:OTHER:CELL:ACCess:RSS_MIN]

Specifies RSS_ACC_MIN (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 31.

Received Signal Strength/Analog Control Channel Minimum. Used for the cell (re)selection process. RSS_ACC_MIN is the minimum received signal strength required to access the cell.

RSS MIN? n

Returns current value of RSS_MIN indexed by n. Range of n is 0 to 31.

EBCCH:

NEIGHbor:

OTHER:

CELL:

PSID RSID:

Private/Residential System Identification

INDicator n,m

[CSS:EBCCH:NEIGHbor:OTHER:CELL:PSID_RSID:INDicator] Enables (m = 1) or disables (m = 0) PSID/RSID Indicator indexed by n. Range of n is 0 to 31.

Indicates if the PSID/RSID related mapping fields are present for the associated DCCH neighbor. Specifically, if the PSID/RSID Indicator value is set to 1, the PSID/RSID Support Length and PSID/RSID Support fields are present. If the PSID/RSID Indicator value is set to 0, the PSID/RSID Support Length and PSID/RSID Support fields are not present.

INDicator? n

Returns current state of INDicator indexed by n. Range of n is 0 to 31.

LENGth n.m

[CSS:EBCCH:NEIGHbor:OTHER:CELL:PSID_RSID:LENGth]

Specifies PSID/RSID Support Length (m) indexed by n. Range of n is 0 to 31; range m is 0 to 15 (if present, 0 if not present).

The PSID/RSID Support Length field is only present when the PSID/RSID Indicator field is set to 1. When present, this field is always 4 bits long and is used to determine the length of the PSID/RSID Support field.

LENGth? n

Returns current value of LENGth indexed by n. Range of n is 0 to 31.

EBCCH:

NEIGHbor:

OTHER:

CELL:

PSID_RSID:

SUPport n,m

[CSS:EBCCH:NEIGHbor:OTHER:CELL:PSID_RSID:SUPport]

Specifies PSID/RSID Support (m) indexed by n. Range of n is 0 to 31; range of m is 1 to #hFFFF (if present, 0 if not present).

The PSID/RSID Support field is only present when the PSID/RSID Indicator field is set to 1. When present, the length is determined by adding 1 to the value of the PSID/RSID Support Length field.

The PSID/RSID Support field indicates which PSID/RSID values identified in the PSID/RSID Set information element of the System Identity message of the current DCCH are supported by the DCCH neighbor under consideration. The ordering of the bits in this field reflects the ordering of the PSID/RSID Set sent in the System Identity message in that the least significant bit is corresponds with the first PSID/RSID listed in the PSID/RSID Set. If a bit in this field is set to 1, then the corresponding PSID/RSID entry in the PSID/RSID Set is supported by the neighbor cell under consideration. If a bit in this field is set to 0, then the corresponding PSID/RSID entry in the PSID/RSID Set is **not** supported by the neighbor cell under consideration.

For example if 16 PSID/RSIDs are listed in the System Identity message and the neighbor cell supports the 1st, 2nd,3rd, and 5th PSID/RSIDs in the PSID/RSID Set, the values of PSID/RSID Support Length and PSID/RSID Support shall be:

PSID/RSID Support length = 0100 PSID/RSID Support = 10111

If 16 PSID/RSIDs are listed in the System Identity message and the neighbor cell supports 3rd and 16th PSID/RSID Set, the values of PSID/RSID Support Length and PSID/RSID Support shall be:

PSID/RSID Support length = 1111
PSID/RSID Support = 100000000000100

SUPport? n

[CSS:EBCCH:NEIGHbor:OTHER:CELL:PSID_RSID:SUPport]
Returns current value of SUPport indexed by n. Range of n is 0 to 31.

EBCCH:

NEIGHbor:

OTHER:

INFO:

Service Info - Provides service attribute information for TDMA neighbors.

HYPERband n

[CSS:EBCCH:NEIGHbor:OTHER:INFO:HYPERband] Specifies HYPERband. Range of n is 0 to 3.

Provides service attribute information for Other Hyperband TDMA neighbors.

HYPERband?

Returns current value of HYPERband.

COUNt n

[CSS:EBCCH:NEIGHbor:OTHER:INFO:COUNt]
Specifies TDMA Neighbor Count. Range of n is 0 to 31.

Identifies the number of TDMA Service Map instances present in the Neighbor Service Info message. Set to 1 plus the value in this field..

COUNt?

Returns current value of COUNt.

SERVice:

Provides service information for one or more TDMA neighbors.

INDicator n.m

[CSS:EBCCH:NEIGHbor:OTHER:INFO:SERVice:INDicator]

Enables (m = 1) or disables (m = 0) Service Map Indicator indexed by n. Range of n is 0 to 31.

When enabled, indicates the Service Map field is present.

INDicator? n

Returns current state of INDicator.

MAP n,m

[CSS:EBCCH:NEIGHbor:OTHER:INFO:SERVice:MAP]

Specifies Service Map (m) indexed by n. Range of n is 0 to 31; range of m is 0 to 1023 (if present, 0 if not present).

This field, when present, provides service information.

MAP? n

Returns current value of MAP indexed by n. Range of n is 0 to 31.

EBCCH:

RCI n

[CSS:EBCCH:RCI]

Specifies Regulatory Configuration. Range of n is 0 to 3.

RCI?

Returns current value of RCI.

CHANnel:

RF Channel Allocation - Indicates an RF channel allocation for system configurations that are not described in this standard.

NUMber n

[CSS:EBCCH:CHANnel:NUMber]

Specifies Number of Channel Groups. Range of n is 0 to 63.

NUMber?

Returns current value of NUMber.

GROUP:

Channel Group is an ordered pair indicating the first/last RF Channel Numbers assigned to the Channel Group.

FIRST n,m

[CSS:EBCCH:CHANnel:GROUP:FIRST]

Specifies First Channel (m) indexed by n. Range of n is 0 to 63; range of m is 0 to 2047.

FIRST? n

Returns current value of FIRST indexed by n. Range of n is 0 to 63.

LAST n.m

[CSS:EBCCH:CHANnel:GROUP:LAST]

Specifies Last Channel (m) indexed by n. Range of n is 0 to 63; range of m is 0 to 2047.

LAST? n

Returns current value of LAST indexed by n. Range of n is 0 to 63.

EBCCH:

BSMC n

[CSS:EBCCH:BSMC]

Specifies Base Station Manufacture Code. Range of n is 0 to 255.

Identifies the assigned manufacture code. The BSMC value of 0 is reserved. A reserved BSMC value shall be considered an unknown base station manufacture code by the receiving mobile station.

BSMC?

Returns current value of BSMC.

CUSTOM:

LENGth n

[CSS:EBCCH:CUSTOM:LENGth]

Specifies Length of Custom Control in octets. Range of n is 1 to 64.

LENGth?

Returns current value of LENGth.

CONTrol n,m

[CSS:EBCCH:CUSTOM:CONTrol]

Specifies CONTrol (m) indexed by n. Range of n is 0 to 63; range of m is 0 to 255.

CONTrol?

Returns current value of CONTrol.

TEXT:

Text Message Data Unit - Contains the message to be broadcast.

LENGth n

[CSS:EBCCH:TEXT:LENGth]

Specifies Length Indicator. Range of n is 0 to 255.

LENGth?

Returns current value of LENGth.

ENCoding n

[CSS:EBCCH:TEXT:ENCoding]

Specifies Encoding Identifier. Range of n is 0 to 31.

ENCoding?

Returns current value of ENCoding.

EBCCH:

TEXT:

REServed n

[CSS:EBCCH:TEXT:REServed]
Specifies Reserved. Range of n is 0 to 7.

REServed?

Returns current value of REServed.

CHARacter n,m

[CSS:EBCCH:TEXT:CHARacter]

Specifies Short Message Character (m) indexed by n. Range of n is 0 to 255; range of m is 0 to 255.

CHARacter? n

Returns current value of CHARacter indexed by n. Range of n is 0 to 255.

SIGnal:

Conveys alerting information to a mobile station.

PITCH n

[CSS:EBCCH:SIGnal:PITCH]

Specifies Signal Pitch. Range of n is 0 to 3.

PITCH?

Returns current value of PITCH.

CADence n

[CSS:EBCCH:SIGnal:CADence]

Specifies Signal Cadence. Range of n is 0 to 63.

CADence?

Returns current value of CADence.

DURation n

[CSS:EBCCH:SIGnal:DURation]

Specifies Signal Duration. Range of n is 0 to 15.

DURation?

Returns current value of DURation.

EBCCH:

MACA:

Mobile Assisted Channel Allocation.

STATus n

[CSS:EBCCH:MACA:STATus]

Specifies MACA_STATUS. Range of n is 0 to 3.

Determines which MACA function combinations are enabled.

STATus?

Returns current value of STATus.

TYPE n

[CSS:EBCCH:MACA:TYPE]

Specifies MACA_TYPE. Range of n is 0 to 15.

Determines when MACA reporting is to take place.

TYPE?

Returns current value of TYPE.

EIGHT:

CONTrol n

[CSS:EBCCH:MACA:EIGHT:CONTrol]

Enables (n = 1) or disables (n = 0) CONTrol.

This information element, together with MACA_TYPE and MACA_STATUS, determines the number of channels reported

CONTrol?

Returns current state of CONTrol.

LIST:

Contains information regarding the channels (other than the current DCCH) the mobile station shall measure for mobile assisted channel allocation.

NUMber n

[CSS:EBCCH:MACA:LIST:NUMber]

Specifies Number of MACA Channels. Range of n is 0 to 15.

NUMber?

Returns current value of NUMber.

EBCCH:

MACA:

LIST:

CHAN n,m

[CSS:EBCCH:MACA:LIST:CHAN]

Specifies Channel (m) indexed by n. Range of n is 0 to 15; range of m is 0 to 2047.

CHAN? n

Returns current value of CHAN indexed by n. Range of n is 0 to 15.

OTHER:

Contains information regarding the channels other than the current DCCH. A mobile station that is not capable of performing measurements on a channel specified in this list shall report a RSS value of 00000 for that channel.

HYPERband n

[CSS:EBCCH:MACA:LIST:OTHER:HYPERband]

Specifies Frequency band information. Range of n is 0 to 3.

HYPERband?

Returns current value of HYPERband.

NUMber n

[CSS:EBCCH:MACA:LIST:OTHER:NUMber]

Specifies Number of MACA Channels. Range of n is 0 to 15.

NUMber?

Returns current value of NUMber.

CHAN n.m

[CSS:EBCCH:MACA:LIST:OTHER:CHAN]

Specifies Channel (m) indexed by n. Range of n is 0 to 15; range of m is 0 to 2047.

CHAN? n

Returns current value of CHAN indexed by n. Range of n is 0 to 15.

EBCCH:

MAP:

VPM n

[CSS:EBCCH:MAP:VPM]

Specifies Voice Privacy Mode Map. Range of n is 0 to 15.

Identifies the forms of voice privacy supported by the BMI.

VPM?

Returns current value of VPM.

DPM n

[CSS:EBCCH:MAP:DPM]

Specifies Data Privacy Mode Map. Range of n is 0 to 15.

Identifies the forms of data privacy supported by the BMI.

DPM?

Returns current value of DPM.

CODER n

[CSS:EBCCH:MAP:CODER]

Specifies Voice Coder Map. Range of n is 0 to 63.

Identifies the types of voice coders supported by the BMI.

CODER?

Returns current value of CODER.

MEA:

Message Encryption Algorithm Map - Identifies the message encryption algorithms, domain and keys supported by a DCCH or a DTC.

DOMAIN n

[CSS:EBCCH:MAP:MEA:DOMAIN]

Specifies Domain Map. Range of n is 0 to 255.

Identifies the number of instances and ordering of the Encryption Algorithms field.

DOMAIN?

Returns current value of DOMAIN.

ALGORithms n,m

[CSS:EBCCH:MAP:MEA:ALGORithms]

Specifies Encryption Algorithms (m) indexed by n. Range of n is 0 to 7; range of m is 0 to 15.

ALGORIthms? n

Returns current value of ALGORithms indexed by n. Range of n is 0 to 7.

EBCCH:

MAP:

MEK n

[CSS:EBCCH:MAP:MEK]

Specifies Message Encryption Key Map. Range of n is 0 to 15.

Identifies the message encryption keys supported by the BMI

MEK?

Returns current value of MEK.

MENU n

[CSS:EBCCH:MAP:MENU]

Specifies Menu Map. Range of n is 0 to #h3FF.

Identifies the services supported by the BMI

MENU?

Returns current value of MENU.

ARQ n

[CSS:EBCCH:MAP:ARQ]

Enables (n = 1) or disables (n = 0) FACCH/SACCH ARQ (Automatic Retransmission Request) Map.

Identifies if the BMI supports FACCH/SACCH ARQ mode on its IS-136 digital traffic channels.

ARQ?

Returns current state of ARQ.

USER n

[CSS:EBCCH:MAP:USER]

Enables (n = 1) or disables (n = 0) User Group Map.

Identifies whether or not the BMI supports User Group operation.

USER?

Returns current state of USER.

SMS n

[CSS:EBCCH:MAP:SMS]

Specifies Short Message Service Map. Range of n is 0 to 3.

Identifies the extent to which the BMI supports the CMT teleservice.

SMS2

Returns current value of SMS.

EBCCH:

SOC n

[CSS:EBCCH:SOC]

Specifies System Operator Code. Range of n is 0 to 4095.

Identifies which operator is providing service. A reserved SOC value shall be considered an unknown system operator code by a receiving mobile station.

SOC?

Returns current value of SOC.

TIME n

[CSS:EBCCH:TIME]

Specifies TIME. Range of n is 0 to #hFFFFFFF.

Time from Jan 1, 1980 - This information element is a non-critical sequential time counter in seconds elapsed since January 1, 1980, 00:00 hour, 0 seconds using Greenwich Mean Time as the reference point.

TIME?

Returns current value of TIME.

ZONE:

Time Zone Offset - Used to identify the time zone offset in minutes relative to Greenwich Mean Time (GMT).

DIRection n

[CSS:EBCCH:ZONE:DIRection]

Selects Time Zone Offset Direction. Range of n is 0 or 1.

Specifies whether to add or subtract minutes from the GMT.

DIRection?

Returns current setting of DIRection.

MINutes n

[CSS:EBCCH:ZONE:MINutes]

Specifies Minutes. Range of n is 0 to 1023.

Specifies the number of minutes.

MINutes?

Returns currents value of MINutes.

EBCCH:

ZONE:

DST n

[CSS:EBCCH:ZONE:DST]

Selects Time Zone Offset Daylight Savings Indicator. Range of n is 0 or 1.

Indicates Standard or Daylight Savings Time.

DST?

Returns current setting of DST.

CHAN n

[CSS:EBCCH:CHAN]

Specifies E-BCCH CHAN. Range of n is 0 to 2047.

CHAN?

Returns current value of CHAN.

HYPERband:

INFO n

[CSS:EBCCH:HYPERband:INFO]

Specifies INFO. Range of n is 0 to 3.

Used to specify the Hyperband associated with the specified channel.

INFO?

Returns current value of INFO.

MCC n

[CSS:EBCCH:MCC]

Specifies Mobile Country Code. Range of n is 0 to 1023.

Indicates the Mobile Country Code of the current DCCH.

MCC?

Returns current value of MCC.

SID n

[CSS:EBCCH:SID]

Specifies System Identification. Range of *n* is 0 to 32767.

Provides a digital identification associated with a cellular system where each system is assigned a unique number.

SID?

Returns current value of SID.

EBCCH:

ENABLE:

NONPublic n

[CSS:EBCCH:ENABLE:NONPublic]

Enables (n = 1) or disables (n = 0) Non-Public Probability Blocks.

NONPublic?

Returns current state of NONPublic.

NEIGHbor:

TDMA n

[CSS:EBCCH:ENABLE:NEIGHbor:TDMA]

Enables (n = 1) or disables (n = 0) Time Division Multiplex Access.

TDMA?

Returns current state of TDMA.

TDMA:

INFO n

[CSS:EBCCH:ENABLE:NEIGHbor:TDMA:INFO]

Enables (n = 1) or disables (n = 0) TDMA info.

INFO?

Returns current state of INFO.

ANALOG n

[CSS:EBCCH:ENABLE:NEIGHbor:ANALOG]

Enables (n = 1) or disables (n = 0) Analog.

ANALOG?

Returns current state of ANALOG.

OTHER n

[CSS:EBCCH:ENABLE:NEIGHbor:OTHER]

Enables (n = 1) or disables (n = 0) Other Hyperband.

OTHER?

Returns current state of OTHER.

OTHER:

INFO n

[CSS:EBCCH:ENABLE:NEIGHbor:OTHER:INFO]

Enables (n = 1) or disables (n = 0) Other Hyperband Info.

INFO?

Returns current state of INFO.

EBCCH:

ENABLE:

CHANnel n

[CSS:EBCCH:ENABLE:CHANnel]

Enables (n = 1) or disables (n = 0) RF Channel Allocation.

CHANnel?

Returns current state of CHANnel.

SIGnal n

[CSS:EBCCH:ENABLE:SIGnal]

Enables (n = 1) or disables (n = 0) alerting information to a mobile station user.

SIGnal?

Returns current state of SIGnal.

MACA:

EIGHT:

CONTrol n

[CSS:EBCCH:ENABLE:MACA:EIGHT:CONTrol]

Enables (n = 1) or disables (n = 0) MACA_8_CONTROL.

CONTrol?

Returns current state of CONTrol.

LIST n

[CSS:EBCCH:ENABLE:MACA:LIST]

Enables (n = 1) or disables (n = 0) MACA_LIST.

LIST?

Returns current state of LIST.

LIST:

OTHER n

[CSS:EBCCH:ENABLE:MACA:LIST:OTHER]

Enables (n = 1) or disables (n = 0) MACA_LIST Other Hyperband.

OTHER?

Returns current state of OTHER.

MCC n

[CSS:EBCCH:ENABLE:MCC]

Enables (n = 1) or disables (n = 0) Mobile Country Code.

MCC?

Returns current state of MCC.

EBCCH:

ENABLE:

HYPERband:

INFO n

[CSS:EBCCH:ENABLE:HYPERband:INFO] Enables (n = 1) or disables (n = 0) Hyperband Information.

INFO?

Returns current state of INFO.

7-16-5 SPACH COMMANDS

CSS:

SPACH:

BUILD:

HARD

[CSS:SPACH:BUILD:HARD]
Builds a Hard Page of any type.

ARG

[CSS:SPACH:BUILD:ARQ]
Builds an ARQ SPACH Message of any type.

NONARQ

[CSS:SPACH:BUILD:NONARQ]
Builds a Non ARQ SPACH Message

LENGth:

HARD?

[CSS:SPACH:LENGth:HARD?]

Returns current value of hard page length (1 bit value).

ARQ?

[CSS:SPACH:LENGth:ARQ?]

Returns current value of ARQ SPACH message length (7 bit value).

NONARQ?

[CSS:SPACH:LENGth:NONARO?]

Returns current value of NONARQ SPACH message length (7 bit value).

DATA:

HARD? n

[CSS:SPACH:DATA:HARD?]

Returns current 16 bit word (indexed by n) within a hard page. Range of n is 0 to 6.

ARQ? n,m

[CSS:SPACH:DATA:ARQ?]

Returns current 16 bit word (indexed by m) within a selected frame (n) of the ARQ SPACH message. Range of n is 0 to 255; range of m is 0 to 6.

NONARQ? n,m

[CSS:SPACH:DATA:NONARQ?]

Returns current 16 bit word (indexed by m) within a selected frame (n) of the NONARQ SPACH message. Range of n is 0 to 255; range of m is 0 to 6.

SPACH:

PROGRAM:

HARD dest

[CSS:SPACH:PROGRAM:HARD]

Copies the hard page into the superframe. The location in the superframe is selected by dest. Range of dest is 0 to 31.

ARQ dest, source, length

[CSS:SPACH:PROGRAM:ARQ]

Copies the ARQ message into the superframe. The location in the superframe is selected by *dest*. The *source* selects the frame from the ARQ buffer. The number of frames moved is selected by *length*. Range of *dest* is 0 to 31; range of *source* is 0 to 255; range of length is 0 to 32.

NONARQ dest, source, length

[CSS:SPACH:PROGRAM:NONARQ]

Copies the NONARQ message into the superframe. The location in the superframe is selected by dest. The source selects the frame from the NONARQ buffer. The number of frames moved is selected by length. Range of dest is 0 to 31; range of source is 0 to 255; range of length is 0 to 32.

BU n

[CSS:SPACH:BU]

Specifies Burst Usage. Range of n is 0 to 7.

BU?

Returns current value of BU.

PCON n,m

[CSS:SPACH:PCON]

?? Paging Channel Continuation. n is (0-1) m is ().

PCON? n

Returns current value of PCON indexed by n. Range of n is 0 or 1.

BCN n

[CSS:SPACH:BCN]

Enables (n = 1) or disables (n = 0) Broadcast Channel Change Notification Flag.

BCN?

Returns current state of BCN.

PFM n

[CSS:SPACH:PFM]

Enables (n = 1) or disables (n = 0) Paging Frame Modifier.

PFM?

Returns current state of PFM.

SPACH:

BT n

[CSS:SPACH:BT]

Specifies Burst Type. Range of n is 0 to 7.

BT?

Returns current value of BT.

IDT n

[CSS:SPACH:IDT]

Specifies Identity Type. Range of n is 0 to 3.

DT?

Returns current value of IDT.

MSID:

MS n,m

[CSS:SPACH:MSID:MS]

Specifies the 18 Most Significant Bits (m) of Mobile Station Identification indexed by n. Range of n is 0 to 4; range of m is 0 to #h3FFFF.

MS? n

Returns the 18 Most Significant Bits of Mobile Station Identification indexed by n. Range of n is 0 to 4.

LS n.m

[CSS:SPACH:MSID:LS]

Specifies the 32 Least Significant Bits (m) of Mobile Station Identification indexed by n. Range of n is 0 to 4; range of m is 0 to #hFFFFFFF.

LS? n

Returns the 32 Least Significant Bits of Mobile Station Identification indexed by n. Range of n is 0 to 4.

MIN1 "n"

[CSS:SPACH:MIN1]

Specifies MIN1 used in a SPACH Message. (ASCII string).

(example: "316/522-4981")

MIN1?

Returns current value of MIN1.

SPACH:

MIN2 "n"

[CSS:SPACH:MIN2]

Specifies MIN2 used in a SPACH Message. (ASCII string).

(example: "316/522-4981")

MIN2?

Returns current value of MIN2.

MIN3 "n"

CSS:SPACH:MIN3

Specifies MIN3 used in a SPACH Message. (ASCII string).

(example: "316/522×4981")

MIN3?

Returns current value of MIN3.

UGID:

MS n

[CSS:SPACH:UGID:MS]

Specifies the 18 Most Significant Bits of User Group Identification. Range of n is 0 to #h3FFFF.

MS?

Returns the 18 Most Significant Bits of User Group Identification.

LS n

[CSS:SPACH:UGID:LS]

Sets the 32 Least Significant Bits of User Group Identification. Range of n is 0 to #hFFFFFFF.

LS?

Returns the 32 Least Significant Bits of User Group Identification.

MMn

[CSS:SPACH:MM]

Enables (n = 1) or disables (n = 0) Message Mapping.

MM?

Returns current state of MM.

SPACH:

PEA n

[CSS:SPACH:PEA]

Specifies Partial Echo Assigned. Range of n is 0 to 127.

Partial Echo value used by a mobile station during an ARQ mode transaction.

PEA?

Returns current value of PEA.

Pl n.m

[CSS:SPACH:PI]

Enables (m = 1) or disables (m = 0) Polling Indicator indexed by n. Range of n is 0 to 79.

Indicates whether or not the BMI is soliciting a response (ARQ STAUS Frame) from the mobile station.

P1? n

Returns current state of PI indexed by n. Range of n is 0 to 79.

SRM n

[CSS:SPACH:SRM]

Enables (n = 1) or disables (n = 0) SPACH Response Mode.

Indicates how a mobile station is to respond once it has received all frames associated with a given SPACH message.

SRM?

Returns current state of SRM.

EHI n

[CSS:SPACH:EHI]

Enables (n = 1) or disables (n = 0) Extended Header Indicator.

EHI?

Returns current state of EHI.

MEA n

[CSS:SPACH:MEA]

Specifies Message Encryption Algorithm. Range of n is 0 to 3.

MEA?

Returns current value of MEA.

SPACH:

MEK n

[CSS:SPACH:MEK]

Specifies Message Encryption Key. Range of n is 0 to 3.

MEK?

Returns current value of MEK.

RSVD:

Reserved

HEADER n

[CSS:SPACH:RSVD:HEADER]

Enables (n = 1) or disables (n = 0) reserved field in SPACH Header A.

HEADER?

Returns current state of HEADER.

ARQ n

[CSS:SPACH:RSVD:ARQ]

Specifies Automatic Retransmission Request. Range of n is 0 to 3.

ARQ?

Returns current value of ARQ.

ARM n

[CSS:SPACH:ARM]

Enables (n = 1) or disables (n = 0) ARQ Response Mode.

Indicates how a mobile station is to respond once it has received an ARQ frame with PI set to 1.

ARM?

Returns current state of ARM.

FRNO n.m

[CSS:SPACH:FRNO]

Specifies Frame Number (m) indexed by n. Range of n is 0 to 79; range of m is 0 to 31.

Uniquely identifies specific frames sent in support of an ARO mode transaction.

FRNO? n

Returns current value of FRNO indexed by n. Range of n is 0 to 79.

SPACH:

GA n

[CSS:SPACH:GA]

Enables (n = 1) or disables (n = 0) Go Away.

Indicates if the DCCH is barred.

GA?

Returns current state of GA.

MSGTYPE1:

<COMMAND FROM Table below>

[CSS:SPACH:MSGtype1:<Command from Table below>]
Specifies message type 1 used in a SPACH message.

MSGTYPE2:

<COMMAND FROM Table below>

[CSS:SPACH:MSGTYPE2:<Command from Table below>]
Specifies message type 2 used in a SPACH message.

MSGTYPE3:

<COMMAND FROM Table below>

[CSS:SPACH:MSGtype3:<Command from Table below>]
Specifies message type 3 used in a SPACH message.

MSGTYPE4:

<COMMAND FROM Table below>

[CSS:SPACH:MSGtype4:<Command from Table below>]
Specifies message type 4 used in a SPACH message.

ANALOG	AUDIT	BSCHALcon	вѕмс
CAPability	DIGital	DRETRY	MSGWTG
PAGE	PU	RDATA	RDATA_ACCept
RDATA_REJect	RELease	REORDer	soc
SPACHnotification	SSDUP	TESTreg	UCHAL
REG_ACCept	REG_REJect	USERalert	

SPACH:

MEM n

[CSS:SPACH:MEM]

Enables (n = 1) or disables (n = 0) Message Encryption Mode.

Indicates whether or not message encryption algorithm A and message encryption domain. A are enabled on the assigned voice channel.

MEM?

Returns current state of MEM.

SCC n

[CSS:SPACH:SCC]

Specifies SAT Color Code. Range of n is 0 to 3.

Defines SAT Color Code used on the assigned analog voice channel.

SCC?

Returns current value of SCC.

VMAC n

[CSS:SPACH:VMAC]

Specifies VMAC. Range of n is 0 to 15.

Indicates the power level to be used on the assigned analog voice channel.

VMAC?

Returns current value of VMAC.

CHAN n

[CSS:SPACH:CHAN]

Specifies Channel used in a Digital or Analog channel assignment. Range of n is 0 to 2047.

CHAN?

Returns current value of CHAN.

PROTocol n

[CSS:SPACH:PROTocol]

Specifies Protocol version. Range of n is 0 to 15.

PROTocol?

Returns current value of PROTocol.

SPACH:

SUBaddress:

Identifies the subaddress of a called or calling party.

LENGth n

[CSS:SPACH:SUBaddress:LENGth]

Specifies Length of Subaddress Info content. Range of n is 0 to 255.

LENGth?

Returns current value of LENGth.

ODD EVEN n

[CSS:SPACH:SUBaddress:ODD_EVEN]

Enables (n = 1) or disables (n = 0) Odd/Even Indicator.

ODD_EVEN?

Returns current state of ODD EVEN.

TYPE n

[CSS:SPACH:SUBaddress:TYPE]

Specifies Type of Subaddress. Range of n is 0 to 7.

TYPE?

Returns current value of TYPE.

REServed n

[CSS:SPACH:SUBaddress:REServed]

Enables (n = 1) or disables (n = 0) Reserved.

REServed?

Returns current state of REServed.

ADDRess n,m

[CSS:SPACH:SUBaddress:ADDRess]

Specifies Subaddress (m) indexed by n. Range of n is 0 to 19; range of m is 0 to 255.

ADDRess? n

Returns current value of Subaddress indexed by n. Range of n is (0-19).

SPACH:

DTX:

SUPport n

[CSS:SPACH:DTX:SUPport]

Specifies DTX Support. Range of n is 0 to 3.

Used to indicate DTX capabilities supported on the analog voice channel

SUPport?

Returns current value of SUPport.

DISPlay:

Used to supply display information that may be displayed to the mobile station user. The information contained in this information element is coded in IRA characters. If the mobile station receives this information element with a length exceeding the maximum length that it supports, the information element should be truncated

LENGth n

[CSS:SPACH:DISPlay:LENGth]

Specifies Length of Display info. Range of n is 0 to 81.

LENGth?

Returns current value of LENGth.

CHARacter n, m

[CSS:SPACH:DISPlay:CHARacter]

Specifies Display Character (m) indexed by n. Range of n is 0 to 255; range of m is 0 to 255.

Up to 82 instances may be sent.

CHARacter? n

Returns current value of CHARacter indexed by n. Range of n is 0 to 255.

REREG n

[CSS:SPACH:REREG]

Enables (n = 1) or disables (n = 0) Forced Re-registration.

Indicates if the mobile station is required to initiate a Registration attempt with Registration Type set to Forced.

REREG?

Returns current state of REREG.

SPACH:

DEBUG n

[CSS:SPACH:DEBUG]

Enables (n = 1) or disables (n = 0) Debug Display Allowed.

When enabled, the mobile station is allowed to include a Display information element in the Audit Confirmation message.

DEBUG?

Returns current state of DEBUG.

AUTHBS n

ICSS:SPACH:AUTHBSI

Specifies AUTHBS. Range of n is 0 to #hFFFF.

Contains the output from the Authentication procedure.

AUTHBS?

Returns current value of AUTHBS.

BSMC n

[CSS:SPACH:BSMC]

Specifies Base Station Manufacture Code. Range of n is 0 to 255.

Identifies the assigned manufacture code. The BSMC value of 0 is reserved. A reserved BSMC value shall be considered an unknown base station manufacture code by the receiving mobile station.

BSMC?

Returns current value of BSMC.

CUSTOM:

LENGth n

[CSS:SPACH:CUSTOM:LENGth]

Specifies Length of Custom Control Control in octets. Range of n is 1 to 64.

LENGth?

Returns current value of LENGth.

CONTrol n,m

[CSS:SPACH:CUSTOM:CONTrol]

Specifies Custom Control (m) indexed by n. Range of n is 0 to 63; range of m is 0 to 255.

CONTrol?

Returns current value of CONTrol indexed by n.

SPACH:

DVCC n

[CSS:SPACH:DVCC]

Specifies Digital Verification Color Code. Range of n is 0 to 255.

DVCC?

Returns current value of DVCC.

DMAC n

[CSS:SPACH:DMAC]

Specifies DMAC. Range of n is 0 to 15.

Indicates the power level to be used on the assigned digital traffic channel.

DMAC?

Returns current value of DMAC.

ATS n

[CSS:SPACH:ATS]

Specifies Assigned Time Slot. Range of n is 0 to 15.

ATS?

Returns current value of ATS.

SB n

[CSS:SPACH:SB]

Enables (n = 1) or disables (n = 0) Shortened Burst.

Defines whether the mobile station shall use the shortened burst initially on the assigned digital traffic channel.

SB?

Returns current state of SB.

TA n

[CSS:SPACH:TA]

Specifies Time Alignment. Range of n is 0 to 31.

Indicates the absolute timing offset from the standard offset reference (SOR) position.

TA?

Returns current value of TA.

SPACH:

MODE:

DIC n

[CSS:SPACH:MODE:DIC]

Enables (n = 1) or disables (n = 0) Delay Interval Compensation Mode.

Used to control the application of the DIC mode in the mobile station. When received in the access parameters message, the domain of DIC application shall be the DCCH. When received in the Digital Traffic Channel Designation message, the domain of DIC application shall be the DTC

DIC?

Returns current state of DIC.

VOICE:

Identifies the mode to be used for the requested Voice Call.

VC n

[CSS:SPACH:MODE:VOICE:VC]

Specifies Voice Coder. Range of n is 0 to 7.

VC?

Returns current value of VC.

PM Vn

[CSS:SPACH:MODE:VOICE:VC]

Specifies Voice Privacy. Range of n is 0 to 7.

PM V?

Returns current value of PM_V.

MEM:

Message Encryption Mode- Identifies the selected message encryption algorithm, key and domain.

MEA n

[CSS:SPACH:MODE:MEM:MEA]

Specifies Message Encryption Algorithm. Range of n is 0 to 7.

MEA?

Returns current value of MEA.

SPACH:

MODE:

MEM:

MED n

[CSS:SPACH:MODE:MEM:MED]

Specifies Message Encryption Domain. Range of n is 0 to 7.

MED?

Returns current value of MED.

MEK n

[CSS:SPACH:MODE:MEM:MEK]

Specifies Message Encryption Key. Range of n is 0 to 7.

MEK?

Returns current value of MEK.

HYPERband:

If present, this information element is used to specify the Hyperband associated with the specified channel.

INFO n

[CSS:SPACH:MODE:HYPERband:INFO]

Specifies Hyperband Info. Range of n is 0 to 3.

Provides frequency band information

INFO?

Returns current value of INFO.

LT n

[CSS:SPACH:LT]

Enables (n = 1) or disables (n = 0) Last Try.

If a mobile station receives a Directed Retry and attempts a new access on another DCCH, it shall set the Last Try flag in the Origination or the Page Response message to the value of the Last Try flag received in the Directed Retry message. Otherwise, the mobile station shall set the Last Try flag to 0 at system access.

LT?

Returns current state of LT.

SPACH:

RCF n

[CSS:SPACH:RCF]

Enables (n = 1) or disables (n = 0) Control Filler information.

When enabled, the mobile station is to read Control Filler information.

RCF?

Returns current state of RCF.

AUTH n

[CSS:SPACH:AUTH]

Enables (n = 1) or disables (n = 0) Authentication information.

When enabled, Authentication information is sent when making an access on an ACC as a result of a Directed Retry received on the DCCH.

AUTH?

Returns current state of AUTH.

MSGWTG:

NV n

[CSS:SPACH:MSGWTG:NV]

Specifies Number of Values. Range of n is 0 to 15.

NV?

Returns current value of NV.

TYPE n,m

[CSS:SPACH:MSGWTG:TYPE]

Specifies Type of Message Waiting (m) indexed by n. Range of n is 0 to 15; range of m is 0 to 15.

TYPE? n

Returns current value of TYPE indexed by n. Range of n is 0 to 15.

NUMber n,m

[CSS:SPACH:MSGWTG:NUMber]

Specifies Number of Messages Waiting (m) indexed by n. Range of n is 0 to 15; range of m is 0 to 63.

Up to 16 instances of this field may be sent.

NUMber? n

Returns current value of NUMber indexed by n. Range of n is 0 to 15.

SPACH:

SERVice n

[CSS:SPACH:SERVice]

Specifies Service Code. Range of n is 0 to 15.

Indicates the requested service.

SERVice?

Returns current value of SERVice.

SIGnal:

PITCH n

[CSS:SPACH:SIGnal:PITCH]

Specifies Signal Pitch. Range of n is 0 to 3.

PITCH?

Returns current value of PITCH.

CADence n

[CSS:SPACH:SIGnal:CADence]

Specifies Signal Cadence. Range of n is 0 to 63.

CADence?

Returns current value of CADence.

DURation n

[CSS:SPACH:SIGnal:DURation]

Specifies Signal Duration. Range of n is 0 to 15.

DURation?

Returns current value of DURation.

CALLED:

Called Party - Identifies the called party associated with a mobile station.

TYPE n

[CSS:SPACH:CALLED:TYPE]

Specifies Type of Number. Range of n is 0 to 7.

TYPE?

Returns current value of TYPE.

PLANId n

[CSS:SPACH:CALLED:PLANId]

Specifies Numbering Plan Identification. Range of n is 0 to 15.

PLANId?

Returns current value of PLANid.

SPACH:

CALLED:

ENCoding n

[CSS:SPACH:CALLED:ENCoding]

Enables (n = 1) or disables (n = 0) Address Encoding.

ENCoding?

Returns current state of ENCoding.

ADDRess "n"

[CSS:SPACH:CALLED:ADDRess]

Specifies Called Address. (ASCII string).

ADDRess?

Returns current string value of ADDRess.

SUBaddress:

Identifies the address of a called or calling party.

LENGth n

[CSS:SPACH:CALLED:SUBaddress:LENGth]

Specifies Length of Subaddress Info content. Range of n is 0 to 255.

LENGth?

Returns current value of LENGth.

ODD EVEN n

[CSS:SPACH:CALLED:SUBaddress:ODD_EVEN]

Enables (n = 1) or disables (n = 0) Odd/Even Indicator.

ODD EVEN?

Returns current state of ODD_EVEN.

TYPE n

[CSS:SPACH:CALLED:SUBaddress:TYPE]

Specifies Type of Subaddress. Range of n is 0 to 7.

TYPE?

Returns current value of TYPE.

REServed n

[CSS:SPACH:CALLED:SUBaddress:REServed]

Enables (n = 1) or disables (n = 0) Reserved.

REServed?

Returns current state of REServed.

SPACH:

CALLED:

ADDRess n.m

[CSS:SPACH:CALLED:SUBaddress:ADDRess]

Specifies Called Subaddress (m) indexed by n. Range of n is 0 to 19; range of m is 0 to 255.

ADDRess? n

Returns current value of ADDRess indexed by n. Range of n is 0 to 19.

CALLING:

Calling Party - Identifies the calling party associated with a mobile station.

TYPE n

[CSS:SPACH:CALLING:TYPE]

Specifies Type of Number. Range of n is 0 to 7.

TYPE?

Returns current value of TYPE.

PLANId n

[CSS:SPACH:CALLING:PLANId]

Specifies Numbering Plan Identification. Range of n is 0 to 15.

PLANId?

Returns current value of PLANid.

ENCoding n

[CSS:SPACH:CALLING:ENCoding]

Enables (n = 1) or disables (n = 0) Address Encoding.

ENCoding?

Returns current state of ENCoding.

ADDRess "n"

[CSS:SPACH:CALLING:ADDRess]

Specifies Address. Range of n is 0 to 255.

Up to 254 instances of this field may be sent.

ADDRess?

Returns current value of ADDRess.

SPACH:

CALLING:

SUBaddress:

Identifies the address of a called or calling party.

LENGth n

[CSS:SPACH:CALLING:SUBaddress:LENGth]

Specifies Length of Subaddress Info content. Range of n is 0 to 255.

LENGth?

Returns current value of LENGth.

ODD EVEN n

[CSS:SPACH:CALLING:SUBaddress:ODD_EVEN]

Enables (n = 1) or disables (n = 0) Odd/Even Indicator.

ODD_EVEN?

Returns current state of ODD_EVEN.

TYPE

[CSS:SPACH:CALLING:SUBaddress:TYPE]

Specifies Type of Subaddress. Range of n is 0 to 7.

TYPE?

Returns current value of TYPE.

REServed n

[CSS:SPACH:CALLING:SUBaddress:REServed]

Enables (n = 1) or disables (n = 0) Reserved.

REServed?

Returns current state of REServed.

ADDRess n.m

[CSS:SPACH:CALLING:SUBaddress:ADDRess]

Specifies Calling Subaddress (m) indexed by n. Range of n is 0 to 19; range of m is 0 to 255.

ADDRess? n

Returns current value of Calling Subaddress indexed by n. Range of n is 0 to 19.

SPACH:

CALLING:

PRESentation:

Identifies the presentation restrictions and screening related to the Calling Party information element.

PIn

[CSS:SPACH:CALLING:PRESentation:PI]

Specifies Calling Party Number Presentation Indicator. Range of n is 0 to 3.

P17

Returns current value of Pl.

SIn

[CSS:SPACH:CALLING:PRESentation:SI]

Specifies Screening Indicator. Range of n is 0 to 3.

\$12

Returns current value of SI.

RN n

[CSS:SPACH:RN]

Specifies Request Number. Range of n is 0 to 15.

Used in a Parameter Update message to allow the mobile station to recognize duplicate Parameter Update messages.

RN?

Returns current value of RN.

RTRANSaction n

[CSS:SPACH:RTRANSaction]

Specifies R-Transaction Identifier. Range of n is 0 to 255.

Used to associate a R-DATA ACCEPT or a R-DATA REJECT message to the R-DATA message being acknowledged.

RTRANSaction?

Returns current value of RTRANSaction.

SPACH:

RDATA_UNIT:

Contains the Higher Layer Protocol Data Unit and is mandatory in an R-DATA message.

LENGth n

[CSS:SPACH:RDATA_UNIT:LENGth]

Specifies Length Indicator. Range of n is 0 to 255.

LENGth?

Returns current value of LENGth.

HLP:

IDentifier n

[CSS:SPACH:RDATA_UNIT:HLP:IDentifier]

Specifies Higher Protocol Identifier. Range of n is 0 to 255.

Identifier?

Returns current value of IDentifier.

DATA n.m

[CSS:SPACH:RDATA_UNIT:HLP:DATA]

Specifies Higher Layer Protocol Data Unit (m) indexed by n. Range of n is 0 to 255; range of m is 0 to 255.

DATA? n

Returns current value of DATA indexed by n. Range of n is 0 to 255.

MESSage:

CENTer:

Identifies the Message Center Address for the message being sent.

TYPE n

[CSS:SPACH:MESSage:CENTer:TYPE]

Specifies Type of Number. Range of n is 0 to 7.

TYPE?

Returns current value of TYPE.

PLANId n

[CSS:SPACH:MESSage:CENTer:PLANid]

Specifies Numbering Plan Identification. Range of n is 0 to 15.

PLANId?

Returns current value of PLANid.

SPACH:

MESSage:

CENTer:

ENCoding n

[CSS:SPACH:MESSage:CENTer:ENCoding] Enables (n = 1) or disables (n = 0) Address Encoding.

ENCoding?

Returns current state of ENCoding.

ADDRess "n"

[CSS:SPACH:MESSage:CENTer:ADDRess]
Specifies Address. Range of n is 0 to 255.

Up to 254 instances of this field may be sent.

ADDRess?

Returns current value of ADDRess.

USER:

DEST:

User Destination Address.

TYPE n

[CSS:SPACH:USER:DEST:TYPE]
Specifies Type of Number. Range of n is 0 to 7.

TYPE?

Returns current value of TYPE.

PLANId n

[CSS:SPACH:USER:DEST:PLANId]

Specifies Numbering Plan Identification. Range of n is 0 to 15.

PLANId?

Returns current value of PLANid.

ENCoding n

[CSS:SPACH:USER:DEST:ENCoding]

Enables (n = 1) or disables (n = 0) Address Encoding.

ENCoding?

Returns current state of ENCoding.

SPACH:

USER:

DEST:

ADDRess "n"

[CSS:SPACH:USER:DEST:ADDRess]

Specifies Address. Range of n is 0 to 255.

Up to 254 instances of this field may be sent.

ADDRess?

Returns current value of ADDRess.

SUBaddress:

Identifies the address of a called or calling party.

LENGth n

[CSS:SPACH:USER:DEST:SUBaddress:LENGth]

Specifies Length of Subaddress Info content. Range of n is 0 to 255.

LENGth?

Returns current value of LENGth.

ODD_EVEN n

[CSS:SPACH:USER:DEST:SUBaddress:ODD_EVEN]

Enables (n = 1) or disables (n = 0) Odd/Even Indicator.

ODD_EVEN?

Returns current state of ODD_EVEN.

TYPE n

[CSS:SPACH:USER:DEST:SUBaddress:TYPE]

Specifies Type of Subaddress. Range of n is 0 to 7.

TYPE?

Returns current value of TYPE.

REServed n

[CSS:SPACH:USER:DEST:SUBaddress:REServed]

Enables (n = 1) or disables (n = 0) Reserved.

REServed?

Returns current state of REServed.

SPACH:

USER:

DEST:

SUBaddress:

ADDRess n.m

[CSS:SPACH:USER:DEST:SUBaddress:ADDRess]

Specifies User Destination Subaddress (m) indexed by n. Range of n is 0 to 19; range of m is 0 to 255.

ADDRess? n

Returns current value of ADDRess indexed by n. Range of n is 0 to 19.

GROUP:

Identifies the User Group ID that a mobile station has requested or has been allocated.

STATUS n

[CSS:SPACH:USER:GROUP:STATus]

Specifies User Group Status. Range of n is 0 to 3.

STATUS?

Returns current value of STATUS.

TYPE n

[CSS:SPACH:USER:GROUP:TYPE]

Specifies User Group Type. Range of n is 0 to 3.

TYPE?

Returns current value of TYPE.

ID:

MS n

[CSS:SPACH:USER:GROUP:ID:MS]

Specifies the 18 Most Significant Bits of User Group Identification. Range of n is 0 to #h3FFFF.

MS?

Returns current value of MS.

SPACH:

USER:

GROUP:

ID:

LS n

[CSS:SPACH:USER:GROUP:ID:LS]

Specifies 32 Least Significant Bits of User Group Identification. Range of n is 0 to #hFFFFFFF.

LS?

Returns current value of LS.

ORIG:

TYPE n

[CSS:SPACH:USER:ORIG:TYPE]

Specifies Type of Number. Range of n is 0 to 7.

TYPE?

Returns current value of TYPE.

PLANId n

[CSS:SPACH:USER:ORIG:PLANId]

Specifies Numbering Plan Identification. Range of n is 0 to 15.

PLANId?

Returns current value of PLANid.

ENCoding n

[CSS:SPACH:USER:ORIG:ENCoding]

Enables (n = 1) or disables (n = 0) Address Encoding.

ENCoding?

Returns current state of ENCoding.

ADDRess "n"

[CSS:SPACH:USER:ORIG:ADDRess]

Specifies Address. Range of n is 0 to 255.

Up to 254 instances of this field may be sent.

ADDRess?

Returns current value of ADDRess.

SPACH:

USER:

ORIG:

SUBaddress:

Identifies the address of a called or calling party.

LENGth n

[CSS:SPACH:USER:ORIG:SUBaddress:LENGth]
Specifies Length of Subaddress Info content. Range of n is 0 to 255.

LENGth?

Returns current value of LENGth.

ODD EVEN n

[CSS:SPACH:USER:ORIG:SUBaddress:ODD_EVEN] Enables (n = 1) or disables (n = 0) Odd/Even Indicator.

ODD_EVEN?

Returns current state of ODD EVEN.

TYPE /

[CSS:SPACH:USER:ORIG:SUBaddress:TYPE]
Specifies Type of Subaddress. Range of n is 0 to 7.

TYPE?

Returns current value of TYPE.

REServed n

[CSS:SPACH:USER:ORIG:SUBaddress:REServed] Enables (n = 1) or disables (n = 0) Reserved.

REServed?

Returns current state of REServed.

ADDRess n,m

[CSS:SPACH:USER:ORIG:SUBaddress:ADDRess]

Specifies User Origination Subaddress (m) indexed by n. Range of n is 0 to 19; range of m is 0 to 255.

ADDRess? n

Returns current value of ADDRess indexed by n. Range of n is 0 to 19.

SPACH:

PFC:

ASSIGNment n

[CSS:SPACH:PFC:ASSIGNment]

Specifies PFC Assignment. Range of n is 0 to 3.

Identifies the Paging Frame Class that a mobile station may be assigned at registration.

ASSIGNment?

Returns current value of ASSIGNment.

RNUM:

Contains the registration number that is used to define a particular mobile station's VMLA (Virtual Mobile Location Area).

NUMber n

[CSS:SPACH:RNUM:NUMber]

Specifies Number of RNUMs. Range of n is 1 to 50.

NUMber?

Returns current value of NUMber.

LIST n.m

[CSS:SPACH:RNUM:LIST]

Specifies LIST (m) indexed by n. Range of n is 0 to 49; range of m is 0 to 1023.

Up to 50 instances of this field may be sent.

LIST?

Returns current value of LIST indexed by n. Range of n is 0 to 49.

MSID:

Mobile Station Identification Assignment - Contains information specifying the MSID the mobile station shall use.

IDT n

[CSS:SPACH:MSID:IDT]

Specifies Identity Type. Range of n is 0 to 3.

IDT?

Returns current value of IDT.

SPACH:

MSID:

ASSIGNment n

[CSS:SPACH:MSID:ASSIGNment]

Specifies MSID Assignment. Range of n is 0 to #hFFFFFF.

ASSIGNment?

Returns current value of ASSIGNment.

PSID_RSID:

Private/Residential System Identification.

AVAILable:

PSID/RSID Available

NUMBer n

[CSS:SPACH:PSID_RSID:AVAILable:NUMBer]
Specifies Number of PSID/RSID. Range of n is 0 to 15.

NUMBer?

Returns current value of NUMBer.

TYPE n,m

[CSS:SPACH:PSID_RSID:AVAILable:TYPE]

Enables (m = 1) or disables (m = 0) PSID/RSID Type Indicator indexed by n. Range of n is 0 to 15.

TYPE? n

Returns current state of TYPE indexed by n. Range of n is 0 to 15.

VALUE n,m

[CSS:SPACH:PSID_RSID:AVAILable:VALUE]

Specifies PSID/RSID Value (m) indexed by n. Range of n is 0 to 15; range of m is 0 to #hFFFF.

VALUE? n

Returns current value of VALUE indexed by n. Range of n is 0 to 15.

SPACH:

PSID_RSID:

MAP n

[CSS:SPACH:PSID_RSID:MAP]

Specifies PSID/RSID Map. Range of n is 0 to #hFFFF.

This information is included in the Test Registration message to indicate which private/residential systems have been queried by the mobile station. This information is included in the Test Registration Response message to indicate the private/residential systems on which the mobile station may receive service. The ordering of the PSID/RSID Map reflects the ordering of the PSID/RSID Set sent on the system identity message.

MAP?

Returns current value of MAP.

DIRectory:

TYPE n

[CSS:SPACH:DIRectory:TYPE]

Specifies Type of Number. Range of n is 0 to 7.

TYPE?

Returns current value of TYPE.

PLANId n

[CSS:SPACH:DIRectory:PLANid]

Specifies Numbering Plan Identification. Range of n is 0 to 15.

PLANId?

Returns current value of PLANid.

ENCoding n

[CSS:SPACH:DIRectory:ENCoding]

Enables (n = 1) or disables (n = 0) Address Encoding.

ENCoding?

Returns current state of ENCoding.

ADDRess "n"

[CSS:SPACH:DIRectory:ADDRess]

Specifies Address. Range of n is 0 to 255.

Up to 254 instances of this field may be sent.

ADDRess?

Returns current value of ADDRess.

SPACH:

DIRectory:

SUBaddress:

Identifies the address of a called or calling party.

LENGth n

[CSS:SPACH:DIRectory:SUBaddress:LENGth]

Specifies Length of Subaddress Info content. Range of n is 0 to 255.

LENGth?

Returns current value of LENGth.

ODD EVEN n

[CSS:SPACH:DIRectory:SUBaddress:ODD_EVEN]

Enables (n = 1) or disables (n = 0) Odd/Even Indicator.

ODD_EVEN?

Returns current state of ODD_EVEN.

TYPE n

[CSS:SPACH:DIRectory:SUBaddress:TYPE]

Specifies Type of Subaddress. Range of n is 0 to 7.

TYPE?

Returns current value of TYPE.

REServed n

[CSS:SPACH:DIRectory:SUBaddress:REServed]

Enables (n = 1) or disables (n = 0) Reserved.

REServed?

Returns current state of REServed.

ADDRess n,m

[CSS:SPACH:DIRectory:SUBaddress:ADDRess]

Specifies Directory Subaddress (m) indexed by n. Range of n is 0 to 19; range of m is 0 to 255.

ADDRess? n

Returns current value of Directory Subaddress indexed by n. Range of n is 0 to 19.

SPACH:

REJect:

REGistration:

Registration Reject message

CAUSE n

[CSS:SPACH:REJect:REGistration:CAUSE]

Specifies CAUSE. Range of n is 0 to 15.

Indicates the cause for a Registration Reject.

CAUSE?

Returns current value of CAUSE.

TIME:

Reject Time - Used by the system to indicate to a mobile station the interval of time when it will be allowed to register, again.

LOWer n

[CSS:SPACH:REJect:REGistration:TIME:LOWer]

Specifies Lower time boundary in 100 Superframe (SF). Range of n is 0 to 15.

LOWer?

Returns current value of LOWer.

UPPer n

[CSS:SPACH:REJect:REGistration:TIME:UPPer]

Specifies Upper time boundary in 100 Superframe (SF). Range of n is 0 to 15.

UPPer?

Returns current value of UPPer.

RDATA:

CAUSE n

[CSS:SPACH:REJect:RDATA:CAUSE]

Specifies CAUSE. Range of n is 0 to 127.

The cause for the R-DATA Reject.

CAUSE?

Returns current value of CAUSE.

SPACH:

REJect:

RDATA:

SPARE n

[CSS:SPACH:REJect:RDATA:SPARE]

Enables (n = 1) or disables (n = 0) R-Cause Reserved field.

SPARE?

Returns current state of SPARE.

RELease:

Used when the BMI (Base Station, MSC and Interworking Function) clears a mobile station terminated call.

CAUSE n

[CSS:SPACH:RELease:CAUSE]

Specifies CAUSE. Range of n is 0 to 15.

Indicates the cause for a Release.

CAUSE?

Returns current value of CAUSE.

REorder:

Used when the BMI (Base Station, MSC and Interworking Function) rejects an Origination or a R-DATA message sent by the mobile station.

CAUSE n

[CSS:SPACH:REorder:CAUSE]

Specifies CAUSE. Range of n is 0 to 15.

Indicates the cause for a Reorder/Intercept.

CAUSE?

Returns current value of CAUSE.

TONE n

[CSS:SPACH:REorder:TONE]

Specifies Tone Indicator. Range of n is 0 to 3.

Used to indicate the type of tone to be generated by the mobile station.

TONE?

Returns current value of TONE.

SPACH:

SOC n

[CSS:SPACH:SOC]

Specifies System Operator Code. Range of n is 0 to 4095.

Identifies which operator is providing service. A reserved SOC value shall be considered an unknown system operator code by a receiving mobile station.

SOC?

Returns current value of SOC.

NOTification n

[C\$S:SPACH:NOTification]

Specifies SPACH Notification Type. Range of n is 0 to 63.

Contains the message type identifying the message that the BMI intends to deliver to the mobile station. The valid values for SPACH Notification Type shall be limited to the Message Type associated with Page, SSD Update and R-DATA.

NOTification?

Returns current value of NOTification.

RANDSSD1 n

[CSS:SPACH:RANDSSD1]

Specifies Shared Secret Data. Range of n is 0 to #hFFFFFF.

Identifies a random number generated by the BMI that is used in the SSD (Shared Secret Data) Update procedure.

RANDSSD1?

Returns the value of RANDSSD1.

RANDSSD2 n

[CSS:SPACH:RANDSSD2]

Specifies Shared Secret Data. Range of n is 0 to #hFFFFFFF.

Identifies a random number generated by the BMI that is used in the SSD (Shared Secret Data) Update procedure.

RANDSSD2?

Returns current value of RANDSSD2.

SPACH:

ALPHA:

SID "n"

[CSS:SPACH:ALPHA:SID]

Specifies Alphanumeric System ID. n is a phone number, e.g., 316/522-4981.

The purpose of the Alphanumeric System ID information element is to supply an alphanumeric system ID to each user. The information contained in this information element is coded in IRA characters.

SID?

Returns current value of SID.

PSID RSID:

Alphanumeric PSID/RSID List - The purpose of this information element is to supply an Alphanumeric PSID/RSID to the user. The ordering of the Alphanumeric PSID/RSID list reflects the ordering of the PSID/RSID Set sent to the System Identity message. The information contained in this information element is coded in IRA characters.

NUMBer n

[CSS:SPACH:ALPHA:PSID RSID:LENGth]

Specifies Length of Alphanumeric PSID/RSID List. Range of n is 0 to 16.

NUMBer?

Returns current value of LENGth.

NAME:

CHARacter n,"m"

[CSS:SPACH:ALPHA:PSID_RSID:NAME:CHARacter]

Specifies Display Character (m) indexed by n. Range of n is (0-16); m is an ASCII string.

CHARacter? n

Returns current value of CHARacter indexed by n. Range of n is 0 to 16.

RANDU n

[CSS:SPACH:RANDU]

Specifies RANDU. Range of n is 0 to #hFFFFFF.

Identifies the random number generated by the BMI that is used in the Unique Challenge Response procedure.

RANDU?

Returns current value of RANDU.

SPACH:

ENABLE:

SUBaddress n

[CSS:SPACH:ENABLE:SUBaddress]

Enables (n = 1) or disables (n = 0) Subaddress.

SUBaddress?

Returns current state of SUBaddress.

DTX n

[CSS:SPACH:ENABLE:DTX]

Enables (n = 1) or disables (n = 0) DTX Support.

DTX?

Returns current state of DTX.

DISPlay n

[CSS:SPACH:ENABLE:DISPlay]

Enables (n = 1) or disables (n = 0) Display.

DISPlay?

Returns current state of DISPlay.

MODE:

VOICE n

[CSS:SPACH:ENABLE:MODE:VOICE]

Enables (n = 1) or disables (n = 0) Voice Mode.

VOICE?

Returns current state of VOICE.

MEM n

[CSS:SPACH:ENABLE:MODE:MEM]

Enables (n = 1) or disables (n = 0) Message Encryption Mode.

MEM?

Returns current state of MEM.

HYPERband:

INFO n

[CSS:SPACH:ENABLE:HYPERband:INFO]

Enables (n = 1) or disables (n = 0) Hyperband Info.

INFO?

Returns current state of INFO.

CSS.

SPACH:

ENABLE:

RCF AUTH n

[CSS:SPACH:ENABLE:RCF_AUTH]

Enables (n = 1) or disables (n = 0) RCF and AUTH.

RCF AUTH?

Returns current state of RCF_AUTH.

SiGnal n

[CSS:SPACH:ENABLE:SIGnal]

Enables (n = 1) or disables (n = 0) SIGnal.

SIGnal?

Returns current state of SIGnal.

CALLED:

ADDRess n

[CSS:SPACH:ENABLE:CALLED:ADDRess]

Enables (n = 1) or disables (n = 0) Called Party Address.

ADDRess?

Returns current state of ADDRess.

SUBaddress n

[CSS:SPACH:ENABLE:CALLED:SUBaddress]

Enables (n = 1) or disables (n = 0) Called Party Subaddress.

SUBaddress?

Returns current state of SUBaddress

CALLING:

ADDRess n

[CSS:SPACH:ENABLE:CALLING:ADDRess]

Enables (n = 1) or disables (n = 0) Calling Party Address.

ADDRess?

Returns current state of ADDRess.

SUBaddress n

[CSS:SPACH:ENABLE:CALLING:SUBaddress]

Enables (n = 1) or disables (n = 0) Calling Party Subaddress.

SUBaddress?

Returns current state of SUBaddress

SPACH:

ENABLE:

CALLING:

PRESentation n

[CSS:SPACH:ENABLE:CALLING:PRESentation]

Enables (n = 1) or disables (n = 0) Calling Party Number Presentation Indicator.

PRESentation?

Returns current state of PRESentation.

MESSage:

CENTer:

ADDRess n

[CSS:SPACH:ENABLE:MESSage:CENTer:ADDRess]

Enables (n = 1) or disables (n = 0) Message Center Address.

ADDRess?

Returns current state of ADDRess.

USER:

DEST:

ADDRess n

[CSS:SPACH:ENABLE:USER:DEST:ADDRess]

Enables (n = 1) or disables (n = 0) User Destination Address.

ADDRess?

Returns current state of ADDress.

SUBaddress n

[CSS:SPACH:ENABLE:USER:DEST:SUBaddress]

Enables (n = 1) or disables (n = 0) User Destination Subaddress.

SUBaddress?

Returns current state of SUBaddress.

ORIG:

ADDRess n

[CSS:SPACH:ENABLE:USER:ORIG:ADDRess]

Enables (n = 1) or disables (n = 0) User Originating Address.

ADDRess?

Returns current state of ADDRess.

SPACH:

ENABLE:

USER:

ORIG:

SUBaddress n

[CSS:SPACH:ENABLE:USER:ORIG:SUBaddress] Enables (n = 1) or disables (n = 0) User Originating Subaddress.

SUBaddress?

Returns current state of SUBaddress.

GROUP n

[CSS:SPACH:ENABLE:USER:GROUP] Enables (n = 1) or disables (n = 0) User Group.

GROUP?

Returns current state of GROUP.

PFC:

Paging Frame Class.

ASSIGNment n

[CSS:SPACH:ENABLE:PFC:ASSIGNment] Enables (n = 1) or disables (n = 0) PFC Assignment.

ASSIGNment?

Returns current state of ASSIGNment.

RNUM:

Registration Number.

LIST n

[CSS:SPACH:ENABLE:RNUM:LIST] Enables (n = 1) or disables (n = 0) RNUM List.

LIST?

Returns current state of LIST.

SPACH:

ENABLE:

MSID:

Mobile Station Identification.

ASSIGNment n

[CSS:SPACH:ENABLE:MSID:ASSIGNment] Enables (n = 1) or disables (n = 0) MSID Assignment.

ASSIGNment?

Returns current state of ASSIGNment.

PSID RSID:

Private/Residential System Identification.

AVAILable n

[CSS:SPACH:ENABLE:PSID_RSID:AVAILable] Enables (n = 1) or disables (n = 0) PSID/RSID Available.

AVAILable?

Returns current state of AVAILable.

DIRectory:

ADDRess n

[CSS:SPACH:ENABLE:DIRectory:ADDRess] Enables (n = 1) or disables (n = 0) Directory Address.

ADDRess?

Returns current state of ADDRess.

SUBaddress n

[CSS:SPACH:ENABLE:DIRectory:SUBaddress] Enables (n = 1) or disables (n = 0) Directory Subaddress.

SUBaddress?

Returns current state of SUBaddress.

REJect:

TIME n

[CSS:SPACH:ENABLE:REJect:TIME] Enables (n = 1) or disables (n = 0) Reject Time.

TIME?

Returns current state of TIME.

SPACH:

ENABLE:

ALPHA:

SID n

[CSS:SPACH:ENABLE:ALPHA:SID]

Enables (n = 1) or disables (n = 0) Alphanumeric System ID.

SID?

Returns current state of SID.

PSID_RSID n

[CSS:SPACH:ENABLE:ALPHA:PSID_RSID]

Enables (n = 1) or disables (n = 0) Alphanumeric PSID/RSID List.

PSID_RSID?

Returns current state of PSID_RSID.

7-17 RDCCH DATA MONITOR

7-17-1 SETUP COMMANDS

RDCCH:

SETup

[RDCCH:SETup]

Configures the FM/AM-1600CSA to receive on the RDCCH.

The 1600S is forced into the duplex mode of operation.

SLOT n

[RDCCH:SLOT]

Specifies SLOT pair on which to receive. Range of n is 1 to 3.

SLOT?

Returns current value of SLOT.

CHANnel n

[RDCCH:CHANnel]

Specifies Reverse Channel to monitor. Range of n is 1 to 1023.

The FM/AM-1600S is forced into Duplex Operation.

CHANnel?

Returns current value of CHANnel.

RATE n

[RDCCH:RATE]

Selects Transmission Rate: Full (n = 0) or Half (n = 1).

RATE?

Returns current setting of RATE.

DVCC n

[RDCCH:DVCC]

Specifies Digital Verification Color Code. Range of n is 1 to 255.

Digital Verification Color Code, which is used when calculating the CRC, must be specified to decode the message.

DVCC?

Returns current value of DVCC.

RDCCH:

LENGth:

NORMal

[RDCCH:LENGth:NORMal]
Configures the 1600CSA to decode normal length bursts on the RDCCH.

ABBREViated

[RDCCH:LENGth:ABBREViated] Configures the 1600CSA to decode abbreviated length bursts on the RDCCH.

LENGth?

Returns current setting of LENGth: 0 = Normal, 1 = Abbreviated.

7-17-2 CONTINUOUS REMOTE RAW TIMESLOT DATA

The RDCCH timeslot data is presented exactly as received with no de-interleaving, error correction or formatting of data. The number of bits in a timeslot is 312 for a normal slot and 274 for an abbreviated slot, corresponding to 78 ASCII characters. The data on the RDCCH is present only when the mobile station is accessing the system. The baud rate should be set to 57600 for both the FM/AM-1600CSA and the RS-232 terminal. The following TMAC commands are used to start and stop this operation:

RDCCH:

REMote:

TIMEslot:

STAR

[RDCCH:REMote:TIMEslot:STARt]
Starts sending the received data out the RS-232 Connector.

STOP

[RDCCH:REMote:TIMEslot:STOP]

Stops sending the received data out the RS-232 Connector.

7-17-3 CONTINUOUS REMOTE RAW DATA

This mode differs from Continuous Remote Raw Timeslot Data in Section 7-17-2. This mode de-interleaves the data and performs forward error correction before presenting the data. The timeslot is broken into the various data fields and continuously transmitted out the RS-232 Connector. Following the data is a millisecond time stamp which provides relative time between slots of data.

The RDCCH data is presented in hexadecimal out the RS-232 Connector with each frame of data being separated by a newline character. The data is formatted as follows:

- The first 7 characters represent the 28 bits of the SYNC word.
- The next 6 characters are the hexadecimal value of the 24 bits of SYNC+.
- The next 30 characters are the hexadecimal value (left justified) of the 117 bits of data.
- The flag is followed by a millisecond time stamp.

The following TMAC commands are used to set up and start and stop this operation:

RDCCH:

REMote:

RAW:

DVCC n

[RDCCH:REMote:RAW:DVCC]

Specifies Digital Verification Color Code. Range of n is 1 to 255.

A DVCC, which is used when calculating the CRC, must be specified to decode the message.

LENGth:

ABBREViated

[RDCCH:REMote:RAW:LENGth:ABBREViated]

Configures the FM/AM-1600CSA to decode abbreviated length bursts on the RDCCH.

NORMal

[RDCCH:REMote:RAW:LENGth:NORMal]

Configures the FM/AM-1600CSA to decode normal length bursts on the RDCCH.

STARt

[RDCCH:REMote:RAW:STARt]

Starts sending the received, de-interleaved and decoded data out the RS-232 Connector.

STOP

[RDCCH:REMote:RAW:STOP]

Stops sending the received data out the RS-232 Connector.

An embedded macro named RRAW initiates the START when executed and sends a STOP when any key on the RS-232 Terminal is pressed. To use this macro, type in the command RRAW at the RS-232 terminal.

7-17-4 BUFFERED RAW DATA

The RDCCH Buffered Raw Data commands consist of the TMAC commands used for Layer 1 raw data buffering. Up to 100 frames of raw data can be captured (similar to FOCC raw data TMAC commands). The following commands are used for this operation:

RDCCH:

RAW:

COUNT?

[RDCCH:RAW:COUNT]

Returns current number of frames (0 to 100 bit value) received and stored into the raw buffer.

When COUNT is equal to DEPTH, the raw buffer is full. Allows the user to access or decode the raw data as it is received instead of waiting until the raw buffer is completely full.

DATA? n.x

[RDCCH:RAW:DATA]

Returns current raw data byte (8 bit value) (indexed by x) in selected raw data frame (n). Range of n is 0 to 99; range of x is 0 to 15.

DEPTH n

[RDCCH:RAW:DEPTH]

Specifies depth of the raw buffer. Range of n is 0 to 99.

PREAMble? n

[RDCCH:RAW:PREAMble]

Returns current value of Preamble (16 bit value) in selected raw data frame (n). Range of n is 0 to 99.

STAR

[RDCCH:RAW:STARt]

Starts capturing raw data on the RDCCH.

STOP

IRDCCH:RAW:STOPI

Stops capturing raw data on the RDCCH.

STOP happens automatically when the buffer is full.

SYNC? n

[RDCCH:RAW:SYNC]

Returns current value of SYNC (28 bit value) in selected raw data frame (n). Range of n is 0 to 99.

SYNCPLUS? n

[RDCCH:RAW:SYNCPLUS]

Returns current value of SYNC+ (24 bit value) in selected raw data frame (n). Range of n is 0 to 99.

RAW:

TS? n [RDCCH:RAW:TS] Returns Time Stamp (in milliseconds) of selected raw data frame (n). Range of n is 0 to 99.

7-17-5 LAYER 2 DATA MONITOR

The Layer 2 Data Monitor is made up of the TMAC commands necessary to decode a Layer 2 message.

The process involves the following steps:

- 1. Capture 1 to 100 words into the raw data buffer for non real-time decoding into Layer 2 data fields. Use the RDCCH Buffered Raw data commands described in Section 7-17-4.
- 2. Select one frame of raw data from the raw buffer and decode the frame into Layer 2 fields:

RDCCH:

LAYER2:

DECode n[RDCCH:LAYER2:DECode]
Decodes selected frame of data (n) in the raw buffer. Range of n is 0 to 99.

The decoded Layer 2 data (after issuing the RDCCH:LAYER2:DECode command) is accessed with the following commands:

RDCCH:

LAYER2:

RACH:

ARQ RSVD?

[RDCCH:LAYER2:RACH:ARQ_RSVD]

Returns current value of Automatic Retransmission Request RSVD (2 bit value). Returns -1 if not available.

BT?

[RDCCH:LAYER2:RACH:BT]

Returns current value of Burst Type (3 bit value). Returns -1 if not available.

CI?

[RDCCH:LAYER2:RACH:CI]

Returns current state of Change Indicator (1 bit value). Returns -1 if not available.

EHI?

[RDCCH:LAYER2:RACH:EHI]

Returns current state of Extension Header Indicator (1 bit value). Returns -1 if not available.

EH RSVD?

[RDCCH:LAYER2:RACH:EH_RSVD]

Returns current state of Extended Header RSVD (1 bit value). Returns -1 if not available.

END_RSVD?

[RDCCH:LAYER2:RACH:END_RSVD]

Returns current state of END frame RSVD (1 bit value). Returns -1 if not available.

FRNO MAP?

[RDCCH:LAYER2:RACH:FRNO_MAP]

Returns current value of Frame Number Map (32 bit value). Returns -1 if not available.

IDT?

[RDCCH:LAYER2:RACH:IDT]

Returns current value of Identity Type (2 bit value). Returns -1 if not available.

LAYER2:

RACH:

L3DATA? n,x

[RDCCH:LAYER2:RACH:L3DATA]

Returns current 8 bit word (indexed by x) of selected Layer 3 Data message (n). Returns -1 if not available. Range of n is 0 to 7; range of x is 0 to 15.

The number of Layer 3 data messages embedded within a Layer 2 frame can be just a portion of single data message on up to 8 full data messages. The maximum number of bytes in a Layer 2 frame is 16 bytes. The data returned is left justified.

The L3LENGTH command may be used to determine how many 8 bit "words" make up the Layer 3 data field in the frame currently being decoded.

L3LENGTH? n

[RDCCH:LAYER2:RACH:L3LENGTH]

Returns current 8 bit value of Length (indexed by n) in Layer 3 data field. Returns -1 if not available. Range of n is 0 to 7.

Length of the Layer 3 data field in the RACH Layer 2 frame currently being decoded. This is necessary because the L3LIs are all contained in the first frame of a multiframe RACH message and subsequent frames do not have the information in them specifying the length of the Layer 3 data field.

L3LI? n

[RDCCH:LAYER2:RACH:L3LI]

Returns current 8 bit value of Layer 3 Length Indicator indexed by n. Returns -1 if not available. Range of n is 0 to 7.

A RACH Layer 2 frame may contain up to eight Layer 3 Length Indicators.

MEA?

[RDCCH:LAYER2:RACH:MEA]

Returns current value of Message Encryption Algorithm (2 bit value). Returns -1 if not available.

MEK?

[RDCCH:LAYER2:RACH:MEK]

Returns current value of Message Encryption Key (2 bit value). Returns -1 if not available.

MIN?

[RDCCH:LAYER2:RACH:MIN]

Returns current value of Mobile Identification Number (ASCII string). Returns -1 if not available.

This command is associated with a 34 bit Mobile Station Identity.

LAYER2:

RACH:

MSID:

LS?

[RDCCH:LAYER2:RACH:MSID:LS]

Returns the 32 Least Significant Bits of Mobile Station Identification. Returns -1 if not available.

MS?

[RDCCH:LAYER2:RACH:MSID:MS]

Returns the 18 Most Significant Bits of Mobile Station Identification. Returns -1 if not available.

NL3M?

[RDCCH:LAYER2:RACH:NL3M]

Returns current value of Number of Layer 3 Messages (3 bit value). Returns -1 if not available.

PEA?

[RDCCH:LAYER2:RACH:PEA]

Returns current value of Partial Echo Assigned (7 bit value). Returns -1 if not available.

7-17-6 RDCCH REAL TIME DATA MONITOR

RDCCH:

START

[RDCCH:START]

Starts a background task running that decodes the RDCCH message information elements. Elements that are decoded and returned with their corresponding TMAC command.

STOP

[RDCCH:STOP]

Stops the RDCCH decode background task.

SYNC?

[RDCCH:SYNC?]

Returns the last decoded value of the RDCCH sync word (28 bit value). Returns -1 if not available.

SYNCPlus?

[RDCCH:SYNCPLus?]

Returns the last decoded value of the RDCCH sync plus word. (24 bit value). Returns -1 if not available.

BT?

[RDCCH:BT?]

Returns current value of Burst Type (3 bit value). Returns -1 if not available.

CI?

[RDCCH:CI?]

Returns current state of Change Indicator (1 bit value). Returns -1 if not available.

EHI?

[RDCCH:EHI?]

Returns current state of Extension Header Indicator (1 bit value). Returns -1 if not available.

IDT?

Returns current value of Identity Type (2 bit value). Returns -1 if not available.

MSID:

MS?

[RDCCH:MSID:MS?]

Returns the 18 Most Significant bits of Mobile Station Identification. Returns -1 if not available.

LS?

[RDCCH:MSID:LS?]

Returns the 32 Least Significant bits of Mobile Station Identification. Returns -1 if not available.

MIN?

[RDCCH:MIN?]

Returns current Mobile Identification Number (ASCII String) associated with a 34 bit Mobile Station Identity. Returns -1 if not available.

NL3M?

[RDCCH:NL3M?]

Returns current value of Number of Layer 3 Messages (3 bit value). Returns -1 if not available.

L3LI? n

[RDCCH:L3L1?]

Returns current 8 bit value of Layer 3 Length Indicator indexed by n. Returns -1 if not available. Range of n is 0 to 7.

A RACH layer 2 frame may contain up to 8 layer 3 length indicators.

PEA?

[RDCCH:PEA?]

Returns current value of Partial Echo Assigned (7 bit value). Returns -1 if not available.

MEA?

[RDCCH:MEA?]

Returns current value of Message Encryption Algorithm (2 bit value). Returns -1 if not available.

MEK?

[RDCCH:MEK?]

Returns current value of Message Encryption Key (2 bit value). Returns -1 if not available.

FRNO MAP?

[RDCCH:FRNO_MAP?]

Returns current value of Frame Number Map (26 bit value). Returns -1 if not available.

RSVD:

EHI?

[RDCCH:RSVD:EHI?]

Returns current state of Extended Header Indicator RSVD (1 bit value). Returns -1 if not available.

ARQ?

[RDCCH:RSVD:ARQ?]

Returns current value of ARQ RSVD field (2 bit value). Returns -1 if not available.

END?

[RDCCH:RSVD:END?]

Returns current state of END frame RSVD field (1 bit value). Returns -1 if not available.

CRC?

[RDCCH:CRC?]

Returns current value of Cyclic Redundancy Code (16 bit value). Returns -1 if not available.

L3DATA:

SELect n

[RDCCH:L3DATA:SELect]

Specifies Layer 3 data message from which to access data. Range of n is 0 to 7.

Up to eight Layer 3 messages can be included in one RDCCH message. Each message is decoded and stored. The following commands access the information elements from the selected layer 3 message.

SELect?

Returns current value of SELect.

Returns the last selection of eight Layer 3 messages.

MSGtype?

[RDCCH:MSGtype?]

Returns current Message Type.

The following are possible message types:

AUDITCON	AUTHENTICATION	BSCHALcon	BSMC
CAPability	MACA	ORIGINATION	PAGE RESPONSE
R-DATA	R-DATA ACCEPT	RDATA REJECT	REGISTRATION
SERIAL NUMBER	soc	SPACHCON	SSD UPDATE
TEST	UCHAL		

PD?

[RDCCH:PD?]

Returns current value of Protocol Discriminator (2 bit value). Returns -1 if not available.

PFC 1?

[RDCCH:PFC_1?]

Returns current value of Paging Frame Class (3 bit value). Returns -1 if not available.

PSID RSID:

SELect?

[RDCCH:PSID_RSID:SELect?]

Returns current value of Selected PSID/RSID (4 bit value). Returns -1 if not available.

MAP?

[RDCCH:PSID_RSID:MAP?]

Returns current value of PSID/RSID Map (16 bit value). Returns -1 if not available.

DISPlay:

LENGth?

[RDCCH:DISPlay:LENGth?]

Returns current value of Length of Display Information (8 bit value). Returns -1 if not available.

CHARacter? n

[RDCCH:DISPlay:CHARacter?]

Returns current 8 bit value of Display Character indexed by n. Range of n is 0 to 81.

COUNt?

[RDCCH:COUNt?]

Returns current value of COUNt (6 bit value). Returns -1 if not available.

RANDC?

[RDCCH:RANDC?]

Returns current value of RANDC (8 bit value). Returns -1 if not available.

AUTHR?

[RDCCH:AUTHR?]

Returns current value of AUTHR (18 bit value). Returns -1 if not available.

RANDBS?

[RDCCH:RANDBS?]

Returns current value of RANDBS (32 bit value). Returns -1 if not available.

BSMC?

[RDCCH:BSMC?]

Returns current value of Base Station Manufacture Code (8 bit value). Returns -1 if not available.

PROTocol:

VERsion?

[RDCCH:PROTocol:VERsion?]

Returns current value of Protocol Version (4 bit value). Returns -1 if not available.

SCM?

[RDCCH:SCM?]

Returns current value of Station Class Mark (5 bit value). Returns -1 if not available.

VINtage:

SOFTware?

[RDCCH:VINtage:SOFTware?]

Returns current value of Software Vintage (6 bit value). Returns -1 if not available.

FIRMware?

[RDCCH:VINtage:FIRMware?]

Returns current value of Firmware Vintage (6 bit value). Returns -1 if not available.

MODEL?

[RDGCH:MODEL?]

Returns current value of Model Number (4 bit value). Returns -1 if not available.

MANufacture?

[RDCCH:MANufacture?]

Returns current value of Manufacture Code (8 bit value). Returns -1 if not available.

SUPPort:

MAX:

PFC?

[RDCCH:SUPPort:MAX:PFC?]

Returns current value of MAX_SUPPORTED_PFC (3 bit value). Returns -1 if not available.

SUPPort:

SOC?

[RDCCH:SUPPort:SOC?]

Returns current value of SOC Support (1 bit value). Returns -1 if not available.

BSMC?

[RDCCH:SUPPort:BSMC?]

Returns current value of BSCM Support (1 bit value). Returns -1 if not available.

ASYNC?

[RDCCH:SUPPort:ASYNC?]

Returns current value of Async Data Support (1 bit value). Returns -1 if not available.

G3fax?

[RDCCH:SUPPort:G3fax?]

Returns current value of G3-Fax Support (1 bit value). Returns -1 if not available.

SMS?

[RDCCH:SUPPort:SMS?]

Returns current value of SMS Broadcast Support (1 bit value). Returns -1 if not available.

SUBaddress?

[RDCCH:SUPPort:SUBaddress?]

Returns current value of Subaddressing Support (1 bit value). Returns -1 if not available.

FREQuency:

BANDS?

[RDCCH:SUPPort:FREQuency:BANDS?]

Returns current value of Supported Frequency Bands (8 bit value). Returns -1 if not available.

SUPPort:

IRA?

[RDCCH:SUPPort:IRA?]

Returns current value of IRA Support (1 bit value). Returns -1 if not available.

USER?

[RDCCH:SUPPort:USER?]

Returns current value of User Group Support (1 bit value). Returns -1 if not available.

ANA800?

[RDCCH:SUPPort:ANA800?]

Returns current value of 800 MHz Analog Speech Support (1 bit value). Returns -1 if not available.

HALF?

[RDCCH:SUPPort:HALF?]

Returns current value of Half-Rate DTC Support (1 bit value). Returns -1 if not available.

DOUBle?

[RDCCH:SUPPort:DOUBLe?]

Returns current value of Double Rate DTC Support (1 bit value). Returns -1 if not available.

TRIPle?

[RDCCH:SUPPort:TRIPLe?]

Returns current value of Triple Rate DTC Support (1 bit value). Returns -1 if not available.

MEASurement:

LTM:

WER?

[RDCCH:MEASurement:LTM:WER?]

Returns current value of LTM Measurement Receive Signal Strength (3 bit value). Returns -1 if not available.

BER?

[RDCCH:MEASurement:LTM:BER?]

Returns current value of LTM Measurement Bit Error Rate (3 bit value). Returns -1 if not available.

RSS?

[RDCCH:MEASurement:LTM:RSS?]

Returns current value of LTM Measurement Receive Signal Strength (5 bit value). Returns -1 if not available.

MEASurement:

LTM:

FULL?

[RDCCH:MEASurement:LTM:FULL?]

Returns current value of LTM Measurement Full Measurement Indicator (1 bit value). Returns -1 if not available.

STM:

NV?

[RDCCH:MEASurement:STM:NV?]

Returns current value of STM Measurement Number of Values (4 bit value). Returns -1 if not available.

RSS? n

[RDCCH:MEASurement:STM:RSS?]

Returns current 5 bit value of STM Measurement Receive Signal Strength indexed by n. Range of n is 0 to 15. Returns -1 if not available.

EMERgency?

[RDCCH:EMERgency?]

Returns current value of Emergency Call (1 bit value). Returns -1 if not available.

LT?

[RDCCH:LT?]

Returns current value of Last Try (1 bit value). Returns -1 if not available.

SERVice?

[RDCCH:SERVice?]

Returns current value of Service Code (4 bit value). Returns -1 if not available.

MODE:

VOICe:

VC?

[RDCCH:MODE:VOICe:VC?]

Returns current value of Voice Mode VC (3 bit value). Returns -1 if not available.

PM?

[RDCCH:MODE:VOICe:PM?]

Returns current value of Voice Mode PM_V (3 bit value). Returns -1 if not available.

MODE:

DATA:

PM?

[RDCCH:MODE:DATA:PM?]

Returns current value of Data Mode PM_D (3 bit value). Returns -1 if not available.

SAP?

[RDCCH:MODE:DATA:SAP?]

Returns current value of Data Mode SAP (1 bit value). Returns -1 if not available.

ACKED?

[RDCCH:MODE:DATA:ACKED?]

Returns current value of Data Mode Acked Data (1 bit value). Returns -1 if not available.

CRC?

[RDCCH:MODE:DATA:CRC?]

Returns current value of Data Mode CRC (2 bit value). Returns -1 if not available.

PART?

[RDCCH:MODE:DATA:PART?]

Returns current value of Data Mode Data Part (3 bit value). Returns -1 if not available.

RLP?

[RDCCH:MODE:DATA:RLP?]

Returns current value of Data Mode RLP (2 bit value). Returns -1 if not available.

MEM:

Message Encryption Mode- Identifies the selected message encryption algorithm, key and domain

MEA?

[RDCCH:MEM:MEA?]

Returns current value of Message Encryption Algorithm (3 bit value). Returns -1 if not available.

MED?

[RDCCH:MEM:MED?]

Returns current value of Message Encryption Domain (3 bit value). Returns -1 if not available.

MEK?

[RDCCH:MEM:MEK?]

Returns current value of Message Encryption Key (3 bit value). Returns -1 if not available.

BANDWidth?

[RDCCH:BANDWidth?]

Returns current value of Bandwidth (3 bit value). Returns -1 if not available.

CALLED:

Called Party - Identifies the called party associated with a mobile station.

ADDRess?

[RDCCH:CALLED:ADDRess?]

Returns current string value of ADDRess (ASCII string). Returns -1 if not available.

ENCodina?

[RDCCH:CALLED:ENCoding?]

Returns current value of ENCoding (1 bit value). Returns -1 if not available.

PLANId?

[RDCCH:CALLED:PLANid?]

Returns current value of PLANid (4 bit value). Returns -1 if not available.

TYPE?

[RDCCH:CALLED:TYPE?]

Returns current value of TYPE (3 bit value). Returns -1 if not available.

SUBaddress:

Identifies the address of a called or calling party.

LENGth?

[RDCCH:CALLED:SUBaddress:LENGth?]

Returns current value of LENGth (8 bit value). Returns -1 if not available.

ODD EVEN?

[RDCCH:CALLED:SUBaddress:ODD_EVEN?]

Returns current value of ODD_EVEN (1 bit value). Returns -1 if not available.

TYPE?

[RDCCH:CALLED:SUBaddress:TYPE?]

Returns current value of TYPE (3 bit value). Returns -1 if not available.

ADDRess? n

[RDCCH:CALLED:SUBaddress:ADDRess?]

Returns last decoded 8 bit value of Called Subaddress from selected L3DATA Message (n). Range of n is 0 to 19. Returns -1 if not available.

CALLING:

Calling Party - Identifies the calling party associated with a mobile station.

ADDRess?

[RDCCH:CALLING:ADDRess?]

Returns current string value of ADDRess (ASCII string). Returns -1 if not available.

ENCoding?

[RDCCH:CALLING:ENCoding?]

Returns current value of ENCoding (1 bit value). Returns -1 if not available.

PRESentation:

Identifies the presentation restrictions and screening related to the Calling Party information element.

PI?

[RDCCH:CALLING:PRESentation:PI?]

Returns current value of PI (2 bit value). Returns -1 if not available.

SI7

[RDCCH:CALLING:PRESentation:SI?]

Returns current value of SI (2 bit value). Returns -1 if not available.

PLANId?

[RDCCH:CALLING:PLANId?]

Returns current value of PLANid (4 bit value). Returns -1 if not available.

TYPE?

[RDCCH:CALLING:TYPE?]

Returns current value of TYPE (3 bit value). Returns -1 if not available.

SUBaddress:

Identifies the address of a called or calling party.

LENGth?

[RDCCH:CALLING:SUBaddress:LENGth?]

Returns current value of LENGth (8 bit value). Returns -1 if not available.

ODD EVEN?

 $[RDCCH: CALLING: SUBaddress: ODD_EVEN?]$

Returns current value of ODD_EVEN (1 bit value). Returns -1 if not available.

TYPE?

[RDCCH:CALLING:SUBaddress:TYPE?]

Returns current value of TYPE (3 bit value). Returns -1 if not available.

CALLING:

SUBaddress:

ADDRess? n

[RDCCH:CALLING:SUBaddress:ADDRess?]

Returns last decoded 8 bit value of Calling Subaddress from selected L3DATA Message (n). Range of n is 0 to 19. Returns -1 if not available.

RTRANSaction?

[RDCCH:RTRANSaction?]

Returns current value of RTRANSaction (8 bit value). Returns -1 if not available.

RDATA UNIT:

Contains the Higher Layer Protocol Data Unit and is mandatory in an R-DATA message.

LENGth?

[RDCCH:RDATA_UNIT:LENGth?]

Returns current value of LENGth (8 bit value). Returns -1 if not available.

HLP:

IDentifier?

[RDCCH:RDATA_UNIT:HLP:IDentifier?]

Returns current value of IDentifier (8 bit value). Returns -1 if not available.

DATA? n

[RDCCH:RDATA_UNIT:HLP:DATA?]

Returns current 8 bit value of DATA indexed by n. Range of n is 0 to 255. Returns -1 if not available.

RCAUSE?

[RDCCH:RCAUSE?]

Returns current value of RCAUSE (8 bit value). Returns -1 if not available.

MESSage:

CENTer:

Identifies the Message Center Address for the message being sent.

ADDRess?

[RDCCH:MESSage:CENTer:ADDRess?]

Returns current string value of ADDRess (ASCII string). Returns -1 if not available.

ENCoding?

[RDCCH:MESSage:CENTer:ENCoding?]

Returns current value of ENCoding (1 bit value). Returns -1 if not available.

MESSage:

CENTer:

PLANId?

[RDCCH:MESSage:CENTer:PLANid?]

Returns current value of PLANid (4 bit value). Returns -1 if not available.

TYPE?

[RDCCH:MESSage:CENTer:TYPE?]

Returns current value of TYPE (3 bit value). Returns -1 if not available.

USER:

GROUP:

Identifies the User Group ID that a mobile station has requested or has been allocated.

STATUS?

[RDCCH:USER:GROUP:STATUS?]

Returns current value of STATUS (2 bit value). Returns -1 if not available.

TYPE?

[RDCCH:USER:GROUP:TYPE?]

Returns current value of TYPE (2 bit value). Returns -1 if not available.

UGID:

MS?

[RDCCH:USER:GROUP:UGID:MS?]

Returns the 18 Most Significant Bits of User Group Identification.

LS?

[RDCCH:USER:GROUP:UGID:LS?]

Returns the 32 Least Significant Bits of User Group Identification.

DEST:

ADDRess?

[RDCCH:USER:DEST:ADDRess?]

Returns current string value of ADDRess (ASCII string). Returns -1 if not available.

ENCoding?

[RDCCH:USER:DEST:ENCoding?]

Returns current value of ENCoding (1 bit value). Returns -1 if not available.

PLANId?

[RDCCH:USER:DEST:PLANid?]

Returns current value of PLANid (4 bit value). Returns -1 if not available.

USER:

DEST:

TYPE?

[RDCCH:USER:DEST:TYPE?]

Returns current value of TYPE (3 bit value). Returns -1 if not available.

SUBaddress:

Identifies the address of a called or calling party.

LENGth?

[RDCCH:USER:DEST:SUBaddress:LENGth?]

Returns current value of LENGth (8 bit value). Returns -1 if not available.

ODD EVEN?

[RDCCH:USER:DEST:SUBaddress:ODD_EVEN?]

Returns current value of ODD EVEN (1 bit value). Returns -1 if not available.

TYPE?

[RDCCH:USER:DEST:SUBaddress:TYPE?]

Returns current value of TYPE (3 bit value). Returns -1 if not available.

ADDRess? n

[RDCCH:USER:DEST:SUBaddress:ADDRess?]

Returns last decoded 8 bit value of User Destination Subaddress from selected L3DATA Message (n). Range of n is 0 to 19. Returns -1 if not available.

ORIG:

ADDRess?

[RDCCH:USER:ORIG:ADDRess?]

Returns current string value of ADDRess (ASCII string). Returns -1 if not available.

ENCoding?

[RDCCH:USER:ORIG:ENCoding?]

Returns current value of ENCoding (1 bit value). Returns -1 if not available.

PLANId?

[RDCCH:USER:ORIG:PLANId?]

Returns current value of PLANid (4 bit value). Returns -1 if not available.

TYPE?

[RDCCH:USER:ORIG:TYPE?]

Returns current value of TYPE (3 bit value). Returns -1 if not available.

USER:

ORIG:

SUBaddress:

Identifies the address of a called or calling party.

LENGth?

[RDCCH:USER:ORIG:SUBaddress:LENGth?]

Returns current value of LENGth (8 bit value). Returns -1 if not available.

ODD EVEN?

[RDCCH:USER:ORIG:SUBaddress:ODD_EVEN?]

Returns current value of ODD_EVEN (1 bit value). Returns -1 if not available.

TYPE?

[RDCCH:USER:ORIG:SUBaddress:TYPE?]

Returns current value of TYPE (3 bit value). Returns -1 if not available.

ADDRess? n

[RDCCH:USER:ORIG:SUBaddress:ADDRess?]

Returns last decoded 8 bit value of User Origination Subaddress from selected L3DATA Message (n). Range of n is 0 to 19. Returns -1 if not available.

REG:

TYPE?

[RDCCH:REG:TYPE?]

Returns current value of Registration Type (4 bit value). Returns -1 if not available.

CNUMBer:

ADDRess?

[RDCCH:CNUMber:ADDRess?]

Returns current string value of C-Number Address (ASCII string). Returns -1 if not available.

ENCoding?

[RDCCH:CNUMber:ENCoding?]

Returns current value of C-Number Address Encoding (1 bit value). Returns -1 if not available.

PLANId?

[RDCCH:CNUMber:PLANid?]

Returns current value of C-Number Identification Plan (4 bit value). Returns -1 if not available.

TYPE?

[RDCCH:CNUMber:TYPE?]

Returns current value of C-Number Type of Number (3 bit value). Returns -1 if not available.

PFC:

REQuest?

[RDCCH:PFC:REQuest?]

Returns current value of Paging Frame Class Request (3 bit value). Returns -1 if not available.

DCCH_MEM:

ALGORIthm?

[RDCCH:DCCH_MEM:ALGORithms?]

Returns current value of DCCH Message Encryption Algorithm (4 bit value). Returns -1 if not available.

DOMAIN?

[RDCCH:DCCH_MEM:DOMAIN?]

Returns current value of DCCH Message Encryption Domain (8 bit value). Returns -1 if not available.

KEY?

[RDCCH:DCCH_MEM:KEY?]

Returns current value of DCCH Message Encryption Key (4 bit value). Returns -1 if not available.

ESN?

[RDCCH:ESN?]

Returns current value of Electronic Serial Number (32 bit value). Returns -1 if not available.

SOC?

[RDCCH:SOC?]

Returns current value of SOC (12 bit value). Returns -1 if not available.

CUSTom:

LENGth?

[RDCCH:CUSTOM:LENGth?]

Returns current value of Custom Control Length (8 bit value). Returns -1 if not available.

CONTrol? n

[RDCCH:CUSTOM:CONTrol?]

Returns current 8 bit value of Custom Control indexed by. Range of n is 0 to 252) Returns -1 if not available.

CONFIRMed:

MSGtype?

[RDCCH:CONFIRMed:MSGtype?]

Returns current value of Confirmed Message Type (6 bit value). Returns -1 if not available.

SSDUP:

STATus?

[RDCCH:SSDUP:STATus?]

Returns current value of SSD Update Status (2 bit value). Returns -1 if not available.

AUTHU?

[RDCCH:AUTHU?]

Returns current value of AUTHU (18 bit value). Returns -1 if not available.

SECTION 8 - CSA QUICK REFERENCE LIST

The CSA Quick Reference List is a brief listing of the Specific and most General TMAC commands used with the FM/AM-1600CSA. The Quick Reference List is an aid to the experienced TMAC user. If more detailed information is needed, refer to the specified page.

COMMAND	RANGE	PAGE	DESCRIPTION
BER COMMANDS			
BER:			
RDTC:			
BER?		7-61	Returns Bit Error Rate (percentage).
BITS?		7-61	
CHANnel n	1 to 1023	7-61	Selects Digital Traffic Channel.
CLEAR		7-62	Clears current results.
DATA:			
USER		7-61	
PSUEDO		7-61	
LOOPBACK		7-61	
45MHZ_OFFset		7-61	
ERRORS? GO		7-61	
RFLVL n	20.01- 127.0	7-61	
SETup	-30.0 to -127.0	7-61 7-61	
OLIOP		7-61	The same of the sa
SLOT n	1 to 3	7-61	Digital Traffic BER screen.
STATUS?	1 10 3	7-62	
STOP		7-61	,
	A 5.55.5 1 1 m A	, .	otopo baso otation bigitai iramo ben test.
ELL SITE SIMULATION C	OMMANDS		
SS: CALL:			
CHANnel n	1 to 1023	7-34	Colonia Mahila Ciatian and Observed
CHANnel?	1 10 1023	7-34 7-34	
DEViation n	0.0 to 4.0	7-34 7-34	
DEViation?	0.0 10 4.0	7-34	
DMAC n	0 to 7	7-34	
DMAC?	·	7-34	
DVCC n	0 to 255	7-34	
DVCC?		7-34	
EF n	1 or 0	7-34	
EF?		7-34	Returns Extended Protocol Forward Channel Indicato setting.
MEM n	1 or 0	7-34	Sets Message Encryption Mode.
MEM?	, -, -	7-34	
MIN "n"			Selects Mobile Identification Number to call.
MIN?		7-34	
PM n	1 or 0		Sets Privacy Mode bit.
PM?		7-35	Returns Privacy Mode bit setting.
PROCess:			, J
ASSIGNment		7-36	Sends initial channel designation command.
FDTC:			·
HANDoff?		7-37	Performs digital to digital or analog handoff.
FVC:			
HANDoff		7-36	Performs analog to analog handoff.
SLOT1		7-36	Performs analog to digital handoff (Timeslot 1).
SLOT2		7-36	Performs analog to digital handoff (Timeslot 2).
SLOT3 MOBINIT		7-36	Performs analog to digital handoff (Timeslot 3).
PAGE		7-36	Sets FM/AM-1600CSA for Mobile Station initiated call.
REGistration		7-36 7-36	Simulates Base Station (Cellsite) initiated call.
SAT n	5965 to 6035	7-35 7-35	The second secon
SAT?	0000 10 0000	7-35 7-35	Sets Supervisory Audio Tone in Hz. Returns Supervisory Audio Tone cetting
SLOT n	1 to 3		Returns Supervisory Audio Tone setting. Selects Timeslot.
SLOT?			Returns Timeslot setting.
TYPE n	1 or 0	7-35 7-35	
TYPE?		7-35	Returns channel type setting.

7-35 Returns channel type setting.

COMMAND	RANGE	PAGE	DESCRIPTION
CSS:			
CALL:	0.4	~ ~ ~	
VMAC n VMAC?	0 to 7		Selects Voice Mobile Attenuation Code. Returns Voice Mobile Attenuation Code setting.
CHANnel n	1 to 1023		Selects Forward Control Channel.
FDTC:	. 10 1020	, 01	Selects I of ward Control Chalines.
AMT:			
CONNect		7-45	Selects Connect Acknowledgment message.
RELease		7-45	Selects Release Acknowledgment message.
STATus			Selects Status Acknowledgment message.
AMT?			Returns Acknowledgment Message Type setting.
AUTHBS n	0 to 262143		Sets AUTHBS value.
AUTHBS?		7-46	Returns AUTHBS value setting.
CALLING: NUM "n"		7.46	Sets Calling Party Number (string).
NUM?			Returns Calling Party Number (string).
PI n	0 to 3		Sets Calling Party Number Presentation Indicator.
PI?	0 (0 0		Returns Calling Party Number Presentation Indicator
		,	setting.
PLANId n	0 to 15	7-46	Sets Calling Party Numbering Plan Identification.
PLANId?		7-46	Returns Calling Party Numbering Plan Identification
			setting.
SIn	0 to 3	7-46	Sets Calling Party Screening Indicator.
SI?			Returns Calling Party Screening Indicator setting.
TYpe n	0 to 7	7-46	Sets Calling Party Type.
TYpe?			Returns Calling Party Type setting.
CONTROL n	0 to 31		Sets Local Control field.
CONTROL?	1 0 0		Returns Local Control field setting.
DIC n DIC?	1 or 0		Sets Delay Interval Compensation bit. Returns Delay Interval Compensation bit setting.
DMAC n	0 to 10		Sets Digital Mobile Attenuation Code.
DMAC?	0 (0 ,0		Returns Digital Mobile Attenuation Code setting.
DTX n	1 or 0		Sets Discontinuous Transmission bit.
DTX?			Returns Discontinuous Transmission bit setting.
DVCC n	1 to 255	7-47	Sets Digital Verification Color Code.
DVCC?		7-47	Returns Digital Verification Color Code setting.
ENABLE:			
CALLING:			
NUM n	1 or 0		Enables or disables Calling Party Number field.
NUM?	4 0		Returns Calling Party Number Enable setting.
DIC n DIC?	1 or 0		Enables or disables Delay Interval Compensation bit. Returns Delay Interval Compensation bit Enable setting.
DMAC n	1 or 0		Enables or disables Digital Mobile Attenuation Code.
DMAC?	1 01 0		Returns Digital Mobile Attenuation Code Enable setting.
DTX n	1 or 0		Enables or disables Discontinuous Transmission bit.
DTX?			Returns Discontinuous Transmission bit Enable setting.
LDP:			•
BSACK n	1 or 0	7-48	Enables or disables LDP in BS ACK message.
BSACK?		7-48	•
FLASHACK n	1 or 0	7-48	
FLASHACK?			Returns LDP Enable setting for FLASH ACK message.
SBDA n	1 or 0	7-48	•
SBDA?	1 0 0	7-48	
NOMW n NOMW?	1 or 0	7-48 7-48	
RECHAN n,x	0 to 11, 1 or 0	7-48	
RFCHAN? n	0 to 11	7-48	
SIGNAL n	1 or 0	7-48	<u> </u>
SIGNAL?		7-48	•
STATUS:			
CMODE n	1 or 0	7-48	Enables or disables Call Mode field in Status Request.
CMODE?		7-48	Returns Call Mode field Enable setting.
ESN n	1 or 0	7-49	
		_	Status Request message.
ESN?		7-49	•
MEM n	1 or 0	7-49	5 2 1
MEM?	•	7-49	Returns Message Encryption Mode field Enable setting.

COMMAND	RANGE	PAGE	DESCRIPTION
CSS:	1171102	rave	DECOMP HOR
FDTC:			
ENABLE:			
STATUS:			
TI n	1 or 0		Enables or disables Terminal Information field.
TI?	4 0		Returns Terminal Information field Enable setting.
VPM n VPM?	1 or 0		Enables or disables Voice Privacy Mode bit.
TA n	1 or 0		Returns Voice Privacy Mode bit Enable setting. Enables or Disables Time Alignment field.
TA?	1 0, 0	7-49	Returns Time Alignment field Enable setting.
FACCH:		, ,,	Tretains Time Tilginient Hold Endole Sotting.
ALERT		7-43	Sends Alert with Information message.
AUDIT			Sends Audit message.
BSACK			Sends Base Station Acknowledgment message.
BSCHALCON			Sends Base Station Challenge Confirmation message.
FLASH FLASHACK			Sends Flash with Information message. Sends Flash Acknowledgment message.
HANDoff			Sends Handoff message.
LC			Sends Local Control message.
MAINTenance			Sends Maintenance message.
MEASure			Sends Measurement message.
PLC			Sends Physical Layer Control message.
PU			Sends Parameter Update message.
RELease			Sends Release message.
SBDA SCDA			Sends Send Burst DTMF Acknowledge message.
SMEASure			Sends Send Continuous DTMF Acknowledge message. Sends Stop Measurement message.
SR			Sends Status Request message.
SSDUP		7-44	Sends Shared Secret Data Update message.
UCHAL			Sends Unique Challenge message.
HANDoff:			
CHANnel n	1 to 1023	7-49	
CHANnel? LDP n	0 10 15		Returns Channel for Handoff.
LDP?	0 to 15		Sets Last Decoded Parameter. Returns Last Decoded Parameter setting.
MEM n	1 or 0	7-50	
MEM?	, ., .	7-50	
NOMW n	0 to 63	7-50	
NOMW?		7-50	Returns Number of Messages Waiting field setting.
RANDSSD "n"	0 to FFFFFFFFFFFFF		(=======
RANDSSD?	0.4-40777045	7-50	
RANDU n RANDU?	0 to 16777215	7-50 7-50	
RATe n	1 or 0		Returns UCHAL 24 bit Random Number setting. Sets Channel Rate (1 [half-rate] or 0 [full-rate]).
RATe?		7-50	
RFCHAN n,x	0 to 11, 1 to 1023		Sets selected RF Channel index.
RFCHAN? n	0 to 11	7-50	Returns selected RF Channel index setting.
RN n	0 to 15		Sets Request Number.
RN?		7-50	Returns Request Number setting.
SACCH: ALERT		7 44	Conde Alost with Information and an
AUDIT			Sends Alert with Information message. Sends Audit message.
BSACK		7-44	Sends Base Station Acknowledgment message.
BSCHALCON		7-44	Sends Base Station Challenge Confirmation message.
FLASH		7-44	Sends Flash with Information message.
FLASHACK			Sends Flash Acknowledgment message.
HANDoff			Sends Handoff message.
LC MAINTanana			Sends Local Control message.
MAINTenance MEASure			Sends Maintenance message. Sends Measurement message.
PLC		7-45	Sends Physical Layer Control message.
PU		7-45	Sends Parameter Update message.
RELease		7-45	Sends Release message.
SBDA		7-45	Sends Send Burst DTMF Acknowledge message.
SCDA			Sends Send Continuous DTMF Acknowledge message.
SMEASure		7-45	Sends Stop Measurement message.
SR		7-45	Sends Status Request message.

COMMAND	RANGE	PAGE	DESCRIPTION
CSS:			
FDTC:			
SACCH:			
SSDUP		7-45	
UCHAL SBI n	0 to 3		Sends Unique Challenge message.
SBI?	0 10 3	7-50	Sets Shortened Burst Indicator. Returns Shortened Burst Indicator setting.
SIGNAL:		7-50	neturns onortened barst malcator setting.
CADENCE n	0 to 63	7-51	Sets on, off pattern of Alert tone.
CADENCE?		7-51	Returns Alert tone on, off pattern setting.
PITCH n	0 to 3	7-51	Sets pitch of Alert tone.
PITCH?		7-51	Returns Alert tone pitch setting.
SLOT n	1 to 3	7-51	Sets Timeslot.
SLOT?			Returns Timeslot setting.
TA n	0 to 31	7-51	
TA?		7-51	Returns Time Alignment setting.
TALK:	0.4. 050	~ ~ ~	A did to the first the second of the control of the
DELAY n	0 to 250	7-52	Adds delay between receiving and transmitting in
START		750	20 ms intervals. Starts Talkback operation.
STOP			Stops Talkback operation.
TI n	0 to 6		Sets Timeslot Indicator. (0 is analog.)
TI?	0.10.0	7-5 1	
VPM n	1 or 0	7-51	Sets Voice Privacy Mode bit.
VPM?		7-51	Returns Voice Privacy Mode bit setting.
FOCC:			, ,
AUTH n	1 or 0	7-31	Sets Authentication bit.
AUTH?			Returns Authentication bit setting.
B_! <i>n</i>	1 or 0	7-31	
B_1?	_	7-31	Returns Busy-Idle bit setting.
CMAC n	0 to 7	7-31	Sets Control Mobile Attenuation Code.
CMAC?	4	7-31	Returns Control Mobile Attenuation Code setting.
CMAX n	1 to 32	7-31	Sets maximum Number of Access Channels to be
CMAX?		7-31	scanned.
DCC n	0 to 3		Returns maximum Number of Access Channels setting. Sets Digital Color Code.
DCC?	0.100		Returns Digital Color Code setting.
E n	1 or 0		Sets Extended Address bit.
E?			Returns Extended Address bit setting.
EP n	1 or 0		Sets Extended Protocol bit.
EP?		7-32	Returns Extended Protocol bit setting.
N n	1 to 32		Sets Number of Paging Channels to be scanned.
N?			Returns Number of Paging Channels setting.
PCI n	1 or 0		Sets Protocol Capability Indicator.
PCI?			Returns Protocol Capability Indicator setting.
RCF n	1 or 0	7-32	
RCF?	4 0		Returns Read Control Filler bit setting.
REGH n REGH?	1 or 0	7-32 7-32	
REGR n	1 or 0	7-32 7-32	•
REGR?	1 01 0		Returns Roaming Registration bit setting.
S n	1 or 0		Sets Serial Number bit.
\$?		7-33	
SDCC1 n	0 to 3	7-33	
SDCC1?		7-33	Returns Supplementary Digital Color Code 1 setting.
SDCC2 n	0 to 3	7-33	Sets Supplementary Digital Color Code 2.
SDCC2?		7-33	Returns Supplementary Digital Color Code 2 setting.
SID n	0 to 32767	7-33	Sets System Identification Number.
SID?		7-33	Returns System Identification Number setting.
WFOM n	1 or 0	7-33	Sets Wait For Overhead Message bit.
WFOM?		7-33	Returns Wait For Overhead Message bit setting.
FVC:	0.4- 000440	7.00	Cata AUTURG value
AUTHBS n	0 to 262143	7-39	Sets AUTHBS value.
AUTHBS?		7-39	Returns AUTHBS value setting.

COMMAND	RANGE	PAGE	DESCRIPTION
css:			
FVC:			
CALLING: NUM "n"		7-40	Sets number of calling party (string).
NUM?			Returns number of calling party setting.
Pln	0 to 3		Sets Calling Party Number Presentation Indicator.
PI?			
SI n	0 to 3		
SI?			Returns Calling Party Screening Indicator setting.
DMAC n	0 to 10	7-40	
DMAC?	4 4 000		Returns Digital Mobile Attenuation Code setting.
DVCC n	1 to 255		Sets Digital Verification Color Code.
DVCC? EF n	1 or 0	7-40	Returns Digital Verification Color Code setting. Sets Extended Protocol Forward Channel Indicator.
EF?	1 01 0		Returns EF setting.
ENABLE:		, 40	notorno El Jotting.
VOICEPrivacy n	1 or 0	7-40	Sets Voice Privacy in CALLMODEACK message.
VOICEPrivacy?			Returns Voice Privacy setting.
HANDoff:			, , , , , , , , , , , , , , , , , , ,
CHANnel n	1 to 1023	7-41	Sets Channel for Handoff.
CHANnel?		7-41	Returns Channel for Handoff setting.
LOCAL n	0 to 31	7-41	
LOCAL?		7-41	•
MEM n	1 or 0		Sets Message Encryption Mode.
MEM?			Returns Message Encryption Mode setting.
MT n	0 to 31	7-41	0 /1
MT?		7-41	Returns Message Type field setting.
ORDER: ALERT		7-38	Sends Alert message.
ALERTWinfo			Sends Alert with Information message.
AUDIT			Sends Audit message.
BSCHALCON			Sends Base Station Challenge Confirmation message.
CALLMODEACK			Sends Call Mode Acknowledgment message.
DISDTMF			Sends Disable DTMF message.
DISMEM			Sends Disable Message Encryption Mode message.
ENAMEM			Sends Enable Message Encryption Mode message.
FLASHWinfo			Sends Flash with Information message.
HANDoff			Sends Handoff messag@.
LC			Sends Local Control message.
MAINTenance			Sends Maintenance message.
MSGWTG PAGE			Sends Message Waiting message. Sends Page message.
PU	<i>4</i>		Sends Parameter Update message.
PWRLVL			Sends Power Level message.
RELease		7-39	
SALERT		7-39	Sends Stop Alert message.
SLOT1		7-39	Sends Slot message (assigns DTC Timeslot 1).
SLOT2		7-39	· · · · · · · · · · · · · · · · · · ·
SLOT3		7-39	- · · · · · · · · · · · · · · · · · · ·
SNDAddr		7-39	•
SNRreq		7-39	,
SSDUP		7-39	, , , , , , , , , , , , , , , , , , ,
UCHAL	1 0 0	7-39 7-41	, ,
PM n PM?	1 or 0	7-41	
PSCC n	0 to 2	7-41	Sets Present SAT Color Code.
PSCC?	0.10.2	7-41	Returns Present SAT Color Code setting.
PWRLVL n	0 to 7	7-41	Sets Power Level requested of Mobile Station.
PWRLVL?		7-41	Returns requested Power Level setting.
RANDSSD "n"	0 to FFFFFFFFFFFFF	7-41	Sets RANDSSD 56 bit value in hexadecimal (string).
RANDSSD?			Returns RANDSSD 56 bit value setting.
RANDU n	0 to 16777215	7-42	-
RANDU?			Returns UCHAL 24 bit Random Number setting.
SBI n	0 to 3		Sets Shortened Burst Indicator.
SBI?			Returns Shortened Burst Indicator setting.
SCC n	0 to 2	7-42	1
SCC?		7-42	Returns Supervisory Audio Tone Color Code setting.

COMMAND	RANGE	PAGE	DESCRIPTION
CSS:			
FVC:			
SIGNAL:			
CADENCE n	0 to 63	7-42	Sets on, off pattern of Alert tone.
CADENCE?		7-42	Returns Alert tone on, off pattern setting.
PITCH n	0 to 3	7-42	Sets Alert tone pitch.
PITCH? TA n	0 1- 01	7-42	Returns Alert tone pitch setting.
TA?	0 to 31	7-42	Sets Time Alignment.
VMAC n	0 to 7	7-42	Returns Time Alignment setting.
VMAC?	0 10 /	7-42	Sets Voice Mobile Attenuation Code. Returns Voice Mobile Attenuation Code setting.
GLACT:		1.42	Returns voice mobile Attenuation Code setting.
ACTion:			
ACCess n	1 or 0	7-53	Enables or disables Access Attempt Parameters msg.
ACCess?		7-53	
			setting.
BIS n	1 or 0	7-53	Enables or disables Access Type Parameters message.
BIS?		7-53	Returns Access Type Parameters message Enable
			setting.
LOCAID n LOCAID?	1 or 0	7-53	Enables or disables Location Area message.
LOCAL1 n	1 01 0	7-53	Returns Location Area message Enable setting.
LOCAL1?	1 or 0	7-53 7-53	Enables or disables Local Control 1 message.
LOCAL2 n	1 or 0	7-53 7-53	Returns Local Control 1 message Enable setting.
LOCAL2?		7-53	Enables or disables Local Control 2 message. Returns Local Control 2 message Enable setting.
NEWACC n	1 or 0	7-54	Enables or disables New Access Channel Set message.
NEWACC?		7-54	Returns New Access Channel Set message Enable
		, , ,	setting.
OLC n	1 or 0	7-54	Enables or disables Overload Control message.
OLC?		7-54	
RANDA n	1 or 0	7-54	Enables or disables Random Challenge A message.
RANDA?		7-54	Returns Random Challenge A message Enable setting.
RANDB n	1 or 0	7-54	Enables or disables Random Challenge B message.
RANDB?	4 0	7-54	Returns Random Challenge B message Enable setting.
REGINCR n REGINCR?	1 or 0	7-54	Enables or disables Registration Increment message.
REGINON!		7-54	Returns Registration Increment message Enable
RESCAN n	1 or 0	7-54	setting.
RESCAN?	. 0. 0	7-54	Enables or disables Rescan message. Returns Rescan message Enable setting.
BIS n	1 or 0	7-54	Sets Busy-Idle Status bit.
B!S?		7-54	Returns Busy-Idle Status bit setting.
LOCAID n	0 to 4095	7-54	
LOCAID?		7-55	Returns Cell Site Location Area Identification setting.
LOCALentl n	0 to 65535	7-55	Sets Local Control bits.
LOCALenti?		7-55	Returns value set for Local Control bits.
LREG n	1 or 0	7-55	Sets Local Area Identification Registration bit.
LREG?		7-55	Returns Local Area Identification Registration bit.
MAXBusy: OTHer n	0 +~ +#	7 6 5	
OTHer?	0 to 15	7-55	Sets Max # of Busy incidents (Non-Page responses).
PGR n	0 to 15	7-55 7-55	Returns Max # of Busy incidents (Non-Page responses).
PGR?	3 (0 13	7-55 7-55	Sets Max # of Busy incidents (Page responses). Returns Max # of Busy incidents (Page responses).
MAXSztr:		, 00	rictains max # or basy incluents (rage responses).
OTHer n	0 to 15	7-55	Sets Max # of Seizure Tries (Non-Page responses).
OTHer?		7-55	Returns Max # of Seizure Tries (Non-Page responses).
PGR n	0 to 15	7-55	Sets Max # of Seizure Tries (Page responses).
PGR?		7-55	Returns Max # of Seizure Tries (Page responses).
NEWACC n	0 to 2047	7-56	Sets New Access Channel starting point.
NEWACC?	0.4-00707	7-56	Returns New Access Channel starting point setting.
OLC n	0 to 32767	7-56	Sets Overhead Class field.
OLC? PDREG n	1 or 0	7-56	Returns Overhead Class field setting.
PDREG?	1 or 0	7-56	Sets Power Down Registration bit.
PUREG n	1 or 0	7-56 7-56	Returns Power Down Registration bit setting.
PUREG?	1 01 0	7-56 7-56	Sets Power Up Registration bit. Returns Power Up Registration bit setting.
RAND1_A n	0 to 32767	7-56 7-56	Sets value of 16 most significant bits of RAND.
RAND1_A?		7-56	Returns value set for 16 most significant bits of RAND.
·		·	man and the man and an armine arm of the of the or

COMMAND	RANGE	PAGE	DESCRIPTION
CSS:			
GLACT:			
RAND1_B n	0 to 32767	7-56	Sets value of 16 least significant bits of RAND.
RAND1_B?			Returns value set for 16 least significant bits of RAND.
REGINCR n	0 to 4095		Sets Registration Increment field.
REGINCR?			Returns Registration Increment field setting.
REPEAT:			
OFF		7-53	Sets to send Global Action message once.
ON			Sets to send Global Action message continuously.
SEND			Starts sending Global Action message.
STOP		7-53	
MSCM:		, 00	otopo domaning araba. Adam massaga.
AUTHBS n	0 to 262143	7-58	Sets AUTHBS value.
	0 10 202140		Returns AUTHBS value setting.
AUTHBS?	1 +0 1000		Selects RF Channel.
CHAN n	1 to 1023		Returns RF Channel setting.
CHAN?	0 1- 5 0 1- 107		Sets selected Channel Position field sent in Directed
CHANPos n,x	0 to 5, 0 to 127	7-56	
	0.5	7 50	Retry message.
CHANPos? n	0 to 5		Returns selected Channel Position field setting.
DMAC n	0 to 10		Sets Digital Mobile Attenuation Code.
DMAC?			Returns Digital Mobile Attenuation Code setting.
DVCC n	1 to 255		Sets Digital Verification Color Code.
DVCC?		7-58	Returns Digital Verification Color Code setting.
EF n	1 or 0	7-59	Sets Extended Protocol Forward Channel Indicator.
EF?		7-59	Returns Extended Protocol Forward Channel Indicator
			setting.
LOCAL n	0 to 31		Sets Local Control field.
LOCAL?			Returns Local Control field setting.
MEM n	1 or 0	7-59	Sets Message Encryption Mode.
MEM?		7-59	Returns Message Encryption Mode setting.
MIN "n"		7-59	Selects Mobile Identification Number (string).
MIN?		7-59	Returns Mobile Identification Number string setting.
ORDER:			
A_ALERT		7-57	Selects Abbreviated Alert message.
AŪDIT		7-57	Selects Audit message.
BSCHALCON		7-57	Selects Base Station Challenge Confirmation message.
DIR_RTRY		7-57	Selects Directed-Retry message.
INTROPT			Selects Intercept message.
LC			Selects Local Control message.
MSG_WTG			Selects Message Waiting message.
REG_CNF		7-57	Selects Registration Confirmation message.
RELease			Selects Release message.
REORDER			Selects Reorder message.
SLOT1		7-58	Selects Digital Channel Assignment to Timeslot 1
020.1		,	message.
SLOT2		7-58	Selects Digital Channel Assignment to Timeslot 2
020,2			message.
SLOT3		7-58	Selects Digital Channel Assignment to Timeslot 3 message.
CCD UD		7-58	
SSD_UP		7-58 7-58	· · · · · · · · · · · · · · · · · · ·
UCHAL		7-58	
VC_DES	A	7-59	the contract of the contract o
ORDQ n	0 to 7		
ORDQ?	4 6	7-59	•
PM n	1 or 0	7-59	
PM?	A 1 . 4 A TTT A 4 E	7-59	,
RANDSSD1 n	0 to 16777215	7-59	•
RANDSSD1?	_ ,	7-59	
RANDSSD2 n	0 to 16777215	7-59	
RANDSSD2?		7-60	
RANDSSD3 n	0 to 255	7-60	
RANDSSD3?		7-60	
RANDU n	0 to 16777215	7-60	
RANDU?		7-60	Returns UCHAL message Random Number setting.

COMMAND	RANGE	PAGE	DESCRIPTION
CSS:			
MSCM: REPEAT:			
OFF		7-57	Sets to send Mobile Station Control message once.
ON			Sets to send Mobile Station Control message once.
		, 0,	continuously.
SBI n	0 to 3	7-60	Sets Shortened Burst Indicator.
SBI?		7-60	Returns Shortened Burst Indicator setting.
SCC n	0 to 2		Sets Supervisory Audio Tone Color Code.
SCC?			Returns Supervisory Audio Tone Color Code setting.
SEND STOP		7-57 7-57	Starts sending Mobile Station Control message. Stops sending Mobile Station Control message.
VMAC n	0 to 7		Sets Voice Mobile Attenuation Code.
VMAC?			Returns Voice Mobile Attenuation Code setting.
RECC:			
STATus?		7-37	
RFLvI n	-30.0 to -127.0	7-31	
SETup		7-31	
STARt		7-31	Simulation screen. Starts Cell Site Simulation transmission.
STOP		7-31	
0.0.		, 0,	otops den dite dimetation transmission.
DEFINE COMMANDS			
*DMC "name, command;		348	Defines a macro.
CONST name, expression		3-54	
DATA name={expression,}		3-55	
FORMat X	BINary, DECimal,	3-64	Sets data format.
	HEXadecimal or OCTal		
STRING name,,name		3-84	
STRING name[index],name[index	()	3-84	3 ,
/AR name,,name		3-86	([index] mandatory, not optional.) Declares variables.
AR name[index],,name[index]		3-86	
m. name[maex],,manse[maex]		300	([index] mandatory, not optional.)
NODLAY COLLEGANDO			
DISPLAY COMMANDS			
BCOLOR b	0 to 15 or name	3-25	Sets background color.
BOX f, x1, y1, x2, y2, c	1 or 0, 0 to 639,	3-51	Creates box on CRT display.
	0 to 349, 0 to 639,		
	0 to 349, 0 to 15		
CENTER element,x,y,pw	string or text in quotes,	3-31	Centers and displays text element in defined area.
	0 to 639, 0 to 349, 1 to (640- <i>x</i>)		
CLS	1 (0 (040-%)	3-54	Clears display screen or selected window of
		• • •	everything except active readings.
OLOR f,c	0 to 15 or name,	3-25	Sets foreground and character contrast colors.
	0 to 15 or name		
OLOR?		3-25	Returns current foreground color.
DRAW x1, y1, x2, y2, c	0 to 639, 0 to 349,	3-58	Creates line on CRT display.
	0 to 639, 0 to 349,		
ERASE:TEXT x,y,pw	0 to 15 0 to 639, 0 to 349,	3-31	France defined CPT display area
	1 to (640-x)	3-31	Erases defined CRT display area.
IEIGHT n	1 to 4	3-64	Sets height of text from 0.175 to 0.7 inches.
IPRINT %0nl, expression,\		3-66	Prints expression on CRT display.
expression, ,expression,			• • • • • • • • • • • • • • • • • • • •
JPRINT value,x,y,pw		3-31	Displays value, left justified, in defined area on CRT.
PIXEL		3-77	Displays point at current xy position on CRT.
PIXLEN? value		3-31	Returns number of pixels required to display value.
'RINT %0nl, expression, IJPRINT value,x,y,pw		3-79 3-31	Prints expression out CSA RS-232 Connector.
ISER		3-26	Displays value, right justified, in defined area on CRT. Clears display screen or active window of everything.
(Y n, m	0 to 639, 0 to 349	3-20	Sets xy position for HPRINT and PIXEL commands.
(YPRINT x,y,%0nl, expression,)	, - 	3-91	Prints expression at selected xy position on CRT.
expression,, expression,			, , , , , , , , , , , , , , , , , , , ,
•			

FORWARD DIGITAL TRAFFIC CHANNEL (FDTC) MONITOR COMMANDS

NOTE: Queries for received data, return -1 if data is not available or has already been read.

, addition for foothour			•
FDTC:			Outside Forward Digital Traffic Channel to monitor
CHANnel n	1 to 1023		Selects Forward Digital Traffic Channel to monitor.
DVCC?		7-15	Returns Digital Verification Color Code.
FACCH:			D. I. M. C. C. Tour a make and and
AMT?		7-15	
AUTHBS?		7-15	Returns AUTHBS value.
CALLING:			man and the state of the state
NUM?		7-16	Returns number of calling party.
P1?		7-16	Returns Calling Party Presentation Indicator.
PLANId?		7-16	Returns Calling Party Numbering Plan Identification.
SI?			Returns Calling Party Screening Indicator.
SPare?			Returns value of Calling Party Number spare bits.
TYpe?		7-16	Returns Calling Party Number Type.
CNPC?			Returns Calling Number Presentation Code.
DIC?			Returns Delay Interval Compensation.
DIGits? n	0 to 2		Returns selected digit set.
DMAC?		7-16	Returns Digital Mobile Attenuation Code.
DTX?		7-16	Returns Discontinuous Transmission.
HDVCC?		7-16	Returns Handoff Digital Verification Color Code.
LC?			Returns Local Control.
LDP?		7-16	Returns Last Decoded Parameter.
MEM?		7-16	Returns Message Encryption Mode.
MSGtype?			Returns Message Type.
NOMW?		7-16	Returns Number of Messages Waiting.
NV? n	0 to 5	7-17	Returns Number of Values for selected element.
PD?		7-17	Returns Protocol Discriminator.
PT? n	0 to 5	7-17	Returns Parameter Type for selected element.
RANDSSD1?		7-17	Returns value of 24 most significant bits of RANDSSD.
RANDSSD2?		7-17	Returns value of bits 8 through 31 of RANDSSD.
RANDU?		7-17	Returns RANDU value.
RATE?			Returns Channel Rate.
RFCHAN? n	0 to 11	7-17	Returns RF Channel for selected index.
RL? n	0 to 2		Returns Remaining Length in selected segment.
	0 10 2	7-17	Returns Request Number.
RN?		7-17	Returns Shortened Burst Indicator.
SBI?			Returns Signal field.
SiGnal?			Returns Time Alignment.
TA?		7-17	Returns Timeslot Indicator. (0 is analog.)
T1?			Returns Voice Privacy Mode.
VPM?		7-17	Helding voice i hivady mode.
1854:	0 to 00	7-91	Returns Coded Digital Verification Color Code from
CDVCC? n	0 to 99	7-21	selected data word.
		7.01	Returns number of data words received.
COUNt?	0.1-00.41.05	7-21	Returns character data from selected data word.
DATA? n,x	0 to 99, 1 to 65		
SACCH? n	0 to 99		Returns 12 bits of SACCH message.
START			Starts IS-54 timeslot raw data Capture.
STOP		7-21	Stops IS-54 timeslot raw data Capture.
SYNC? n	0 to 99	7-21	
TIME? n	0 to 99	7-21	
R0?		7-15	Returns VSELP frame energy value.
RAW:			القدادية والاستعادة والمتارية والمتارية والمتارية والمتارية والمتارية والمتارية والمتارية والمتارية
CF? n	0 to 99	7-20	Returns Continuation Flag bit from selected data word.
COUNt?		7-20	
DEPTH n	1 to 100	7-20	
DVCC? n	0 to 99	7-21	Returns Digital Verification Color Code from selected data word.
MESSage? n,x	0 to 99,0 to 5	7-21	Returns selected message byte from selected data word.
RSVD? n	0 to 99	7-21	Returns Reserved bits from selected data word.
SELect:			
FACCH		7-20	Selects Fast Associated Control Channel for raw data.
SACCH		7-20	
START		7-20	Starts raw data Capture.

COMMAND	RANGE	PAGE	DESCRIPTION
FDTC:			
RAW:			
STOP		7-20	Stops raw data Capture.
TIME? n	0 to 99	7-21	Returns Time Stamp in ms of selected data word.
SACCH:			The state of the s
AMT?		7-18	Returns Message Type acknowledged.
AUTHBS?		7-18	
CALLING:			
NUM?		7-18	Returns number of calling party.
PI?		7-18	Returns Calling Party Presentation Indicator.
PLANId?		7-18	Returns Calling Party Numbering Plan Identification.
SI?		7-18	Returns Calling Party Screening Indicator.
SPare?		7-18	Returns value of Calling Party Number spare bits.
TYpe?		7-18	Returns Calling Party Number Type.
CNPC?		7-18	Returns Calling Number Presentation Code.
DIC?		7-18	Returns Delay Interval Compensation.
DIGits? n	0 to 2	7-18	Returns selected digit set.
DMAC? DTX?		7-18	Returns Digital Mobile Attenuation Code.
HDVCC?		7-18	Returns Discontinuous Transmission.
LC?		7-19	Returns Handoff Digital Verification Color Code.
LDP?			Returns Local Control.
MEM?		7-19	Returns Last Decoded Parameter.
MSGtype?		7-19	Returns Message Encryption Mode.
NOMW?		7-18	Returns Message Type.
NV? n	0 to 5	7-19	Returns Number of Messages Waiting. Returns Number of Values for selected element.
PD?	0.000	7-19 7-10	Returns Protocol Discriminator.
PT? n	0 to 5	7-19	Returns Parameter Type for selected element.
RANDSSD1?	3 10 0	7.19	Returns value of 24 most significant bits of RANDSSD.
RANDSSD2?		7-19	Returns value of bits 8 through 31 of RANDSSD.
RANDU?		7-19	Returns RANDU value.
RATE?		7-19	Returns Channel Rate.
RECHAN? n	0 to 11		Returns RF Channel for selected index.
BL? n	0 to 2	7-19	Returns Remaining Length octets in selected segment.
RN?		7-19	Returns Request Number.
SBI?		7-20	Returns Shortened Burst Indicator.
SIGnal?		7-20	Returns Signal Field.
TA?		7-20	Returns Time Alignment.
TI?		7-20	Returns Timeslot Indicator. (0 is analog.)
VPM?		7-20	Returns Voice Privacy Mode.
SETup		7-15	Sets FM/AM-1600CSA as when entering Forward
			Digital Traffic Channel screen.
SLOT n	1 to 3	7-15	Selects Digital Traffic Channel Timeslot.
STARt		7-15	Starts decoding FDTC data.
STOP		7-15	Stops decoding FDTC data.

FORWARD CONTROL CHANNEL (FOCC) MONITOR COMMANDS

NOTE: Queries for received data, return -1 if data is not available or has already been read.

FOCC:		
ACT?	7-5	Returns Global Action value.
AUTH?	7-5	Returns Authentication bit.
AUTHBS?	7-5	Returns AUTHBS value.
BIDle?	7-5	Returns Busy-Idle bit.
BIS? CAPTure:	7-5	Returns Busy-Idle Status bit.
A_ALERT	7-3	Selects Abbreviated Alert message for Capture.
AUDIT	7-3	Selects Audit message for Capture.
AUT_REG	7-3	Selects Autonomous Registration Confirmation message for Capture.
BSCHALCON	7-3	Selects Base Station Challenge Confirmation Message for Capture.
CLEAR	7-3	Restarts Capture Function.
DIR_RTRY	7-3	Selects Directed-Retry message for Capture.
INTROPT	7-3	Selects Intercept message for Capture.
LC	7-3	Selects Local Control message for Capture.

OMMAND	RANGE	PAGE	DESCRIPTION
DCC:			
CAPTure:			
MIN "n"		7-4	Selects Mobile Identification Number to Capture.
MIN?		7-4	Returns MIN currently selected for Capture.
MODE?		7-3	Returns current Capture Mode: 0-NONE, 1-ORDER
			2-MIN or 3-BOTH (MIN and ORDER).
MSG_WTG		7-3	Selects Message Waiting message for Capture.
N_AUT_REG		7-4	Selects Non-autonomous Registration Confirmation
		, -	message for Capture.
ORDer?		7-4	Returns name of order currently selected for Captur
PAGE		7-4	Selects Page for Capture.
RELease		7-4	Selects Release message for Capture.
REORDER		7-4	Selects Reorder message for Capture.
		• -	Colours House Manager III - april 1
SELect:		7-3	Sets Capture Mode to BOTH (MIN and ORDER).
BOTH		7-3 7-3	Sets Capture Mode to MIN.
MIN		7-3 7-3	
NONE			Sets Capture Mode to NONE.
ORDER		7-3	Sets Capture Mode to ORDER.
SLOT_1		7-4	Selects Slot 1 Handoff message for Capture.
SLOT_2		7-4	Selects Slot 2 Handoff message for Capture.
SLOT_3		7-4	Selects Slot 3 Handoff message for Capture.
SSD_UPdate		7-4	Selects Shared Secret Data Update for Capture.
UCHAL		7-4	Selects Unique Challenge message for Capture.
VC_DES		7-4	Selects Voice Channel Designation message for
			Capture.
CAPTure?		7-2	Returns Capture condition (1 [occurred] or 0).
CHANnel n	1 to 1023	7-2	Selects Forward Control Channel to monitor.
CHAN?		7-5	Returns Channel Number field.
CHANPOS1?		7-5	Returns Channel Position 1.
CHANPOS2?		7-5	Returns Channel Position 2.
CHANPOS3?		7-5	Returns Channel Position 3.
CHANPOS4?		7-5	Returns Channel Position 4.
CHANPOS5?		7-5	Returns Channel Position 5.
CHANPOS6?		7-5	Returns Channel Position 6.
CMAC?		7-5	Returns Control Mobile Attenuation Code.
CMAX_1?		7-5	Returns number of Access Channels minus one.
CPA?		7-6	Returns Combined Paging/Access.
DCC?		7-6	Returns Digital Color Code.
		7-6	Returns Digital Mobile Attenuation Code.
DMAC?		7-6	Returns Discontinuous Transmission.
DTX?		7-6	Returns Digital Verification Color Code.
DVCC?		7-6 7-6	Returns Extended Address.
E?			Returns Extended Protocol Forward Channel Indica
EF?		7-6	
END?		7-6	Returns End Indication.
EP?		7-6	Returns Extended Protocol.
LOC CONTRL?		7-6	Returns Local Control Message.
LOCAID?		7-6	Returns Location Area Identity.
LOCAL_MT?		7-6	Returns Local Control/Message Type.
LREG?		7-6	Returns Location Registration.
MBUSY:			
OTH?		7-6	Returns Max # of Busy incidents (Non-Page respons
PGR?		7-6	Returns Max # of Busy incidents (Page responses)
MEM?		7-6	Returns Message Encryption Mode.
MIN?		7-7	Returns Mobile Identification Number.
MSZTR:			
OTH?		7-7	Returns Max # of Seizure Tries (Non-Page respons-
PGR?		7-7	Returns Max # of Seizure Tries (Page responses).
		7-7	Returns number of Paging Channels minus one.
N_1?		7-7	Returns Number of Additional Words Coming.
NAWC?		7-7 7-7	Returns New Access Channel Starting Point.
NEWACC?		7-7 7-7	Returns Overload Control Class.
OLC?			***
ORDER?		7-7	Returns Order.
ORDERCD?		7-7	Returns Order Code.
ORDQ?		7-7	Returns Order Qualifier.
PCI?		7-7	Returns Protocol Capability Indicator.
PDREG?		7-7 7-7	Returns Power Down Registration. Returns Privacy Mode.

COMMAND	RANGE	PAGE	DESCRIPTION
FOCC:			
PUREG?		7-7	Returns Power Up Registration.
RANDSSD_1?		7-7	Returns value of 24 most significant bits of RANDSSD.
RANDSSD_2?		7-7	Returns value of bits 8 through 31 of RANDSSD.
RANDSSD_3?		7-8	Returns value of 8 least significant bits of RANDSSD.
RANDU?		7-8	Returns 24 bit Random Number UCHAL message.
RAND1_A?		7-8	Returns 16 most significant bits of RAND Value.
RAND1_B?		7-8	Returns 16 least significant bits of RAND Value.
RAW;			•
A:			
CHECK? n	0 to 99	7-11	Returns CRC Check for selected Stream A data word.
DATA? n	0 to 99	7-11	Returns Raw Data word from Stream A.
PARITY? n B:	0 to 99	7-11	Returns Parity for selected data word from Stream A.
CHECK? n	0 to 99	** 4 4	Patricia ODO OL 17 de 1800 - 1
DATA? n	0 to 99	7-11 7-11	Returns CRC Check for selected Stream B data word.
PARITY n	0 to 99	7-11	the second state of the second
B_1? n	0 to 99	7-11	
CAPTure:	0 10 00	7-11	Returns Busy-Idle bit for selected data word.
A_ALERT		7-9	Selects Abbreviated Alert Message for Capture.
AŪDIT		7-9	Selects Audit Message for Capture.
AUT_REG		7-9	Selects Autonomous Registration Confirmation
-			message for Capture.
BSCHALCON		7-9	Selects Base Station Challenge Confirmation Message
			for Capture.
DIR_RTRY		7-9	Selects Directed-Retry message for Capture.
INDex?		7-10	Returns position of Captured Order in buffer.
INTROPT		7-9	Selects Intercept message for Capture.
LC		7-9	Selects Local Control Message for Capture.
MSG_WTG		7-10	Selects Message Waiting message for Capture.
N_AUT_REG		7-10	Selects Non-Autonomous Registration Confirmation
			message for Capture.
NONE		7-9	Sets Capture Mode to NONE (no message selected).
ORDer?		7-10	Returns name of order currently selected for Capture.
PAGE		7-10	Selects Page message for Capture.
RELease		7-10	Selects Release message for Capture.
REORDER		7-10	Selects Reorder message for Capture.
SLOT_1 SLOT_2		7-10	Selects Slot 1 Handoff message for Capture.
SLOT		7-10	Selects Slot 2 Handoff message for Capture.
SSD_UPdate		7-10	
UCHAL		7-10	Selects Shared Secret Data Update for Capture.
VC_DES		7-10 7-10	Selects Unique Challenge message for Capture. Selects Voice Channel Designation message for
		7-10	Capture.
CAPTure?		7-11	
FULL?		7-11	Returns buffer status (1 [full] or 0).
STARt		7-10	Starts raw data Capture.
STOP		7-10	Stops raw data Capture.
TRIGger n	0 to 4	7-10	
TS? n	0 to 99	7-11	Returns Time Stamp in ms of selected data word.
WORD:			The state of the s
Α		7-9	Selects raw data from Stream A to monitor.
В		7-9	Selects raw data from Stream B to monitor.
вотн		7-9	Selects raw data from Streams A and B to monitor.
RCF?		7-8	Returns Read Control-Filler.
REGH?		7-8	Returns Registration for Home Mobile Stations.
REGID? REGINCR?	tage of the end of the	7-8	Returns Registration Identification.
		7-8	Returns Registration Increment.
REGR?		7-8	Returns Registration for Roaming Mobile Stations.
REMote:			
STARt		7-2	Redirects Forward Control Channel data out RS-232
STOR			Connector.
STOP		7-2	Stops sending Forward Control Channel data out
5.3			RS-232 Connector.
S? SCC?			Returns Serial Number bit value.
SDCC1?		7-8	Returns Supervisory Audio Tone Color Code.
		7-8	Returns Supplementary Digital Color Code 1.

COMMAND	RANGE	PAGE	DESCRIPTION
FOCC:			
SDCC2?		7-8	Returns Supplementary Digital Color Code 2.
SETup		7-2	Sets FM/AM-1600CSA as when entering Forward Control Channel Screen.
SID?		7-8	Returns System Identification Number.
STARt		7-2	Starts decoding FOCC data.
STREAM:		7-2	Selects data from Stream A.
A			
В		7-2	Selects data from Stream B.
STOP		7-2	Stops decoding FOCC data.
VMAC?		7-8	Returns Voice Mobile Attenuation Code.
WFOM?		7-8	Returns Wait For Overhead Message.
WORD:			
A		7-2	Selects Stream A to monitor.
B		7-2	Selects Stream B to monitor.
вотн		7-2	Selects Streams A and B to monitor.

FORWARD VOICE CHANNEL (FVC) MONITOR COMMANDS

	\$ ₁ .			
F۷	C·			
, •	AUTHBS?		7-12	Returns Output Response of Base Station Authentication Algorithm.
	CHANnel n	1 to 1023	7-12	Selects Forward Voice Channel to monitor.
	CHAN?	1 10 100		Returns Channel Number field.
	CHAR1?			Returns first Characters in Called or Calling Party
	CHARLE			Number message.
	CHAR2?		7-12	Returns last Characters in Called or Calling Party
	OHANZ!		,	message.
	CPN RL?		7-13	Returns Calling Party Number Remaining Length.
	DMAC?		7-13	Returns Digital Mobile Attenuation Code.
	DVCC?		7-13	Returns Digital Verification Color Code.
	EF?		7-13	Returns Extended Protocol Forward Channel Indicator.
	LOCAL MT2		7-13	Returns Local Control/Message Type.
	MEM?			Returns Message Encryption Mode.
	ORDER?		7-13	Returns Order.
	ORDERCD?			Returns Order Code.
	ORDQ?			Returns Order Qualifier.
	PI?		7-13	Returns Calling Party Number Presentation Indicator.
	PM?			Returns Privacy Mode.
	PSCC?		7-13	Returns Present SAT Color Code.
	PWRL?			Returns requested Power Level.
	RANDSSD1?			Returns value of 24 most significant bits of RANDSSD.
	RANDSSD2?		7-13	Returns value of bits 8 through 31 of RANDSSD.
	RANDSSD3?		7-13	Returns value of 8 least significant bits of RANDSSD.
	RANDU?			Returns RANDU value.
	RAW:			
	CHECK? n	0 to 99	7-14	Returns CRC Check for selected data word (0 [good]).
	COUNT? n	0 to 99	7-14	Returns number of data words received.
	DATA? n	0 to 99		Returns raw data word (28 bits).
	DEPTH n	1 to 100	7-14	Selects size of data buffer.
	PARITY? n	0 to 99	7-14	Returns Parity for selected data word.
	STARt		7-14	Starts raw data Capture.
	STOP		7-14	Stops raw data Capture
	TS? n	0 to 99	7-14	Returns Time Stamp of selected data word in seconds
				from 0 data word.
	RL W?		7-13	Returns Remaining Length in number of Words.
	SBI?		7-14	Returns Shortened Burst Indicator.
	SCC n	5955 to 6044	7-12	Specifies SCC with corresponding SAT frequency.
	SCC?		7-14	Returns Supervisory Audio Tone Color Code.
	SETup		7-12	Sets FM/AM-1600CSA as when entering Forward
	· · · !			Voice Channel Screen.
	SI?		7-14	Returns Calling Party Screening Indicator.
	SIGNAL?		7-14	Returns Signal field.
	STARt		7-12	Starts decoding Forward Voice Channel.
	STOP		7-12	Stops decoding Forward Voice Channel.
	TA?		7-14	Returns Time Alignment.
	VMAC?	•	7-14	Returns Voice Mobile Attenuation Code.

COMMAND	RANGE	PAGE	DESCRIPTION
GENERIC MEASURE COMM	IANDS		
MEASure:			
SAT? ST?		7-62 7-62	Returns Supervisory Audio Tone frequency in Hz. Returns Signal Tone frequency in Hz.
GPIB COMMANDS			
GPIB:ADDRess a	0 to 31	3-36	Sets GPIB address of FM/AM-1600CSA.
GPIB:MASK n GPIB:SRQ n	0 to 255 0 to 255	3-36	Sets SRQ interrupt mask. Sets user defined Status Byte to trigger SRQ.
HOST COMMANDS			
HOST "string"		7-1	Sends 1600S command as string.
HOST? "string?"		7-1	Sends 1600S query as string.
IEEE 488.2 COMPLIANCE C	OMMANDS		Δ.
*CLS *DMC "name, command;		3-46	Sets user defined Status Byte to zero.
*IDN?			Defines a macro. Returns FM/AM-1600CSA identification.
*PMC		3-49	
KEY COMMANDS			
KEY		3-32	Returns keycode of next control terminal key pressed.
KEY?		3-32	Returns 1 if control terminal key is pressed or 0.
KEYPAD COMMAND			
KEYPAD:LABel n, "Label"	1 to 6	3-74	Creates Label for Soft Function Key Fn.
MACRO FUNCTION COMMA	NDS		
BEGIN		3-50	Allows macro to have multiple lines.
CASE variable OF value1: command		3-52	Provides predetermined decision point.
OF value2: command OTHERWISE: command			
DELAY t		3-56	Provides time delay in ms.
DO sequence UNTIL condition END		3-56	Performs set of commands.
ENDCASE			Ends macro. Ends Case command.
EXEC address or EXEC & name		3-59	Executes a macro.
FLUSH FOR variable=initial TO ending	CTED atam	3-60	Returns pending responses.
sequence	SIEF SIUP	3-61	Performs set of commands repeatedly.
NEXT variable			
FORGET "name" HFLUSH		3-63	Deletes macro called "name" from memory.
IF condition sequence; ENDIF		3-65 3-68	Quickly sends HOST commands through SCSI. Provides decision point.
IF condition sequence; ELIF condition sequence ELIF condition sequence; ENDIF			Provides decision points.
IF condition sequence		3-70	Provides decision point.
ELSE condition sequence;EliNPUT variable	AD1L	3-72	Allows data entry through RS-232 Connector during macro execution.
INTERP "string;string;;string"		3-72	Executes commands, unknown when macro is defined.
RETURN		3-81	Returns value from function or returns macro execution to previous macro.
ROOM WHILE condition sequence: WEN	n		Used with PRINT to return memory bytes available.
WHILE condition sequence;WEN	U	3-87	Performs set of commands repeatedly until conditional expression is false.

MACRo "m","f" STATE "f" 7-64 Loads macros and variables stored as file name from Flash to CSA memory, executing macros STATE "f" 7-64 Frees memory space from deleted files. STORE: CALibration "f" MACRo "m","f" 7-64 Stores current Calibration Data as f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros activate from JBox Flash Files Directory. STATE "f" 7-64 Stores current CSA settings as f in Flash Memory with designated macros activate from JBox Flash Files Directory. STATE "f" 7-64 Returns file type of file name f. MODULATION ACCURACY COMMANDS MODacc: FDTC: CHANnel n 1 to 1023 7-62 Sets RF Channel. COMPlete? 7-62 Returns RMS Error Vector Magnitude in percent FREQ_ERRor? 7-62 Returns Frequency Error in hertz. IQ_OFFset? 7-62 Returns Frequency Error in hertz. IQ_OFFset? 7-62 Returns RMS Magnitude Error in percent. PHASE_ERRor? 7-62 Returns RMS Magnitude Error in degrees. RUN? 7-62 Starts measurement and returns adjusted AGC SET UP MULTITASKING MACROS COMMANDS ACTIVATE "name" 3-80 Puts specified task in schedule queue. SLEEP "name" 3-81 Removes specified task from schedule queue. STOP 3-84 Stops all macros. PASSE command execution to next task in queue. STOP 3-85 Declares specified loaded macro to be a task. TPAUSE 3-85 Passes command execution to next task in queue.	COMMAND	RANGE	PAGE	DESCRIPTION
CALCÜLATE? expression 2-52 Calculates expression functions and returns res (COS(n) 3-14 Produces cosine of in radians. EXP(n) 3-14 Produces 0 to the power of n. FALSE_OFF 3-12 Produces 0. to the power of n. FALSE_OFF 3-12 Produces 0. to the power of n. FALSE_OFF 3-12 Produces 0. to the power of n. FLOOR(n) 3-13 Produces natural logarithm (base e) of n. LOG(n) 3-13 Produces natural logarithm (base e) of n. FRO(n) 3-14 Produces natural logarithm (base e) of n. FRO(n) 3-14 Produces natural logarithm (base e) of n. FRO(n) 3-14 Produces natural logarithm (base e) of n. FRO(n) 3-14 Produces natural logarithm (base e) of n. FRO(n) 3-14 Produces natural logarithm (base e) of n. FRO(n) 3-14 Produces natural logarithm (base e) of n. FRUECON 3-14 Produces natural logarithm (base e) of n. FRUECON 3-14 Produces natural logarithm (base e) of n. FRUECON 3-14 Produces natural logarithm (base e) of n. FRUECON 3-14 Produces natural logarithm (base e) of n. FRUECON 3-14 Produces natural logarithm (base e) of n. FRUECON 3-14 Produces natural logarithm (base e) of n. FRUECON 3-14 Produces natural logarithm (base e) of n. FRUECON 3-14 Produces natural logarithm (base e) of n. FRUECON 3-14 Produces natural logarithm (base e) of n. FRUECON 3-14 Produces natural logarithm (base e) of n. FRUECON 3-14 Produces natural logarithm (base e) of n. FRUECON 3-14 Produces natural logarithm (base e) of n. FRUECON 3-14 Produces natural logarithm (base e) of n. FRUECON 3-14 Produces natural logarithm (base e) of n. FRUECON 3-14 Produces natural logarithm (base e) of n. FRUECON 3-14 Produces natural logarithm (base e) of n. FRUECON 3-14 Produces natural logarithm (base e) of n. FRUECON 3-15 Produces natural logarithm (base e) of n. FRUECON 3-15 Produces natural logarithm (base e) of n. FRUECON 3-15 Produces natural logarithm (base e) of n. FRUECON	MATHEMATICAL FUNCTION	ON COMMANDS		
CALCULATE? expression COS(n) SAP(n)	ARS(p)		3-13	Produces absolute value of n
South Sout				
EXP[n	•			•
FALSÉ, OFF FLOOR(n) S13-13 Froduces truncated value of n. LN(n) LN(n) S13-13 Froduces truncated value of n. S13-13 Froduces truncated value of n. S13-13 Froduces strunal logarithm of n. RAND x S13-13 Froduces sand trail logarithm of n. RAND x S13-14 Froduces and trail logarithm of n. SIGN(n) S14-14 Froduces -1 if ne0, 0 if ne0 or 1 if ne0. SIGN(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SIGN(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SOR(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SOR(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SOR(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SOR(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SOR(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SOR(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SOR(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SOR(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SOR(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SOR(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SOR(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SOR(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SIGN(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SIGN(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SIGN(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SIGN(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SIGN(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SIGN(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SIGN(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SIGN(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SIGN(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SIGN(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SIGN(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SIGN(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SIGN(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SIGN(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. SIGN(n) S14-14 Froduces -1 if ne0, 0 if ned or 1 if ne0. S14-14 Froduces -1 if ne0, 0 if ne0 or 1 if ne0. SIGN(n) S14-14				
FLODR(n) (Nn) (DG(n) (AND) (DG(n) (AND) (AND)				
LN(n) LOG(n) RAND x SARD (n) SIGN(n) SIGN(n) SIGN(n) SOR(n) SOR(n) MASS MEMORY COMMANDS MMEMory: CATalog: CATalog: ENTRY? CATalog? CATalog? CATalog? CALibration "T" MACRO "m","f" PACR STATE "f" PACR CALibration "f" MACRO "m","f" PACR CALibration "f" MACRO "m","f" ACTIVATE "flash Memory vaccuting macer CALibration "f" MACRO "m","f" TOGA TIGHE ON MACRO "m","f" TOGA TIGHE ON MACRO "m","f" TOGA TOGA TIGHE ON MACRO "m","f" TOGA TOGA STATE "f" TOGA TOGA TOGA STATE "f" TOGA STORE: CALIbration "f" MACRO "m","f" TOGA STATE "f" TOGA STORE: CALIBRATION ACCURACY COMMANDS MODULATION ACCURACY COMMA	· · · · · · · · · · · · · · · · · · ·			
LOG(n) RAND x S.12 Sets seed (starting point) to x for random gene RND(n) SIN(n) SIN(n	` '			
RAND x RND(n) SIGN(n) SIGN(n) SIGN(n) SIGN(n) SOR(n) SOR(n	` ,			
RND(n) SIGN(n)	, ,			
SIGN(n) 3-14 Produces 1 if n.o.0, 0 if n.o.o.r 1 if n.o.0. SIN(n) 3-14 Produces size of n in radians. SOR(n) 3-14 Produces positive square root of n. 3-12 Produces 1. MASS MEMORY COMMANDS MMEMory: CATalog: ENTRY? n 0 to 512 7-64 Returns available file space in bytes. 7-64 Returns available file space in bytes. 7-64 Returns savailable file space in bytes. 7-64 Returns files homency status. 7-64 Returns files homency status. 7-64 Loads Calibration of the status. 7-64 Returns files homency status. 7-64 Returns files homency. Returns 1 for file system initialized or 0 otherwit of the status of the system initialized or 0 otherwit of the status of the system initialized or 0 otherwit of the status for files homency. STATe "f" 7-64 Loads Calibration Data from Flash to CSA Memory, exocuting macro. STATe "f" 7-64 Stores current Calibration Data as fin Flash Memory. STATe "f" 7-64 Stores current Calibration Data as fin Flash Memory. STATe "f" 7-64 Stores current Calibration Data as fin Flash Memory. STATe "f" 7-64 Stores current Calibration Data as fin Flash Memory. STATe "f" 7-64 Stores current Calibration Data as fin Flash Memory. STATe "f" 7-64 Stores current CSA setting status from Blash Files Directory. 7-65 Returns file stype of file name f. Returns file type of file name f. Returns file stype of file name f. Returns file stype of file name f. Returns Flash Memory for the status for files files. Returns Research CSA setting Research files. Returns Research fil				
SIN(n) SOR(n) SO				
MASS MEMORY COMMANDS MMEMory: CATalog: ENTRY? n 0 to 512 7-64 Returns line n from JBox Flash Files Directory, FREE? 7-64 Returns available file space in bytes. DELete "!" 7-64 Returns Flash Memory status. T-64 Returns Flash Memory status. T-65 Flash Memory status. T-66 Flash Memory status. T-67 Flash Memory status. T-68 Flash Memory status. T-69 Stores currently loaded macros and variables as a name file flash Memory status. T-69 Flash Memory status from JBox Flash Files Directory. TYPE? "f" T-69 Stores current CSA setting bir set in Flash Memory status. T-69 Flash Files Directory. T-69 Flash Files Directory. T-69 Flash Files Directory. T-60 Returns flash Files Directory. T-60 Returns flash Files Directory. T-60 Flash Files Directory. T-60 Flash Files Directory. T-60 Flash Files Directory. T-61 Flash Memory status from JBox Flash Files Directory. T-62 Flash Files Directory. T-63 Flash Files Directory. T-64 Flash Memory status from JBox Flash Files Directory. T-65 Flash Memory status from JBox Flash Files Directory. T-68 Flash Memory status from JBox Flash Files Directory. T-69 Flash Files Directory. T-69 Flash Files Directory. T-60 Flash Files Directory. T-60 Flash Memory status from JBox Flash Files Directory. T-60 Flash Files Directory. T-60 Flash Files Directory. T-61 Flash Memory status from JBox Flash Files Directory. T-69 Flash Files Dire				
MASS MEMORY COMMANDS MMEMORY: CATalog: ENTRY? n 0 to 512 7-64 Returns line n from JBox Flash Files Directory. FREE? 7-64 Returns available file space in bytes. USED? 7-64 Returns used file space in bytes. CATalog? 7-64 Returns line m from JBox Flash Files Directory. FREE? 7-64 Returns line m from JBox Flash Files Directory. Free members of the more space in bytes. CALalog of the more space in bytes. CALibration "I" 7-64 Returns I for file system the file with file name f. MACRo "m"."" 7-64 Erases all files stored in Flash Memory. INITialize? 7-64 Erases all files stored in Flash to CSA Mem MACRo "m"."" 7-64 Loads macros and variables stored as fine name from Flash to CSA Mem from Flash to CSA Memory. executing macro STATE "F 7-64 Loads CSA State stored as firom Flash Memory PACK STORE: 7-64 Stores current Calibration Data as f in Flash Memory Frees memory space from files files Directory. STATE "F 7-64 Stores current Calibration Data as f in Flash Memory TYPE?" "F 7-64 Returns File type of file name f. MODULATION ACCURACY COMMANDS MULTITASKING MACROS COMMANDS ACTIVATE "name" 3-62 Sets RM: Amenique Error in percent. 7-62 Returns FMS Phase Error in degrees. 7-62 Returns RMS Phase Error in degrees. 8-7-62 Starts measurement and returns adjusted AGC Starts me				
MMEMory: CATalog: ENTRY? n 0 to 512 7-64 Returns line n from JBox Flash Files Directory. FREE? 7-64 Returns used file space in bytes. CATalog? 7-64 Returns used file space in bytes. CATalog? 7-64 Returns lash Memory status. DELete "" 7-64 Deletes file with file name f. INITialize 7-64 Erases all files stored in Flash Memory. INITialize 7-64 Returns 1 for file system initialized or 0 otherwind to Activate from Flash for CSA Memory. CALibration "f" 7-64 Loads Galibration Data from Flash to CSA Memory. STATe "f" 7-64 Loads Galibration Data from Flash to CSA Memory. STATe "f" 7-64 Loads Sat State stored as file name from Flash to CSA Memory. STATE "f" 7-64 Stores current CSA state stored as file name from Flash to CSA Memory. ACK 7-64 Frees memory space from deleted files. STORE: CALibration "f" 7-64 Stores current Calibration Data from Flash Memory with designated man to activate from JBox Flash Files Directory. STATE "f" 7-64 Stores current CSA settings as f in Flash Memory TYPE? "7-65 Stores current CSA settings as f in Flash Memory STORE: CHANNEI 1 to 1023 7-62 Sets RF Channel. COMPlete? 7-62 Returns RMS Error Vector Magnitude in percent FREQ_ERROr? 7-62 Returns RMS Error vector Magnitude in percent PHASE_ERROr? 7-62 Returns RMS Magnitude Error in percent. PHASE_ERROr? 7-62 Returns RMS Magnitude Error in percent. PHASE_ERROr? 7-62 Returns RMS Magnitude Error in percent. PHASE_ERROr? 7-62 Sets RMS Magnitude Error in percent. PHASE_ERROR? 7-62 Sets RMS Magnitude Error in percent. PHASE_ERROR? 7-62 Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. MULTITASKING MACROS COMMANDS MULTITASKING MACROS COMMANDS ACTIVATE "name" 3-50 Puts specified task in schedule queue. SLEEP "name" 3-83 Removes specified task from schedule queue. SLEEP "name" 3-83 Removes specified toaded macro to be a task. TASK "name" 3-85 Declares specified toaded macro to be a task. TASK "name" 3-85 Stops and removes current task from queue.				
CATalog: ENTRY? n 0 to 512 7-64 Returns line n from JBox Flash Files Directory. FREE? 7-64 Returns available file space in bytes. CATalog? 7-64 Returns used file space in bytes. CATalog? 7-64 Returns lash Memory status. DELete "I" 7-64 Deletes file with file name f. INITialize 7-64 Returns Flash Memory status. CALibration "f" 7-64 Loads calibration Data from Flash Memory. INITialize 7-65 Returns 1 for file system initialized or 0 otherwith LOAD: CALibration "f" 7-64 Loads calibration Data from Flash Memory. STATE "I" 7-64 Loads calibration Data from Flash to CSA Memory executing macros and variables stored as file name from Flash to CSA memory, executing macros STATE "I" 7-64 Loads CSA States stored as file name from Flash Memory. FACK 7-64 Frees memory space from deleted files. STORE: CALibration "I" 7-64 Stores current Calibration Data as f in Flash Memory MACRO "m"," I" 7-64 Stores current Calibration Data as f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros current CSA stores current CSA stores current CSA statings as f in Flash Memory with designated macros and variables a name f in Flash files Directory. MODULATION ACCURACY COMMANDS MODULATION ACCURACY	MASS MEMORY COMMAN	DS		
CATalog: ENTRY? n 0 to 512 7-64 Returns line n from JBox Flash Files Directory. FREE? 7-64 Returns available file space in bytes. CATalog? 7-64 Returns used file space in bytes. CATalog? 7-64 Returns lash Memory status. DELete "t" 7-64 Deletes file with file name f. INITialize 7-64 Erases all files stored in Flash Memory. INITialize 7-64 Loads Calibration Tell CALibration "f" 7-64 Loads Calibration Tell STATE TELL	MMEMory:			
FREE? USED? CATalog? CATalog? DELete "f" INITialize T-64 Returns used file space in bytes. 7-64 Returns used file space in bytes. 7-64 Returns used file space in bytes. 7-64 Returns used file space in bytes. 7-64 Returns Islah Memory status. 7-64 Deletes file with file name f. INITialize T-64 Loads calibration in Flash Memory. INITialize CALibration "f" T-64 MACRO "m", "f" T-64 Loads Calibration Data from Flash to CSA Memory. T-64 Loads Calibration Data from Flash to CSA Memory. T-64 Loads CSA State to Store as file name from Flash to CSA Memory. T-64 Returns 1 for file system initialized or 0 otherwice control of the file name from Flash to CSA Memory. T-64 MACRO "m", "f" T-64 Loads Calibration Data from Flash Memory. T-64 Loads CSA State stored as firom Flash Memory. T-64 Loads CSA State stored as firom Flash Memory. T-64 Returns 1 for file system initialized or 0 otherwice control of the file name from Flash Memory. T-64 Returns to the file space in bytes. T-64 Returns to the file space in bytes. T-65 Returns to the file space in bytes. T-66 Returns to the file space in bytes. T-67 Returns to the file space in bytes. T-68 Returns to the file space in bytes. T-69 Returns to the file space in the file space in the file space in f	CATalog:			
USED? CATalog? DELete "f" DELete "f" T-64 Returns Plash Memory status. P-64 Petrurs Flash Memory status. P-64 Petrurs Flash Memory status. P-64 Petrurs Flash Memory status. P-65 Petrus Flash Memory status. P-66 Petrurs Flash Memory status. P-67 Petrus Flash Memory status. P-68 Petrurs Flash Memory status. P-69 Petrus Flash Memory status. P-69 Petrus Flash Memory status. P-69 Petrus Flash Memory. P-69 Petrus Flash Memory. P-69 Petrus Flash Memory. P-69 Petrus Flash Memory. P-60 Petrus Flash Memory. P-60 Petrus Flash Memory. P-61 Petrus Flash Memory. P-62 Petrus Flash Memory. P-63 Petrus Flash Memory. P-64 Petrus Flash Memory. P-65 Petrus Flash Memory. P-66 Petrus Flash Memory. P-67 Petrus Flash Memory. P-68 Petrus Flash Memory. P-69 Petr		0 to 512		
CATalog? DELete "I" Telebets "I" Telebets file with file name f. INITialize Telebets file with file name f. INITialize? Telebets file with file name f. Terases all files stored in Flash Memory. Telebets file with file name f. Telebets file with file name				
DELete "I" INITialize				
INITialize				
INITialize? LOAD: CALibration "t" MACRo "m","f" A-64 MACRo "m","f" A-64 MACRo "m","f" A-64 MACRo "m","f" A-64 MACRo "m","f" A-65 STATE "f" A-66 MACRO "m","f" A-66 MACRO "m","f" A-67 MACRO "m","f" A-68 MACRO "m","f" A-69 MACULATION ACCURACY COMMANDS MACULATION ACCURACY COMMANDS MACULATION ACCURAC				
LOAD: CALibration "f" 7-64 Loads Calibration Data from Flash to CSA Mem MACRo "m", "f" 7-64 Loads macros and variables stored as file name from Flash to CSA memory, executing macro STATe "f" 7-64 Loads SA State stored as file name from Flash to CSA memory, executing macro STATE "f" 7-64 Loads CSA State stored as file name from Flash demory PACK 7-64 Stores current Calibration Data as f in Flash Memory STOPE: CALibration "f" 7-64 Stores current Calibration Data as f in Flash Memory with designated mato activate from JBox Flash Files Directory. STATE "f" 7-64 Stores current CSA settings as f in Flash Memory With designated mato activate from JBox Flash Files Directory. STATE "f" 7-64 Returns file type of file name f. MODULATION ACCURACY COMMANDS MULTITASKING MACROS COMMANDS ACTIVATE "name" 3-50 Puts specified task in schedule queue. SLEEP "name" 3-51 Puts specified task from schedule queue. 3-52 Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. MULTITASKING MACROS COMMANDS ACTIVATE "name" 3-53 Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. MULTITASKING MACROS COMMANDS ACTIVATE "name" 3-54 Stops and removes current task from queue. 3-55 Stops and removes current task from queue. 3-56 Stops and removes current	**************************************			
CALibration "f" MACRo "m","f" T-64 Loads Calibration Data from Flash to CSA Mem MACRo "m","f" T-64 Loads macros and variables stored as file name from Flash to CSA memory, executing macro FACK STORE: CALibration "f" MACRo "m","f" T-64 Stores current Calibration Data as f in Flash Memor FACK STORE: CALibration "f" MACRo "m","f" T-64 Stores current Calibration Data as f in Flash Me MACRo "m","f" T-64 Stores currently loaded macros and variables a name f in Flash Memory with designated ma to activate from JBox Flash Files Directory, STATe "f" T-64 Stores current CSA settings as f in Flash Memor TYPE? "f" T-64 Stores current CSA settings as f in Flash Memor TYPE? "f" T-65 Stores current CSA settings as f in Flash Memor TYPE? "f" T-66 Returns file type of file name f. MODULATION ACCURACY COMMANDS MODULATION			7-64	Returns 1 for file system initialized or 0 otherwise.
MACRo "m","f" STATe "f" PACK STORE: CALibration "f" MACRO "m","f" T-64 MACRO "m","f" T-64 MACRO "m","f" T-64 Stores current Calibration Data as f in Flash Memory STATE "f" T-64 Stores currently loaded macros and variables a fame f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables a name f in Flash Memory with designated macros and variables and name f in Flash Memory with designated macros f name f in Flash Memory with designated macros f name f in Flash Memory with designated macros and variables and name f in Flash Memory with designated macros and variables and name f in Flash Memory with designated macros and variables and name f in Flash Memory with designated macros and variables and name f in Flash Memory with designated macros and variables and name f in Flash Memory with designated macros and variables and name f in Flash Memory with designated macros and variables and name f in Flash Memory				
STATE "!" PACK PACK STORE: CALibration "f" MACRo "m","f" STATE "f" MACRO "m","f" T-64 Stores current Calibration Data as f in Flash Memory Stores current Statis from Flash Memory with designated manage in Flash				Loads macros and variables stored as file name f
PACK STORe: CALibration "f" MACRo "m","f" ACRO "m", f" flash Memory with designated ma to activate from JBox Flash Files Directory. ACRO "m", f" flash Memory activated ma to activate from JBox Flash Files Directory. ACRO "mame"	STATe "f"		7-64	
STORe: CALibration "f" MACRo "m","f" ACRO "m Macro Ma	PACK			
MACRO "m","f" 7-64 Stores currently loaded macros and variables a name f in Flash Memory with designated ma to activate from JBox Flash Files Directory. STATE "f" 7-64 Stores current CSA settings as f in Flash Memor TYPE? "f" 7-65 Returns file type of file name f. MODULATION ACCURACY COMMANDS MODacc: FDTC: CHANnel n 1 to 1023 7-62 Sets RF Channel. COMPlete? 7-62 Returns test status (1 [complete] or 0). EVM? 7-62 Returns RMS Error Vector Magnitude in percenter FREQ_ERROr? 7-62 Returns Frequency Error in hertz. IQ_OFFset? 7-62 Returns RMS Magnitude Error in percent. PHASE_ERROr? 7-62 Returns RMS Magnitude Error in percent. PHASE_ERROr? 7-62 Returns RMS Phase Error in degrees. RUN? 7-62 Starts measurement and returns adjusted AGC SETup 7-62 Starts measurement and returns adjusted AGC Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. MULTITASKING MACROS COMMANDS ACTIVATE "name" 3-50 Puts specified task in schedule queue. SICP 3-84 Stops all macros. TASK "name" 3-85 Declares specified loaded macro to be a task. TPAUSE 3-85 Passes command execution to next task in queing TPAUSE STOP 3-85 Stops and removes current task from queue.	STORe:			, ,
MACRO "m","f" 7-64 Stores currently loaded macros and variables a name f in Flash Memory with designated ma to activate from JBox Flash Files Directory. STATE "f" 7-64 Stores current CSA settings as f in Flash Memor TYPE? "f" 7-65 Returns file type of file name f. MODULATION ACCURACY COMMANDS MODacc: FDTC: CHANnel n 1 to 1023 7-62 Sets RF Channel. COMPlete? 7-62 Returns test status (1 [complete] or 0). EVM? 7-62 Returns RMS Error Vector Magnitude in percenter FREQ_ERROr? 7-62 Returns Frequency Error in hertz. IQ_OFFset? 7-62 Returns I/Q Offset in dB. MAG_ERROr? 7-62 Returns RMS Magnitude Error in percent. PHASE_ERROr? 7-62 Returns RMS Phase Error in degrees. RUN? 7-62 Starts measurement and returns adjusted AGC SETup 7-63 Starts measurement and returns adjusted AGC SETUP 7-64 Starts measurement and returns adjusted AGC Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. MULTITASKING MACROS COMMANDS ACTIVATE "name" 3-50 Puts specified task in schedule queue. SICP 3-84 Stops all macros. TASK "name" 3-85 Declares specified loaded macro to be a task. TPAUSE 3-85 Passes command execution to next task in queing TPAUSE Stops and removes current task from queue.	CALibration "f"		7-64	Stores current Calibration Data as f in Flash Memo
STATE "f" 7-64 Stores current CSA settings as f in Flash Memor TYPE? "f" 7-64 Returns file type of file name f. MODULATION ACCURACY COMMANDS MODacc: FDTC: CHANnel n 1 to 1023 7-62 Sets RF Channel. COMPlete? 7-62 Returns test status (1 [complete] or 0). EVM? 7-62 Returns RMS Error Vector Magnitude in percent REQ_ERROr? 7-62 Returns Frequency Error in hertz. IQ_OFFset? 7-62 Returns RMS Magnitude Error in percent. PHASE_ERROr? 7-62 Returns RMS Magnitude Error in percent. PHASE_ERROR? 7-62 Returns RMS Phase Error in degrees. RUN? 7-62 Starts measurement and returns adjusted AGC SETup 7-62 Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. MULTITASKING MACROS COMMANDS ACTIVATE "name" 3-83 Removes specified task in schedule queue. STOP 3-84 Stops all macros. TASK "name" 3-85 Declares specified loaded macro to be a task. PAUSE 3-85 Stops and removes current task from queue.	MACRo "m","f"			Stores currently loaded macros and variables as fil name f in Flash Memory with designated macro
TYPE? "f" 7-64 Returns file type of file name f. MODULATION ACCURACY COMMANDS MODacc: FDTC: CHANnel n 1 to 1023 7-62 Sets RF Channel. COMPlete? 7-62 Returns test status (1 [complete] or 0). EVM? 7-62 Returns RMS Error Vector Magnitude in percent FREQ_ERROr? 7-62 Returns Frequency Error in hertz. IQ_OFFset? 7-62 Returns I/Q Offset in dB. MAG_ERROr? 7-62 Returns RMS Magnitude Error in percent. PHASE_ERROr? 7-62 Returns RMS Phase Error in degrees. RUN? 7-62 Returns RMS Phase Error in degrees. STUP 7-62 Starts measurement and returns adjusted AGC Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. MULTITASKING MACROS COMMANDS ACTIVATE "name" 3-50 Puts specified task in schedule queue. STOP 3-84 Removes specified task from schedule queue. STOP 3-85 Passes command execution to next task in queints and removes current task from queue. Stops and removes current task from queue.	STATA "F"		7.64	
MODULATION ACCURACY COMMANDS MODacc: FDTC: CHANnel n 1 to 1023 7-62 Sets RF Channel. COMPlete? 7-62 Returns test status (1 [complete] or 0). EVM? 7-62 Returns RMS Error Vector Magnitude in percent FREQ_ERROr? 7-62 Returns Frequency Error in hertz. IQ_OFFset? 7-62 Returns IVQ Offset in dB. MAG_ERROr? 7-62 Returns RMS Magnitude Error in percent. PHASE_ERROr? 7-62 Returns RMS Magnitude Error in percent. PHASE_ERROR? 7-62 Returns RMS Phase Error in degrees. RUN? 7-62 Starts measurement and returns adjusted AGC SETup 7-62 Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. MULTITASKING MACROS COMMANDS ACTIVATE "name" 3-83 Removes specified task from schedule queue. STOP 3-84 Stops all macros. TASK "name" 3-85 Declares specified loaded macro to be a task. TPAUSE 3-85 Passes command execution to next task in queic. Stops and removes current task from queue.				
MODacc: FDTC: CHANnel n 1 to 1023 7-62 Sets RF Channel. COMPlete? 7-62 Returns test status (1 [complete] or 0). EVM? 7-62 Returns RMS Error Vector Magnitude in percent FREQ_ERROr? 7-62 Returns Frequency Error in hertz. IQ_OFFset? 7-62 Returns RMS Magnitude Error in percent. MAG_ERROr? 7-62 Returns RMS Magnitude Error in percent. PHASE_ERROr? 7-62 Returns RMS Phase Error in degrees. RUN? 7-62 Starts measurement and returns adjusted AGC SETup 7-62 Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. MULTITASKING MACROS COMMANDS ACTIVATE "name" 3-80 Puts specified task in schedule queue. STOP 3-84 Stops all macros. TASK "name" 3-85 Declares specified loaded macro to be a task. TPAUSE 3-85 Stops and removes current task from queue.	1 1 1 1 1 1		7-04	netunts me type of me name i.
FDTC: CHANnel n 1 to 1023 7-62 Sets RF Channel. COMPlete? 7-62 Returns test status (1 [complete] or 0). EVM? 7-62 Returns RMS Error Vector Magnitude in percent FREQ_ERROr? 7-62 Returns Frequency Error in hertz. IQ_OFFset? 7-62 Returns RMS Magnitude Error in percent. MAG_ERROr? 7-62 Returns RMS Magnitude Error in percent. PHASE_ERROR? 7-62 Returns RMS Phase Error in degrees. RUN? 7-62 Starts measurement and returns adjusted AGC SETup 7-62 Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. MULTITASKING MACROS COMMANDS ACTIVATE "name" 3-50 Puts specified task in schedule queue. SLEEP "name" 3-83 Removes specified task from schedule queue. STOP 3-84 Stops all macros. TASK "name" 3-85 Declares specified loaded macro to be a task. TPAUSE 3-85 Stops and removes current task from queue.	MODULATION ACCURACY	COMMANDS		
CHANnel n 1 to 1023 7-62 Sets RF Channel. COMPlete? 7-62 Returns test status (1 [complete] or 0). EVM? 7-62 Returns RMS Error Vector Magnitude in percent FREQ_ERRor? 7-62 Returns Frequency Error in hertz. IQ_OFFset? 7-62 Returns RMS Magnitude Error in percent. MAG_ERRor? 7-62 Returns RMS Phase Error in degrees. RUN? 7-62 Returns RMS Phase Error in degrees. RUN? 7-62 Starts measurement and returns adjusted AGC SETup 7-62 Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. MULTITASKING MACROS COMMANDS ACTIVATE "name" 3-80 Puts specified task in schedule queue. SLEEP "name" 3-81 Removes specified task from schedule queue. STOP 3-84 Stops all macros. TASK "name" 3-85 Declares specified loaded macro to be a task. TPAUSE 3-85 Passes command execution to next task in queue. Stops and removes current task from queue.				
COMPlete? EVM? FREQ_ERRor? FREQ_ERRor? IQ_OFFset? FASE_ERRor? PHASE_ERROR? FRUN? FRUN? FRUN? FREQ_ERROR? FREQ_ERROR? FREQ_ERROR? FREQ_ERROR? FREQ_ERROR? FREQ_ERROR? FREQ_ERROR? FREQ_ERROR? FREUTHS I/Q Offset in dB. FREQ_ERROR? FREUTHS I/Q Offset in dB. FREQ_ERROR? FREUTHS I/Q Offset in dB. FREQ_ERROR III DETERMINE MAGNITURE Error in percent. FRUN? FREQ_ERROR? FREUTHS I/Q Offset in dB. FREQ_ERROR FREQ_ERROR FREQUENTS I/Q Offset in dB. FREQ_ERROR FREQ_ERROR FREQUENTS I/Q Offset in dB. FREQ_ERROR FREQUENTS I/Q Offset in dB. FREQ_ERROR FREQUENTS I/Q Offset in dB. FREQ_ERROR FREQ_ERROR FREQUENTS I/Q Offset in dB. FREQ_ERROR FREQUENTS I/Q Offset in dB. FREQ_ERROR FREQUENTS I/Q Offset in dB. FREQ_ERROR FREQ_ERROR FREQUENTS I/Q Offset in dB. FREQ_ERROR FREQUENTS I/Q Offset in dB. FREQ_ERROR FREQ_ERRO	. –	1 to 1023	7-62	Sets RF Channel
EVM? FREQ_ERRor? IQ_OFFset? IQ_OFFset? NAG_ERROr? PHASE_ERROR? FRUNT FREQ_ERROR? FREQ_ERROR FREQ_ERROR Frequency Error in hertz. Frequency Error in degrees. Frequency Error in degr		I CO COROLO		
FREQ_ERRor? IQ_OFFset? NAG_ERRor? PHASE_ERRor? RUN? SETup ACTIVATE "name" STOP TASK "name" TASK "name" FREQ_ERRor? IQ_OFFset? Returns Frequency Error in hertz. Returns I/Q Offset in dB. Returns RMS Magnitude Error in percent. Returns RMS Phase Error in degrees. Returns RMS Phase Error in degrees. Starts measurement and returns adjusted AGC Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. Puts specified task in schedule queue. Steps all macros. Removes specified task from schedule queue. Stops all macros. Passes command execution to next task in queing stops and removes current task from queue. Stops and removes current task from queue.				
IQ_OFFset? MAG_ERRor? PHASE_ERRor? RUN? SETup ACTIVATE "name" STOP TASK "name" TASK "name" TASK "name" IQ_OFFset? Returns I/Q Offset in dB. Returns RMS Magnitude Error in percent. Returns RMS Phase Error in degrees. Returns RMS Phase Error in degrees. Starts measurement and returns adjusted AGC Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. Puts specified task in schedule queue. Steps all macros. Removes specified task from schedule queue. Stops all macros. Passes command execution to next task in quein stops and removes current task from queue. Stops and removes current task from queue.				
MAG_ERRor? PHASE_ERRor? RUN? SETup MULTITASKING MACROS COMMANDS ACTIVATE "name" SLEEP "name" STOP TASK "name" TPAUSE TPAUSE TPAUSE TSTOP ACTIVATE TRAUSE TSTOP ACTIVATE TRAUSE TSTOP ACTIVATE TRAUSE TSTOP TASK "name" TSTOP TASK "name" TSTOP TASK "stats measurement and returns adjusted AGC Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. Teause Trause TSTOP TASK "name" TRAUSE TSTOP TASK "stats measurement and returns adjusted AGC Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. Teause TSTOP TASK "stats measurement and returns adjusted AGC Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. Teause TSTOP TASK "stats measurement and returns adjusted AGC Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. Teause TSTOP TASK "stats measurement and returns adjusted AGC Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. Teause Tstats measurement and returns adjusted AGC Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. Teause Tstats measurement and returns adjusted AGC Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. Teause Tstats measurement and returns adjusted AGC Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. Teause Tstats measurement and returns adjusted AGC Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. Teause Tstats measurement and returns adjusted AGC Sets FM/AM-1600CSA as when entering Modulat Accuracy screen.				
PHASE_ERRor? RUN? SETup T-62 Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. MULTITASKING MACROS COMMANDS ACTIVATE "name" SLEEP "name" STOP TASK "name" TASK "name" TASK "TABLE TASK "Name" TASK "N				
RUN? SETup 7-62 Starts measurement and returns adjusted AGC Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. MULTITASKING MACROS COMMANDS ACTIVATE "name" 3-50 Puts specified task in schedule queue. SLEEP "name" 3-83 Removes specified task from schedule queue. STOP 3-84 Stops all macros. TASK "name" 3-85 Declares specified loaded macro to be a task. TPAUSE TSTOP 3-85 Stops and removes current task from queue.				
SETup 7-62 Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. MULTITASKING MACROS COMMANDS ACTIVATE "name" SLEEP "name" STOP TASK "name" TPAUSE TSTOP 7-62 Sets FM/AM-1600CSA as when entering Modulat Accuracy screen. Puts specified task in schedule queue. Removes specified task from schedule queue. Stops all macros. Declares specified loaded macro to be a task. Passes command execution to next task in queing the passes command execution to next task in queing task in the passes command execution to next task in queing task in the passes command execution to next task in queing task in the passes command execution to next task in queing task in the passes command execution to next task in queing task in the passes command execution to next task in queing task in the passes command execution to next task in the passes command execution to next task in the passes command execution to next task in the passes command execu				~
Accuracy screen. MULTITASKING MACROS COMMANDS ACTIVATE "name" SLEEP "name" STOP TASK "name" TPAUSE TSTOP Accuracy screen. Puts specified task in schedule queue. 3-50 Puts specified task in schedule queue. Stops all macros. Jeclares specified loaded macro to be a task. Passes command execution to next task in quein stops. Jeclares specified loaded macro to be a task. Passes command execution to next task in quein stops. Stops and removes current task from queue.				
ACTIVATE "name" SLEEP "name" STOP TASK "name" TASK "name" TASTOP 3-50 Puts specified task in schedule queue. 3-83 Removes specified task from schedule queue. 3-84 Stops all macros. Declares specified loaded macro to be a task. Passes command execution to next task in queue. Stops and removes current task from queue.	SETUP		7-02	
SLEEP "name" STOP 3-84 Stops all macros. TASK "name" TASK "name" TASE TOP 3-85 TOP 3-85 TOP 3-85 TOP 3-85 TOP TOP 3-85 TOP 3	MULTITASKING MACROS	COMMANDS		
SLEEP "name" STOP 3-84 Stops all macros. TASK "name" TASK "name" TASE TOP 3-85 TOP 3-85 TOP 3-85 TOP 3-85 TOP TOP 3-85 TOP 3	ACTIVATE "name"		3-50	Puts specified task in schedule queue.
STOP 3-84 Stops all macros. TASK "name" 3-85 Declares specified loaded macro to be a task. TPAUSE 3-85 Passes command execution to next task in quel TSTOP 3-85 Stops and removes current task from queue.				
TASK "name" 3-85 Declares specified loaded macro to be a task. TPAUSE 3-85 Passes command execution to next task in quel TSTOP 3-85 Stops and removes current task from queue.				
TPAUSE 3-85 Passes command execution to next task in quel TSTOP 3-85 Stops and removes current task from queue.				
TSTOP 3-85 Stops and removes current task from queue.				Passes command execution to next task in queue.
WAKE "name" 3-86 Puts specified task in queue/executes from last	WAKE "name"		3-86	Puts specified task in queue/executes from last sto

COMMAND RANGE PAGE DESCRIPTION

REVERSE DIGITAL TRAFFIC CHANNEL (RDTC) MONITOR COMMANDS

RDTC:			
CHANnel n	1 to 1023	7-25	Selects Reverse Digital Traffic Channel to monitor.
FACCH:			
AMT?			Returns Acknowledge Message Type.
AUTHU?			Returns AUTHU value.
BER?		7-26	Returns Bit Error Rate value.
CALLED:			
NUM?			Returns number of Called Party.
PLANId?			Returns Called Party Numbering Plan Identification.
SPare?		7-26	Returns value of Called Party Number spare bit.
TYpe?		7-26	Returns Called Party Number Type.
CALLING:			
NUM?			Returns number of Calling Party.
PLANId?		7-26	
SPare?			Returns value of Calling Party Number spare bits.
TYpe?		7-26	9 , ,,
CM?			Returns Call Mode.
DIC?		7-27	· · · · · · · · · · · · · · · · · · ·
DIGits?		7-27	• •
DMAC?		7-27	•
DTX?		7-27	
ESN?		7-27	
FI?		7-27	
KF?			Returns Keypad Facility (32 digits).
LDP?		7-27	
MEM?			Returns Memory Encryption Mode.
MSGtype?			Returns Message Type received from Mobile Station.
NV?	•		Returns Numbers of Values bits.
PD?			Returns Protocol Discriminator.
PT?		7-27	Returns Parameter Types.
RANDBS?		7-27	Returns RANDBS value.
RFCHAN? n	0 to 11		Returns RF Channel for selected index.
RL?	•	7-28	Returns Remaining Length.
RN?		7-28	Returns Number of Requests.
RR?		7-28	Returns Release Reason.
RSSI? n	1 to 1023	7-28	Returns Received Signal Strength Indicator for
			selected RF Channel index.
RSSIC?		7-28	Returns Received Signal Strength Indicator for
			current RF Channel.
SSDUP?		7-28	Returns Shared Secret Data Update.
TA?			Returns Time Alignment.
TERMinf?		7-28	
VPM?		7-28	•
RO?		7-25	Returns VSELP frame energy value.
REMote:			
STARt		7-25	
STOP		7-25	Stops VSELP data out RS-232 Connector.
SACCH:			
AMT?		7-28	
AUTHU?		7-28	
BER?		7-28	Returns Bit Error Rate value.
CALLED:			
NUM?		7-28	•
PLANId?		7-28	, ,
SPare?		7-29	
TYpe?		7-29	Returns Called Party Number Type.
CALLING:			
NUM?		7-29	· · · · · · · · · · · · · · · · · · ·
PLANId?		7-29	Q , Q
SPare?		7-29	• , , ,
TYpe?		7-29	
CM?		7-29	
DIC?			Returns Delay Interval Compensation.
DIGits?		7-29	· · · · · · · · · · · · · · · · · · ·
DMAC?		7-29	Returns Digital Mobile Attenuation Code.

COMMAND	RANGE	PAGE	DESCRIPTION
RDTC:			
SACCH:			
DTX?		7-29	Returns Discontinuous Transmission.
ESN?		7-29	Returns Electronic Serial Number.
FI?		7-29	Returns Feature Indicator.
KF?		7-29	Returns Keypad Facility (32 digits).
LDP?		7-29	Returns Last Decoded Parameter.
MEM?		7-29	Returns Memory Encryption Mode.
MSGtype?		7-30.	
NV?		7-30	Returns Numbers of Values.
PD?		7-30	Returns Protocol Discriminator.
PT?		7-30	Returns Parameter Types.
RANDBS?		7-30	Returns RANDBS value.
RFCHAN?n	0 to 11	7-30	Returns RF Channel for selected index.
RL?		7-30	Returns Remaining Length.
RN?		7-30	Returns Number of Requests.
RR?		7-30	Returns Release Reason.
RSSI?n	0 to 11	7-30	Returns Received Signal Strength Indicator for selected RF Channel index.
RSSIC?		7-30	Returns Received Signal Strength Indicator for current RF Channel.
SSDUP?		7-30	Returns Shared Secret Data Update.
TA?			Returns Time Alignment.
TERMinf?		7-30	
VPM?		7-30	Returns Voice Privacy Mode.
SETup		7-25	Sets FM/AM-1600CSÅ as when entering Reverse Digital Traffic Channel Screen.
SLOT n	1 to 3	7-25	Selects Timeslot .
STARt		7-25	Starts decoding RDTC data.
STOP		7-25	Stops decoding RDTC data.

REVERSE CONTROL CHANNEL (RECC) MONITOR COMMANDS

RECC:			
AUTHR?		7-22	Returns AUTHR value.
AUTHU?		7-22	Returns AUTHU value.
CHANnel n	1 to 1023	7-22	Selects Reverse Control Channel to monitor.
COUNt?			Returns modulo-64 count sent from Mobile Station.
DCC?			Returns Digital Color Code.
DIGITS1?			Returns up to 16 digits.
DIGITS2?			Returns up to 16 digits.
E?			Returns Extended Address.
EP?		7-22	Returns Extended Protocol.
ER?		7-22	Returns Extended Protocol Reverse Channel Indicator.
ESN?		7-22	Returns Electronic Serial Number.
LOCAL_MT?		7-23	Returns Local Control/Message Type.
LT?			Returns Last Try.
MIN?		7-23	Returns Mobile Identification Number.
MPCI?		7-23	Returns Mobile Protocol Capability Indicator.
ORDERCD?			Returns Order Type.
ORDQ?		7-23	Returns Order Qualifier.
RANDBS?		7-23	Returns RANDBS value.
RANDC?		7-23	Returns RANDC value.
S?		7-23	Returns Serial Number bit value.
SCM?		7-23	Returns Station Class Mark.
SDCC1?		7-23	Returns Supplementary Digital Color Code 1.
SDCC2?		7-23	Returns Supplementary Digital Color Code 2.
SETup		7-22	Sets FM/AM-1600CSA as when entering Reverse
			Control Channel Screen.
STARt		7-22	Starts decoding RECC data.
STOP		7-22	Stops decoding RECC data.
TORDer?		7-23	Returns combination of T and Order fields.

COMMAND	RANGE	PAGE	DESCRIPTION
REVERSE VOICE CHANNEL	(RVC) MONITOR COM	MANDS	5
RVC:			
AUTHu?		7-24	Returns AUTHU value.
CHANnel n	1 to 1023	7-24	
DIGITS?	, , , , , , , , , , , , , , , , , , , ,		Returns up to 32 digits.
ESN?			Returns Electronic Serial Number.
LOCAL_MT?			Returns Local Control/Message Type.
ORDEROD?		7-24	Returns Order Type.
ORDQ?			Returns Order Qualifier.
RANDbs?			Returns RANDBS value.
SETup			Sets FM/AM-1600CSA as when entering Reverse Voice Channel Screen.
STARt		7-24	
STOP			Stops decoding RVC data.
TORDer?		7-24	
101100;		1-24	returns combination of Calla Order Helds.
SOUND COMMAND			
SOUND f,t		3-83	Creates and sends audio tone to Test Set Speaker
			(frequency set in Hz and duration time set in ms).
STRING FUNCTION COMMA	NDS		
ASC(\$)		3-17	Returns ASCII value of first character in string \$.
CHR(n)			Returns character equivalent of ASCII number n.
LEN(\$)		3-17	Deturns length of string & in number of share-term
PIXLEN(\$)		3-17	Returns length of string \$ in number of characters.
STR(n)			
		3-17	
STRPOS(\$1,\$2)		3-18	Returns position of string \$2 inside string \$1.
TAB(n) VAL(\$)			Returns blank string containing n number of spaces.
ν ΑL(Φ)		3-17	Returns numeric value represented by string \$.
SYSTEM COMMANDS			
SYSTem:			
COMMunicate:			
SERial:			
BAUD n	300 to 38400	3-34	Sets baud rate.
BITS n	7 or 8	3-34	Sets number of data bits per word.
ECHo b	1 or 0		Enables or disables RCI echo.
PACe type	XON or NONE		Sets software handshake mode.
PARity type	NONE, ODD or EVEN		Sets parity check.
SBITs n	MARK or SPACE	2 24	Cata symbol of atom hits many years
DATE year, month, day	1 or 2 1992 to 9999, 1 to 12,		Sets number of stop bits per word. Sets date.
	1 to 31		
DATE?			Returns date.
ERRor?		3-33	Returns error number and message.
TIME hour, minute, second	0 to 23, 0 to 59, 0 to 59		
TIME?		3-33	Returns time.
WINDOW COMMANDS			
CLS		3-54	
Heed		0 00	selected window.
USER	4.4-40	3-26	3
WCLOSE n	1 to 16	3-87	• • • • • • • • • • • • • • • • • • • •
WINDOW?	0.4	3-88	
WMOVE x,y	0 to 639,0 to 349	3-89	Moves currently selected window to selected new top left xy location.
WOPEN c,x1,y1,x2,y2	0 to 15,0 to 639,	3-89	Creates windows.
· mit opn ryg synmyg m	0 to 349,0 to 639,	5.05	CIOCLOS WIIIGOWS.
	0 to 349		
WSEL n,h	0 to 15,0 or 1	3-90	Selects and hides or shows window.
	, -, 1		COLOR WIND WIND ALL MANAGEMENTS AND

SECTION 9 - CSA PROGRAM EXAMPLES

9-1 GENERAL

focc:stream:b

if \$="PAGE"

endif until key?

end

\$=focc:order?

focc:stream:B

print \$," ",syst:time?

\$=focc:min?

This Section provides some general guidelines and examples of remote operation and macro programs using FM/AM-1600CSA specific commands. All macros are executed remotely through RS-232.

NOTE: A file containing these macros is available on the IFR BBS (316-524-0270).

FORWARD CONTROL CHANNEL (FOCC)

```
9-2-1
       MONITORING DECODED DATA
MACRO NAME: focc_page
     SYNTAX: focc_page n
              (n=FOCC channel number, 1 to 1023.)
    PURPOSE: Look for Page orders on the FOCC.
              If and when found, print out the MIN and time of day for each occurrence.
              (Macro continues until key is pressed on the host RS-232 terminal.)
    EXAMPLE: focc page 332
      MACRO:
*dmc "focc page", begin
                             // Define macro named focc page.
focc:setup
                             // Setup for receiving FOCC.
focc:start
                             // Start decoding FOCC data.
focc:chan $1
                            // Set RF Channel to value entered with macro.
focc:word:both
                            // Decode both Streams A and B.
                            // Initiate do loop.
do
tpause
                            // Allow time for decoding.
focc:stream:a
                            // Select Stream A for response.
 $=focc:order?
                            // Return order as string variable $.
 if $="PAGE"
                            // Look for a Page order.
 focc:stream:a
                            // Select Stream A for response.
 $=focc:min?
                            // Return MIN as string variable $.
 print $," ",syst:time?
                            // Print MIN and time to RS-232 Connector.
 endif
 tpause
```

// Print MIN and time to RS-232 Connector. // Do until key pressed on RS-232 terminal.

// Return MIN as string variable \$.

// End macro focc page.

9-2-2 MONITORING RAW DATA

```
MACRO NAME: focc raw
     SYNTAX: focc_raw n
               (n=FOCC channel number, 1 to 1023.)
    PURPOSE: Monitor FOCC until Page order is detected.
               If and when found, fill raw data buffer (100 words) and place Page order data
               at the 50% point.
    EXAMPLE: focc raw 332
      MACRO:
*dmc "focc raw", begin
                              // Define macro named focc raw.
                              // Setup for receiving FOCC.
focc:setup
delay 1500
focc:chan $1
                              // Set RF Channel to value entered with macro.
focc:raw:word:both
                              // Monitor Streams A and B.
focc:capt:sel:order
                             // Select ORDER to capture on.
                             // Select Page as order for capture.
focc:raw:capt:page
focc:raw:trig 2
                             // Select middle trigger position.
                              // Start monitoring raw FOCC data.
focc:raw:start
print "WAITING FOR PAGE"
                              // Print out through RS-232 Connector.
                              // Initiate do loop.
do
                             // Allow time to capture PAGE order.
tpause
until key? or focc:raw:capt? // Wait for capture condition to end do loop.
print "CAPTURED PAGE"
                              // Indicate Page order was found.
                              // Initiate do loop.
                              // Allow time to fill data buffer.
tpause
until key? or focc:raw:full? // Wait for full data buffer before ending do loop.
print "CAPTURE BUFFER FULL" // Indicate data buffer is full.
i=focc:raw:capt:index?
                              // Return Page order position in data buffer as i.
a=focc:raw:ts? i
                              // Return time stamp of Page order as a.
print "A Data Parity Check
                               B Data Parity Check Busy/Idle
                              /* Print out header for raw data. */
for i=0 to 99
                              // Print out raw data through RS-232 Connector.
print %07h, focc: raw: a:data? i, " ",
print %03h, focc:raw:a:parity? i,"
 if (focc:raw:a:check? i)=0
  print "GOOD
 else
 print "BAD
 endif
print %07h, focc:raw:b:data? i, " ",
print %03h, focc: raw:b:parity? i, "
 if (focc:raw:b:check? i)=0
  print "GOOD
 else
  print "BAD
 endif
print %2d, focc:raw:b i? i,"
print %6d, (focc:raw:ts? i)-a
next i
focc:raw:stop
                              // Stops raw data capture.
                              // End macro focc raw.
end
```

9-3 FORWARD VOICE CHANNEL (FVC)

9-3-1 MONITORING DECODED DATA

Specify SAT Color Code (FVC:SCC) before requesting decoded data.

MACRO NAME: fvc_char
SYNTAX: fvc_char n

(n=FVC channel number, 1 to 1023.)

PURPOSE: Monitor FVC until Flash with Information order is detected.

If and when found, display the characters sent in the Flash with Infomation

order message.

(Macro continues until key is pressed on the host RS-232 terminal.)

EXAMPLE: fvc char 3

MACRO:

```
// Define macro named fvc_char.
*dmc "fvc_char", begin
                           // Setup for receiving FVC.
fvc:setup
                           // Start decoding FVC data.
fvc:start
                           // Set RF Channel to variable entered with macro.
fvc:chan $1
                           // Select SCC to match SAT.
fvc:scc :meas:sat?
                           // Initiate do loop.
do
                          // Allow time for FM/AM-1600CSA tasks to run.
tpause
                           // Return last decoded order as string variable $.
$=fvc:order?
                           // Compare order with Flash with Information.
if $="FLASH W/INFO"
               // Allow time for order to complete first 16
delay 3000
                          // characters.
 $=fvc:char1?
                           // When available, print first 16 characters
 if $!="-1"
                           // out RS-232 Connector.
  print $,
  endif
                          // Receive second set of 16 characters.
  $=fvc:char2?
                           // When available, print second 16 characters
  if $!="-1"
  print $,
                           // out RS-232 Connector.
                           // If no second set of 16 characters received,
  else
  print ""
                           11
                               send carriage return out RS-232 Connector.
  endif
 endif
                            // Do until key pressed on RS-232 terminal.
until key?
                            // End macro fvc char.
end
```

9-3-2 MONITORING RAW DATA

Set the FVC Capture Mode to NONE (FVC:CAPT:SEL:NONE) prior to initiating raw data queries.

```
MACRO NAME: fvc raw
      SYNTAX: fvc raw n
              (n=FVC channel number, 1 to 1023.)
    PURPOSE: Collect raw data on the FVC.
               Display five data words, starting with the first word as soon as received.
    EXAMPLE: fvc raw 3
      MACRO:
*dmc "fvc raw", begin
                             // Define macro named fvc raw.
fvc:setup
                             // Setup for receiving FVC.
fvc:chan $1
                             // Set RF Channel to value entered with macro.
                             // Eliminate FOCC capture interference.
focc:capt:sel:none
                             // Set size of raw data buffer to 5 data words.
fvc:raw:depth 5
fvc:raw:start
                             // Start collecting raw FVC data.
print "WAIT"
                             // Indicate waiting out RS-232 Connector.
a=0
                             // Set variable a to 0.
                             // Initiate do loop.
do
 tpause
                             // Allow time for FM/AM-1600CSA tasks to run.
 b=fvc:raw:count?
                             // Return number of words in raw data buffer.
 if a<b
                             // When new data is available, print data
  for i = a to b-1
                             11
                                  information out RS-232 Connector.
   print %07h,fvc:raw:data? i," "
   print %03h, fvc:raw:parity? i, " "
   a=fvc:raw:check? i
   if (a)
                             // If a=1 (true), then CRC check is bad.
    print "BAD
                             // Indicate bad CRC check out RS-232 Connector.
   else
                             // If a=0 (false), then CRC check is good.
   print "GOOD
                             // Indicate good CRC check out RS-232 Connector.
   endif
   print %5d, fvc:raw:ts? i
                             // Indicate time of data word out RS-232 Connector.
                             // Show data information for all 5 data words.
  next i
  a=b
                             // Prevent displaying same data twice.
 endif
until key? or b=5
                             /* Do until key pressed on RS-232 terminal
                                  or raw data buffer is full. */
end
                             // End macro fvc raw.
```

9-4 FORWARD DIGITAL TRAFFIC CHANNEL (FDTC)

9-4-1 MONITORING DECODED DATA

```
MACRO NAME: fdtc msg
     SYNTAX: fdtc msg n,x
              (n=FDTC channel number, 1 to 1023. x=timeslot, 1 to 3)
    PURPOSE: Monitor FDTC.
              Display FACCH and SACCH message types, each with respective DVCC.
              (Macro continues until key is pressed on the host RS-232 terminal.)
    EXAMPLE: fdtc msg 100,3
      MACRO:
                             // Define macro named fdtc msg.
*dmc "fdtc msg",begin
                             // Setup for receiving FDTC.
fdtc:setup
                             // Set RF Channel to 1st value entered with macro.
fdtc:chan $1
                             // Set Timeslot to 2nd value entered with macro.
fdtc:slot $2
                             // Start FDTC decoding.
fdtc:start
                             // Initiate do loop.
                             // Allow time for decoding.
tpause
                             // Return FACCH message type as string variable.
 $=fdtc:facch:msg?
                             // When available, indicate FACCH message type.
if $!="-1"
 print "Facch Message type is ",$
 print "DVCC is ", %1d, fdtc:dvcc?
endif
                             // Return SACCH message type as string variable.
$=fdtc:sacch:msg?
                             // When available, indicate SACCH message type.
if $!="-1"
 print "Facch Message type is ",$
 print "DVCC is ",%1d,fdtc:dvcc?
 endif
                              // Do until key pressed on RS-232 terminal.
until key?
                              // End macro fdtc msg.
end
```

9-4-2 MONITORING RAW DATA

Set size of data buffer (FDTC:RAW:DEPTH) prior to using raw data queries. Limit selected data word to a range from 0 to the FDTC:RAW:DEPTH setting minus one, for raw data queries.

```
MACRO NAME: fdtc raw
      SYNTAX: fdtc raw n,x
               (n=FDTC channel number, 1 to 1023. x=timeslot, 1 to 3)
    PURPOSE: Collect FACCH raw data from FDTC.
               Display 20 FACCH raw data words, starting with the first word as soon as
               received.
    EXAMPLE: fdtc_raw 100,3
      MACRO:
*dmc "fdtc raw", begin
                              // Define macro named fdtc raw.
fdtc:setup
                              // Setup for receiving FDTC.
fdtc:chan $1
                              // Set RF Channel to 1st value entered with macro.
fdtc:slot $2
                             // Set Timeslot to 2nd value entered with macro.
fdtc:raw:sel:facch
                             // Select FACCH raw data for data buffer.
fdtc:raw:depth 20
                             // Set size of raw data buffer to 20 data words.
                             // Start collecting raw FDTC data.
fdtc:raw:start
print "WAIT"
                             // Indicate waiting out RS-232 Connector.
a = 0
                             // Set variable a to 0.
do
                             // Initiate do loop.
 tpause
                             // Allow time for FM/AM-1600CSA tasks to run.
b=fdtc:raw:count?
                             // Return number of words in raw data buffer.
 if a<b
                             // When new data is available, print data
  for i = a to b-1
                                  information out RS-232 Connector.
                              //
   print %2d, fdtc:raw:cf? i," "
   for j=0 to 5
                              // Set range of j to indicate message byte.
    print %02h,fdtc:raw:mess? i,j
                              // Show data for all 5 bytes.
   print " ",%4d,fdtc:raw:dvcc? i, " ",
   print %3d, fdtc:raw:time? i
  next i
                              // Show data information for all 20 data words.
  a=b
                              // Prevent displaying same data twice.
 endif
until key? or b=20
                             /* Do until key pressed on RS-232 terminal
                                  or raw data buffer is full. */
end
                              // End macro fdtc raw.
```

9-4-3 MONITORING IS-54 RAW DATA

```
MACRO NAME: fdtc_is54
      SYNTAX: fdtc is54 n,x
               (n=FDTC channel number, 1 to 1023. x=timeslot, 1 to 3)
    PURPOSE: Collect FDTC raw data corresponding to the IS-54B timeslot.
               Display 100 raw data words when raw data buffer is full.
               (Macro continues until key is pressed on the host RS-232 terminal.)
     EXAMPLE: fdtc_is54 100,3
       MACRO:
                               // Define macro named fdtc_is54.
*dmc "fdtc_is54",begin
                               // Setup for receiving FDTC.
fdtc:setup
                              // Set RF Channel to 1st value entered with macro.
fdtc:chan $1
                              // Set Timeslot to 2nd value entered with macro.
fdtc:slot $2
                              // Initiate do loop.
                               // Start collecting raw FDTC timeslot data.
 fdtc:is54:start
                               // Initiate internal do loop
 dо
                               // Allow time to fill data buffer.
  tpause
 until key? or fdtc:is54:count?=100
  for i=0 to 99
  print %07h, fdtc:is54:sync? i, " ",
  print %03h, fdtc:is54:cdvcc? i, " ",
  print %03h, fdtc:is54:sacch? i, " ",
  print %5f,fdtc:is54:time? i
  for j=1 to 65
   print %01h,fdtc:is54:data? i,j,
                               // Show all 65 characters.
  print
                               // Show data information for all 100 data words.
  next i
                               // Do until key pressed on RS-232 terminal.
 until key?
                               // End macro fdtc is54.
 end
```

9-5 REVERSE CONTROL CHANNEL (RECC)

```
MACRO NAME: recc min
      SYNTAX: recc_min n
               (n=RECC channel number, 1 to 1023.)
     PURPOSE: Monitor RECC.
               Display the MIN of the Mobile Station.
               (Macro continues until key is pressed on the host RS-232 terminal.)
     EXAMPLE: recc min 100
       MACRO:
*dmc "recc min", begin
                              // Define macro named recc min.
recc:setup
                              // Setup for receiving RECC.
recc:chan $1
                              // Set RF Channel to value entered with macro.
recc:start
                              // Start decoding RECC data.
do
                              // Initiate do loop.
 tpause
                              // Allow time for FM/AM-1600CSA tasks to run.
 $=recc:min?
                              // Return MIN as string variable $.
 if $!="-1"
                              // When available, indicate MIN out RS-232
  print "MIN received is ",$ // Connector.
 endif
until key?
                              // Do until key pressed on RS-232 terminal.
end
                              // End macro recc min.
9-6
      REVERSE VOICE CHANNEL (RVC)
MACRO NAME: rvc order
      SYNTAX: rvc_order n
               (n=RVC channel number, 1 to 1023.)
    PURPOSE: Monitor RVC.
               Display name of each order received.
               (Macro continues until key is pressed on the host RS-232 terminal.)
    EXAMPLE: rvc order 100
      MACRO:
*dmc "rvc_order",begin
                              // Define macro named rvc_order.
rvc:setup
                              // Setup for receiving RVC.
rvc:chan $1
                              // Set RF Channel to value entered with macro.
rvc:start
                              // Start decoding RVC data.
do
                              // Initiate do loop.
                              // Allow time for FM/AM-1600CSA tasks to run.
tpause
 $=rvc:torder?
                              // Return last decoded order as string variable $.
if \$! = "-1"
                              // When available, indicate last decoded order out
 print "ORDER RECEIVED ON RVC IS ",$
 endif
                              // RS-232 Connector.
until key?
                              // Do until key pressed on RS-232 terminal.
end
                              // End macro rvc order.
```

9-7 REVERSE DIGITAL TRAFFIC CHANNEL (RDTC)

```
MACRO NAME: rdtc_maho
     SYNTAX: rdtc maho n,x
              (n=RDTC channel number, 1 to 1023. x=timeslot, 1 to 3)
    PURPOSE: Monitor RDTC.
              Display mobile assisted handoff information returned in Channel Quality
              messages.
              (Macro continues until key is pressed on the host RS-232 terminal.)
    EXAMPLE: rdtc_maho 100,2
      MACRO:
*dmc "rdtc maho", begin // Define macro named rdtc maho.
var i, reading
                             // Setup for receiving RDTC.
rdtc:setup
                             // Set RF Channel to 1st value entered with macro.
rdtc:chan $1
                             // Set Timeslot to 2nd value entered with macro.
rdtc:slot $2
                             // Start decoding RDTC data.
rdtc:start
print "Mobile Assisted Handoff Information"
print "Press any key to stop."
                              // Initiate do loop.
do
                              // Allow time for background decoding.
 tpause
                              // Set initial i value to 0.
 i=0
                              // Phone measures RSSI on up to 12 channels.
while i<12
 reading=rdtc:sacch:rssi? i // Return RSSI of selected channels.
 if reading!=-1
   print "RSSI",%ld,i+1,"=",reading
  endif
  ++i
 reading=rdtc:sacch:rssic? // Report RSSI of current channel.
 if reading!=-1
  print "Current RSSI=",%1d,reading
 endif
 reading=rdtc:sacch:ber?
                            // Report BER of current channel.
 if reading!=-1
  print "BER=",%1d,reading
 endif
                              // Do until key pressed on RS-232 terminal.
until key?
                              // End macro rdtc_maho.
end
```

9-8 CELL SITE SIMULATION (CSS)

Using the **SETup**, **STARt** and **STOP** commands of the RECC, RDTC and RVC nodes will stop the Cell Site Simulation. The RECC, RDTC and RVC nodes are automatically set up by the Cell Site Simulation process at the appropriated time:

- Transmitting on the FOCC activates the RECC node.
- Assigning an Analog Voice Channel activates the RVC node.
- Assigning a Digital Voice Channel activates the RDTC node.

Cell Site Simulation starts with the FM/AM-1600CSA transmitting on the FOCC.

9-8-1 GENERAL OVERHEAD MESSAGE

```
MACRO NAME: css_focc
      SYNTAX: css_focc n,x
              (n=FOCC channel number, 1 to 1023. x=RF level in dBm, -127.0 to -30.0)
    PURPOSE: Transmit an overhead message on the FOCC.
    EXAMPLE: css_focc 332,-55.0
      MACRO:
*dmc "css focc", begin
                             // Define macro named css_focc.
css:setup
                              // Setup for Cell Site Simulation.
css:chan $1
                             // Set RF Channel to 1st value entered with macro.
css:rflv1 $2
                             // Set RF Output Level to 2nd value entered.
css:start
                             // Start Cell Site Simulation tranmission.
css:focc:dcc 0
                             // Set Digital Color Code to 0.
                             // Set Protocol Capability Indicator to 1.
css:focc:pci 1
css:focc:rcf 1
                             // Activate Read Control Filler bit.
css:focc:sid 30
                             // Set System Identification Number to 30.
css:focc:s 1
                             // Activate Serial Number bit.
css:focc:e 1
                             // Activate Extended Address bit.
                             // Deactivate Home Registration bit.
css:focc:regh 0
css:focc:regr 0
                             // Deactivate Roaming Registration bit.
css:focc:n 20
                             /* Set Number of Paging Channels to be scanned
                                  by Mobile Station to 20. */
css:focc:cmax 20
                             /* Set Maximum Number of Access Channels to be
                                  scanned by Mobile Station to 20. */.
css:focc:auth 1
                             // Activate Authentication bit.
css:focc:ep 0
                             // Deactivate Extended Protocol bit.
css:focc:cmac 2
                             /* Set Control Mobile Attenuation Code (Mobile
                                  Station Power Level [-2 dBW nominal]). */
css:focc:sdcc1 0
                             // Set Supplementary Digital Color Code 1 to 0.
css:focc:sdcc2 0
                             // Set Supplementary Digital Color Code 2 to 0.
css:focc:wfom 1
                             // Activate Wait For Overhead Message bit.
css:focc:b i 1
                             // Activate Busy-Idle bit (RVC idle).
css:glact:stop
                             // Deactivate any global action messages.
end
                             // End macro css_focc.
```

9-8-2 GLOBAL ACTION OVERHEAD MESSAGE

```
(n=FOCC channel number, 1 to 1023. x=RF level in dBm, -127.0 to -30.0)
    PURPOSE: Transmit an overhead message on the FOCC (9-8-1).
              Add two global action messages to the overhead message train.
    EXAMPLE: css_glact 332,-55.0
      MACRO:
*dmc "css_glact", begin
                             // Define macro named css glact.
                             // Run css_focc macro to send overhead message.
css focc $1,$2
                             // Enable Location Area ID global action message.
css:glact:action:locaid 1
                             // Disable Power Up Registration bit.
css:glact:pureg 0
                             // Disable Power Down Registration bit.
css:qlact:pdreg 0
                             // Enable Local Area Registration bit.
css:glact:lreg 1
                             // Set Location Area ID.
css:glact:locaid 240
                             /* Enable Access Attempt Parameters global action
css:glact:action:access 1
                                  message. */
                             // Set Maximum Busy occurrences for Page responses.
css:glact:maxb:pgr 8
                             /* Set Maximum Busy occurrences for other
css:glact:maxb:oth 8
                                  responses. */
                             // Set Maximum Seizures for Page responses.
css:glact:naxs:pgr 9
                             // Set Maximum Seizures for other responses.
css:glact:maxs:oth 10
                             /* Set to send global action messages continuously
css:glact:repeat:on
                                  as part of overhead message train. */
                              // Start sending global action messages.
css:glact:send
                              // End macro css glact.
end
9-8-3
        MOBILE STATION CONTROL
```

MACRO NAME: css_mscm SYNTAX: css_mscm

MACRO NAME: css_glact

SYNTAX: css_glact n,x

PURPOSE: Replace one instance of the system parameter overhead message with a

Message Waiting command. (This macro assumes the FM/AM-1600CSA is

already transmitting an overhead message on the FOCC.)

MACRO:

9-8-4 MOBILE STATION INITIATED CALL

MACRO NAME: minit

When assigning a Digital Voice Channel, send a Physical Layer Control (PLC) message to successfully complete the Mobile Station initiated call.

```
SYNTAX: minit n,x
               (n=FOCC channel number, 1 to 1023. x=RF level in dBm, -127.0 to -30.0)
    PURPOSE: Set FM/AM-1600CSA to transmit an overhead message on the FOCC (9-8-1).
               Prepare the FM/AM-1600CSA to respond to an access from the Mobile Station.
               If the access is an Origination, assign the Mobile Station to a digital channel.
    EXAMPLE: minit 332,-55.0
      MACRO:
*dmc "minit", begin
                              // Define macro named minit.
var n
css focc $1,$2
                              // Run css focc macro to send overhead message.
css:call:type 1
                              // Set for digital channel assignment.
css:call:chan 5
                              // Set for RF Channel 5 assignment.
                              // Start mobile initiated call processing.
css:call:proc:mobinit
 delay 500
                              // Look for successful access by Mobile Station.
until key? or css:recc:status?
$=recc:torder?
if $="ORIGIN"
                              // See if Access was an Origination.
 $=recc:min?
                              // Store MIN of Mobile Station (phone) as $.
 css:call:proc:assign
                              // Assign to digital channel 5.
 delay 500
                              \ensuremath{//} Allow time for phone and CSA to respond.
 n=3
                              // Set initial n (count) value to 3.
  css:fdtc:facch:plc
                              // Send Physical Layer Control message ≤3 times.
  delay 500
 until ! (--n) or (rdtc:facch:msgtype?="PLC ACK")
 print "Completed mobile initiated call to ",$
 print "Unsuccessful"
endif
end
                              // End macro minit.
```

9-8-5 BASE STATION INITIATED CALL

When assigning a Digital Voice Channel, send a PLC message and an Alert message to complete the Base Station initiated call. When assigning an Analog Voice Channel, send an Alert message to complete the Base Station initiated call.

After an Analog or Digital Voice Channel has been assigned, any data field on the respective Reverse Channel can be decoded and any message on the respective Forward Channel can be sent.

```
MACRO NAME: page
```

SYNTAX: page n,x

(n=FOCC channel number, 1 to 1023. x=RF level in dBm, -127.0 to -30.0)

PURPOSE: Set FM/AM-1600CSA to transmit a system parameter overhead message

followed by a Page order.

Prepare the FM/AM-1600CSA for an access from the Mobile Station.

When a Page response is received from the Mobile Station, assign an analog

channel to the Mobile Station and send an Alert message.

EXAMPLE: page 332,-55.0

MACRO:

```
*dmc "page", begin
                             // Define macro named page.
var st, sat
                            // Setup overhead message with entered values.
css focc $1,$2
css:call:type 0
                            // Set type for analog.
                            // Set for RF Channel 600 (TX 888 MHz, RX 843 MHz)
css:call:chan 600
css:call:sat 5970
                            // Setup for SAT on analog channel.
css:call:dev 2.0
                            // Setup for SAT deviation of 2.0 kHz.
                             /* Set Voice Mobile Attenuation Code (Mobile
css:call:vmac 3
                                 Station Power Level [-6 dBW nominal]). */.
css:call:min "111/111-0111" // Select MIN of Mobile Station being called.
                             // Start processing for Page.
css:call:proc:page
                             // Wait for access.
 delay 500
until key? or css:recc:status?
$=recc:torder?
                            // Return last decoded order on RECC as variable $.
if $="PAGE RESP"
                             // Look for a Page response.
                       // Assign to FVC 600 and set SAT to 5970 Hz.
 css:call:proc:assign
 do
                             // Return the SAT frequency.
 sat=meas:sat?
 until key? or (sat>5960 and sat<6040)
                             // Set initial n (count) value to 3.
 do
                             // Send an Alert message on the FVC.
  css:fvc:order:alert
 delay 300
                             // Measure the signalling tone frequency.
  st=meas:st?
 until key? or !(--n) or (st>9990 \text{ and } st<10010)
 print "Call successfully completed!"
 print "Unsuccessful!"
endif
                             // End macro page.
end
```

9-8-6 HANDOFF

Analog to Digital Handoff Example:

MACRO NAME: ad_handoff

SYNTAX: ad_handoff n

(n=handoff channel number, 1 to 1023.)

PURPOSE: Send a handoff message to the Mobile Station, handing off the call to a digital

channel. (This macro assumes the FM/AM-1600CSA is on an analog channel

with the Mobile Station.)

EXAMPLE: ad handoff 5

MACRO:

```
*dmc "ad handoff", begin
                             // Define macro named ad handoff.
css:fvc:hand:chan $1
                             // Set handoff channel to value entered with macro.
css:fvc:ta 0
                             // Set Time Alignment offset.
css:fvc:sbi 2
                             /* Set Shortened Burst Indicator for transmit
                                 shortened burst after cell-to-cell handoff. */
css:fvc:dvcc 225
                             // Set Digital Verification Color Code.
css:fvc:dmac 2
                             /* Set Digital Mobile Attenuation Code (Mobile
                                 Station Power Level [-2 dBW nominal]). */
css:fvc:mem 0
                             // Set Memory Encryption Mode off.
                             // Set Privacy Mode off.
css:fvc:pm 0
css:call:proc:fvc:slot1
                             // Process call handoff to digital channel.
delay 500
css:fdtc:facch:plc
                             // Send Physical Layer Control message on FDTC.
delay 500
until !(--n) or (rdtc:facch:msgtype?="PLC ACK")
end
                             // End macro ad handoff.
```

Digital to Analog Handoff Example:

MACRO NAME: da_handoff

SYNTAX: da_handoff n

(n=handoff channel number, 1 to 1023.)

PURPOSE: Send a handoff message to the Mobile Station, handing off the call to an analog

channel. (This macro assumes the FM/AM-1600CSA is on a digital channel

with the Mobile Station.)

EXAMPLE: da_handoff 5

MACRO:

end

```
*dmc "da handoff", begin
                            // Define macro named da_handoff.
css:fdtc:ti 0
                             // ti=0 means analog handoff.
                            // Set 6030 Hz SAT for SCC on analog handoff.
css:fdtc:dvcc 2
                             // Set VMAC for power level 2 on analog handoff.
css:fdtc:dmac 2
                            // Set handoff channel to value entered with macro.
css:fdtc:hand:chan $1
css:fvc:pscc 2
                            // Set present SAT Color Code to match DVCC setup.
                            // Set VMAC to match DMAC setup.
css:fvc:vmac 2
                            // Set Memory Encryption Mode off.
css:fvc:mem 0
css:fvc:pm 0
                            // Set Privacy Mode off.
css:call:sat 6030
                             // Set SAT frequency to correspond with SCC.
css:call:dev 2.0
                             // Set SAT deviation to 2.0 kHz.
a=css:call:proc:fdtc:handoff? // Perform handoff.
                             // Indicate handoff status out RS-232 Connector.
 print "Handoff is successful!"
else
 print "Unsuccessful!"
endif
```

// End macro da handoff.

9-9 BIT ERROR RATE (BER)

```
MACRO NAME: ber_rdtc
     SYNTAX: ber_rdtc
    PURPOSE: Perform BER test (measure BER of a Base Station receiver) on RDTC (RF
               Channel 1). (This macro assumes the UUT will loop back the data from the
               receiver to the transmitter.)
      MACRO:
*dmc "ber rdtc", begin
                             // Define macro named ber rdtc.
ber:rdtc:setup
                             // Setup for Digital Traffic BER.
ber:rdtc:slot 1
                             // Set to Timeslot 1.
                             // Set to RF Channel 1 (TX 825.030 MHz).
ber:rdtc:chan 1
ber:rdtc:data:pseudo
                             // Set to send pseudo-random data on RDTC.
                             // Initiate do loop.
do
ber:rdtc:go
                             // Send pseudo-random RDTC data and start BER test.
delay 100
                             // Allow time for Base Station to sync up with data
until key? or !ber:rdtc:status?
delay 2000
                             /* or until key is pressed on RS-232 Terminal. */
ber:rdtc:clear
                             // Clear current results.
while !key?
                             // Display current results until key is pressed on
 tpause
                             // RS-232 Terminal.
 a=ber:rdtc:ber?
 if a!=-1
  print "Bit Error Rate = ",%4.3d,a
wend
                             //
                             // Stop RDTC data transmission and BER test.
ber:rdtc:stop
end
                             // End macro ber_rdtc.
9-10 MODULATION ACCURACY (MODACC)
MACRO NAME: moderr
     SYNTAX: moderr
    PURPOSE: Perform Modulation Accuracy test (measure accuracy of \pi/4 DQPSK signal) on
              FDTC (RF channel 1).
      MACRO:
*dmc "moderr", begin
                             // Define macro named moderr.
mod:fdtc:setup
                             // Setup to monitor FDTC for modulation accuracy.
mod:fdtc:chan 1
                             // Set to RF Channel 1 (monitor 870.030 MHz).
a=mod:fdtc:run?
                             // Run Modulation Accuracy test until complete or
while !key? and !mod:fdtc:comp?
```

// key is pressed on RS-232 Terminal.

// End macro moderr.

// Indicate RMS Error Vector Magnitude percentage.

end

print mod:fdtc:evm?

9-11 GPIB

LANGUAGE: HPTM Basic

PURPOSE: Perform Cell Site Simulation testing across GPIB. FILE: 10 Dev=705 20 OUTPUT Dev; ": GPIB: MASK 1" 30 ON INTR 7 GOSUB 620 40 ENABLE INTER 7;2 50 CLEAR SCREEN 60 PRINT "START" 70 DIM COMM\$[60] 80 OUTPUT Dev; "CSS: SETUP" 90 OUTPUT Dev; "CSS: CHAN 333" 100 OUTPUT Dev; "CSS:RFLVL -60" 110 OUTPUT Dev; "CSS: FOCC: PCI 1" 120 OUTPUT Dev; "CSS:START" 130 OUTPUT Dev; "CSS: CALL: TYPE 1" 140 OUTPUT Dev; "CSS: CALL: CHAN 5" 150 OUTPUT Dev; "CSS: CALL: SLOT 2" 160 OUTPUT Dev; "CSS:FDTC:ENABLE:SIGNAL 1" 170 OUTPUT Dev; "CSS:FDTC:SIGNAL:PITCH 0; CADENCE 1" 180 OUTPUT Dev; "CSS: FDTC: ENABLE: CALLING: NUM 1" 190 OUTPUT Dev; "CSS:FDTC:CALLING:NUM '316/522-4981'" 200 OUTPUT Dev; "CSS:FDTC:CALLING:TYPE 0" 210 OUTPUT Dev; "CSS:FDTC:CALLING:PLANID 0" 220 OUTPUT Dev; "CSS:FDTC:CALLING:PI 0" 230 OUTPUT Dev; "CSS:FDTC:CALLING:SI 0" 240 OUTPUT Dev; "CSS:FDTC:ENABLE:DMAC 0; TA 1; DTX 0; DIC 0" 250 OUTPUT Dev; "CSS: FDTC: TA 2" 260 Srq flag=0 270 REPEAT 280 OUTPUT Dev; "CSS:CALL:PROC:REG" 290 WAIT 1 300 UNTIL Srq_flag=1 310 PRINT "REGISTRATION COMPLETED" 320 OUTPUT Dev; "CSS: CALL: PROC: PAGE" 330 Srq flag=0 340 REPEAT 350 WAIT .5 360 UNTIL Srq flag=1 370 PRINT "PAGE RESPONSE RECEIVED" 380 OUTPUT Dev; "CSS: CALL: PROC: ASSIGN" 390 WAIT 2 400 PRINT "CALL ASSIGN TO DIGITAL TRAFFIC CHANNEL 410 REPEAT 420 OUTPUT Dev; "CSS:FDTC:FACCH:PLC" 430 WAIT .5 440 OUTPUT Dev; "RDTC: FACCH: MSG?" 450 ENTER Dev; Comm\$ 460 UNTIL Comm\$="PLC ACK"

(The GPIB example program continues on the next page.)

```
470 PRINT "PLC ACK RECEIVED"
480 REPEAT
490
    OUTPUT Dev; "CSS:FDTC:FACCH:ALERT"
500
      WAIT .5
510
    OUTPUT Dev; "RDTC: FACCH: MSG?"
520 ENTER Dev; Comm$
530 UNTIL Comm$="MOBILE ACK"
540 PRINT "PHONE ALERTED"
550 REPEAT
560 WAIT .5
570
     OUTPUT Dev; "RDTC: FACCH: MSG?"
    ENTER Dev; Comm$
580
590 UNTIL Comm$="CONNECT"
600 PRINT "CALL COMPLETED"
610 STOP
620 Srq flag=1
630 S=SPOLL(Dev)
640 ENABLE INTR 7;2
650 RETURN
660 END
```

APPENDICES

APPENDIX A - PREDEFINED MACROS AND CONSTANTS

A-1 PREDEFINED MACROS

The following macros are predefined in the FM/AM-1600S and FM/AM-1600CSA:

*DMC "Chirp_1", BEGIN SOUND 1600,50 DELAY 100 SOUND 1600,50 END *DMC "Chirp_2", BEGIN SOUND 1300,30 SOUND 1500,30 SOUND 1700,30 SOUND 1500,30 SOUND 1300,30 END

A-2 PREDEFINED CONSTANTS

The following colors are predefined constants in the FM/AM-1600S and FM/AM-1600CSA:

WHITE RED BLUE BROWN DARK_CYAN BLACK YELLOW CYAN DARK_GRAY DARK_MAGENTA DARK_GREEN MAGENTA GREEN LIGHT_GRAY DARK_RED DARK_BLUE

The following Front Panel Keys are predefined constants and are equal to the corresponding keycodes (see Appendix B):

DEL STOR AUTO F_RIGHT LEFT DOWN ESC F2 F5

CE SETUP GO F_LEFT F_DOWN UP ENTER F3 F6 RCL SGL_STEP STOP RIGHT F_UP BACK_ARROW

F1 F4

APPENDIX B - FRONT PANEL KEYS AND KEYCODES

Table B-1 lists the FM/AM-1600S Front Panel Keys and the corresponding keycodes. Press the SHIFT Key to toggle the Front Panel Keyboard to the alphabetic characters printed in blue on the Front Panel. Press the SHIFT Key again to toggle the Front Panel Keyboard to the numeric values.

Key	Keycode	Key	Keycode	Key	Keycode
F1	1152	₩-	1025	к	75
F2	2176	4	2056	L	76
F3	4224	5	2052	М	77
F4	8320	6	2050	N	78
F5	16512	M⁄μ	2049	0	79
F6	32896	1	4104	Р	80
RF GEN	1088	2	4100	Q	81
RCVR	2112	3	4098	R	82
DPLX	4160	K/m	4097	S	83
AF GEN	8256	•	8208	Т	84
SCOPE/ANLZ	16448	*	8200	U	85
MTRS	32832	0	8196	٧	86
AUTO	1056	#	8194	W	87
SGL STEP	2080	ENTER	8193	×	88
GO	4128	Α	65	Y	89
STOP	8224	В	66	Z	90
SETUP	16400	С	67	FIELD SELECT ←	257
STORE	32784	D	68	FIELD SELECT↑	513
RCL	32776	E	69	FIELD SELECT↓	258
CE	16388	F	70	FIELD SELECT →	514
DEL	32772	G	71	DATA SCROLL↑	264
7	1032	H	72	DATA SCROLL↓	260
8	1028	l	73	DATA SCROLL ←	520
9	1026	J	74	DATA SCROLL →	516

Table B-1 Front Panel Keys and Keycodes

	1	

APPENDIX C - ABBREVIATIONS

	A		D
Α	Ampere	dB	Decibels
ac	Alternating Current	dBm	Decibels relative to 1 milliwatt
AF	Audio Frequency	dc	Direct Current
AGC	Automatic Gain Control	DCS	Digital Coded Squelch
АМ	Amplitude Modulation	Demod Audio	Demodulated Audio
AMPS	Advanced Mobile Phone Service	DMM	Digital Multimeter
ANLZ	Analyzer	DSAT	Digital Supervisory Audio Tone
ANSI	American National Standards Institute	DST	Digital Signalling Tone
ANT	Antenna	DTMF	Dual Tone Multi-Frequency
ASCII	American National Standard		E
	Code for Information Inter- change	ESD	Electrostatic discharge
	В	ESN	Electronic Serial Number
BFO	Beat Frequency Oscillator	ETACS	Enhanced Total Access Communications System
BER	Bit Error Rate	Ext	External
bps	Bits per second	EXT MOD	External Modulation
	C		F
CCH	Control Channel	FACCH	Fast Associated Control
ccw	Counterclockwise		Channel
CRT	Cathode Ray Tube	FDTC	Forward Digital Traffic Channel
cw	Clockwise	FM	Frequency Modulation
C Wt	C-Weight	FOCC	Forward Control Channel
		Freq	Frequency
		Func Gen	Function Generator
		FVC	Forward Voice Channel

Gen	Generator	MHz	Megahertz
GHz	Gigahertz	MIN	Mobile Identification Number
GND	Ground	MOD	Modulation
GPIB	General Purpose Interface Bus	MODL	Modulation Level
	H	МΩ	Mega ohm
Hz	Hertz	ms	Milliseconds
Hex	Hexadecimal	msg	message
1		MTS	Mobile Telephone Service
	Identification	mV	Millivolts
IEEE	Institute of Electrical and	mW	Milliwatts
N STORY Marcel Brown	Electronic Engineers		N
IMTS	Improved Mobile Telephone Service	N/A	Not applicable
1/0	Input/Output	NAMPS	Narrow Band Advanced Mobile Phone Service
	Κ	NVRAM	Non-Volatile Random
kbps	kilobits per second		Access Memory
kHz	kilohertz	_	0
kΩ	kilo ohm	Opn	Operation
	L		Р
LSB	Lower Sideband	РМ	Phase Modulation
1		PWR	Power
LvI	Level		

M

	R		т	
RAM	Random Access Memory	TDMA	Time Division Multiple Access	
RBW	Resolution Bandwidth	TERM	Terminal	
RCI	Remote Command Interpreter	TRI	Triangle	
RCL	Recall	Tx	Transmit	
RCV	Receive		U	
Rcvr	Receiver	USB	Upper Sideband	
RDTC	Reverse Digital Traffic	UUT	Unit Under Test	
	Channel		V	
RECC	Reverse Control Channel	٧	Volt	
Res	Resolution	VCHAN	Voice Channel	
RF	Radio Frequency	Vrms VSELP	Voltage Root Mean Square	
RF Pwr	RF Power		Vector Sum Excited Linear	
Rgtr	Register		Prediction	
RMS	Root Mean Square	•	W	
RVC	Reverse Voice Channel	W	Watt	
	S		X	
SACCH	Slow Associated Control Channel	Xmtr	Transmitter	
SAT	Supervisory Audio Tone			
SCC	Supervisory Audio Tone Color Code			
sec	Second			
SIN	Sine			
squ	Square			
SSB	Single Side Band			
SSD	Shared Secret Data			

Std

Standard

		The state of the s

INDEX

+ (addition operator)	3-7, 3-11	B (continued)	
= (assignment operator) \ (back slash)	3-7, 3-11 3-2	Photogram A NETh	240 244
& (bitwise AND)	3-10, 3-11	Bitwise AND	3-10, 3-11 3-8, 3-11
~ (bitwise complement)	3-8, 3-11	Bitwise complement Bitwise OR	3-9, 3-11
(bitwise OR)	3-9, 3-11	Bitwise XOR	3-10, 3-11
^ (bitwise XOR)	3-10, 3-11	BOX command	3-29, 3-51, 5-7, 8-8
: (colon)	3-1		
, (comma)	3-1	С	
// (comments)	3-2	· ·	
/* (comments)	3-2 3-2	CALCulate command	3-52, 5-12, 8-15
*/ (comments) (decrement operator)	3-2	Call	
/ (division operator)	3-7, 3-11	Base Station Initiated	9-13
** (exponential operator)	3-7, 3-11	Mobile Station Initiated	9-12
> (greater than)	3-20	Setup	7-34
>= (greater than or equal)	3-20	CASE command	3-52, 5-11, 8-14
++ (increment operator)	3-8	CELL commands	4-90, 5-3
< (less than)	3-20	Cell Site Simulation Base Station Initiated Call	9-13
<= (less than or equal)	3-20	Calling Setup	7-34
! (logical negation)	3-9, 3-11	Commands	7-31, 8-1
% (modulo operator)	3-8, 3-11 3-7, 3-11	FDTC	7-43
<pre>* (multiplication operator) != (not equal)</pre>	3-7, 3-11	Data Fields	7-45
<< (shift left operator)	3-11	Orders	7-43
>> (shift right operator)	3-11	FOCC Overhead Message Para	
; (semicolon)	3-1	FVC	7-38
- (subtraction operator)	3-8, 3-11	Data Fields	7-39
2805 Pulse and Tone command	ds 4-5, 4-13	Orders	7-38
		General Overhead Message FOCC Parameters	7-31, 8-4
Α		Macro	9-10
		Global Action Overhead Messa	
Abbreviations	C-1	Commands	7-53, 8-6
ABS (absolute value)	3-13, 5-12, 8-15	Macro	9-11
ACTIVATE	3-23, 3-50, 5-13, 8-15	Handoff	7-36, 9-14
Addition operator	3-7, 3-11	Mobile Station Control Messag	es
AF Generator commands	4-38, 5-1	Commands	7-57, 8-7
AF Generator examples AF Level Meter command	4-44 4-89, 5-2	Macro Mobile Station Initiated Call	9-11 9-12
AF Meter commands	4-64, 5-2	Process	7-36
AHIT?	4-3, 5-3	Talkback	7-52
AMPS Commands	4-4, 4-14, 4-30, 4,55,	Cellular AMPS commands	4-90, 5-3,
	4-90, 5-3	CHR (character)	3-16, 5-22, 8-18
AMPS Mobile Simulator Comma	ands 4-94, 5-4	CLS command	3-26, 3-54, 5-7, 5-23,
Analyzer			8-8, 8-18
Commands	4-55, 5-20	*CLS command	3-46, 5-11, 8-14
Example	4-63 4-57, 5-21	Colors	3-25, A-1
Marker commands Trace commands	4-60, 5-21	Color commands Comments	3-25 3-2
Tracking Generator	4-61, 5-21	Compliment, bitwise	3-8, 3-11
AND	, , , , = = .	Conditional Expressions	3-20
bitwise operator	3-10, 3-11	Configuring for GPIB Operation	2-7
logical operator	3-11, 3-20	Configuring for RS-232 Operation	
ANLZ commands	4-55, 5-20	CONST command	3-5, 3-54, 5-6, 8-8
Arrays	3-3, 3-22	Constants	3-5
ASC (ASCII value)	3-17, 5-22, 8-18	COS (cosine)	3-14, 5-12, 8-15
ASCII	3-6, 3-64, 5-6 3-7	Creating and Loading CSA Speci	
Assignment operator Audio Tones	3-31	CRT Display CSA Programs	3-26
Auxiliary Test Set commands	4-3, 5-3	Examples	6-6, 9-1
AUX command	4-3, 5-3	Front Panel Operation	6-5
AUX? command	4-3, 5-3	Loading	6-4
	,	Setup	6-1
В		Writing	6-2
.		CSA Program Examples	9-1
Base Station Initiated Call	9-13	CSA Quick Reference List	8-1
BCOLOR command	3-25, 5-7, 8-8	CSA Specific TMAC Commands	7-1
BEGIN command	3-19, 3-50, 5-11, 8-14	CSS commands	7-31, 8-1
BER			
CSA commands	7-61, 8-1		
CSA macro	9-16		
Meter commands	4-80, 5-3		
BER commands	7-61, 8-1		
Binary	3-6, 3-64, 5-6, 8-8		

D	F (continued)
DATA command 3-5, 3-55, 5-6, 8-8	Forward Digital Traffic Channel
Data arrays 3-5	Monitor
DCS commands 4-5, 4-12, 4-15, 4-25	Commands 7-15, 8-9
DECimal 3-6, 3-64, 8-8 Decrement operator 3-8	Control 7-15
Decrement operator 3-8 Define commands 5-6, 8-8	Decode Data 7-15, 9-5 IS-54 Raw Data 7-21, 8-9, 9-7
DELAY command 3-56, 5-11, 8-14	IS-54 Raw Data 7-21, 8-9, 9-7 Raw Data 7-20, 8-9, 9-6
Deviation Meter (Peak) commands 4-71, 5-6	Forward Voice Channel
Deviation Meter (RMS) commands 4-86, 5-6 Digital Multimeter commands 4-82, 5-6	CSS
Digital Multimeter commands 4-82, 5-6 Display commands 5-7, 8-8	Commands 7-38, 8-4 Data Fields 7-39
Distortion Meter commands 4-76, 5-8	Orders 7-38
Division operator 3-7, 3-11	Monitor
*DMC command 3-18, 3-46, 3-48, 5-11, 8-14 DO command 3-56, 5-11, 8-14	Commands 7-12, 8-13
DRAW command 3-29, 3-58, 5-7, 8-8	Control 7-12 Decode Data 7-12, 9-3
DTMF commands 4-6, 4-11, 4-16, 4-23	Raw Data 7-14, 8-13, 9-4
Duplex	Frequency Error Meter commands 4-67, 5-10
Commands 4-29, 5-8 Examples 4-37	Front Panel Keys and Keycodes B-1
Receiver commands 4-34, 5-9	Predefined Constants A-1 Front Panel Operation (Flash Memory)
Transmitter commands 4-29, 5-8	1600\$ 4-100
DUPlex commands 4-29, 5-8	CSA 6-5, 7-63
<u></u>	Function Generator commands 4-38, 5-1 FVC commands 7-12, 8-13
E	FVC commands 7-12, 8-13
EDIT commands 3-25, 5-7	G
ENDCASE command 3-52, 5-11, 8-14	G
END command 3-19, 3-59, 5-11, 8-14	General TMAC Commands 3-47
Equal 3-20 *ESE command 3-43, 3-46, 5-11	GENerator commands 4-4, 5-18
*ESE command 3-43, 3-46, 5-11 *ESE? query 3-43, 3-46, 5-11	Generator commands AF 4-38, 5-1
*ESR? query 3-43, 3-46, 5-11	AF 4-38, 5-1 RF 4-4, 5-18
ETACS commands 4-4, 4-14, 4-30, 4-55	Generic Measure commands
EXEC command 3-59, 5-11, 8-14 EXP (e ⁿ) 3-14, 5-12, 8-15	1600\$ 4-103, 5-10
Exponential operator 3-7, 3-11	CSA 7-62, 8-14 Global Action Overhead Messages
, , , , , , , , , , , , , , , , , , , ,	Commands 7-53, 8-6
F	Macro 9-11
# 1.1 # # # # # # # # # # # # # # # # #	GPIB 1600S
FALSE, OFF 3-12, 5-12, 8-15 FDTC commands 7-15, 8-9	Communication 3-36
FDTC commands 7-15, 8-9 FETCh commands 4-104, 5-11	Controller 3-37
FIND Function commands 4-16, 4-31, 4-56, 5-8,	Listener Only 3-39
5-16, 5-20	Setup and Operation 2-7 System Plot Command 3-33, 5-23
FGEN commands 4-38, 5-1 Flash Memory	Talker Only 3-39
1600S File Directory Operation 4-100	CSA
1600S remote commands 4-101	Commands 8-14
CSA JBox Flash Files Directory 7-63	Communication 3-36 Setup and Operation 2-8
CSA remote commands 7-64 FLOOR command 3-13, 5-12, 8-15	Macro 9-17
FLUSH command 3-60, 5-11, 8-14	Graphics 3-25, 3-29
FMZ 4-21	Greater than 3-20
FOCC commands 7-2, 8-10 FOCC Overhead Message Parameters 7-31	Greater than or equal 3-20
FOC Overhead Message Parameters 7-31 FOR command 3-61, 5-12, 8-14	Н
FORGET command 3-19, 3-63, 5-12, 8-14	7 F
FORMat command 3-6, 3-64, 5-6, 8-8	HANDoff 7-36, 9-14
Forward Control Channel CSS Overhead Message Parameters 7-31, 8-4	HEIGHT command 3-30, 3-64, 5-7. 8-8
Monitor 7-5	HEXadecimal 3-6, 3-64, 5-6, 8-8 HFLUSH command 3-65, 8-14
Commands 7-2, 8-10	HFLUSH command 3-65, 8-14 HOST commands 7-1, 8-14
Control 7-2 Decode Data 7-5, 9-1	Host system operation
Decode Data 7-5, 9-1 Macro 9-1	1600S 2-1
Raw Data 7-9, 8-12, 9-2	CSA 2-3 HPRINT command 3-31, 3-66, 8-8
Forward Digital Traffic Channel CSS	
Commands 7-43, 8-2	
Data Fields 7-45 Orders 7-43	
Talkback 7-52	
, , , , , , , , , , , , , , , , , , , 	

f	M (continued)
ICON command 3-30, 3-67, *IDN? query 3-46, 3-49, 5-11, 8 IEEE commands 3-46, 5-11, 8	8-14 Mathematical Functions 3-12, 5-12, 8-18-14 Mathematical Operators 3-
IF command 3-68, 5-12, 8 IF ELIF command 3-69, 5-12, 8 IF ELSE command 3-70, 3-71, 5-12, 8	8-14 1600S 4-103, 5-10 8-14 CSA 7-62, 8-14
IMTS command Increment operator INITiate commands 4-104, 5 INPUT command 3-22, 3-72, 5-12, 8	
INPUT command 3-22, 3-72, 5-12, 8 Instrument Status Register 3-41, 3 Instrument Summary Status Register 3-41, 3 INTERP command 3-18, 3-72, 5-12, 8	3-44 Mobile Station Control Messages 3-45 Commands 7-57, 8-
J	Mobile Station Initiated Call 9-1: Modem operation 1600S 2-4
JBox Flash Files Directory	7-63 CSA 2-1 MODacc commands 7-62, 8-19
K	Modulation Accuracy Commands 7-62, 8-19 Macro 9-10
Keycodes Predefined Constants KEY commands 3-32, 5-11, 8	
KEYPAD commands 3-28, 3-32, 3-73, 3 3-75, 5-11, 8	
L	N
Less than or equal	3-20 Negative unary operator 3-8, 3-1 3-20 Not equal 3-20
*LMC? query 3-19, 3-46, 8 LN (natural logarithm) 3-13, 5-12, 8 Loading Programs LOG (base 10 logarithm) 3-13, 5-12, 8	8-15 NT400 commands 4-4, 4-15, 4-30, 4-5 6-4 Numerical Notation 3-6
Logical negation (NOT) unary operator 3-9, 3	
M	0
M_AF commands 4-64, M_BER commands 4-80, M_DEV commands 4-71, M_DIST commands 4-76, M_DRMS commands 4-82, M_DRMS commands 4-86, M_MOD commands 4-74,	7.5-3 OCTal 3-6, 3-64, 5-6, 8-1 7.5-6 OFF 3-12, 5-12, 8-1 7.5-8 ON 3-12, 5-12, 8-1 7.5-6 *OPC command 3-43, 3-46, 5-1 7.5-6 *OPC? query 3-43, 3-46, 5-1
M PM commands 4-84, 5 M PMRMS commands 4-88, 5 M PWR commands 4-69, 5	5-15 1600S 5-15 GPIB remote 2- 5-15 Front Panel 4-10
M_RF commands 4-67, 5 M_SIG commands 4-80, 5 M_SINAD commands 4-78, 5 M_VRMS command 4-89,	5-20 Using Host System 2- 5-20 Using Modem 2-
Macros	GPIB remote 2-3-19 Front Panel 7-6
CSA Examples 6-6, Defined 3 Deletion of \$\pm\$DMC command 3-18, 3-46, 3-48, 5-11, 8	9-1 Using Host System 2- 3-18 Using Modem 2- 3-19 Operation Instrument Register 3-41, 3-4 8-14 Operation Status Register 3-41, 3-4
Execution	3-22 bitwise operator 3-9, 3-1 logical operator 3-11, 3-2
Front Panel 4-100, 7-63, Remote 3-18, 3-19, 3-63, 5-12, 8	3-59 Commands 4-45, 5-1
*PMC command 3-19, 3-47, 3-49, 5-11, 8 PROGram commands 4-99, 8	8-14 Marker commands 4-46, 5-1 5-11 Trace commands 4-49, 5-1 3-23 Overhead Message Parameters, FOCC 7-3 8-14 Trace commands 7-3

ı	,	
١	ı	

VAL (value)	3-17, 5-22, 8-18
VAR command	3-3, 3-86, 5-6, 8-8
Variables	
Free	3-3
Global	3-3
Initializing	3-3
In macros	3-22
Local	3-3
Saving in non-volatile memory	3-4
String	3-15
Volume commands	4-21, 5-17

W

*WAI	3-19, 3-47, 3-49, 5-11
WAKE command	3-23, 3-86, 5-13, 8-15
WCLOSE command	3-27, 3-87, 5-23, 8-18
WHILE command	3-87, 5-12, 8-14
WINDOW? query	3-27, 3-88, 5-23, 8-18
Whitespace '	3-1
Window commands	3-26, 5-23, 8-18
Windows	3-26
WMOVE command	3-26, 3-89, 5-23, 8-18
WOPEN command	3-26, 3-89, 5-23, 8-18
Writing Programs	6-2
WSEL command	3-27, 3-90, 5-23, 8-18

X

XY command	3-29, 3-90, 5-7, 8-8
XYPRINT command	3-31, 3-91, 8-8

<i>:</i>				
		,		
,				
)				
·				